



South Carolina Electric & Gas Company  
P.O. Box 88  
Jenkinsville, SC 29065  
(803) 345-4001

John L. Skolds  
Senior Vice President  
Nuclear Operations

July 20, 1994  
Refer to: RC-94-0184

Document Control Desk  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555

Attention: Mr. G. F. Wunder

Gentlemen:

Subject: VIRGIL C. SUMMER NUCLEAR STATION  
DOCKET NO. 50/395  
OPERATING LICENSE NO. NPF-12  
TECHNICAL SPECIFICATION CHANGE - TSP 940003  
REQUEST FOR ADMINISTRATIVE CHANGES

In accordance with 10 CFR 50.90, South Carolina Electric & Gas Company (SCE&G) hereby requests an amendment to the Virgil C. Summer Nuclear Station (VCSNS) Technical Specifications (TS). The proposed changes have been evaluated and determined to be non-significant and administrative in nature.

The purpose of this change is to permit equivalent testing methods to be performed on the diesel fuel oil purchased for the Emergency Diesel Generators, and to change the revision level of a Westinghouse WCAP that will be used in determining the VCSNS Core Operating Limits for future cycles.

SCE&G requests that the NRC review and approve this administrative TS change by September 30, 1994, in order to support preparations for Cycle 9.

The amendment request is contained in the following attachments:

- Attachment I - List of affected pages and marked-up Technical Specifications
- Attachment II - Description of Amendment Request and the supporting Safety Evaluation
- Attachment III - Description of Amendment Request and the associated No Significant Hazards Evaluation

This proposed TS change has been reviewed and approved by both the Plant Safety Review Committee and the Nuclear Safety Review Committee.

250070




9407250294 940720  
PDR ADDCK 05000395  
P PDR

ADD 1/1

I declare that these statements and matters set forth herein are true and correct to the best of my knowledge, information, and belief.

Should you have any questions concerning this amendment request, please call Mr. Philip A. Rose at (803) 345-4052 at your convenience.

Very truly yours,



John L. Skolds

PAR:lcd  
Attachments

c: O. W. Dixon  
R. R. Mahan (w/o attachments)  
R. J. White  
S. D. Ebner  
G. F. Wunder  
G. J. Taylor  
NRC Resident Inspector  
J. B. Knotts Jr.  
A. A. Craft  
Central File System (880)  
RTS (TSP 940003)  
File (813.20)

<u>Section</u>	<u>Page</u>	<u>Change Description</u>
4.8.1.1.2.d	3/4 8-3	Removed specific ASTM Standard and added the words "in accordance with the applicable ASTM Standard" to permit the use of alternative testing methods due to changes in EPA requirements.
4.8.1.1.2.d.1	3/4 8-3	Removed specific ASTM Standard and added the words "in accordance with the applicable ASTM Standard" to permit the use of alternative testing methods due to changes in EPA requirements.
4.8.1.1.2.d.1.d	3/4 8-4	Removed specific ASTM Standard and added the words "in accordance with the applicable ASTM Standard" to permit the use of alternative testing methods due to changes in EPA requirements.
4.8.1.1.2.d.2	3/4 8-4	Removed specific ASTM Standard and added the words "in accordance with the applicable ASTM Standard" to permit the use of alternative testing methods due to changes in EPA requirements.
4.8.1.1.2.e	3/4 8-4	Removed specific ASTM Standard and added the words "in accordance with the applicable ASTM Standard" to permit the use of alternative testing methods due to changes in EPA requirements.
6.9.1.11	6-16a	Revised revision level and date of WCAP-10216-P-A to reflect updated methodology used in determining VCSNS Core Operating Limits.