U.S. NUCLEAR REGULATORY COMMISSION LICENSEE EVENT REPORT CONTROL BLOCK / / / / / (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION) /V/A/N/A/S/1/ (2) /0/0/-/0/0/0/0/0/-/0/0/ (3) /0/1/ /4/1/1/1/1/ (4) / (5) LICENSEE CODE LICENSE NUMBER LICENSE TYPE /0/1/ REPORT SOURCE /L/ (6) /0/5/0/0/0/3/3/8/ (7) /1/2/0/5/8/2/ (8) /1/2/2/2/8/2/ (9) DOCKET NUMBER EVENT DATE REPORT DATE EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10) 10/2/ / On December 5, 1982, with Unit 1 at 20% power, channels FI-1475 and FI-1485 for 10/3/ / Steam Generator "A" and "B" Steam Flow respectively were indicating below the 10/4/ / actual flow. The redundant channels were operable and both channels were placed 10/5/ / in the tripped condition within one hour; therefore, the health and safety of the/ 10/6/ / general public were not affected. This event is within the Action Statement of 10/7/ / T.S. 3.3.2.1 and reportable pursuant to T.S. 6.9.1.9.a and b. /0/8/ SYSTEM CAUSE CAUSE COMP. VALVE CODE CODE SUBCC' E COMPONENT CODE SUBCODE SUBCODE 10/9/ /I/B/ (11) /E/ (12) /E/ (13) /I/N/S/T/R/U/ (14) /T/ (15) /2/ (16) SEQUENTIAL. OCCURRENCE REPORT REVISION LER/RO EVENT YEAR REPORT NO. CODE TYPE NO. (17)REPORT NUMBER /8/2/ 10/3/ /-/ /0/8/4/ 1-1 /L/ 1-1 10/ ACTION FUTURE EFFECT SHUTDOWN ATTACHMENT NPRD-4 PRIME COMP. COMPONENT ON PLANT METHOD HOURS SUBMITTED FORM SUB, SUPPLIER MANUFACTURER TAKEN ACTION /Z/ (19) /Z/ (20) /Z/ (21) /0/0/0/0/ (22) /N/ (23) /N/ (24) /N/ (25) /W/1/2/0/ (26)CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) /1/0/ / The transmitter for FI-1475 was out of calibration low. The multiplier/divider/ / /1/1/ / square root card was out of tolerance low for FI-1485. Both channels were satis-/ /1/2/ / factorily calibrated and returned to service within 52 hours. There are no /1/3/ / generic implications associated with this event. /1/4/ FACILITY METHOD OF STATUS %POWER OTHER STATUS DISCOVERY DISCOVERY DESCRIPTION (32) (30)/1/5/ /0/2/0/ (29) / NA /A/ (31) /C/ (28) Operator Observation CONTENT ACTIVITY AMOUNT OF ACTIVITY (35) RELEASED OF RELEASE LOCATION OF RELEASE (36) /1/6/ /Z/(33)/2/(34)NA PERSONNEL EXPOSURES NUMBER DESCRIPTION (39) TYPE /1/7/ /0/0/0/ (37) /Z/ (38) NA PERSONNEL INJURIES DESCRIPTION (41) NUMBER /1/8/ /0/0/0/ (40) / LOSS OF OR DAMAGE TO FACILITY (43) 8212300238 821222 PDR ADOCK 05000338 DESCRIPTION PDR /1/9/ /2/ (42) / NA

NRC USE ONLY

PHONE (703) 894-5151

1111111111

PUBLICITY

DESCRIPTION (45)

NAME OF PREPARER W. R. CARTWRIGHT

ISSUED

/N/ (44)

/2/0/