

LICENSEE EVENT REPORT

UPDATE REPORT - PREVIOUS
REPORT DATE 12/30/80

CONTROL BLOCK:

--	--	--	--	--	--

 ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	G	A	E	I	H	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5
7	8	LICENSEE CODE						14	LICENSE NUMBER										25	LICENSE TYPE					30	57 CAT		58	

CON'T

0 1
7 8

REPORT SOURCE L 6 0 5 0 0 0 3 2 1 7 1 2 1 1 8 0 8 1 2 1 6 8 2 9
60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | With the unit operating steady-state at 1942 MWt, all points of Drywell
0 3 | Temperature Recorder R611 were found to be reading high. Recorder R611
0 4 | was declared inoperable. Redundant recorder R612 was operable. Tech.
0 5 | Specs. Section 4.2.1 requires two operable channels. A 30-day LCO was
0 6 | initiated. The health and safety of the public were not affected by
0 7 | this repetitive event (as last reported on LER 50-321/1980-075).

[illegible]

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The cause of this event has been attributed to faulty slidewire contacts
1 1 and a faulty printhead mechanism. New parts were installed. The recorder
1 2 was recalibrated, functionally tested, and returned to service. Because
1 3 of the poor reliability of this recorder, a design change was implement-
1 4 ed replacing the old recorder with a Model L&N-250 on 5/22/81.

8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

FACILITY STATUS (28) 0 7 9 (29) NA (30) METHOD OF DISCOVERY (31) Operator Observation (32) DISCOVERY DESCRIPTION (32)

1 5 E 0 7 9 NA B Operator Observation

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35)

1 6 Z (33) Z (34) NA

7 8 9 10 11 44

LOCATION OF RELEASE (36)

NA

45 80

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	37	Z	38	NA	39

PERSONNEL INJURIES		DESCRIPTION	
NUMBER			
1	8	0	0
0	0	0	40
		NA	

1	9	Z	(42)	NA	8212300289 821216 PDR ADOCK 05000321 S PDR
---	---	---	------	----	--

7	8	9	10											80											
PUBICITY																									
ISSUED			DESCRIPTION (45)																						
2	0	N	(44)	NA												NRC USE ONLY									

NAME OF PREPARER S. B. Tipps

PHONE: (912) 367-7851