NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION
UPDATE REPORT - PREVI
REPORT DATE 9/30/80

# LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | GAEIH2 (2) | 00-00000-00 (3) | 41111 (4) | (5)
LICENSEE CODE (14) LICENSE NUMBER (25) LICENSE TYPE (30) CAT (58)

CON'T
01 | REPORT SOURCE L (6) | 05000366 (7) | 091880 (8) | 121682 (9)
DOCKET NUMBER (68) EVENT DATE (74) REPORT DATE (80)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While performing increased surveillance on the Torus/Drywell Vacuum
03 Breakers per Tech. Specs. Section 3.6.4.1, Action a, the "G" Vacuum
04 Breaker failed to open upon actuation of the test switch. The health
05 and safety of the public were not affected by this repetitive event as
06 last reported on LER 50-366/1980-124.
07
08

09 SYSTEM CODE SA (11) | CAUSE CODE E (12) | CAUSE SUBCODE B (13) | COMPONENT CODE VALVOP (14) | COMP. SUBCODE D (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 80 | — | SEQUENTIAL REPORT NO. 129 | / | OCCURRENCE CODE 03 | REPORT TYPE X | — | REVISION NO. 1

ACTION TAKEN E (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0000 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER G202 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The air control valve was found to be out of adjustment. The air
11 control valve was adjusted and the "G" Vacuum Breaker was satisfactorily
12 functionally tested per the "SUPPRESSION CHAMBER TO DRYWELL VACUUM
13 BREAKER SYSTEM OPERABILITY" procedure and returned to service on 9/29/80.
14

15 FACILITY STATUS E (28) | % POWER 078 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Operator Observation

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 PERSONNEL EXPOSURES NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 PERSONNEL INJURIES NUMBER 000 (40) | DESCRIPTION (41) NA

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION (43) NA

20 PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA

8212300346 821216
PDR ADOCK 05000366
S PDR

NRC USE ONLY

NAME OF PREPARER S. B. Tipps PHONE: (912) 367-7851

GPO 917-926