



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215/770-5151

December 20, 1982

Mr. R.C. Haynes
Director, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 82-056/03L-0
ER 100450 FILE 841-23
PLA- 1446

Docket No. 50-387
License No. NPF-14

Dear Mr. Haynes:

Attached please find a copy of Licensee Event Report No. 82-056/03L-0. This event was determined to be reportable per Technical Specification 6.9.1.9.b, in that one set of Drywell Vacuum Breakers were declared inoperable after failing to meet surveillance acceptance criteria.

H.W. Keiser
Superintendent of Plant-Susquehanna

DGM/cw

cc: A. Schwencer
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

G. Rhoads
Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

8301030015 821220
PDR ADOCK 05000387
S PDR

IEU