



PEACH BOTTOM—THE POWER OF EXCELLENCE

PHILADELPHIA ELECTRIC COMPANY

PEACH BOTTOM ATOMIC POWER STATION

R. D. 1, Box 208

Delta, Pennsylvania 17314

(717) 456-7014

D. B. Miller, Jr.
Vice President

Docket Nos. 50-277
50-278

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

SUBJECT: Peach Bottom Atomic Power Station Monthly Operating Report

Gentlemen:

Enclosed are twelve copies of the monthly operating report for Peach Bottom Units 2 and 3 for the month of February 1991 forwarded pursuant to Technical Specification 6.9.1.d under the guidance of Regulatory Guide 10.1, Revision 4.

Sincerely,

AAF
DBM/AAF/TJN/DRM/MJB:cmc

Enclosure

cc: R.A. Burricelli, Public Service Electric & Gas
T.M. Gerusky, Commonwealth of Pennsylvania
J.J. Lyash, USNRC Senior Resident Inspector
R. McLean, State of Maryland
T.T. Martin, Administrator, Region I, USNRC
H.C. Schwemm, Atlantic Electric
J. Urban, Delmarva Power
INPO Records Center

9103190366 910228
PDR ADOCK 05000277
R PDR

IE24
11

NRC Monthly Operations Summary
Peach Bottom Atomic Power Station
February 1991

UNIT 2

The unit remained in the refuel mode for the entire month, with outage activities in progress. The scheduled end of the outage is March 27, 1991. Critical path activities are currently nine days behind scheduled.

UNIT 3

Except for control rod pattern adjustments, the unit operated at nominal 100% power for the entire month.

UNIT 2 REFUELING INFORMATION

1. Name of facility:

Peach Bottom Unit 2

2. Scheduled date for next refueling shutdown:
 - (1) Reload 8 in progress.
 - (2) Reload 9 scheduled for September 7, 1992.

3. Scheduled date for restart following refueling:
 - (1) Restart following refueling forecast for March 21, 1991.
 - (2) Restart following refueling forecast for November 22, 1992.

4. Will refueling or resumption of operation therefore require a technical specification change or other license amendment?
 - (1) Yes.
 - (2) Requirements for Reload 9 have not been determined.

If answer is yes, what, in general, will these be?

 - (1) Safety limit MCPR for cycle 9 prior to resumption of operation.

5. Scheduled date(s) for submitting proposed licensing action and supporting information:
 - (1) Submitted December 17, 1990.

6. Important licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures:

UNIT 2 REFUELING INFORMATION (Continued)

7. The number of fuel assemblies (a) in the core and (b) in the spent fuel storage pool:

Following Reload 8:

- (a) Core - 764 Fuel Assemblies
- (b) Fuel Pool - 1894 Fuel Assemblies, 58 Fuel Rods

8. The present licensed spent fuel pool storage capacity and the size of any increase in licensed storage capacity that has been requested or is planned, in number of fuel assemblies:

The spent fuel pool storage capacity has been relicensed for 3819 fuel assemblies.

9. The projected date of the last refueling that can be discharged to the spent fuel pool assuming the present capacity:

September 2003 without full core offload capability.

September 1997 with full core offload capability.

UNIT 3 REFUELING INFORMATION

1. Name of facility:

Peach Bottom Unit 3

2. Scheduled date for next refueling shutdown:

Reload 8 scheduled for September 9, 1991

3. Scheduled date for restart following refueling

Restart following refueling scheduled for December 8, 1991

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

Yes.

If answer is yes, what, in general, will these be?

Safety limit MCR for cycle 9 fuel.

5. Scheduled date(s) for submitting proposed licensing action and supporting information:

Submitted December 17, 1990.

6. Important licensing consideration associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures:

UNIT 3 REFUELING INFORMATION (Continued)

7. The number of fuel assemblies (a) in the core and (b) in the spent fuel storage pool:
- (a) Core - 764 Fuel Assemblies
 - (b) Fuel Pool - 1496 Fuel Assemblies, 6 Fuel Rods
8. The present licensed spent fuel pool storage capacity and the size of any increase in licensed storage capacity that has been requested or is planned, in number of fuel assemblies:
- The spent fuel pool storage capacity has been relicensed for 3819 fuel assemblies. Modification of the fuel pool is expected to be complete in the second quarter of 1991.
9. The projected date of the last refueling that can be discharged to the spent fuel pool assuming the present capacity:
- With the current fuel pool capacity (prior to the completion of the fuel pool reracking modification):
 - September 1996 without full core offload capability.
 - End of next cycle with full core offload capability (est. January 1991).
 - With increased fuel pool capacity (subsequent to the completion of the fuel pool reracking modification):
 - September 2004 without full core offload capability.
 - September 1998 with full core offload capability.

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50 - 277

UNIT PEACH BOTTOM UNIT 2

DATE MARCH 15, 1991

COMPANY PHILADELPHIA ELECTRIC COMPANY

M. J. BARON
SUPERVISOR
REPORTS GROUP
PEACH BOTTOM ATOMIC POWER STATION

TELEPHONE (717) 456-7014 EXT. 3321

MONTH FEBRUARY 1991

DAY	AVERAGE DAILY POWER LEVEL (MWE-NET)	DAY	AVERAGE DAILY POWER LEVEL (MWE-NET)
1	0	17	0
2	0	18	0
3	0	19	0
4	0	20	0
5	0	21	0
6	0	22	0
7	0	23	0
8	0	24	0
9	0	25	0
10	0	26	0
11	0	27	0
12	0	28	0
13	0		
14	0		
15	0		
16	0		

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50 - 278

PNCH BOTTOM UNIT 3

DATE FEB 15, 1991

COMPANY PHILADELPHIA ELECTRIC COMPANY

M. J. BARON
SUPERVISOR
REPORTS GROUP
PNCH BOTTOM ATOMIC POWER STATION

TELEPHONE (717) 456-7014 EXT. 3321

MONTH FEBRUARY 1991

DAY	AVERAGE DAILY POWER LEVEL (MWE-NET)	DAY	AVERAGE DAILY POWER LEVEL (MWE-NET)
1	1055	17	913
2	1064	18	1049
3	1060	19	1064
4	1060	20	1068
5	1068	21	1077
6	1046	22	1068
7	1050	23	1064
8	1062	24	1064
9	1063	25	1068
10	1067	26	1060
11	1060	27	1068
12	1060	28	1055
13	1060		
14	1058		
15	1063		
16	735		

OPERATING DATA REPORT

DOCKET NO. 50 - 277

DATE MARCH 15, 1991

COMPLETED BY PHILADELPHIA ELECTRIC COMPANY

M. J. BARON
SUPERVISOR
REPORTS GROUP

PEACH BOTTOM ATOMIC POWER STATION
TELEPHONE (717) 456-7014 EXT. 3321

OPERATING STATUS

- 1. UNIT NAME: PEACH BOTTOM UNIT 2
- 2. REPORTING PERIOD: FEBRUARY, 1991
- 3. LICENSED THERMAL POWER (MWT): 3293
- 4. NAMEPLATE RATING (GROSS MWE): 1152
- 5. DESIGN ELECTRICAL RATING (NET MWE): 1065
- 6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE): 1098
- 7. MAXIMUM DEPENDABLE CAPACITY (NET MWE): 1055

NOTES:

REFUELING OUTAGE.

- 8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS NUMBER 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS:
- 9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE):
- 10. REASONS FOR RESTRICTIONS, IF ANY:

	THIS MONTH	YR-TO-DATE	CUMULATIVE
11. HOURS IN REPORTING PERIOD	672	1,416	145,992
12. NUMBER OF HOURS REACTOR WAS CRITICAL	0	264.4	86,965.1
13. REACTOR RESERVE SHUTDOWN HOURS	0.0	0.0	0.0
14. HOURS GENERATOR ON-LINE	0.0	264.4	83,840.5
15. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	0.0
16. GROSS THERMAL ENERGY GENERATED (MWH)	0	855,720	247,272,753
17. GROSS ELECTRICAL ENERGY GENERATED (MWH)	0	284,000	81,292,290
18. NET ELECTRICAL ENERGY GENERATED (MWH)	* -1,836	271,567	77,826,213

DATE MARCH 15, 1991

	THIS MONTH	YR-TO-DATE	CUMULATIVE
19. UNIT SERVICE FACTOR	0.0	18.7	57.4
20. UNIT AVAILABILITY FACTOR	0.0	18.7	57.4
21. UNIT CAPACITY FACTOR (USING MDC NET)	0.0	18.2	50.5
22. UNIT CAPACITY FACTOR (USING DER NET)	0.0	18.0	50.1
23. UNIT FORCED OUTAGE RATE	0.0	0.0	14.3
24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH):			

25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP:
 MODE SWITCH TO STARTUP MARCH 24, 1991.

26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION):	FORECAST	ACHIEVED
INITIAL CRITICALITY		09/16/73
INITIAL ELECTRICITY		02/18/74
COMMERCIAL OPERATION		07/05/74

OPERATING DATA REPORT

DOCKET NO. 50 - 278

DATE MARCH 15, 1991

COMPLETED BY PHILADELPHIA ELECTRIC COMPANY

M. J. BARON
SUPERVISOR
REPORTS GROUP

PEACH BOTTOM ATOMIC POWER STATION
TELEPHONE (717) 456-7014 EXT. 3321

OPERATING STATUS

1. UNIT NAME: PEACH BOTTOM UNIT 3
2. REPORTING PERIOD: FEBRUARY, 1991
3. LICENSED THERMAL POWER (MWT): 3,033
4. NAMEPLATE RATING (GROSS MWE): 1152
5. DESIGN ELECTRICAL RATING (NET MWE): 1065
6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE): 1098
7. MAXIMUM DEPENDABLE CAPACITY (NET MWE): 1035

NOTES:

8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS NUMBER 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS.
9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE):
10. REASONS FOR RESTRICTIONS, IF ANY:

	THIS MONTH	YR-TO-DATE	CUMULATIVE
11. HOURS IN REPORTING PERIOD	672	1,416	141,888
12. NUMBER OF HOURS REACTOR WAS CRITICAL	672.0	1,296.5	86,299.4
13. REACTOR RESERVE SHUTDOWN HOURS	0.0	0.0	0.0
14. HOURS GENERATOR ON-LINE	672.0	1,273.7	83,364.3
15. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	0.0
16. GROSS THERMAL ENERGY GENERATED (MWH)	2,162,664	3,990,264	243,842,770
17. GROSS ELECTRICAL ENERGY GENERATED (MWH)	723,100	1,323,500	79,999,032
18. NET ELECTRICAL ENERGY GENERATED (MWH)	701,905	1,262,772	76,659,444

DATE MARCH 15, 1991

	THIS MONTH	YR-TO-DATE	CUMULATIVE
19. UNIT SERVICE FACTOR	100.0	90.0	58.8
20. UNIT AVAILABILITY FACTOR	100.0	90.0	58.8
21. UNIT CAPACITY FACTOR (USING MDC NET)	100.9	87.5	52.2
22. UNIT CAPACITY FACTOR (USING DER NET)	98.1	85.1	50.7
23. UNIT FORCED OUTAGE RATE	0.0	10.0	12.5
24. SHUTDOWNS SCHEDULED OVER NEXT 5 MONTHS (TYPE, DATE, AND DURATION OF EACH):			

25. IF SHUTDOWN AT END OF REPORT PERIOD ESTIMATED DATE OF STARTUP:

26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION):	FO	ACHIEVED
INITIAL CRITICALITY		08/07/74
INITIAL ELECTRICITY		09/01/74
COMMERCIAL OPERATION		12/23/74

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50 - 277

UNIT NAME PEACH BOTTOM UNIT 2

DATE MARCH 15, 1991

REPORT MONTH FEBRUARY, 1991

COMPLETED BY PHILADELPHIA ELECTRIC COMPANY

M. J. BARON
SUPERVISOR
REPORTS GROUP

PEACH BOTTOM ATOMIC POWER STATION
TELEPHONE (717) 456-7014 EXT. 3321

NO.	DATE	TYPE (1)	DURATION (HOURS) (2)	REASON (3)	METHOD OF SHUTTING DOWN REACTOR (3)	LICENSEE EVENT REPORT #	SYSTEM CODE (4)	COMPONENT CODE (5)	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
1	910201	S	672.0			N/A	ZZ	ZZZZZ	PLANNED REFUEL OUTAGE
			672.0						

(1)
F - FORCED
S - SCHEDULED

(2)
REASON
A - EQUIPMENT FAILURE (EXPLAIN)
B - MAINTENANCE OR TEST
C - REFUELING
D - REGULATORY RESTRICTION
E - OPERATOR TRAINING + LICENSE EXAMINATION
F - ADMINISTRATIVE
G - OPERATIONAL ERROR (EXPLAIN)
H - OTHER (EXPLAIN)

(3)
METHOD
1 - MANUAL
2 - MANUAL SCRAM.
3 - AUTOMATIC SCRAM.
4 - OTHER (EXPLAIN)

(4)
EXHIBIT G - INSTRUCTIONS
FOR PREPARATION OF DATA
ENTRY SHEETS FOR LICENSEE
EVENT REPORT (LER)
FILE (NUREG-0161)

(5)
EXHIBIT I - SAME SOURCE

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50 - 278

UNIT NAME PEACH BOTTOM UNIT 3

DATE MARCH 15, 1991

REPORT MONTH FEBRUARY, 1991

COMPLETED BY PHILADELPHIA ELECTRIC COMPANY

M. J. BARON
SUPERVISOR
REPORTS GROUP

PEACH BOTTOM ATOMIC POWER STATION
TELEPHONE (717) 456-7014 EXT. 3321

NO.	DATE	TYPE (1)	DURATION (HOURS) (2)	REASON (3)	METHOD OF SHUTTING DOWN REACTOR (4)	LICENSEE EVENT REPORT #	SYSTEM CODE (5)	COMPONENT CODE (6)	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
2	910216	S	0.0	H	4	N/A	RB	CONRDD	CONTROL ROD PATTERN ADJUSTMENT. REACTOR WAS NOT SHUT DOWN.

- | | | | |
|-----------------------------|--|--|---|
| (1) | (2) | (3) | (4) |
| F - FORCED
S - SCHEDULED | REASON
A - EQUIPMENT FAILURE (EXPLAIN)
B - MAINTENANCE OR TEST
C - REFUELING
D - REGULATORY RESTRICTION
E - OPERATOR TRAINING + LICENSE EXAMINATION
F - ADMINISTRATIVE
G - OPERATIONAL ERROR (EXPLAIN)
H - OTHER (EXPLAIN) | METHOD
1 - MANUAL
2 - MANUAL SCRAM.
3 - AUTOMATIC SCRAM.
4 - OTHER (EXPLAIN) | EXHIBIT G - INSTRUCTIONS
FOR PREPARATION OF DATA
ENTRY SHEETS FOR LICENSEE
EVENT REPORT (LER)
FILE (NUREG-0161)

(5)
EXHIBIT I - SAME SOURCE |