

APPENDIX A

NOTICE OF VIOLATION

Southern California Edison Company  
San Onofre Nuclear Generating Station,  
Unit 2

Docket No. 50-361  
License No. NPF-10

As a result of the inspection conducted on November 15-19, 1982 and in accordance with NRC Enforcement Policy, (10 CFR Part 2, Appendix C), 47 FR 9987 (March 9, 1982) the following violation was identified:

- A. Technical specification 6.8.1.C requires that written procedures be implemented for surveillance and test activities of safety related equipment. Technical specification 4.8.2.1.b.3 requires quarterly surveillance of safety related batteries to verify that the average electrolyte temperature of ten connected cells is above 60°F. Additionally, maintenance procedure S023-I-2.13, "Quarterly Inspection of Batteries," paragraph 6.5.2, requires as follows: "Average of electrolyte temperature for 10 randomly selected cells and record cell numbers, cell temperature and average temperatures..."

Contrary to these requirements on two occasions (February 15, 1982 for Class IE Battery No. B007, and May 19, 1982 for Class IE battery B009) only five cells were used to calculate average electrolyte temperature.

This is a Severity Level V Violation. (Supplement I)

Pursuant to the provisions of 10 CFR 2.201, Southern California Edison Company is hereby required to submit to this office within 30 days of the date of this Notice, a written statement or explanation in reply, including (1) the corrective steps which have been taken and the results achieved; and (2) corrective steps which will be taken to avoid further items of noncompliance and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

DEC 9 1982

Dated: \_\_\_\_\_

\_\_\_\_\_  
D. F. Kirsch, Chief  
Reactor Projects Section No. 3

8301030106 821209  
PDR ADDCK 05000361  
G PDR



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION V  
1450 MARIA LANE, SUITE 260  
WALNUT CREEK, CALIFORNIA 94596

December 9, 1982

Docket No. 50-361

Southern California Edison Company  
P. O. Box 800  
2244 Walnut Grove Avenue  
Rosemead, California 91770

Attention: Dr. L. T. Papay, Vice President  
Advanced Engineering

Gentlemen:

Subject: NRC Inspection of San Onofre Unit 2

This refers to the routine inspection conducted by M. M. Mendonca of this office during the period of November 15-19, 1982, of activities authorized by NRC License No. NPF-10 and to the discussion of our findings held by Mr. Mendonca with Mr. W. C. Moody and other members of the Southern California Edison staff at the conclusion of the inspection on November 19, 1982.

Areas examined during this inspection are described in the enclosed inspection report. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel and observations by the inspector.

Based on the results of this inspection, it appears that one of your activities was not conducted in full compliance with NRC requirements, as set forth in the Notice of Violation, enclosed herewith as Appendix A.

Your response to this notice is to be submitted in accordance with the provisions of 10 CFR 2.201 as stated in Appendix A, Notice of Violation.

In accordance with 10 CFR 2.790(a), a copy of this letter and the enclosures will be placed in the NRC Public Document Room unless you notify this office, by telephone, within ten days of the date of this letter and submit written application to withhold information contained therein within thirty days of the date of this letter. Such application must be consistent with the requirements of 2.790(b)(1).


DUPE

December 9, 1982

Should you have any questions concerning this inspection, we will be glad to discuss them with you.

The responses directed by this letter and the accompanying Notice are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

Sincerely,



T. W. Bishop, Chief  
Reactor Projects Branch No. 2

Enclosures:

- A. Notice of Violation
- B. NRC Inspection Report  
No. 50-361/82-38

cc w/o enclosure:  
R. Dietch, SCE

cc w/enclosure:  
H. B. Ray, Station Manager (San Clemente)

APPENDIX A

NOTICE OF VIOLATION

Southern California Edison Company  
San Onofre Nuclear Generating Station,  
Unit 2

Docket No. 50-361  
License No. NPF-10

As a result of the inspection conducted on November 15-19, 1982 and in accordance with NRC Enforcement Policy, (10 CFR Part 2, Appendix C), 47 FR 9987 (March 9, 1982) the following violation was identified:


- A. Technical specification 6.8.1.C requires that written procedures be implemented for surveillance and test activities of safety related equipment. Technical specification 4.8.2.1.b.3 requires quarterly surveillance of safety related batteries to verify that the average electrolyte temperature of ten connected cells is above 60°F. Additionally, maintenance procedure S023-I-2.13, "Quarterly Inspection of Batteries," paragraph 6.5.2, requires as follows: "Average of electrolyte temperature for 10 randomly selected cells and record cell numbers, cell temperature and average temperatures..."

Contrary to these requirements on two occasions (February 15, 1982 for Class IE Battery No. B007, and May 19, 1982 for Class IE battery B009) only five cells were used to calculate average electrolyte temperature.

This is a Severity Level V Violation. (Supplement I)

Pursuant to the provisions of 10 CFR 2.201, Southern California Edison Company is hereby required to submit to this office within 30 days of the date of this Notice, a written statement or explanation in reply, including (1) the corrective steps which have been taken and the results achieved; and (2) corrective steps which will be taken to avoid further items of noncompliance and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

Dated: December 9, 1982

  
D. F. Kirsch, Chief  
Reactor Projects Section No. 3

Dupe