

VIRGINIA ELECTRIC AND POWER COMPANY  
RICHMOND, VIRGINIA 23261

W. L. STEWART  
VICE PRESIDENT  
NUCLEAR OPERATIONS

December 29, 1982

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
Attn: Mr. Robert A. Clark, Chief  
Operating Reactors Branch No. 3  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Serial No. 733  
NO/JHL:acm  
Docket No. 50-339  
License No. NPF-7

Gentlemen:

AMENDMENT TO OPERATING LICENSE NPF-7  
NORTH ANNA POWER STATION UNIT NO. 2  
PROPOSED OPERATING LICENSE AMENDMENT

Pursuant to 10 CFR 50.90, the Virginia Electric and Power Company requests an amendment to Operating License NPF-7 for North Anna Power Station Unit No. 2. The proposed change to the Operating License is enclosed.

License Condition 2.C(21)(e) of the North Anna Unit 2 Operating License states, "VEPCO shall complete corrective actions need to provide the capability to promptly obtain and perform radioisotopic and chemical analysis of reactor coolant and containment atmosphere samples under degraded core conditions without excessive exposure by no later than January 1, 1983." The proposed change is to complete License Condition 2.C(21)(e) by no later than April 1, 1983. The Reactor Coolant Sampling System has been installed and is undergoing startup testing. A reactor coolant sample has not been successfully analyzed due to a problem in the sampling and analysis equipment. The schedule extension is required to allow time to correct sampling and analysis equipment problems. The proposed amendment is provided in Attachment 1. A discussion of the proposed change is provided in Attachment 2.

This request has been reviewed and approved by the Station Nuclear Safety and Operating Committee and the Safety Evaluation and Control staff. It has been determined that this request does not involve an unreviewed safety question as defined in 10 CFR 50.59.

We have evaluated this request in accordance with the criteria in 10 CFR 170.22. Since this request involves a safety issue which the Staff should be able to determine does not pose a significant hazard consideration for Unit 2, a Class III license amendment fee is required for Unit 2. Accordingly, a voucher check in the amount of \$4000 is enclosed in payment of the required fees.

Very truly yours,

W. L. Stewart  
W. L. Stewart

8301030178 821229  
PDR ADOCK 05000339  
P PDR

App'd  
1/40  
w/check:  
\$4000.00

VIRGINIA ELECTRIC AND POWER COMPANY TO

Harold R. Denton

Attachments:

1. Proposed Operating License Amendment
2. Discussion of Proposed Operating License Amendment
3. Voucher Check for \$4000

cc: Mr. James F. O'Reilly  
Regional Administrator  
Region II