

Distribution:

DN 50-320 ✓
NRC PDR
Local PDR
DCS
TMI Site r/f
TMI HQ r/f
BJSnyder
LHBarrett
TCPoindexter
RWeller
RBellamy
AFasano
JWiebe
SChandler
ACRS
HRDenton
I&E

NRC/TMI-82-078
December 22, 1982

Docket No. 50-320

Mr. B. K. Kanga
Director, TMI-2
GPU Nuclear Corporation
P. O. Box 480
Middletown, PA 17057

Dear Mr. Kanga:

Your letter 4410-82-L-0065 requested a temporary exemption to certain surveillance requirements while the primary reactor system at TMI-2 is in a draindown condition. The systems involved are the Nuclear Service Closed Cooling Water, Decay Heat Closed Cooling Water, and Mini Decay Heat Removal System. Please note that although your letter was dated December 9, 1982, it did not reach this office until December 21, 1982, and that the reactor coolant system was refilled by December 17, 1982. Therefore, the basis for your request no longer exists, and your request is denied.

Since the Recovery Operations Plan contains the surveillance requirements, any change to these requirements necessitates a change to the Recovery Operations Plan. Appropriately, future requests for changing surveillance requirements should take the form of a Recovery Operations Plan Change Request.

Lake H. Barrett
Deputy Program Director
TMI Program Office

cc: J. Barton
J. Theising
E. Wallace
J. Byrne
J. Larson

8301110051 821222
PDR ADOCK 05000320
P PDR

OFFICE	TMI: PDR	TMI: PDR					
SURNAME	RRBellamy;ws	LHBarrett					
DATE	12/2/82	12/2/82					