

JUNE 15, 1964

MEMORANDUM

TO : C. R. Williams, Saxton Subcommittee Chairman
H. Kouts
Signed R. H. Wilcox

FROM : R. H. Wilcox, Assistant to Executive Secretary,
ACRS

SUBJECT: CATEGORY B REPORT - SAXTON - SUPPLEMENT TO CHANGE REQUEST NO. 12

At URL request, SNEC has submitted the attached additional information dated May 14, 1964 on Change Request #12. This is the proposal to install rod-type control rods instead of the blades in the Saxton reactor which was discussed in my 4/22/64 Category B memo.

The results of testing and analysis are reported. Loop tests of a comparable design for Con Ed Core B resulted in trouble-free performance. The circumferential stress in the absorber cladding will be close to, but apparently less than yield.

No ACRS action appears warranted.

Attachment:

1. Ltr. 5/14/64 & Supple. #1 to Change Req. #12

OFFICE ▶	ACRS					
SURNAME ▶	R.H.WILCOX:s18					
DATE ▶	6/15/64					

A/H1