BRAFT FUX LOWINENT

DRAFT UCID

12.2

THE FINAL PROGRESS REPORT FOR THE SAN ONOFRE NUCLEAR GENERATING STATION UNIT 1 AUXILIARY FEEDWATER SYSTEM PROJECT

SEISMIC SAFETY MARGINS RESEARCH PROGRAM

T. Y. Chuang
L. E. Cover
B. J. B. nda*
D. L. Bernreuter
J. C. Chen
J. J. Johnson*
D. A. Lappa
O. R. Maslenikov*
J. B. Savy
L. C. Shieh
S. N. Shukla
J. E. Wells

June 18, 1982

*Structural Mechanics Associates (SMA)

8301110073 821210 PDR FDIA GALLO82-399 PDR

DRAFT FOR CUMMENT

ABSTRACT

This final progress report describes the accomplishments of the San Onofre Nuclear Generating Station Unit 1 (SONGS-1) Auxiliary Feedwater System (AFWS) Project of the Seismic Safety Margins Research Program (SSMRP). The project was started on May 1, 1981 and terminated by the Nuclear Regulatory Commission (NRC) on January 29, 1982. This report also briefly presents the progress of this project.

The development of the structural and piping models for SONGS-1 was almost completed. Piping fragility data generation and fault tree development for the AFWS were completed. The synthetic time histories targeted to three spectra: the SONGS-1 seismic reevaluation spectra; SONGS Units 2 and 3 design spectra, and the average of the two, were generated. The SSMRF methodology was utilized to compute the seismic responses of the reactor building complex using these time histories as the seismic excitation. The seismic responses have been compared with the SONGS-1 seismic reevaluation results provided by the Southern California Edison Company (SCEC)/Bechtel Power Corporation. In general, the SCEC/Bechtel results enveloped the Lawrence Livermore National Laboratory's (LLNL's) results due to all three target spectra mentioned above. The only exception appears in the in-structure response spectra of several selected points in the reactor building. The LLNL's spectral accelerations in the low frequency range of these spectra due to SONGS Units 2 & 3 design spectra exceeded the SONGS-1 seismic reevaluation results. This effect may be interpreted as a result of the strong motions in the low frequency range of the SONGS Unit 2 & 3 design spectra. Significant progress toward the development of a seismic hazard curve for the SONGS site and the time histories (associated with this hazard curve) required for the probabilistic study of the SONGS-1 has been made. Substantial progress has also been made toward the generation of structural fragility curves. All the design data and drawings obtained from SCEC and the computer files generated by LLNL and its subcontractors are stored in a retrievable manner.

i

TABLE OF CONTENTS

DRAFT FOR CUMMENT

12.3

ABSTRACT

ACKNOWLEDGMENTS

- SECTION 1: INTRODUCTION
- SECTION 2: TASK DESCRIPTIONS
- SECTION 3: TASK ACCOMPLISHMENTS
- SECTION 4: MILESTONE CHART AND DESCRIPTIONS

REFERENCES

- APPENDIX A: STRUCTURAL RESPONSE COMPARISON
- SECTION A1: INTRODUCTION
- SECTION A2: SEISMIC INPUT TIME HISTORIES
- SECTION A3: SOIL, SSI AND STRUCTURAL MODELS
- SECTION A4: RESPONSE COMPARISON FOR REACTOR BUILDING/CONTAINMENT SPHERE
- SECTION A5: REFERENCES

APPENDIX B: FAULT TREE DEVELOPMENT

- APPENDIX C: INCOMPLETE TASKS
- SECTION C1: INTRODUCTION
- SECTION C2: PIPING MODELS
- SECTION C3: EARTHQUAKE OCCURRENCE MODEL FOR THE SONGS SITE
- SECTION C4: GROUND MOTION MODEL FOR THE SONGS SITE
- SECTION C5: BETA-FACTOR FOR PIPE COMPONENTS
- SECTION C6: STRUCTURAL FRAGILITIES
- SECTION C7: REFERENCES

ACKNOWLEDGMENTS

DRAFT FOR GUMMENT

We would like to express our appreciation to the Southern California Edison Company (SCEC) and Bechtel Power Corporation for providing the necessary design data and drawings, as well as the opportunities to visit the San Onofre site. We especially extend our thanks to Mr. R. C. Blaschke, Project Engineer of SCEC for his efforts to coordinate the project with Bechtel Power Corporation, SCEC, and the Lawrence Livermore National Laboratory (LLNL) staff and its subcontractors.

We extend special thanks to Dr. P. D. Smith, Associate Program Leader of Seismic and Structural Safety of LLNL's Nuclear Systems Safety Program, Dr. M. P. Bohn, Program Manager of the Seismic Safety Margins Research Program, and Dr. R. T. Langland, Section Leader of the Engineering Mechanics Section, Nuclear Test Engineering Division of LLNL's Mechanical Engineering Department, for their helpful critical review of the report. We are grateful to Dr. D. H. Chung for his contribution to the development of the earthquake occurrence and ground motion models (Appendix C), and to Mr. S. M. Pratuch for his assistance in developing the auxiliary feedmeter (AFW) piping models. We appreciate the support of the LLNL Nuclear Safety Systems Program Office, Mechanical Engineering Department, Nuclear Test Engineering Division, Engineering Mechanics Section, Methods Development Group and Statistics and Probability Group.

Over the course of our work, our secretaries, Ms. Sue Aubuchon, Ms. Virge Jaramillo, Ms. Terry Patters, Ms. Marilynn Govenor, and Ms. Claudia Ambrose, and Director's Office Correspondence Center's Word Processing Specialist, Sandy Auguadro were indispensable and their efforts are deeply appreciated. We also wish to acknowledge the effort of LLNL technical information specialist, Ms. Carol Meier, who has helped with the editing of this report and produced the draft in a timely and orderly fashion.

444

Light I for Gumment

. . .

The LLNL's Project Manager is Dr. T. Y. Chuang who has the full responsibility for managing the project and would like to thank the project staff and LLNL's subcontractors. Finally, we wish to thank our NRC Project Manager, Mr. Roger M. Kenneally, and the office of Nuclear Reactor Regulatory (NRR) Technical Monitor, Mr. K. S. Herring, who provided guidance and support to this project.

This work was supported by the United States Nuclear Regulatory Commission under a Memorandum of Understanding with the United States Department of Energy.

SECTION 1: INTRODUCTION

GRAFT FOR COMMENT

The seismic qualification requirements for the auxiliary feedwater systems (AFWS) of Pressurized Water Reactors (PWR's) were developed over a number of years. These requirements are formalized in the publication, General Design Criteria, Appendix A to Title 10 of the Code of Federal Regulation (CFR) Part 50. Guidance for the implementation of these requirements was published in 1972 as Regulatory Guide 1.26 (Quality Group Classifications and Standards for Water, Steam, and Radioactive Waste Containing Components of Nuclear Power Plants) and as Regulatory Guide 1.29 (Seismic Design Classification). Although both guides identified that the AFWS is important to safety and required protection against a seismic event, the full recognition of the AFWS as an engineered safety feature (ESF) did not occur until publication of the Standard Review Plan (SRP) in 1975. Efforts to determine how to backfit seismic requirements to earlier PWR plants have been undertaken primarily in the Systematic Evaluation Program (SEP) for a limited number of operating PWR's.

The Three Mile Island Unit 2 (TMI-2) accident in 1979 further focused attention on the importance of decay heat removal systems in general, and on the AFWS in particular. The Nuclear Regulatory Commission's (NRC's) Office of Nuclear Reactor Regulation (NRR) has developed and implemented several short-term improvements related to the AFWS, via the Bulletins and Orders Task Force, Lessons Learned Task Force, through the Division of Licensing. In the course of the development of the TMI-2 Action Plan it was concluded that these short-term changes were sufficient until a comprehensive, three-year study of decay heat removal system requirements was completed (TMI-2 Action Plan Items II.E.3.1, II.E.3.2, II.E.3.3, and II.E.3.4). However, the seismic qualification of the AFWS was not directly addressed by the above Task Forces, and thus this area remained a potential safety issue for the PWR plant operation during the period of time needed to complete the Action Plan studies and any subsequent modifications. In July, 1980, the NRC staff completed a brief risk study of seismically induced loss-of-decay heat removal for plants without a seismically qualified AFWS. The review² of this risk study was completed by the Lawrence Livermore National Laboratory (LLNL) and

-6-

DRAFT FOR COMMENT

concluded that a more detailed study should be conducted. Based on the results of this brief study and until a more detailed study is available, NRC decided to permit continued operation of PWR plants without the AFWS qualified for current standards (i.e., R.G. 1.26, R.G. 1.29, R.G. 1.60 and etc.). This decision reflects, in part, the consideration to preserve the continuity of the SEP and the TMI-2 Action Plan which may call for changes in the area of decay heat removal. It is not desirable to implement unnecessary or marginally necessary changes while these more comprehensive programs are underway.

In December, 1980, the Office of Nuclear Reactor Research (RES) requested³ that LLNL develop a work plan⁴ for a probabilistic study on the AFWS and its related systems for the San Onofre Nuclear Generating Station Unit 1 (SONGS-1) utilizing the tools developed by the Seismic Safety Margins Research Program (SSMRP).⁵ Hereafter, the "AFWS" may be loosely referred to as the AFWS and its related systems: condensate storage system; electric power; auxiliary steam supply; and service water and fire protection system. The work plan was approved by NRC on May 1, 1981, and the SONGS-1 AFWS Project was formally established.

The SONGS-1 is a three-loop PWR plant and the net electric output is 436 MWe. The nuclear steam supply system (NSSS) was provided by the Westinghouse Corporation. The plant is jointly owned by the Southern California Edison Company (SCEC) and the San Diego Gas and Electric Company. It was designed and constructed by Bechtel Power Corporation in the 1960's, and located at San Onofre (about halfway between Los Angeles and San Diego), Californis. The operation of the plant began in January, 1968. The original seismic design criteria was based on a 0.5 g Housner spectra for the design basis earthquake (DBE). The plant is included in the SEP study and has been reevaluated for a criteria based on a 0.67 g modified Housner spectra.

The objectives of the SONGS-1 AFWS project were as follows:

0

To evaluate the conservatism in the SCEC/Bechtel seismic reevaluation program.

 To provide input to NRC licensing decisions on SONGS Unit 1 for the Balance of Plant Seismic Reevaluation Program (BOPSRP).

DRAFT FOR COM

 To assist the NRC in addressing the generic issue of the seismic qualification requirements for AFWS.

In order to accomplish these objectives, the following approaches are taken as part of the SSMRP:

- Compare the seismic responses of structures and piping systems of the AFWS due to different target spectra and the SONGS-1 seismic reevaluation values provided by SCEC/Bechtel.
- o Identify the weak links of the AFWS of SONGS Unit 1.
- c Compare the probability of failure of the AFWS of Zion Unit 1 with SONGS Unit 1.

A parallel NRR effort which will determine the seismic qualification level of the AFWS of all operating PWR's, is currently being conducted at LLNL. This effort is a part of NRC Multiplant Action Plan C-14 whose goals are:

- o Identify deficiencies amenable to simple remedial actions.
- Survey the plants to determine the extent and areas where significant improvements may be needed.
- Complete re-analysis and/or modifications for those plants that do not have an AFWS with demonstrated reasonable assurance of functioning following a safe shutdown earthquake (SSE).

The SSMRP methodology was to be applied to the Zion Unit 1 and SONGS Unit 1 auxiliary feedwater systems in the same level of detail. Steps in the methodology can be broadly outlined as follows:

- o Definition of the earthquake hazard and generation of time histories.
- Calculation of plant response by the SMACS (Seismic Methodology Chain with Statistic) program⁶, which entails calculation of soil-structure interaction (SSI), the responses of structures, and the responses of subsystems, e.g. piping systems.
- Evaluation of failure, which requires definition of the fragilities of structures, components, and systems, and a description of the operation and interaction of components within the AFWS.

URAFT FOR COMMENT

One of the basic assumptions of the work plan was to utilize the SONGS-1 seismic design modifications existing at the time the work plan was prepared. As the work progressed, however, new modifications to the turbine and fuel storage building and their foundations were identified, and were also incorporated in accordance with an NRC request during the site visit in June, 1981. This caused a significant delay in completing the project.

On January 29, 1982, the analysis effort was terminated by NRC, because it became only marginally cost-effective to complete the analysis due to constraints imposed by NRC licensing schedules.

This report documents the accomplishments of the project at the time that the analysis was terminated. The format used in this report closely follows that of the quarterly progress reports issued throughout the project.

This report contains four sections. In addition to Section 1 which contains the introductory material, Section 2 briefly describes the individual tasks which comprise the SONGS-1 AFWS project. Section 3 contains information regarding the accomplishments under each task, and Section 4 includes milestone charts and descriptions. Three appendices have also been employed to provide detailed results documenting the various task accomplishments. Appendix A describes in detail the structural response comparison of the containment sphere and reactor building. Appendix B detailed the fault tree development effort. Finally, the remaining incomplete tasks are elaborated in Appendix C which provides the development of piping models, earthquake occurence model, ground motion model, beta-factor for pipe component and structural fragilities. SECTION 2: TASK DESCRIPTIONS

DRAFT FOR COMMENT

19. 8

Seven major tasks, designated I through VII, were identified for the SONGS-1 AFWS Project. Each of these tasks is described in the following:

Task I-Develop the Models for Response Computation

Task I develops the models for soil, structures, soil-structure interacton (SSI) and auxiliary feedwater (AFW) piping systems. Existing models furnished by SCEC will be carefully studied to evaluate their efficiency. If it is determined to be too inefficient to use the existing models due to, for instance, the differences in computer programs, new models will be developed. For the portion for which SCEC does not have existing models, new models will have to be developed. There are four subtasks, which are described below.

Task I.1-Develop Soil Model

Obtain and evaluate soil data for SONGS Unit 1. Equivalent linear soil properties for system analysis will be estimated.

Task I.2-Develop Structural Hodels

Obtain, evaluate, and rerun the structural models furnished by SCEC/Bechtel. The structural models for the SMACS analysis will be prepared. The structural models will then be benchmarked against the models developed by SCEC/Bechtel. Fixed-base eigenvalue analysis will be performed for model comparison.

Task I.3--Develop Soil-Structure Interaction Models

The impedances and scattering matrices for soil conditions in the coupled soil-structure system analysis will be generated. The SSI models for SMACS analysis will then be prepared.

Task I.4--Develop the Models of the AFWS Piping System

Obtain the piping models for the AFWS from SCEC. Evaluate and rerun these models. Create new models if necessary, e.g., the portion of the AFWS not

LIGHT FOR COMMENT

recently modified, since the SCEC may not have existing models for this portion. Identify the support points in the structures of these models in order to provide the input motions to the AFW piping systems.

Task II-Compare the Seismic Responses of Structures and Piping Systems of the SONGS-1 AFWS with the Seismic Reevaluation Results

Task II is to compare the seismic responses of structures and piping systems of the AFWS due to three different target spectra and the seismic reevaluation results furnished by SCEC. The three target spectra are:

- 1. SONGS Unit 1 seismic reevaluation (modified Housner) spectra.
- 2. The design (modified Newmark & Hall) spectra for SONGS Units 2 and 3.
- 3. An average spectra of the above two.

A set of synthetic time histories for each spectra will be generated. The analyses of soil-structure interaction (SSI) analysis, structure housing the AFWS, and the AFW piping systems will be performed using SMACS. The seismic responses of the structure and piping systems will then be computed. These results will be compared with the seismic reevaluation results furnished by SCEC. This task has four subtasks, which are described below.

Task II.1-Develop Seismic Input Time Histories for Different Target Spectra

A set of time histories will be generated for each target spectra as mentioned above. The response spectra of the time history will envelop their target spectra, respectively.

Task II.2-Compute Seismic Responses of Structures due to Different Target Spectra

The seismic responses of structures will be computed for each target spectra as described above. The input motions for the AFW piping support locations will also be computed.

Task II.3-Compute Seismic Responses of the AFW Piping Systems due to Different Target Spectra

The input motions from the structures supporting the auxiliary feedwater (AFW) piping systems will be imposed on the AFW piping models. The multisupport time history analysis techniques will then be utilized to compute the seismic responses of the AFW piping systems for each input target spectra as described above.

Task II.4--Compare the SMACS Results of Structures and Piping Systems with Seismic Reevaluation Results

DRAFT FOR COMMENT

The results computed in Tasks II.2 and II.3 will be compared with the seismic reevaluation results furnished by SCEC/Bechtel. This comparison will estimate the conservatism in the reevaluation analysis which was based on the 0.67 g modified Housner spectra.

Task III--Develop the SONGS Site Specific Seismic Hazard Curves, Spectra and Time Histories

In this task, the seismic input required for both the systems analysis (SEISIM) and structural analysis program (SMACS) will be developed. SEISIM, Seismic Evaluation of Important Safety Importance Measure, requires (as one of its inputs) the annual exceedance probability of any level of peak ground acceleration at the SONGS site. SMACS, Seismic Methodology Analysis Chain with Statistics, requires (as input) sets of time histories which are correlated with the hazard curve used in SEISIM. To develop this required input, it is necessary to first develop an earthquake occurrence model which gives the locations of the earthquake relative to the SONGS site and rate of occurrence of various magnitude earthquakes. Along with the earthquake occurrence model, a ground motion model is also required to predict the ground motion at the SONGS site from an earthquake of a specific magnitude located at a specific distance from the site. The earthquake occurrence model and ground motion model are then incorporated into the hazard analysis program (HAZARD) to generate the required input for SEISIM and SMACS. Three subtasks are defined and outlined below.

Task III.1--Develop the Earthquake Occurrence Model for the SONGS Sice

A range of earthquake occurrence models will be developed using both the extensive geologic and seismological investigation carried out by SCEC. The SCEC investigations will provide the basic zonation. Also a brief literature review will be conducted to develop a range of alternative models. Rates of occurrence will be estimated using both LLNL and SCEC data. Largest earthquakes will be estimated using several approaches based on fault length, strain rate, and so on. Task III.2-Develop the Ground Motion Model for the SONGS Site

Ground motion models will be developed to account for the saturation of the magnitude scale based on such parameters as seismic moment, stress drop, and surface wave magnitude. In addition to source modeling, statistical analysis will be performed to establish reasonable bounds for correction factors. These will then be applied to generic ground motion models to account for focusing of seismic energy from nearby earthquakes. The models will represent an extension of a project underway at LLNL for RES and an analysis of near source ground motion. In addition to these model other ground motion models will also be used.

DIAFT FOR COMMENT

Task III.3-Develop Hazard Curves and Time Histories for the SONGS Site

The HAZARD program developed in Phase I of the SSMRP will be used to develop the seismic hazard and spectra at the SONGS site using the earthquake occurrence and ground motion models. Sensitivity studies will be carried out to determine which faults contribute most to the seismic hazard. This information will be used to improve the model and reduce the uncertainty in the estimates. Time histories will be generated from the spectra developed from the improved model using the SIMQKE program developed by the Massachusett Institute of Technology (MIT).

Task IV-Develop the AFWS Fault Tree

Task IV generates the fault tree for the AFWS of SONGS Unit 1. This task will also modify the AFWS Fault tree of Zion Unit 1 to be comparable to SONGS Unit 1. The fault tree of the Zion-1 AFWS was trimmed down considerably due to the size limitation of the SEISIM program, because there were other systems (e.g., residual heat removal, safety injection, and etc.) included in the systems analysis. Since the AFWS is the only system considered in this project, the level of the details of the Zion-1 AFWS fault tree could be expanded. There are two subtasks for this task.

Task IV.1--Develop Fault Tree of SONGS-1 AFWS

The fault tree for the AFWS, including water supply to AFW pumps, electric rower buses, AFW pump discharge to steam generators, and the auxiliary steam supply to AFW pump turbine will be generated. The fault tree will be analyzed to minimize the cut sets. The human and maintenance failure data, and fragility related basic event listings will also be generated.

LART FOR COMMENT

Task IV.2--Modify the Fault Tree of the AFWS of Zion Unit 1

The AFWS fault tree for Zion Unit 1 will be modified to be comparable to the one for SONGS Unit 1. The fault tree of the auxiliary steam supply to the AFW pump turbine will be developed. These fault trees will be analyzed for the input to SEISTM program.

Task V-Develop Fragility Data and Coordinate with Fault Tree

Task V develops the fragility curves of the structures and the beta-factors of the specific pipe sizes for the SONGS Unit 1 AFWS. The fragility data for electrical and mechanical components of Phase I of the SSMRP (which are generic in nature) will be used to the maximum extent. The fault tree will be coordinated with the responses of the electrical and . mechanical components and the AFW piping systems. There are four subtasks as described below.

Task V.1-Develop the Fragility Curves for the Structures Housing the AFWS

Using loads computed in the structures as part of Task II.2, the load .paths, critical wall shear loads and collapse mechanisms will be examined to determine the most likely modes of failure and corresponding fragility curves. These curves will include inelastic energy absorption through consideration of ductility factors. The building design specifications will also be examined for any potential local failures which might affect critical AFWS components.

Task V.2--Develop the Beta-factor for the Pipe Components of the AFWS

Piping failure probability is determined by scaling the computed (SMACS) response appropriately and then compared with a single master fragility curve. These scale factors (the beta-factors) must be determined for all pipe sizes. A large number of these factors have already been derived for those pipes in the Zion Unit 1. However, some additional factors will have to be developed for pipe sizes in 30NGS-1 which were not needed in the Zion Unit 1 analysis.

LAFT FOR COMMENT

Task V.3--Coordinate the Electrical and Mechanical Components of the AFWS with Fault Tree and Structure Responses

The location of the components (or groups of components) for each basic event identified on the fault trees developed in Task IV.1 will be determined from either piping and instrumentation diagrams (P & ID's) or plant inspection, and then a table correlating all these components with their locations and fragility categories will be prepared. The minimum set of responses sufficient to provide the necessary SEISIM input for all the basic events will be identified and correlated with the components on the fault

Task V.4 -- Coordinate the Responses and Fault Tree of the Songs-1 AFWS

Coordinate the seismic responses and fault tree of the Songs-1 AFWS. The beta-factor technique developed in Phase I of the SFMRP will be used to normalize the responses, i.e., resultant moments of pipes. Only those valves or pipe components identified in the fault tree of the AFWS will be analyzed.

Task VI-Identify the Weak Links of the AFWS

Task VI computes the probabilities of failure of the AFWS of SONGS Unit 1. The responses of structures and AFW piping systems will be computed by SMACS. The probabilities of failure of the AFWS will be computed by the SEISIM program. The weak links of AFWS will then be identified. There are two subtasks, as described below. Task VI.1-Compute the Seismic Responses of Structures and Piping Systems of the AFWS

L.J. TFOR COMMENT

The responses of structures and AFW piping systems will be computed over a range of earthquake time histories developed in Task III.3. These responses will be coordinated with the basic events of the fault tree of the AFWS. SMACS will be used to generate the response corresponding to its basic event as an input to SEISIM.

Task VI.2-Compute the Probabilities of Failure of AFWS and Identify the Weak Links

The hazard curves, SMACS's responses, fragility data and fault tree will be incorporated into the SEISIM program. The probabilities of failure of the SONGS-1 AFWS will be computed. The initial dominance ranking will be produced, and additional dominance measures will be generated. The risk contributors to the failure of the AFWS will be ranked to identify the weak links of the AFWS of SONGS Unit 1.

Task VII-Compare the Probabilities of Failure of the AFWS Between SONGS-1 and Zion-1

The probabilities of failure of the AFWS of Zion Unit 1 will be computed. The initial dominance ranking will be produced and additional dominance measures will be generated. The risk contributors to the failure of the AFWS will be ranked to identify the weak links of the AFWS of Zion Unit 1. These results will be compared to the results for SONGS Unit 1. SECTION 3: TASK ACCOMPLISHMENTS

L.ATTER COMMENT

PROJECT MANAGEMENT AND DATA RETENT ON

The LLNL staff was instructed by NRC to terminate the analytical effort related to the SONGS Unit 1 AFWS at the end of January, 1982. All pertinent information was filed in a retrievable manner. The following controls have been employed to assure that efficient retrieval can be accomplished:

- All published documents are retained in the LLNL Technical Information Department Library.
- Aperture cards of the design drawings obtained from Southern California Edison Company and Eechtel Power Corporation are retained in the LLNL Mechanical Engineering Department Library in a permanent print file.
- 3. .Essential computer program and data files are being retained in an indexed tape library file at the LLNL Computer Center.
- 4. History and correspondence files are being retained in storage at the LLNL Forms and Records Office.

The accomplishments for each subtask (until the project was terminated) are summarized, with supportive details either referenced in published documents or included in the appendices of this report, as follows.

TASK I.1 - SOIL MODEL DEVELOPMENT

The purpose of this task was to obtain and evaluate soil data for SONGS-1. Nominal soil properties (shear modulus and material damping) and their variability were estimated. Major effort was concentrated on the 0.67 g excitation level. The 0.67 g excitation level was of interest for two reasons: to compare seismic responses of structures and AFW piping systems with the seismic reevaluation result; and as one excitation level for the probabilities analysis of the SONGS-1 AFWS. The results of the 0.67 g excitation level, in conjunction with selected analyses at other excitation levels, were extrapolated to estimate soil properties over the entire range of excitations for the risk analysis. A number of sensitivity studies were performed (e.g., variation in soil material damping with bearing pressure, shear modulus degradation with increasing strain level, etc.). The soil properties were used to develop the SSI models. Appendix A provides more details on the development of soil models.

TASK I.2 - STRUCTURAL MODELS DEVELOPMENT

Structural models development proceeded in several steps beginning with the initial examination of the structural drawings, proceeding to coding and debugging of the model, eigenvalue extraction of the fixed-base structure, preliminary stress analysis for fragility assessment, independent review and ending with a benchmark comparison of the model with SCEC/Bechtel results. Output requirements for later fragility, system, and subsystem analysis must be specified. Details of the SONGS-1 structure model development are given in Appendix A. A summary of the work follows.

1. Reactor Building Complex

The reactor building complex includes sphere enclosure building, containment sphere and reactor building. Each structure was modeled separately in accordance with the input requirements of SMACS. The sphere enclosure building model is completed through eigenvalue extraction of the fixed-base modes (as required for the SMACS analysis). The containment sphere model, including generation of preliminary stress information for assessing structural fragility, was completed. The reactor building model was completed through the stage of preliminary stress analysis for fragility assessment. Benchmarking the reactor building model with SCEC/Bechtel required extensive effort. The modeling details of the reactor building by SCEC/Bechtel were compared as closely as possible to permit a valid model comparison. The resulting fixed-base frequencies were compared and significant frequencies were within 15% of each other. Remaining differences in modal analysis results were attributed to differences in the modeling approach.

DEAT FOR CUMMENT

2. Turbine Building Complex

This building complex includes five separate structures, i.e., turbine pedestal, north and south turbine building extensions, and east and west feedwater heater platforms. They are interconnected on five foundations which also interconnect with the foundation of the fuel storage building. Three of these five structures, the turbine pedestal, the north turbine building extension, and the west feedwater heater platform, are of interest because they house a portion of the AFWS. Detailed models of these structures and the south turbine building extension were developed. The dynamic characteristics of the east feedwater heater platform are similar to the west feedwater heater platform, and the same model was used. These models reflect the latest design configurations at the time the project was terminated. The equipment loadings were specified by SCEC/Bechtel. All models were completed through the eigenvalue extraction stage.

GRAFT FOR COMMENT

3. Fuel Storage Building

Initially, a model reflecting the proposed design modifications to the fuel storage building was constructed and a modal (eigenvalue) analysis completed. However, further modification from SCEC/Bechtel required additional changes. These changes were incorporated into the model, but no modal analysis was performed. Finally, SCEC/Bechtel returned to the unmodified configuration. The information for roof decking of the fuel storage building will be required in order to change the modal to its unmodified configuration. Therefore, no progress on model analysis was accomplished at the time the project was terminated.

4. Control-administration Building

The control-administration building model incorporated the latest set of floor and equipment loads supplied by SCEC/Bechtel. The model was , completed through the eigenvalue extraction stage. An initial comparison was made with frequencies provided by SCEC/Bechtel; however, no progress was accomplished to reconcile the observed differences before the project was terminated.

TASK I.3 - SSI MODEL DEVELOPMENT

SONGS-1 soil-structure interaction (SSI) model development proceeded as follows.

1. Reactor Building/Containment Sphere

These two structures are supported on a partially embedded spherical foundation. Preliminary SSI models (impedances and scattering matrices) were generated for the 0.67 g excitation level. Evaluation of these preliminary results proceeded along several paths. The wethodology was benchmarked against known analytical and finite element solutions of a full hemispherical foundation in a uniform half-space. Simpler cases were analyzed (e.g., rigid circular disk on a layered half-space and approximate solution procedures), and the results compared. A sensitivity study of the effects of soil layer discretization on the variation in impedances was made prior to selecting the final soil profile and discretization used. Final impedances and scattering matrices for the 0.67 g excitation reflect a finer soil discretization and frequency interval than the preliminary results. The preliminary values were smoothed to better match variations expected due to smooth soil variability. The results were used to compute the seismic responses of structures due to different target spectra.

LIATI FUR COMMENT

2. Other Buildings

The remaining SONGS-1 structures of interest (except the control-administration building) are supported by a complicated, interconnected foundation. Although they are not connected through their super-structure, the five structures of the turbine building complex and the fuel storage building share portions of foundations resulting in a complex structural system. SSI models were developed for the turbine pedestal foundation, both anchor blocks, the fuel storage pool, and several column footings. Sensitivity studies of the spatial discretization of the foundation impedance models were conducted. Selection of the final model configurations was based on these studies. Appendix A describes in detail the work associated with this task.

TASK I.4 - AFVS PIPING MODELS DEVELOPMENT

This task was concerned with the development of models of the AFW piping systems. Fourteen dynamic piping models were developed. They are: nine models for the discharge piping of the auxiliary feedwater (AFW) pumps; one

L. I FUR COMMENT

for the suction piping of the AFW pumps; two for auxiliary steam supply piping; and two for service water and fire protection piping. The natural frequencies and mode shapes for these fourteen piping models were computed. The support locations for the fourteen models were identified and coordinated with their location in the structure models in order to provide input motions to piping systems. These piping models and the analytical methods used are described in Appendix C.

TASK II.1 - SEISMIC INPUT TIME HISTORIES DEVELOPMENT

The goal of this task was to generate time histories for each of three target spectra: the SONGS Unit 1 seismic reevaluation spectra, the SONGS Units 2 & 3 design spectra, and the average of the two. Thirty sets of time histories (consisting of two horizontal components and a vertical component) were generated for these three target spectra. They are all anchored at 0.67 g zero period acceleration (ZPA) in the horizontal directions and 0.45 g ZPA in the vertical direction. Refer to Appendix A for details.

TASK II.2 - COMPUTATION OF SEISMIC RESPONSES OF STRUCTURES DUE TO'DIFFERENT INPUT SPECTRA

The seismic responses of the structures were computed for the three target spectra described in Task II.1. Using the dynamic characteristics of the reactor building and containment sphere, and the impedance and scattering matrices for the partial spherical foundation; response analyses were performed for three cases of the free-field ground motion. The three cases corresponded to the three specified target spectra for the SONGS site. In each case, thirty sets of time histories defined the input motion. The time histories were targeted to the SONGS Unit 1 seismic reevaluation spectra, the SONGS Units 2 and 3 design response spectra, and the average of the two. In-structure response spectra at selected points were generated for comparison with SCEC/Bechtel seismic reevaluation results. Details of the response analyses are given in Appendix A.

TASK II.3 - COMPUTATION OF SEISMIC RESPONSES OF AFW PIPING SYSTEMS

This task had not been initiated at the time the project was terminated, because the piping systems are interconnected with different buildings and the structural and SSI models were not all completed.

DRAFT FOR COMM

TASK II.4 - COMPARISON OF THE SEISMIC RESPONSES OF STRUCTURES AND AFW PIPING SYSTEMS WITH THE SEISMIC REEVALUATION

The results of the SMACS analyses were compared with data generated by SCEC/Bechtel from a deterministic analysis. The latter used procedures and parameter values selected for seismic reevaluation. It was performed by SCEC/Bechtel with the SONGS Unit 1 seismic reevaluation spectra anchored to 0.67 g ZPA.

Comparison with the SMACS analyses using time histories whose spectra were targeted to the SONGS Unit 1 seismic reevaluation spectra, shows that the SCEC/Bechtel seismic reevaluation results envelop those of SMACS over the entire frequency range. The SCEC/Bechtel results also envelop and are significantly larger than the SMACS results computed using both the SONGS Units 2 and 3 design response spectra and the average spectra of SONGS-1 and SONGS 2 & 3 as seismic input definitions in the amplified frequency range. The exception only occurs in the lower frequency range where the SMACS results due to the SONGS Units 2 and 3 design spectra exceeded the SCEC/Bechtel SONGS Unit 1 seismic reevaluation results. Details of the comparison appear in Appendix A.

TASK III.1 - EARTHQUAKE OCCURRENCE MODEL DEVELOPMENT

Considerable progress was made on this task. A report on the assessment of active faults and maximum earthquakes of the Southern California-Northern Baja region that adjoins the SONGS site⁸ has been completed. A study of the seismic activity rates using the earthquake history indicated that activity rates would have to be determined from estimates of the geological slip rate for the various faults. The required slip rates and the zones for the hazard assessment model were developed. Details of the earthquake occurrence model development are described in Appendix C.

-23-

TASK III.2 - GROUND MOTION MODEL DEVELOPMENT

To obtain improved estimates of the ground motion in the near-field, the effect of various schemes of weighting the near-field data were explored. Various scaling schemes were found and led to significant differences in the ground motion estimates, particularly for larger magnitude earthquakes. Several models will be used in the hazard analysis, since it was difficult to choose one model over another. Details of the development of the ground motion model are described in Appendix C.

DRAFT FOR COMMENT

TASK III.3 - HAZARD CURVES AND TIME HISTORIES DEVELOPMENT

Preliminary work on the task of incorporating the ground motion models, developed in Task III.1 into the computer model was underway at the time the project was terminated. No hazard curves or time histories were obtained.

TASK IV.1 - SONGS-1 AFWS FAULT TREE DEVELOPMENT

The objective of this task was to generate a fault tree for the SONGS AFWS, including the water supply to AFW pumps, electric power buses, AFW pump discharge to steam generators, and the auxiliary steam supply to AFW pump turbine. A fault tree for the SONGS Unit 1 AFWS was developed. Appendix B contains the top levels of the fault tree. The remaining data are stored in the files at LLNL. The model includes the AFWS as well as those portions of other systems (condensate storage, auxiliary steam supply, electric power, service water and fire protection) which relate to the AFWS. This work has been documented in the report on fault tree modeling of AFWS.⁹

The fault trees were drawn down to the component level, i.e., valves, pumps, pipe segments, etc. The different failure modes of such components were considered to be primary events of the fault tree. The top event was chosen to be: "Insufficient cooling of the steam generators during required operation of the AFWS." The fault tree was analyzed using the WAMCUT and FTAP programs.¹⁰ The doubles, i.e., cut sets that contain two basic events, generated by this analysis are shown in Appendix B. The basic event coding scheme is described in Appendix E of the Phase I final report of SSMRP. The remaining minimum cut sets are on file at LLNL.

URAFI FOR COMPLENT

TASK IV.2 - ZION UNIT 1 AFWS FAULT TREE MODIFICATION

Modifications were performed on the Zion Unit 1 AFWS fault tree to make it comparable to the SONGS Unit 1.⁹ The modified fault tree covers all the AFWS components plus the headers of the service water system (SWS), which connect to the suction of the AFW pumps, up to the common SWS main header. The fault tree for the auxiliary steam supply to AFW pump turbine was also generated. These fault trees were prepared for analysis with the FTAP program.

TASK V.1 - STRUCTURAL FRAGILITY CURVES DEVELOPMENT

The SONGS Unit 1 structures evaluated in this study included the reactor building, containment sphere, sphere enclosure building, control, administration building, diesel generator building, turbine pedestal, north turbine building extension, west feedwater heater platform, and the fuel storage building. Structural failure is defined as occurring when inelastic deformations are of sufficient magnitude to potentially interfere with the operability of attached equipment. When complete these analytical fragility relations provide the correlation between earthquake input and structural failure.

The methods used in the structural fragility development and the results are described in the report on seismic structural fragility investigation on the SONGS-1.¹² Only fragilities (median structure strengths and variabilities) which were completed are described. These median strengths are based on median material properties estimated from actual plant specific test data, where available, or by comparison to other data bases. Predictive models derived from actual test data were used whenever possible, to eliminate design conservatism normally associated with building code requirements. Refer to Appendix C for more details.

TASK V.2 - AFWS PIPE COMPONENT BETA-FACTORS DEVELOPMENT

Only one fragility description is provided to SEISIM to asscribe the fragility of all pipe components, and the pipe component fragilities are related to a master (i.e., reference) pipe component fragility by a load scale factor (beta-factor). This factor is defined as:

DRAFT FOR COMME

Beta-factor = Capacity of reference pipe component Capacity of pipe component under consideration

A large number of these factors were developed in Passe I of the SSMRP. A complete discussion of the methodology used in their divelopment is contained in Section 4.2 of a the report on subsystem fragilities.¹² The factors developed for Zion-1 did not, however, include all of those needed for the SONGS-1 AFWS analysis. Hence, a sufficient number of additional factors were calculated to permit interpolating over a wide range of parameters. This has the twofold benefit of providing the needed factors for the SONGS-1 AFWS while also providing a wide range of factors for other future applications.

The Zion-1 factors were plotted as functions of both temperature and pipe schedule to determine which data points were missing and which would be needed to allow interpolation. Missing data were then calculated by scaling from existing data. The basis for scaling of different pipe schedules was sertion modulus, and scaling from one material to another was based on yield strength. This is consistent with the methodology described in the report¹³ as mentioned above.

Appendix C contains the tables of the resulting beta-factors for different sizes of carbon and stainless steel pipe. For each pipe size, the beta-factors for different schedules (10, 40, 60, 80, 120, and 160) are shown. Factors are also shown for butt welds, elbows, and straight pipes at different temperatures (100°F, 300°F, and 500°F). As indicated in the subsystem fragilities report, ¹³ the beta-factors for butt welds can be used for reinforced branches, and the beta-factors for elbows can be used for unreinforced branches. TASK V.3 - AFWS ELECTRICAL AND MECHANICAL COMPONENTS, FAULT TREE AND STRUCTURAL RESPONSES COORDINATION

The locations of nearly all of the electrical and mechanical components were determined. The locations of the few remaining components will have to be determined by on-site inspection. Once established, these locations determine the appropriate SMACS response to use for each component in the failure and risk analysis. This effort was not completed at the time the project was terminated.

BRAFT FOR COM

TASK V.4 - AFWE PIPING RESPONSES AND FAULT TREE COORDINATION

Critical pipe components (such as tees, nozzles, elbows/pipe bends, etc.) were identified for all fourteen piping models as described in Task I.4. However, the data proparation effort for only seven of these fourteen piping wodels was completed. They are identified in Appendix C. No effort on coordination between critical pipe components and basic event of fault tree was initiated at the time the project was terminated.

TASK VI.1 - COMPUTATION OF THE SEISMIC RESPONSES OF STRUCTURES AND AFWS PIPING

Since the time histories development for the SONGS site was not completed at the time the project was terminated, only preliminary set-up for the SMACS analysis was accomplished.

TASK VI.2. - COMPUTATION OF THE PROBABILITIES OF FAILURE OF THE AFWS AND

The fault trees for both SONGS-1 and Zion-1 AFWS were solved, and the cut sets were generated in a form suitable for SEISIM.¹⁴ No SEISIM runs were initiated at the time the project was terminated.

SECTION 4: MILESTONE CHARTS AND DESCRIPTIONS

DISTI I FUR GUMMENT

13.3

In Section 4, milestone charts and descriptions are given for each of the tasks in the SONGS-1 AFWS project. Milestone dates include the original target dates, the revised target dates, and the completed dates. All tasks were terminated in accordance with NRC request.

URALI FUR GUMMENT

DUND & PLING FEALERS HEREADERS

7 1.07	T	F	Y 81		T	FY 82															FY	83									
- IASK -	м	J	3 1	s	0	N	D	1	F	M	A	M	J	J	A	s	0	N	D	J	F	M	A	м	J						
Troject Planning and Management			223		6	1.1	7a 7.	4.9 1.9 ▼	21	96	1 Il	1.1	7c 7d 7																		
I.1 Develop soil model	E C					1	.8	it it Suff.	1632																						
I.2 Develop structural models					- M	1.14			-	1.9		23a																			
I.3 Develop SSI models						1	35	223		1	.10																				
I.4 Develop AFWS piping models	N.	-		-	- 21-				1.1	2a- 7																					
II.1 Develop time histories for three input spectra	100			1.13			-																								
II.2 Compute seismic responses of structures due to three input spectra		-			1		4-	1				1	15																		
II.3 Compute seismic responses of AFWS piping systems due to three input spectra									Ė			1	16																		
II.4 Compare SMACS result with SCEC/Bechtel seismic reevaluation results	is 1						1.1 2	70-					1																		

*All tasks were terminated by NRC on January 29, 1982.

Enn' I FUR GUMENT

10 00 M

SONGS-1 AFWS Project Milestone Charts * (continued)

TASY		F	Y 8	1							FY	82									F	Y	13		-	
an a paras - and Abd Ana a se	M	J	J	A	s	0	N	D	J	F	М	A	M	1	J	A	s	0	N	D	1	F	M	A	M	1
III.1 Develop earthquake occurrence models	BI			No.				State of the second sec		.18																
III.2 Develop ground motion models	1	2			- 19		No.		1	19																
III.3 Develop hazard curves and time histories								· 開始		1	20															
IV.1 Develop fault tree of SONGS-1 AFWS		1				1.	21	2											,							-
IV.2 Modify fault tree of Zion Unit 1 AFWS				Eta .	-	1.	22			-									7							
V. 1 Develop fragility curves of structures				20																						
V.2 Develop beta factor of pipes						1.	24																			
V.3 Coordinate electrica and mechanical compo nents with fault tre and structures	1 es				1				-		1	25														
V.4 Coordinate responses and fault trees for piping system					ETH .	-							1	26												

*All tasks were terminated by NPC on January 29, 1982.

SONGS-1 AFWS Project Milestone Charts*

(continued)

TASK			FY	81							FY	82									F	YS	3			
insit .	M	J	J	A	s	0	N	D	1	F	М	A	М	J	1	A	s	0	N	D	J	F	м	A	M	J
VI.1 Compute responses of structures and piping systems									3			1		1.	27											
VI.2 Compute probability of failure of AFWS and identify weak links									22						1.1	28										
VII Compute probability of failure of Zion Unit 1 AFWS and compare with SONGS Unit 1	-													1	.291		29									
Documentation		2		海	A A A A A A A A A A A A A A A A A A A			Tr all	10		- Ma	1	10	1	35	361	31	10	21	.33						

*All tasks were terminated by NRC on January 29, 1982.

1.0

SONGS-1 AFWS Project Milestone Dates **

8 . *

č

-

	Mileston e	Original Target Date	Revised Target Date	Completed Date
1.1	Kickoff meeting	11-21-80		11-21-80
1.2	SONGS site visit	11-24-80		11-25-80
1.3	NRC-LLNL meeting	12-18-80		12-18-80
1.4	Proposed work plan completed	1-15-81		1-22-81
1.5	Proposed work plan revised	2-6-81		2-6-81
1.6	Proposed work plan finalized	2-24-81		2-24-81
1.6a 1.6b 1.7	Final work plan approved by NRC Project terminated by NRC All necessary data and models obtained from SCEC	NA*** 7-3-81	1-29-82	5-1-81 1-29-82
1.8	Soil model developed	7-3-81	12-1-81	12-1-81
1.9	All structural models developed	10-23-81	4-5-82	
1.9a	Modification of turbine and fuel storage building obtained	1-29-82		
1.9b	SCEC/Bechtel fixed-base results of all structures obtained	3-19-82		
1.9c	All LLNL fixed base structure models compared with SCEC/Bechtel	4-5-82		
1.10	All SSI models developed	10-23-81	4-5-82	
1.11	SMACS test runs completed	12-4-81	5-1-82	
1.12	AFW piping models developed	10-23-81	4-5-82	
1.12a	AFW pipe supports location in the structural models identified	3-1-82		
1.13	Time histories for the three target spectra developed	7-3-81	7-15-81	8-31-81
1.14	Reactor building responses due to the three target spectra computed	8-14-81	11-24-81	11-24-81

All tasks were terminated by NRC on January 29, 1982. *NA = not applicable

DRAFT FOR COMMENT

and the second

1 . C.

SONGS-1 AFWS Project Hilestone Dates ** (continued)

	Milestone	Original Target Date	Revised Target Date	Completed Date
1.14a	Reactor building model compared with SCEC/Bechtel	11-15-81		11-15-81
1.15	All structural responses due to the three target spectra computed	1-8-82	6-1-82	
1.16	AFWS piping responses due to the three target spectra computed	1-8-82	6-1-82	
1.17	SCEC/Bechtel seismic reevaluation results and SMACS results compared	2-5-82	7-1-82	
1.17a	SCEC/Bechtel seismic reevaluation results of reactor building obtained	11-30-81		
1.17b	SCEC/Bechtel seismic reevaluation results of_reactor building compared	12-15-81		12-15-81
1.17c	SCEC/Bechtel seismic reevaluation results of all structures obtained	6-1-8,2,		
1.17d	SCEC/Bechtel seismic reevaluation results of AFW piping systems obtained	s 6-1-82		
1.18	Earthquake occurrence model developed	9-18-81	2-15-82	
1.19	Ground motion model developed	9-4-81	2-1-82	
1.20	Hazard curves and time histories developed	11-20-81	3-5-82	
1.21	Fault tree of SONGS-1 AFWS developed	9-18-81	10-31-81	10-31-81
1.22	Fault tree of Zion Unit 1 AFWS modified	6-12-81	10-31-81	10-31-81
1.23	Fragility curves for structures developed	11-6-81	5-15-82	
1.23	Preliminary stress analysis of structures for input to fragilities completed	4-15-82		
1.24	Beta-factor for AFW pipe components	10-16-81	10-31-81	10-31-81
1.25	AFWS components, fault tree, and structure coordinated	1-15-82	3-31-8	2
1.26	Responses and fault tree of piping systems coordinated	12-18-81	6-1-82	

**All tasks were terminated by NRC on January 29, 1982.

ga Andel I

UKALI FUR COMMENT

SONGS-1 AFWS Project Milestone Dates ** (continued)

	Milestone	Original Target Date	Revised Target Date	Completed Date
1.27	Seismic responses of structures and AFW piping systems due to the time histories generated by Task III.3 computed	2-15-82	7-1-82	
1.28	Probabilities of failure of SONGS-1 AFWS computed	3-19-82	8-1-82	
1.29	Probabilities of failure of Zion-1 compared with SONGS-1 result	4-16-82	9-1-82	
1.29a	Probabilities of failure of Zion-1 AFWS computed	8-1-82		
1.30	Documentation of AFWS fault trees development	12-31-81		12-15-
1.31	Draft report of the SONGS-1 AFWS project transmitted to NRC	10-1-82		
1.32	NRC comments on the draft report of SONGS-1 AFWS project received	10-15-82	**.**	
1.33	Camera-ready copy of the final report of SONGS-1 AFWS project transmitted to NRC	11-15-82		
1.34	Preliminary final progress report of the SONGS-1 AFWS project transmitted	4-30-82	6-28-8	2 /
1.35	to NRC and SCEC for comment NRC and SCEC comment on draft final progress report of the SONGS-1 AFWS project received	7-19-82		
1.30	6 Final progress report of the SONGS-1 AFWS Project transmitted to NRC	8-15-82		

*All tasks were terminated by NRC on January 29, 1982.

REFERENCES

DRAFT FOR COMMENT

- R. W. Mattson, Director of Safety Technology, NRR, U.S. Nuclear Regulatory Commission, memorandum to D. G. Eisenhut, Director of Licensing, NRR, <u>Analysis and Recommendations Related to Plants without Seismically</u> Qualified Auxiliary Feedwater Systems, (August 8, 1980).
- P. D. Smith, D. L. Bernreuter, M. P. Bohn, T. Y. Chuang, G. E. Cummings, R. G. Dong, J. J. Johnson, R. W. Mensing and J. W. Wells, <u>A Review of a</u> <u>Seismic Risk Analysis of the Decay Heat Removal Capability of Nuclear</u> <u>Power Plants</u>, Lawrence Livermore National Laboratory, Livermore, CA., UCID-18692, (1980).
- J. E. Richardson, U.S. Nuclear Regulatory Commission, telegraphic message to P. D. Smith, LLNL, "Use of SSMRP for San Onofre AFWS," (December 19, 1980).
- T. Y. Chuang, P. D. Smith, R. G. Dong, D. L. Bernreuter, M. P. Bohn,
 G. E. Cummings, and J. E. Wells, <u>Seismic Safety Margins Research Program</u>, <u>Project I, SONGS-1 AFWS Project</u>, Lawrence Livermore National Laboratory, Livermore, CA., UCID-18959, (February 24, 1981).
- 5. P. D. Smith, R. G. Dong, D. L. Bernreuter, M. P. Bohn, T. Y. Chuang, G. E. Cummings, J. J. Johnson, R. W. Mensing, J. E. Wells, <u>Seismic Safety</u> <u>Margins Research Program: Phase I Final Report-Overview</u>, Lawrence Livermore National Laboratory, Livermore, CA., UCRL-53021, NUREG/CR-2015, Vol. 1, (April, 1981).
- J. J. Johnson, G. L. Goudreau, S. E. Bumpus, O. R. Maslenikov, <u>Seismic</u> <u>Safety Margins Research Program Phase I Final Report - SMACS - Seismic</u> <u>Methodology Analysis Chain with Statistics (Project VIII)</u>, Lawrence Livermore National Laboratory, Livermore, CA., UCRL-53021, NUREG/CR2015, Vol. 9, (July, 1981).
- 7. D. Gasparini and E. H. Vanmarcke, <u>Simulated Earthquake Motions Compatible</u> with Prescribed Response Spectra, Report 2 or <u>Evaluation of Seismic Safety</u> of <u>Buildings</u>, Department of Civil Engineering, Massachussetts Institute of Technology, Cambridge, Massachussetts, Pub. No. R76-4, (January, 1976).
- B. Slemmons, P. Omalley, R. A. Whitney, D. H. Chung, and D. L. Bernreuter, <u>Assessment of Active Faults for Maximum Credible Earthquakes</u> of the Southern California - Northern Baja Region, Lawrence Livermore National Laboratory Livermore, CA., UCID-19125, (1982).

-35-

DANT I TUR GUMMENT

- 9. B. Najafi and S. Eide, <u>San Onofre/Zion Auxiliary Feedwater System Seismic</u> <u>Fault Tree Modeling</u>, Seismic Safety Margins Research Program, Lawrence Livermore Laboratory, Livermore, CA, UCRL-in print, (1982).
- R. R. Willie, <u>Computer-Aided Fault Tree Analysis</u>, Operations Research Center, University of California, Berkeley, CA, ORC78-14, (1978).
- 11. J. Wells, L. George and G. Cummings, <u>SSMRP Phase I Final Report Systems</u> <u>Analysis (Project VII)</u>, Seismic Safety Margins Research Program, Lawrence Livermore National Laboratory, Livermore, CA., UCRL-53021, NUREG/CR-2015, Vol. 8, (1982).
- 12. D. A. Wesley and P. S. Hashimoto, <u>Seismic Structural Fragility</u> <u>Investigation for the San Onofre Nuclear Generating Station Unit 1</u>, Seismic Safety Margins Research Program, Lawrence Livermore National Laboratory, Livermore, CA., UCRL-in print, (1982).
- 13. R. P. Kennedy, R. C. Campbell, G. Hardy and H. Banon, <u>Seismic Safety</u> <u>Margins Research Program (Phase I) Subsystem Fragility</u>, Structural Mechanics Associates, Newport Beach, CA., UCRL-15407, NUREG/CR-2405 (February, 1982).
- 14. J. M. Hudson, J. D. Gasca and B. Kennedy, <u>SEISIM Option 1, User's Manual,</u> (Revision 1), J. H. Wiggins Company Technical Report No. 80-1366-2, J. H. Wiggins, Redondo Beach, CA. (1980).
APPENDIX A

DRAFT FOR COMMENT

13 4

STRUCTURAL RESPONSE COMPARISON

A1 INTRODUCTION

One of the major objectives of the San Onofre Nuclear Generating Station Unit 1 (SONGS-1) Auxiliary Feedwater System (AFWS) Project was to assess the conservatism in the SCEC/Bechtel Balance of Plant Seismic Reevaluation Program (BOPSRP). Meeting this objective required the development of seismic input time histories, soil properties and soil models of the San Onofre site, and mathematical models of the structures and piping systems affecting the response of the AFWS. The computer program, SMACS, Seismic Methodology Analysis Chain with Statistics calculates the seismic response of scructures, systems, and components.

DRAFT FOR COMMENT

The program SMACS links the seismic input with soil-structure interaction (SSI), structural response, and piping response calculations. Seismic input is defined by ensembles of acceleration time histories for three orthogonal directions (two horizontal and a vertical) on the surface of the soil. SSI and detailed structural response are determined simultaneously by the substructure approach to SSI. This approach analyzes the coupled soil-structure system in a series of steps, i.e., determination of the foundation input motion, calculation of the foundation impedances, and analysis of the coupled system. The result of this approach is structural responses in the form of peak values and time histories of accelerations, displacements, and forces. Using these results, SMACS then calculates time history responses of piping systems through a multisupport time history analysis technique.

Throughout these computations, uncertainties are accounted for probabilistically. The largest source of variability in seismic input is acknowledged by using ensembles of time histories; in the SSI link, the shear modulus and damping in the soil are varied; in the computation of structural and piping responses, variation in the natural frequencies and modal damping ratios account for uncertainties. This appendix describes both this developmental effort and the results of the subsequent design comparison analyses performed on the SONGS Unit 1 reactor building complex.

Section A2 describes the seismic input time histories which is comprised of three elements: generation of artificial time histories which match the three target spectra (SONGS Unit 1 seismic reevaluation spectra, SONGS Units 2

-38-

and 3 design spectra, and the average of the two). Section A3 contains the development of best estimate equivalent linear soil properties and their variability. It also describes the SONGS Unit 1 structures that influence the seismic response of the AFWS, the SSI and structural models that defined the dynamic characteristics of these buildings. Finally, a comparison of dynamic characteristics with the SCEC/Bechtel model of reactor building is also included in Section A4.

UNALI FUR GUMMENT

A2 SEISMIC INPUT TIME HISTORIES

Thirty sets of (two horizontal and a vertical) time histories were generated for the three target spectra: the SONGS Unit 1 seismic reevaluation spectra, the SONGS Units 2 and 3 design spectra, and the average of the two. All spectra were anchored at 0.67 g zero period acceleration (ZPA) for the horizontal components and 0.45 g for the vertical component. A sensitivity study calculating mean response using 90 sets of input time histories varied little from the mean results obtained using 30 time history sets. This study confirmed the adequacy of using 30 sets in subsequent response analyses.

All time histories were generated using the computer program, SIMQKE.¹ The time histories were generated at a time step of 0.01 seconds (s). All time histories were 18 s in duration and generated for a target spectrum with 22 damping. Figure 1 shows a comparison between the mean of the thirty spectra and the target spectrum for the three target spectra as mentioned above.

SIMQKE generates statistically independent artificial acceleration time histories which match a specified response spectrum, and it refines the spectral match through an iterative procedure. It also performs a baseline correction on the generated motion to ensure zero final ground velocity; and, of course, it calculates response spectra with the time histories as input.

Target Spectra For;

o---o SONGS Units 2 & 3

A--- Average

△---△ SONGS Unit 1





LRATI FUR CUMMENT

The method used by the program for artificial motion generation is superposition of sinusoids having random phase angles and amplitudes derived from a stationary power spectral density function of the motion. To simulate the transient character of real earthquakes, an envelope function, I(t), is used. The final simulated motion, z(t), then becomes:

 $z(t) = I(t) \Sigma A_n \sin (\omega_n t - \phi_n).$

It is stationary in frequency content with a peak acceleration close to the target peak acceleration. In order to introduce variability consistent with real time histories only one iteration for each generated time history was allowed. This led to a coefficient of variation (COV) of about 0.10 - 0.15 for frequencies higher than 2 Hz and about 0.15 - 0.20 for frequencies higher than 0.2 Hz but lower than 2 Hz. For the set of real time histories used to generate Regulatory Guide 1.60 design spectra (all scaled to 1.0 g), the COV is over a factor of 2 to 3 times larger than for the sets of time histories, the spectrum of each time history as generated is a "reasonable" match to the target spectrum. Figure 2 shows a typical example.

GRAFT FUR COMMENT



MAXIMUM VELOCITY (IPS)



-41-

A3 SOIL, SSI AND STRUCTURAL MODELS

The soil model of the SONGS site and the soil-structure interaction (SSI), and structural models the SONGS-1 structures housing the AFWS are described below.

DRAFT FOR COMMENT

A3.1 Methodology

A potentially large source of uncertainty in the soil-structure interaction (SSI) analysis is associated with the determination of soil properties to be used in the analysis. This process involves selecting a mathematical model to represent soil stress-strain behavior, measuring properties for this model in the laboratory and relating them to the properties in situ and determining the variation of these properties at a constant strain level, and for increasing levels of strain corresponding to higher levels of seismic excitation.

The stress-strain behavior of soil was modeled on the basis of a linear viscoelastic theory. The parameters defining the model are two elastic constants, i.e., shear modulus and Poisson's ratio, and a material damping factor. The nonlinear behavior of soil was taken into account by equivalent linear techniques, i.e., values of the material constants (shear modulus and material damping) were selected on the basis of average strain levels expected in the soil as a result of the earthquake. An iterative linear analysis was then performed to estimate the final soil properties.

SSI and detailed structural response are determined by simultaneously using the substructure approach to SSI. The substructure approach divides the problem into a series of simpler problems, solves each independently, then superposes the results. Typically, these simpler problems are: determination of the foundation input motion; determination of the foundation impedances; and analysis of the coupled soil-structure system. This process culminates in a prediction of the response of the soil-structure system. The CLASSI family of computer programs, an implementation of the substructure approach, forms the basis of the SSI and structural response calculations in SMACS.² CLASSI is organized according to the steps of the substructure approach. The set of continuum linear analysis (CLA) codes solves the first two steps, i.e., foundation input motion and impedances, then the SSIN code analyzes the coupled soil-structure system. SSIN forms the core of the SSI and major structure response calculation in SMACS. Some general comments concerning the procedure are in order.

-43-

Several general features characterized the solution of the SSI problems as formulated in CLASSI. The basic formulation is in the frequency domain, which permits modeling the behavior of the soil by frequency-dependent impedances and scattering matrices. Fourier transform techniques are applied to obtain the time history of response.

The mathematical model selected to represent the stress-strain behavior of soil is based on a linear viscoelastic theory. The parameters defining the model produce constant hysteretic-type (i.e., frequency-independent) damping and consist of two elastic constants (typically, shear modulus and Poisson's ratio) and a material damping factor. The nonlinear behavior of soil was taken into account by equivalent linear techniques. Equivalent linear soil properties were determined by an iterative process that estimates material constants as a function of an average strain level over the duration of the excitation. The process and results for the SONGS-1 site are described in subsection A3.2. Note that one-dimensional wave propagation analysis was performed to determine the properties. Only the "primary nonlinearity," i.e., the nonlinear behavior induced in the free-field by the earthquake itself, was treated. Best estimate values of the material constants for differing excitation levels were estimated along with the expected variability in these values.

The three steps of the substructure approach are shown schematically in Fig. 3. Specification of the free-field ground motion (i.e., the control point, frequency characteristics of the control motion, and the spatial variations of the motion) is a preliminary step which was discussed in Section A2. Each of the three steps is briefly described as follows.

1. Determination of the Foundation Input Motion

The foundation input motion differs from the free-field ground motion in all cases, except for surface foundations subjected to vertically propagating waves. The motions differ primarily for two reasons. First, waves are scattered from the soil-foundation interface. Second, points on the foundation are constrained to move according to the geometry and stiffness of the foundation. This constraint leads to a reduction in the total number of degrees of freedom necessary to define the motion of the foundation. When the effective stiffness of the foundation is large compared to the soil, rigid

-44-



Figure 3. A schematic representation of the elements of the substructure approach to soil-structure interaction analysis.

behavior is assumed, and the motion of the foundation is uniquely defined by six rigid-body degrees of freedom, i.e., three translations and three rotations.

DRAFT FOR COMM

The foundation input motion, {U*}, is related to the free-field ground motion by means of a transformation defined by a scattering matrix, [S(w)], which is complex-valued and frequency dependent:

 $\{U^{*}(\omega) = [S(\omega)] \{f(\omega)\},\$

where the vector, {f(w)}, is the complex Fourier transform of the free-field ground motion, which contains a complete description of the free-field motion. For a particular frequency, w, each complex number in the vector corresponds to the amplitude and phase of an assumed wave component of the free-field motion. Each column of [S(w)] represents the response of a massless rigid foundation to a given incident wave of unit amplitude. The response is frequercy-dependent, because the incident wavelength, and in some cases the apparent velocity of the wave front, varies with frequency. There can be numerous columns in [S(w)] because incoming seismic waves may be assumed to contain many surface modes, each having a different phase velocity. In addition to its dependence on the composition of the free-field motion in terms of the different types of waves, $[S(\omega)]$ depends on the geometry of the foundation and the characteristics of the soil, i.e., its material properties and configuration. The matrix product, $[S(\omega)]$ $\{f(\omega)\}$, is therefore the response of the rigid, massless foundation to a particular seismic event.

Of the SONGS Unit 1 structures to be analyzed, only the reactor building/containment sphere is embedded to a significant extent. The fuel storage building foundation is slightly embedded. In addition, for SONGS Unit 1 analyses completed to date, vertically propagating waves were assumed. Hence, the scattering matrix, $[S(\omega)]$ reduces to its simplest form (i.e., unity for translational components, zero for all others, and constant over the frequency range) for all foundations except the reactor building/containment sphere.

2. Determination of Foundation Impedances

The second step in the substructure approach is determining the force-displacement characteristics of the soil. The relationship is typically presented in the form of impedances, $[K_s(\omega)]$. Foundation impedances depend on soil configuration and material behavior, the frequency of the excitation, and the geometry of the foundation. The SONGS-1 analysis assumed rigid foundations for which the force-displacement characteristics are uniquely defined by a 6 x 6 matrix relating a resultant set of forces and moments to the six rigid-body degrees of freedom.

DRAFT FOR COMMENT

In general, for a linear elastic or viscoelastic material and a uniform or horizontally stratified soil deposit, each element of the impedance matrix is complex-valued and frequency dependent. Each complex element of the matrix, $[K_s(\omega)]$, can be thought of as a pair of functions: the real part representing the stiffness of the soil, and the imaginary part the damping.

3. Solution of the Coupled Soil-Structure System

The final step in the substructure approach is performing the actual SSI analysis. The results of the first two steps are combined with a dynamic model of the structure to solve the equations of motion of the coupled soil-structure system. The solution procedure in SMACS for completing this step is quite powerful. The structure is modeled by its fixed-base eigensystem and modal damping factors. The structure dynamic characteristics are projected in the form of modal participation factors to a reference point on the foundation at which SSI response of the foundation is determined. This projection reduces the characterization of structural dynamic effects to a size dependent only on the number of modes and the number of foundation degrees-of-freedom. This permits the use of extremely complicated structural models. For a single foundation, the SSI response computation requires solution of, at most, six simultaneous equations. In-structure response is determined with a similar size reduction.

-47-

A3.2 SOIL MODEL

The soil model for the SONGS site is described below.

A3.2.1 Soil Conditions

The subsurface soil conditions were investigated by drilling exploratory borings around the site. The site stratigraphic column for SONGS Unit 1 as published in the SONGS Unite 1 Final Safety Analysis Report (FSAR)³ is shown in Fig. 4. For SONGS Units 2 and 3,⁴ a detailed geophysical investigation, consisting of seismic refraction surveys, seismic velocity surveys, micromotion and borehole surveys was performed by Dames and Moore.⁵ The measured and computed data are presented in Fig. 5.

The site is underlain by terrace deposits, consisting of approximately 30 - 45 ft of sands, silts, and clays with layers of gravel and cobbles. These soils are generally dry, and some are cemented. Measured compressional and shear wave velocities for the terrace deposits range from 1000 to 3100 feet per second (fps), and 300 to 1250 fps, respectively. The Poisson's ratio for this material ranges from 0.40 to 0.44. The unit weight varies from 120 to 130 pounds per cubic foot (pcf).

52



Figure 4. Subsurface profile of SONGS Unit 1 (extracted from SONGS Unit 1 FSAR³).



. VALUES FOR UPPER 50' OF FORMATION

() INDICATES ESTIMATED VALUES

APPROXIMATE FOUNDATION LEVEL

Figure 5. Stratigraphic column showing geophysical data (extracted from SONGS Units 2 and 3 FSAR⁴).

DRAFT FOR COMMENT

The terrace deposits are underlain by a deep deposit of fine-to-coarse well-graded and slightly cemented sands, termed San Mateo formation. The San Mateo sands extend approximately 940 ft below the existing ground surface. The unit weight varies from 130 to 135 pcf. The average dry unit weight ranges from 119 to 127 pcf with an average of about 123 pcf. The relative density was estimated to be close to 100%. The measured compressional and shear wave velocities range from 3000 to 7000 fps, and 1000 to 2750 fps, respectively. The Poisson's ratio based on these measured wave velocities ranges from 0.40 to 0.45. The average elevation of the ground water table was approximately 5 ft above mean lower low water (MLLW). MLLW describes an average height over a 19 year period of the lower of the two low waters of all tidal days.

A3.2.2 Dynamic Material Properties

In order to conduct site response analyses, dynamic material properties of the subsurface soils must be assigned. For analysis of the San Onofre site, only the properties of San Mateo sand need be considered. Dynamic properties generally refer to the low-strain shear modulus, strain-dependent shear modulus, and damping ratio.

The low-strain shear modulus (G_{max}) of the San Mateo sand was based on laboratory and in-situ tests that determined the shear wave velocity as a function of depth. The range of the measured shear wave velocities is shown in Fig. 6. The low-strain shear modulus can then be computed from the equation:

 $G_{max} = \rho V_s^2$,

where $\rho = \text{mass density}$, and $V_s = \text{shear wave velocity}$. The range of G_{\max} based on measured shear wave velocities are shown in Table 1.

Site Depth	Shear Wave Velocity (V _s , fps)	Low-strain Shear Modulus (G _{max} , ksf)				
upper 50 ft	. 1000 - 2200	4037	- 19540			
below 50 ft	. 1900 - 2750	15135	- 31706			

Table 1. Ranges of shear wave velocity and Gmax.

The shear modulus of San Mateo sands was also calculated from an empirical equation. Using parametric values recommended by Woodward-McNeill⁶, the equation for low-strain shear modulus is:

$$G_{max} = 59 (\sigma_m)^{2/3}$$

where σ_m = the mean effective stress in units of pounds per square foot (psf), while G_{max} is measured in units of kips per square foot (ksf). Computed shear wave velocities at different depths based on this equations are also shown in Fig. 6. A comparison between the measured and calculated values for ∇_s indicates a variation that ranges from 18% to 37%. This range implies that the values for G_{max} as a function of depth could vary by approximately as much as 50% of the mean values.

The nominal strain-dependent shear modulus and damping ratio curves are recommended by Woodward-McNeill⁶ on the basis of the field seismic tests and laboratory tests. The average value of Poisson's ratio, 0.42, was used to convert major principal strains to shear strains. As shown in Fig. 7, the shear modulus of San Mateo sand decreases rapidly with increased strain levels.

55



Figure 6. Variation of shear wave velocity with depth.

65





In order to estimate the variation in soil properties at different strain levels, strain-controlled dynamic triaxial tests were performed on samples takes from emploratory borings at the site. The variation in the modulus of elasticity and damp ng was obtained by testing seven samples at each of three confining pressures. The greatest scatter of data for Young's modulus was found at the lowest confining pressure. The deviation was about 25% at low strain and 51% at high strain levels. On the basis of this scattering and uncertainties associated with calculated values of G_{max} described previously, it is reasonable to assume values of \pm 50% of nominal as the upper and lower bounds for shear modulus over the entire strain range. The variation is illustrated in Fig. 7.

The dynamic triaxial tests also provided the basis for determining the nominal values and the scatter of damping ratios (β). The data scatter shows a variation of 80% of the nominal value at low shear strain and a variation of 42% at high strain. The estimated range is shown in Fig. 8.

A3.2.3 Development of Equivalent Linear Soil Models

Equivalent linear soil characteristics were evaluated by one-dimensional wave propagation analysis. Computer program, SHAKE, ⁷ was used for this study. Soil properties described in earlier paragraphs were used in the SHAKE analyses. For each acceleration level, sets of synthetic time histories developed to represent variability in design motion were used. Variations in three input parameters, low-strain shear modulus, shear modulus react the strain level, and damping with strain level, were considered. The parameter values were selected according to a simulated experimental scheme that covered the parameter spaces. For each acceleration level, iterative, linear analyses were performed until the calculated soil properties were compatible with the average calculated shear strain in each soil layer. Since subsequent structural response calculations were performed at a ground acceleration of 0.67 g, emphasis was given to determining the parameter values at this input level.

-55-

63





1. Generalized Soil Profile

The SONGS site is underlain by approximately 40 ft of terrace deposit and about 900 ft of San Mateo sand. The terrace deposit was excavated and all structures were founded below the finished plant grade at an elevation of 20 ft in San Mateo sand. The finished grade will be referred to as the free-field ground surface of the idealized soil profile used for the SSI model.

Since the main purpose of using equivalent linear soil properties in SSI analysis is to approximately account for non-linear soil effects due to seismic wave motions, it is not necessary to define the soil model to the bottom of San Mateo formation. The selection of a rigid base in a deep soil site is dependent not only on the size of the foundation but also on the justification of the existing soil properties in the soil profile. It has been customary to assume the rigid base exists at a certain depth where the low-strain shear wave velocity is 2500 fps or greater.

Based on the dimension of the reactor building, as well as the relationships between shear wave velocity and the depth at the SONGS site recommended by Dames and Moore⁵, the rigid base was initially selected at a depth of 260 ft below the finished grade. To assure the adequacy of the rigid base location, simplified analyses to simulate SSI effects were conducted for several cases with the base located at three different depths. Input motion was specified at ground surface in order to compute the motion at different elevations. For all cases, the response spectra at the same elevation were compared and the differences in response shape at a depth of 260 ft or greater are negligible as shown in Fig. 9. Therefore, the location of the artificial rigid base at 260 ft is adequate. The idealized soil profile used for SHAKE analysis is shown earlier in Fig. 6.

2. Nominal Soil Properties for 0.67 g

Two sets of synthetic motions were used as input in the analysis to determine soil properties at 0.67 g. One set was targeted to a the SONGS Units 2 and 3 design response spectrum of 2% damping, the other set was





based on the SONGS Unit 1 seismic reevaluation spectrum of 2% damping. Four time histories comprised each set. Their mean spectra are shown in Fig. 10. The frequency content of the two spectra is significantly different at levels below 9 Hz. This difference may contribute to variations in the soil properties.

LARI FUR LUMBER

Having established the input motion and the generalized soil profile, the analyses to determine the nominal equivalent soil properties were conducted. Iteration on soil properties uses the curves of strain-dependent moduli and damping shown earlier in Fig. 8. Two cases using different empirical formulations defining the low-strain shear modulus were considered. The nominal values given by each case for shear modulus and damping were plotted in Fig. 11. Small differences are seen between the two cases at depths less than 100 ft, and it is believed that the overall effect on generated impedance and scattering matrices due to these differences is insignificant.

3. Uncertainty of Strain-Compatible Soil Properties

The uncertainty of strain compatible soil properties is a function of the variation in the soil parameters, G_{max} , G/G_{max} , β (where G is the shear modulus and B is the damping ratio) and the characteristics of the input motion. To assess the variability, multiple analyses were conducted with SHAKE. The soil parameters were modeled as three random variables. For each analysis, the values of the soil parameters were chosen by a Latin hypercube sampling technique.⁸ Two sets of synthetic motions, each consisting of four time histories and targeted to the specified spectra, were employed to provide the variability attributed to seismic input. Twenty-nine sets of property combinations were combined with eight control motions to define 232 SHAKE analyses. A second simulation was performed treating G as a dependent variable. This served to reduce the variability of soil properties. The difference in the coefficient of variation (COV) of the equivalent linear soil properties due to the two different simulation schemes was negligible. The results of these analyses are shown in Figs. 12, 13 and Table 2. Figure 12 concentrates on the soil properties calculated at 0.67 g. The mean and the one-plus and minus standard deviation values are plotted for both shear modulus and damping ratio. Figure 13 shows the mean values as a function of soil depth for each of four acceleration levels. The variations in G and β are listed in Table 2.

Table 2. Mean values and coefficient of variations (COV) of G and β for each g level.

0.204 g		0.460 g			0.670 g				0.890 g						
G ()	(sf)	β ((2)	G (k	sf)	β (z)	G (ka	ef)	β (1	()	G (ksf)		β (%))
Mean	COV	Mean	COV	Mean	cov	Mean	cov	Mean	COV	Mean CC	οv	Mean CO	V Me	an CO	/
757	.478	7.09	.491	485	.482	10.32	.476	393	.481	11.66	.452	338	.471	12.80	.438
1319	.488	7.43	.493	857	.485	9.67	.468	699	.472	10.92	.445	610	.479	11.98	.433
1721	.484	7.10	.475	1139	.486	9.18	.269	940	.481	10.37	.449	817	.481	11.39	.436
1922	.477	7.03	.495	1297	.486	9.03	.470	1076	.486	10.21	.452	934	.480	11.23	.434
2053	.472	7.10	.472	1413	.487	9.05	.467	1172	.489	10.26	.450	1024	.478	11.27	.430
2271	.474	7.02	.488	1595	.494	8.89	.471	1320	.472	10.09	.450	1160	.482	11.07	.427
2508	.477	6.88	.488	1785	.504	8.67	.474	1473	.496	7.86	.450	1278	.487	10.83	.427
2751	.482	6.72	.490	1975	.512	8.44	.477	1629	.502	9.61	.451	1435	.495	10.56	.427
2998	.488	6.55	.492	2163	.518	8.21	.480	1780	.504	9.36	.453	1570	.501	10.30	.431
3240	.493	6.39	.494	2343	.519	8.00	.482	1930	.508	9.13	.456	1703	.506	10.05	.432
3478	.496	6.25	.495	2528	.524	7.80	.485	2078	.511	8.91	.458	1833	.511	9.81	.435
3712	.499	6.10	.476	2708	.531	7.62	.487	2220	.514	8.71	.459	1960	.516	9.59	.436
5317	.508	5.57	.505	3858	.542	6.98	.498	3138	.533	7.99	.472	2755	.537	8.83	.452
5894	.513	5.37	.507	4272	.551	6.73	.500	3471	.543	7.70	.473	3043	.549	8.52	.452
6454	.516	5.18	.508	4681	.563	6.50	.501	3777	.543	7.44	.474	3308	.550	8.24	.452
6990	.519	5.01	.509	5071	.568	6.29	.502	4083	.546	7.20	.474	3574	.551	7.97	.453
8691	.521	4.71	.513	6294	.572	5.91	.508	5054	.554	6.78	.481	4393	.556	7.50	.461
9255	.523	4.58	.512	6725	.576	5.74	.509	5394	.554	6.58	.482	4682	.554	7.29	.462
9815	.524	4.46	.512	7159	.579	5.58	.511	5727	.554	6.40	.483	4976	.557	7.09	.464
10368	.524	4.24	.513	7584	.580	5.43	.512	6067	.556	6.23	.484	5274	.560	6.89	.466

---areas. j 6 Ging BRAIN





Figure 10. Mean input spectra targeted to the SONGS Unit 1 seismic reevaluaton spectra and the SONGS Units 2 & 3 design spectra.



Figure 11.



118



Figure 12. Variation of strain compatible soil properties at 0.67 g level based on simulation experiment and 8 design motions specified at ground surface.

75-



Figure 13. Strain compatible soil properties for different acceleration levels based on simulation experiment and 8 design motion specified at ground surface.

18.0

12.4

A3.3 SSI AND STRUCTURAL MODELS

Determination of the dynamic response of structures housing (or supporting) the auxiliary feedwater system (AFWS) components is needed to provide input motion to the AFWS models. Figure 14 shows a plan view of the San Onofre Unit 1 and schematically illustrates the location of the auxiliary feedwater system. The west feedwater heater platform houses the auxiliary feedwater pumps. Piping system is supported within the heater platform, along the fuel storage building, and within the north turbine building extension before joining the main feedwater lines that penetrate the containment sphere. The main feedwater lines then connect to the steam generators inside the reactor building. Foundation impedance and scattering matrices were obtained and detailed finite element models were constructed for each of these structures. In addition, detailed soil and structural models were made for the turbine pedestal, the south turbine extension, and the control administration building. Although these structures do not house the auxiliary feedwater system itself, they all influence its response and bouses its related systems, e.g. electric power, and etc.

A3.3.1 Reactor Building Complex

The SONGS-1 reactor building complex consists of three basic structures. The reactor building is a massive, reinforced concrete structure which is housed inside a spherical steel containment shell. Both the reactor building and the containment sphere are supported on a common foundation whose external surface, which is in contact with the soil, has the shape of a spherical scgment. The geometry of this foundation is shown in Fig. 15. Above the foundation the containment sphere and reactor building are isolated from each other. Immediately surrounding the reactor building and containment sphere is the cylindrical sphere enclosure building which is supported on a segmented circular strip footing.

25









A3.3.1.1 Soil Impedance and Scattering Matrices for the Reactor Building Complex

GLAFT FOR COMMENT

For the initial studies of the reactor building foundation, the foundation of the reactor building is modeled as an isolated, rigid sphere of radius 75.6 ft, embedded in the soil 19.75 ft. The impedance and scattering matrices for the idealized foundation geometry were computed by Prof. J. E. Luco, University of California, San Diego. Typical impedance and scattering components are shown in Figs. 16 and 17, respectively. Similar calculations were performed for a circular surface foundation for comparison purposes. An equivalent circular foundation of radius 68.33 ft and founded 30 ft below the ground surface was analyzed. The size of the foundation corresponds to the projected area of the spherical foundation. It was asusmed to be founded with properties corresponding to those of the SONGS-1 site beginning 30 ft below the free surface-the average depth of the spherical foundation below grade. Two different soil profiles were assumed: the first was the same as that used by Prof. Luco; the second was a uniform halfspace with the same properties as were used by Bechtel in their earlier design calculations. A comparison of the impedances from the three calculations shows reasonably good agreement between results. Differences can be explained by differences in embedment conditions, in soil properties in the immediate vicinity of the foundation and in assumed Poisson's ratios.

Comparisons of static impedance values from these analyses with those obtained from simplified methods (as suggested by Woodward-Clyde and by Roesset) and with values used by Bechtel in their design calculations were also performed. With the exception of the horizontal and rocking impedances ($K_{\rm HH}$ and $K_{\rm RR}$) for Bechtel design springs and the horizontal impedance ($K_{\rm HH}$) from Woodward-Clyde formulas, the results appear to be in reasonable agreement when differences in embedment and soil property assumptions are considered. The high value for $K_{\rm HE}$ from the Woodward-Clyde formulas is a result of their assumptions of the correction factor for embedment. The differences in Bechtel springs, $K_{\rm HH}$ and $K_{\rm RR}$, have not yet been reconciled completely.

24



 $K_{\rm HH} = k_{\rm HH} + 12 \, {\rm muc}_{\rm HH}$, the horizontal component;





Typical Figure 17. Scattering component for the reactor building foundation.

A.3.3.1.2 Structural Model of the Reactor Building Complex

The structural model of the reactor building complex is described below. 1. Reactor Building

The reactor building is a massive, reinforced concrete structure located within the containment sphere that supports and protects the components of a three-loop nuclear steam supply system (NSSS). The principal elements of the reactor building are the primary and secondary radiation shields, the operating deck, refueling pool and steam generator compartments. The primary shield is a 6 ft thick cylinder that surrounds the reactor pressure vessel. The secondary shield is a 5 ft thick wall, rectangular in plan, that essentially forms the outer perimeter of the reactor building. The refueling pool sits atop the primary shield and, along with the secondary shield, supports the operating deck. The steam generator compartments extend above the deck to act as missive shields for the three steam generators and the pressurizer. Both the reactor building and containment sphere are supported on a partial-spherical foundation.

The finite element model of the reactor building employed 3-D thin plate and shell elements to define the concrete slabs while beam elements defined • . structural steel frames. Frames included in the model were the operating deck extension on the south side of the secondary shield and the gantry crane support structure. The NSSS and its support were modeled by the reduced mass and stiffness matrices provided by Bechtel/Westinghouse.⁹ In all, approximately 650 nodes and 630 elements were used to define the model (Fig. 18).

The nominal strength and density values for both concrete and steel used in the reactor building model are shown in Table 3:

	Modulus of elasticit; (psi)	y Poisson's ratio	Mass density 1b-sec /in
Concrete	4.40×10^{6}	0.17	2.25 x 10 ⁻⁴
Steel	29.0×10^{6}	0.30	7.34×10^{-4}

Table 3. Material properties of the reactor building model.





.
Considerable effort was made to benchmark the LLNL modal results of the reactor building model with those computed by SCEC/Bechtel. Some differences were found and resolved by refining the reactor building model and exercising engineering judgement. Finally, a version of the reactor building model for subsequent response analyses was eventually established. Differences in the modal frequencies as given by this model and those of SCEC/Bechtel reflect acceptable differences in modeling approaches.

BRAFT FOR COMMENT

Table 4 lists the major modes of the LLNL reactor building model. The structural response in the y-coordinate (east) direction is dominated by a single mode at 13.3 Hz, while several modes in the range from 13.5 Hz to 20.6 Hz contribute to response in the x-coordinate (south) direction.

Mode Number	Frequency (Hz)	Mass X	Participation Y	FractionZ
	12.24	0.4	30.8	0.0
29	16.15	0.4	0.0	0.4
40	17.45	7.8	0.4	0.1
43	19 10	6.7	0.0	0.0
44	20.61	10.5	0.0	2.1
40	33.71	0.9	0.8	9.2
69	34.47	1.5	0.6	11.2
	Mass sum of all modes	77.9	79.3	59.1

Note: First 20 modes are mainly for NSSS and the steel frames for gantry crane.

Table 4. Significant modes of the reactor building model.

2. Containment Sphere

The containment sphere is a stainless steel sphere of 140 ft in diameter and is slightly greater than one inch thick. The upper portion is free-standing, extending 100 ft above finished grade at elevation 19 ft to an approximate elevation of 120 ft. The lower portion is embedded in a concrete foundation previously described (Fig. 19).

DRAFT FOR COMMENT

1.8. 3

The containment sphere is modeled with isoparametric shell of revolution elements as found in the MODSAP program. The axisymmetric model is assumed to be fixed at the point where the sphere becomes encased by the concrete foundation. Consequently, only a partial sphere is modeled. The sand transition area is defined by axisymmetric solid of revolution elements.

A nonuniform grid of elements was used. In those areas where significant spatial variation in stress was expected, a fine discretization of elements were employed. In the free-standing portion of the sphere, a coarser grid was used. One hundred and ten nodes, 83 shell elements and 24 sand elements defined the model. The material properties of the containment sphere are listed in Table 5:

	Modulus of elasticity (psi)	Poisson's rati	o Mass density (1b-sec/in)
Steel shell	$2.9 \times 10^7 \text{ lb/in}^2$	0.30	7.34×10^{-4}
Sand	$4.86 \times 10^4 \text{ lb/in}^2$	0.35	not applicable

Table 5. Material properties of the containment sphere model.

1:5





The results of two eigenvalue analyses were combined to define the dynamic characteristics of the containment sphere. First, modes corresponding to Fourier harmonic, n = 0, were determined. Then, modes corresponding to n = 1 were found. A total of thirty modes were used in subsequent response analyses of the sphere. Table 6 lists the modal frequencies and mass fractions of major modes where it shows that the first three modes dominate the structural response in the three coordinate directions.

Mode Number	Frequency		Mass Participation Fr			
	(Hz)		x	Y	Z	
1	11.42		75.1	0.0	0.0	
2	11.42		0.0	75.1	0.0	
3	21.31		0.0	0.0	65.3	
	Mass sum of all nodes	76.4	76.4	68.	0	
				1997		
- and the second se	the second se		and the state of the	and industry in success in the		

Table 6. Significant modes of the containment sphere model.

3. Sphere Enclosure Building

As its name implies, the sphere enclosure building surrounds the containment sphere and reactor building. It is independent of the other structures in that it rests on strip footings that are separate from the reactor building foundation. The enclosure building consists of a cylindrical wall approximately 3-ft thick that supports a conical roof. The cylindrical section has major cut-out openings to accommodate the turbine deck and the piping penetrations. Smaller cut-outs provide for cables, piping and hatches.

The conical roof consists of sloping steel beams forming a composite section with the concrete roof slab. A ring girder supports the roof at its intersection with the cylindrical wall.

The finite element model of the sphere enclosure building is shown in Fig. 20. The cut-out that accommodates the turbine deck is evident. Beam elements combined with thin plate and shell elements were used to model the roof while thin plate and shell elements alone defined the cylindrical wall. A total of 463 nodes, 549 shell elements and 160 beam elements were used to produce the fixed-base model. The material properties of sphere enclosure building are described in Table 7.

Modulus of elasticity (psi)		Poisson's ratio	Mass density (1b-sec/in)		
Steel beams	29 x 10 ⁶	0.30	7.34×10^{-4}		
Concrete shell	11 3.834 x 10^6	0.17	2.25×10^{-4}		

Table 7. Material properties of the sphere enclosure building model.

Modal analysis results for the sphere enclosure building are listed in

Table 8.

Mode Number	Frequency (Hz)	Mass Pa X	articipation Y	Fraction Z
1	3.54	48.5	0.2	0.0
3	6.33	1.8	54.1	1.5
4	7.34	0.5	0.5	19.5
7	7.83	9.4	7.5	0.2
25	14.68	0.0	6.8	9.8
Mass sum	of all nodes	90.1	90.3	46.8
Mass sum	of all nodes	90.1	90.3	46.8

Table 8. Significant modes of the sphere enclosure building model.



Figure 20. Sphere enclosure building model.

A3.3.2 Turbine Building Complex

The turbine building is comprised of five structures: the turbine pedestal; the north and south turbine building extensions; and the east and west feedwater heater platforms. These areas and their foundations are shown in Fig. 21. Each of these areas is enclosed by a structure which is physically separated from its adjacent structures above the foundation. However, most of these structures are supported on a combination of isolated and combined column footings and/or large basemats. Furthermore, every structure shares at least one common foundation mat or combined footing with another structure. This structure/foundation configuration greatly complicates the SSI analysis of the turbine building because it means that the foundations will interact not only through the soil, but also through the structures which they support. The SSI problem should be treated for this case by first developing impedance functions and foundation input motions which include the effects of interaction between foundations through the soil. Once these properties are developed, the SSI response of the structures can be calculated using an algorithm which includes the effects of multiple foundations supporting each structure.

Our SSI work on the turbine building proceeded as far as the development of preliminary models of the major foundations, calculation of impedance functions for these models, and in some cases, the performance of sensitivity studies to investigate the effect of the refinement of the spatial discretization of the models. The foundations which have been modeled are: the turbine-generator pedestal foundation mat; Anchor Block No. 1 (West feedwater heater platform); Anchor Block No. 2 (east feedwater heater platform); fuel storage pool; and a typical isolated footing, 5 ft x 12 ft in dimension, supporting a single column.

The studies of impedances for these foundations consisted of calculations assuming isolated foundations. Foundation shapes which have not yet been studied include the combined footings which support three columns spaced about 20 ft apart and the square or near-square footings of differing sizes. These studies are briefly summarized below.



Figure 21. Foundation plan for turbine building complex.

A3.3.2.1 Impedance and Scattering Matrices

The impedance and scattering matrices for the turbine building complex are described below.

1. Turbine Pedestal Foundation Mat

This foundation is the largest of all the foundations associated with the turbine building. It extends about 150 ft from north to south and is about 50 ft wide. The foundation mat is 5 ft thick over most of its extent. In addition to supporting the turbine generator pedestal, the foundation mat also provides support to several columns belonging to adjacent structures: the turbine building northern and southern extensions, and the east and west feedwater heater platforms.

A fairly detailed model was constructed to describe the shape of the turbine generator pedestal foundation mat. The discretization is shown in Fig. 22. The foundation impedances for this model were computed by using the soil profile described previously. A representative impedance is shown in Fig. 23. The foundation reference point (origin of coordinate system of the model) was chosen close to the centroid of the foundation shape in an effort to minimize coupling between east-west translation and torsion and between vertical translation and north-south rocking. Minimizing this coupling helps to isolate different SSI effects and makes it easier to understand the dynamic behavior of the soil/structure system.

The impedances appear to be reasonable by comparing them to impedances published by Wong and Luco¹¹ for an equivalent rectangular foundation on a uniform viscoelastic halfspace. Considering the perfect symmetry of the retangular foundation, differences in material damping (Wong and Luco used 5%, while the material damping in the layered halfspace was nearly 10% near the surface), and differences between behavior of uniform and layered halfspaces, the two sets of impedances agree well.

2. Isolated and Combined Column Footings

A number of isolated column footings are located in the turbine building area. These vary in size from 3 ft x 3 ft to 5 ft x 16 ft. Several combined footings, each supporting three columns of a single structure and spaced at 18 to 20 feet, also exist in this area. A 5 ft x 6 ft spread footing exists near the location where the turbine pedestal foundation mat, the north turbine building extension, the fuel storage building and the west feedwater heater platform meet. This footing supports two closely situated columns, one of which belongs to the fuel storage building, the other to the west feedwater heater platform. Line I for Gumment

114



Figure 22. Turbine pedestal foundation model.

110



Figure 23. Typical impedance component for the turbine pedestal foundation model.

Two models of a typical isolated footing were compared to see the effect of spatial discretization on the impedance functions. Their dimensions are both 5 ft by 12 ft. Most of the impedance terms compared fairly closely, being within 10% of each other. However, for the rocking term about the long axis (K_{44}), the coarse model was 20% softer than the refined one. The significance of the difference that would be introduced by use of the coarse model depends on the importance of the columns being supported.

DRAFT FOR COM

3. Anchor Block No. 1, West Feedwater Heater Platform

Anchor Block No. 1 is a concrete slab about 60 ft long, 40 ft wide and 12.5 ft thick. It is immediately adjacent to the turbine generator pedestal foundation mat on the west side and is separated from it by one inch Flexcell. Four tunnels approximately 6 ft in diameter are located in the anchor block which provide cooling water to the turbine generator.

We constructed a fairly refined model to describe the geometry of the anchor block. The model is shown in Fig. 24. The foundation reference point was selected near the centroid of the foundation shape to minimize coupling between the foundation degrees of freedom. Figure 25 shows a typical impedance computed for the isolated foundation. As might be expected, weak coupling exists between the horizontal translations and torsional impedance and between rocking and vertical translation, since the foundation is not symmetric in either direction.

4. Anchor Block No. 2, East Feedwater Heater Platform

Anchor Block No. 2 is a concrete slab about 100 ft long, 30 ft wide and 14.5 ft thick. It is immediately adjacent to the turbine generator pedestal foundation mat and is separated from it by one inch Flexcell. Four six feet diameter tunnels are located in the slab. These tunnels carry the turbine's cooling water to a 9 ft discharge culvert originating in the anchor block and running its full length and passing into the turbine pedestal foundation mat.

Two foundation models of Anchor Block No. 2 were constructed in order to study the effects of spatial discretization on the computed impedances. The models are shown in Figs. 26 and 27. Model A is the coarser of the two; the



Figure 24. Anchor block number 1 foundation model.



Figure 25. Typical impedance component for anchor block number 1 foundation model.





GRAFT FOR CONMENT





subregions in Model B are either the same as those in Model A, (e.g. along the extreme east & west sides) or are subdivisions of them (e.g. along the x-axis of the model). In order to minimize the coupling effects, the reference point was chosen to be close to the centroid of the foundation shape. Figure 28 shows a comparison of a typical impedance term computed for the two models. For all terms, the impedances compare quite well at frequencies below 10 Hz. The only terms where significant differences occur above 10 Hz are east-west rocking (K_{44}), rocking/vertical translation coupling (K_{34} and K_{35}), and east-west translation (rocking coupling K_{24}). For a detailed SSI analysis of the West Heater Bay area where the auxiliary feedwater system is located, we would expect that these differences would have little effect, and that the coarser Model A would be adequate.

÷





- . .

18.4

A3.3.2.2 Structural Model

The structural models for the turbine building complex are described below.

1. Turbine Pedestal

The turbine pedestal is a massive, reinforced concrete space frame. The structure consists of an 8 ft thick, reinforced concrete roof supported by two end rectangular frames and three intermediate pedestals. The frames and the pedestals rest on a 5 ft thick concrete foundation mat.

The finite element model of the turbine pedestal consists of variable-node, thick shell and three-dimensional solid elements for the roof, columns and pedestals (Fig. 29). One hundred eight elements connect 414 nodes. Equipment loading specified for the turbine pedestal is included by increasing the densities of appropriate elements.

The results of a fixed-base eigenvalue analysis are listed in Table 9.

Mode	Number	ber Frequency		Mass	Mass Participation Fract			.on
			(Hz)	x		Y		Z
	1		7.97		90.9	0.	0	0.0
	2		9.86		0.0	15.	8	0.0
	3	1	1.22		0.0	60.	3	0.0
	6	2	0.95		0.0	0.	0	13.4
	12	2	6.67		0.0	0.	0	18.0
	13	2	7.12		0.0	0.	0	15.4
	15		30.55		0.0	11.	2	0.0
	16	1	30.81		0.0	0.	0	13.2
		Mass	sum of all s	nodes	90.0	89.	6	64.4

Table 9. Significant modes of the turbine pedestal model.





2. North and South Turbine Building Extension

The north and south turbine building extensions are rectangular structures located ou either end of the turbine pedestal. They both consist of prestressed concrete deck at elevation 42 ft supported by steel framing. The columns supporting the roof slabs rest on individual or combined footings.

The finite element models of both structures employed thin plate and shell elements to define the concrete deck, while beam elements modeled the structural steel frames. Where adequate shear anchors exist, composite section properties were calculated for steel roof beams and the concrete deck.

The north turbine building extension model consisted of 95 nodes, 114 beam element and 50 shell elements. Figure 30 illustrates the model, while Table 10 lists the results of a fixed-base eigenvalue analysis.

Mode	Number		Frequen	су	Mass	Partici	pation	Fract	ion	
			(Hz)		X		Y		Z	
										-
	1		4.30		36.6	1	3.3		0.2	
	2		4.65		4.3	8	3.7		0.0	
	3		5.23		55.3		0.2		0.0	
	7		7.61		0.0		0.1		13.6	
	8		8.78		0.2		0.0		26.2	
		Mass	of all	modes	98.0	9	7.5		79.6	

Table 10. Significant modes of the north turbine building extension model.

In a fashion similar to the north extension, the deck and support frame of the south turbine building extension were modeled with thin plate and beam elements, respectively. Concrete block walls that surround the structure on three sides made use of beam elements to define the out-of-plane behavior of the walls and plane-stress elements to model their in-plane behavior. These elements use

LAAFT FOR GUMMENT





properties recommended by the SCEC/Bechtel.¹² The model is shown in Fig. 31. Model frequencies and mass fractions are listed in Table 11.

DRAFT FUR COMME

Mode	Number	Frequency			
Mass	Particip	ation Fraction			
		(Hz)	x	Y	Z
	2	1.18	24.1	0.0	0.0
	3	1.51	12.3	0.0	0.0
	4	1.81	0.0	46.0	0.0
	5	7.71	24.4	0.0	0.5
	6	8.45	29.0	0.0	0.0
	7	8.85	0.0	25.1	0.9
	8	10.44	0.0	23.9	0.0
	13	17.10	0.0	0.0	23.0
	15	17.80	0.0	0.0	14.0
	20	23.66	0.4	0.0	11.3
	23	25.28	0.0	0.1	17.4
	Mass sum	of all nodes			
98.9	9	7.7 92.3			

Table 11. Significant modes of the south turbine building extension model.

137



Figure 31. South turbine building extension model.

3. West Feedwater Heater Platform

The west feedwater heater platform is located on the west side of the turbine pedestal. It is a rectangular structure, approximately 120 ft long and 50 ft wide, consisting of a prestressed concrete deck at elevation 35 ft supported by structural steel framing. Steel support columns extend down to individual or combined footings. Concrete block walls attach to the steel framing on the south, west, and north sides of the building. The entire structure rests on a massive, concrete mat. The west feedwater heater platform is of particular interest, since it houses portions of the AFWS.

LAATI FOR COMME

12 1

The finite element model of the west platform shown in Fig. 32 defined the dynamic characteristics of the roof, steel frames and block walls. Shell and beam elements modeled the deck while beam elements model the support frame.

Same as the south turbine building extension, the behavior of the masonry walls within the feedwater heater platforms was modeled with a combination of beam and plane stress elements. Various equipment loads were included in the structure model by proportionally increasing the mass density of affected elements.

The frequency and mass fraction of all modes with frequencies less than 33.0 Hz are listed in Table 12.

Mode Number	Frequency	Mass Par	ticipation	Fraction
	(Hz)	x	Y	Z
5	3.89	16.3	43.5	0.0
10	7.24	0.1	0.0	13.3
11	8.03	44.4	42.2	1.2
12	8.94	1.9	1.4	14.1
16	12.19	30.3	8.9	0.0
Mass sum (of all modes	98.4	98.4	79.2

Table 12. Significant modes of the west feedwater heater platform.

CRAFT FOR COMMENT 1913 N÷ しままの日

Figure 32. West Feedwater Heater Platform Model.

4. East Feedwater Heater Platform

The dynamic characteristics of the east feedwater heater platform are similar to the west feedwater heater platform and the same model would be used.

LIGHT I TUR GUMMENT

A.3.3 Fuel Storage Building

The fuel storage building lies between the west feedwater heater platform and the sphere enclosure building. It consists in part of a massive, reinforced concrete fuel pool. The surrounding structure is steel framing that supports concrete block walls. The soil-supported mat that forms the bottom of the fuel pool is approximately 5 ft thick. Four foot thick concrete walls form the sides of the pool. The pool is embedded such that the top of the mat is an average of 14 ft below grade. The pool stores both new and spent-fuel assemblies.

On the south side of the structure, concrete block walls and steel frames extend down to strip footings at elevation 14 ft. On the north side, the frames and wall sit atop the refueling pool. The building is covered by a prefabricated deck roof at elevation 64 ft. This portion of the fuel storage building houses the switchgear room and other equipment.

A3.3.1 Impedance and Scattering matrices for the Fuel Storage Pool

The fuel storage pool is a reinforced concrete box-like structure about 75 ft long in east-west direction, 30 ft wide and embedded about 14 ft below the level of adjacent foundations. Its walls are between 4 ft and 5 ft thick. To the south side of the pool lies the remainder of the Fuel Storage Building which consists of concrete block walls supported on a 1.5 ft wide by 8 in. strip footing. Located at intervals along this footing are 4 foot square footings about 1.5 ft thick which support columns for the fuel handling building and for the west heater bay. Because of the flexibility of the strip footings, the column footings must be considered to be isolated from each other except in the axial direction of the strip footing. Two foundation models of the spent fuel pool were constructed. Model A (Fig. 33) was more refined than Model B (Fig. 34) and included the shape of the column footing located in the southeast corner of the pool. The reference point was chosen near the centroid of the rectangular portion of the foundation. Figure 35 showr a comparison of a typical impedance term calculated for both models. The eccentricity of the column footing in Model A caused some additional coupling between horizontal translation and torsion (K_{16} and K_{26}) and between vertical translation and rocking (K_{34} and K_{35}). However, this is not considered to be a significant effect, especially since the footing in Model A is actually cast into the wall of the pool at the elevation of the strip footing and is not level with the bottom of the foundation.

Land I - UN Containe Di

A3.3.2 Structural Model of the Fuel Storage Building

Initially, a model reflecting the proposed design modifications to the fuel storage building was constructed and a modal (eigenvalue) analysis completed. However, further modification from SCEC/Bechtel required additional changes. These changes were incorporated into the model, but no modal anaysis was performed. Finally, SCEC/Bechtel returned to the unmodified configuration. The information for the roof decking of fuel storage building will be required in order to change the model to its unmodified configuration. Therefore, no progress on model analysis was accomplished at the time the project was terminated.

A.3.4 Control-administration Building

The control-administration building is the structure housing the control room and the battery room. The building also houses various laboratories; heating, ventilation and air-conditioning (HVAC) equipment; and locker facilities. The main load-bearing elements of the building are reinforced concrete and concrete-block shear walls. The walls extend to strip footings. Ground-floor slabs at elevations 14 ft, 20 ft and 21 ft are soil-supported. In the administration area, partial floors exists between the ground slab and the roof at elevation 37 ft. In the control room bay, floor slabs are at grade and elevation 42 ft. A grid of steel framing at elevation 37 ft supports cable trays that run under the control room floor. The elevation of the roof is approximately 55 ft.





-101-

UNAR I FOR GUMMENT





usual fost ournately!







Figure 36. Fuel storage building model.

A3.3.4.1 Impedance and Scattering Matrices for the Control-administration Building

The development of SSI models for this structure was not completed at the time the project was terminated.

A3.3.4.2 Structural Model of Control-administration Building

A detailed finite element model of the structure was constructed. Thin plate and shell elements defined the reinforced concrete shear walls and floor slabs. Beam elements modeled the structural steel in the control bay and administration areas. As in the models of the other structures, a combination of beam and plane stress elements were used to characterize the masonry walls. Equipment loads were included either in the form of added masses lumped at nodes or increased element densities.

Figure 37 illustrates the model. Eigenvalue analysis results are listed in Table 13. An initial comparison between these modal data and the frequencies supplied by SCEC/Bechtel indicated significant differences. However, no effort was made to resolve or explain the differences.

Mode	Number	Frequency (Hz)		Mass X	Participation Y	Fraction Z
				a an a constraint a sur		
	14	7.99	0.4		0.1	16.4
	28	10.30	6.2		35.8	0.2
	29	10.50	34.4		2.5	0.4
	40	14.54	0.7		0.0	25.9
	Mass sum o	of all modes	77.7		77.2	81.0

Table 13. Significant modes of the control-administration building model.



Figure 37. Control-administration building model.

A4 RESPONSE COMPARISON FOR REACTOR BUILDING/CONTAINMENT SPHERE

One major objective of this project was to assess the conservatism in the seismic responses of the SONGS-1 structures and piping systems of the AFWS as calculated by SCEC/Bechtel using design procedures by comparing with those calculated by SMACS. In the SCEC/Bechtel case, a deterministic analysis was performed using analysis procedures and parameter values selected for seismic reevaluation and definition of the design ground response spectra termed SONGS Unit 1 seismic reevaluation spectra, anchored to a 0.67 g zero period acceleration (ZPA). In the SMACS case, three sets of analyses were performed. Each set differed by the definition of the seismic input: SONGS Unit 1 seismic reevaluation spectra; the SONGS Units 2 and 3 design spectra; and the average of the two. All of the spectra were anchored to a 0.67 g ZPA in the horizontal direction and to a 0.45 g ZPA in the vertical direction. Each set contained multiple analyses which permitted incorporation of variability in the seismic input, SSI, and structure characteristics.

The response comparison was only completed for the reactor building/ containment sphere at the time the project was terminated. It is reported here.

A4.1 SCEC/Bechtel Seismic Reevaluation

The seismic reevaluation analysis by SCEC/Bechtel was based on the SONGS-1 seismic reevaluation spectra as described above. Both response spectrum analysis and time history analysis were performed. The former case produced force/moment results, and the latter case produced time histories from which in-structure response spectra were generated. An artificial acceleration time history whose response spectra essentially enveloped the seismic reevaluation ground response spectra was used. Three directions of excitation were considered, each direction analyzed independently, and the results combined by the square root of the sum of the squares (SRSS) method. Noteworthy aspects of the analysis include their SSI model and the use of composite modal damping. Frequency-independent soil springs were used to represent the force-displacement characteristics of the soil. Properties of these soil springs were derived from a detailed finite element analysis of the soil and structure, i.e., an axisymmetric model subjected to circumferential

harmonic loadings of n = 0 (vertical) and n = 1 (horizontal). Composite modal damping techniques yielded damping values near 4 percent of critical for structure modes and significantly higher values for coupled soil-structure modes. The in-structure spectra compared here were peak broadened and smoothed by SCEC/Bechtel.

A4.2 SMACS analysis

The modus operandi of SMACS is to perform repeated deterministic analyses, each analysis simulating an earthquake occurrence. By performing many such analyses and by varying the values of the several input parameters, we incorporate the uncertainty inherent in any deterministic analysis. Variability in the seismic input phase was incorporated by using ensembles of time histories. In the SSI area, soil shear modulus and material damping were varied. In the major structures and subsystems, frequencies and modal damping were our uncertainty parameters. Parameter values for each simulation were sampled from assumed probability distributions according to a Latin hypercube experimental design.

Three sets of SMACS analyses were performed. Each set differed by the definition of the seismic input. In each set, thirty earthquake simulations were considered. The seismic input for each simulation comprised three acceleration time histories (two horizontal and a vertical) acting on the surface of the soil. These artificially generated time histories were described in detail in Section A2 of this appendix. The mean of their response spectra closely fit the target spectra. The resulting mean spectra for the three targets was shown in Fig. 1 of Section A2. Spectral accelerations of the target spectra for selected frequencies are superposed, and the close match can be readily observed.

The structure and SSI models of the reactor building-containment sphere described previously were used in the SMACS analyses. The fixed-base frequencies and an assumed modal damping of 4 percent of critical for the structures comprised the nominal values. The impedances and scattering matrices for the partial spherical foundation, shown in Figs. 16 and 17 of Subsection A3.3.1.1. respectively, which were calculated for equivalent
linear soil properties associated with a 0.67 g excitation were termed nominal values. As mentioned above, the parameters were varied in the analysis to incorporate undertainty. Two cases were considered and itemized in Table 14. Two modeling assumptions were made. The wave propagation mechanism at the site was assumed to be vertically-propagating waves. Structure-to-structure interaction effects between the sphere enclosure building and the reactor building/containment sphere were ignored.

방법 경험에 대한 것은 것은 것이다.	Coefficients	of Variation
Parameter	Case 1	Case 2
Soil shear modulus	0.7	0.35
Soil damping	1.0	0.50
Structure frequency	0.5	0.25
Structure damping	0.7	0.35

Table 14. Statistical parameters that define the variation of input values.

Note: Values are given for the median and the coefficient of variation (COV). Case 1 reflects a state of maximum uncertainty about the SONGS-1 plant. Case 2 represents a state of significantly greater knowledge.

Variations in this limited number of parameters are intended to represent all sources of variability in each link of the seismic methodology chain (SSI, structure, etc.). For example, by varying soil shear modulus and damping in the SSI link, the uncertainty in the definition of the viscoelastic material constants at a point were represented as were variations due to phenomena not modeled and the perceived accuracy of analysis procedures. Similar comments apply to structure uncertainty parameters. This is discussed in more detail in Ref. 2. To assess the effect of input parameter distributions on the results, two cases were analyzed and are briefly discussed later.

A4.3 Response Comparison

Two forms of seismic response were compared: in-structure response spectra in the reactor building, and element stress components in the containment sphere. Seven node points in the reactor building were selected for comparison; three directions of response par node point. Figure 39 shows the points: five nodes on the operating deck (four corners and an interior node); the center of gravity of the foundation; and a node on top of a steam generator compartment. Due to the close similarity in response of the five points on the operating deck, results at only one point are shown here, node 201 at the south-east corner of the operating deck. At all points, response in the two horizontal directions was nearly the same, hence, only north-south (x-direction) and vertical response is included. Figures 40 and 41 show response on the foundation, Figs. 42 and 43 on the operating deck, and Fig. 44 and 45 on the top of the steam generator compartment. These results should be considered more appropriate for evaluation than for design purposes. However, this opinion may change with additional research.

The comparison in Figs. 40-45 is between the mean SMACS response and the SCEC/Bechtel seismic reevaluation values. This comparison is believed to be appropriate because the SMACS seismic input is defined so that its mean corresponds to the target spectra (Fig. 38). In Figs. 40-45, in-structure response spectra due to the SONGS Unit 1 seismic reevaluation spectra are shown with a long segmented curve; those due to SONGS Units 2 and 3 are shown with a solid curve; and the average spectra are shown with a short segmented curve. The spectra due to SCEC/Bechtel seismic reevaluation spectra¹³ are overplotted.

It is of interest to examine Figs. 38 and 40-45 which trace response from the free-field ground motion to the foundation to the upper elevations of the structure. Concentrate first on the SMACS results for a specific definition of the seismic input. Comparing Figs. 38 and 40-45, one observes a general reduction in motion from the free-field to the foundation and a subsequent increase in response (albeit small) as one proceeds to the upper elevations. Some observations are in order. In general, the reactor building

162



Figure 26. Response point locations in reactor building.





- SR = Seismic reevaluation
- TS = Target Spectra



11 1

1 1



SR = Seismic reevaluation

TS = Target spectra



SR = Seismic reevaluation

TS = Target Spectra



Figure 43. S-E corner of operating deck mean response spectra: vertical direction.

NOTE: MS = Means response spectra SR = Seismic reevaluation TS = Target Spectra



- SR = Seismic reevaluation
 - TS = Target spectra

spectra



- SR = Seismic reevaluation
- TS = Target Spectra

acts similar to a rigid body on a deformable medium due to its relatively high fixed-base frequencies and mass distribution. Hence, dominant overall motion of the reactor building is due to coupled soil-structure response with little structural deformation. Two aspects of the SSI model contribute significantly to the reduction in motion of the foundation and the minimal amplification through the structure: the scattering matrix, and the impedances. The scattering matrix, which accounts for kinematic interaction and in so doing generates foundation input motion from the free-field motion, results in a reduction in horizontal translation and the addition of a rotational component. For this case, the reduction dominates. Our representation of the foundation impedances includes the effects of radiation and material damping. Earlier the equivalent linear soil properties were described. They included a significant amount of soil material damping (near 10% in the upper layers) for a 0.67 g excitation. The combined effect of radiation and material damping for this case is a significant energy dissipation mechanism. Finally, although no eigenvalue extraction of the coupled soil-structure system is performed (due to the frequency dependence of the impedances), one can estimate the frequency of peak response for the nominal soil-structure system by inspecting in-structure response spectra generated for a single broad-band time history and soll-structure parameters held at their nominal values. In so doing, the frequency is estimated to be near 1.8 Hz which has minimal amplification in the target design ground response spectra (especially for the SONGS Unit 1 seismic reevaluation spectra).

Next consider the comparison between the SCEC/Bechtel seismic reevaluation analysis and the SMACS results. The most appropriate comparison is between the SMACS results due to SONGS Unit 1 seismic reevaluation spectra and the SCEC/Bechtel results. This is because the seismic input target spectra are the same for these two cases. To clarify this point, these two results from Fig. 44 are shown in Fig. 46. In Figs. 46 through 46, the SCEC/Bechtel results are observed to envelop those of SMACS over the entire frequency range; in the amplified frequency range by considerable factors. This may be interpreted as an indication of calculational conservatism or margin. If the comparison of these seismic reevaluation results were carried further, for example, to piping moments, this margin is expected to grow by a significant factor. Studies will soon be underway to quantify this estimate for piping moments in another project at LLNL.





Figure 46. Comparison of the mean spectra due to SONGS-1 seismic reevaluation target spectra and the SCEC/Bechtel results (from Fig. 44).

DRAFT FOR GUMMENT

It is also evident from Figs. 40-45 that significant conservatism in the SCEC/Bechtel results over those due to SMACS exists for both the SONG Units 2 and 3 design spectra and the average spectra in the amplified and higher frequency ranges. In the low frequency range, the SMACS results due to the SONGS Units 2 and 3 design spectra are lower than the SCEC/Bechtel results. This effect may be interpreted as a result of the strong motions in the low frequency range of the SONGS Units 2 and 3 design spectra.

The SMACS results shown are for variations in input parameters corresponding to Case 1 of Table 14. To assess the effect of varying degrees of uncertainty on the mean response, Case 2 (Table 10) was analyzed. A comparison of the mean response for Cases 1 and 2 showed minimal differences.

A comparison of stress components at two locations in the containment shell is shown in Table 15. The two locations are the stiffness discontinuity just above the sand transition zone (grade discontinuity) and a point in the free-standing shell between the foundation and the equator (contintous shell). In all cases, the SCEC/Bechtel results exceeded those computed by SMACS. Again, this can be interpreted as an indication of conservatism or margin. For reasons discussed above, the most appropriate comparison is between the SCEC/Bechtel results and the second column of the three SMACS results, for example, 1172 psi vs. 286 psi, respectively. Finally, Fig. 47 showed a typical cumulative distribution function of the meridian stress of continuous shell due to the SONGS Units 2 and 3 design spectra. The thirty circles represent the calculated responses and the dotted line is a lognormal fit with a median value of 458 psi and a beta of 0.664.

1. 1

....

	Bechtel S Reevaluation	eismic Analysis	SONGS-2&3 SMACS Ar	Spectra malysis	SONGS-	i Spectra Analysis	Average SMACS	Spectra Analysis
Stress (psi) –	Continuous Shell	Grade Discontinuity	Continous Shell	Grade Discontinuity	Continuou Shell	s Grade Discontinuity	Continuous 'Shell	Grade Discontinuity
Membrane-Long								
Stress Ng	1172	2034	553	339	303	187	421	260
Membrane-Merid.								
Stress Ng	1483	6615	458	661	252	362	350	505
Membrane-Shear								
Stress Nos	1517	1849	601	791	332	437	473	622
Bending-Long								
Stress Mg/S	115	7922	4	359	2	196	3	274
Bending-Merid.								
Stress M _s /S	34	2404	14	1180	7	640	10	901
Twist M _{0s} /S	4	26	*	7	•	4	.*	6

Table 15 Response comparison of containment sphere. Stress values from Bechtel seismic reevaluation analysis versus median stress values given by SMACS.

1

Note: * = negligible

FI FOR SOME

Sia 2.12

+





CRAIN FUR GUMMENT

A.5 FEFERENCES

- D. Gasparini and E. H. Vanmarcke, <u>Simulated Earthquake Motions Compatible</u> with Prescribed Response Spectra, Report 2 of <u>Evaluation of Seismic</u> <u>Safety of Buildings</u>, Department of Civil Engineering, Massachussetts Institute of Technology, Cambridge, Massachussetts, Pub. No. R76-4, (January, 1976).
- J. J. Johnson, G. L. Goudreau, S. E. Bumpus, O. R. Maslenikov, <u>Seismic</u> <u>Safety Margins Research Program Phase I Final Report - SMACS - Seismic</u> <u>Methodology Analysis Chain with Statistics (Project VIII)</u>, Lawrence Livermore National Laboratory, Livermore, Calif., UCRL-53021, NUREG/CR2015, Vol. 9, (July, 1981).
- Southern California Edison Company, <u>Final Safety Analysis Report (FSAR)</u>, San Onolice Nuclear Generating Station Unit 1, NRC Docket 50-206.
- Southern California Edison Company, <u>Final Safety Analysis Report (FSAR)</u>, San Onofre Nuclear Generating Station Units 2 & 3, NRC Docket 50-361 and 50-362.
- Dames and Moore, "Seismic and Foundation Studies," proposed Unit 2 and 3, San Onofre Nuclear Generating Station, San Onofre, California, for Southern California Edison Co., (April, 1970).
- Woodward-McNeill and Associates, "Material Properties Studies," San Onofre Nuclear Generating Station, Report Prepared for Southern California Edison Co., (March, 1972).
- P. B. Schnabel, J. Lysmer, and H. B. Seed, <u>SHAKE--A Computer Program for</u> <u>Earthquake Response Analysis of Horizontally Layered Sites</u>, UCB/EERC 72-12, (December, 1972).

LUARI FOR COMMENT

- Westinghouse Electric Corporation letter MA-RCSA-175, from
 T. A. Christopher to J. E. Dempsey, Bechtel Power Corporation, April 7, 1978.
- 9. R. L. Iman, W. H. Conover, and J. E. Campbell, "Risk Methodology for Geologic Disposal of Radioactive Waste: Small-Sample Sensitivity Analysis Techniques for Computer Models, with an Application to Risk Assessment," Sandia Laboratories, Albuquerque, N.M., SANMD80-0020, March 1980 (also published as U. S. Nuclear Regulatory Commission NUREG/CR-1397).
- 10. J. J. Johnson, "A Modified Version of the Structural Analysis Program SAP IV for the Static and Dynamic Response of Linear and Localized Nonlinear Structures," GA-A-14006 REV., (June, 1976).
- 11. H. L. Wong and J. E. Luco, "Tables of Impedance Functions and Input Motions for Rectangular Foundations," Report no. CE 78-15, University of Southern California, December, 1978.
- Bechtel Power Corporation letter BPC/SCE-81-169 from A. Sanders, Bechtel Power Corporation, to R. Blaschke, Southern California Edison Company, July 6, 1981.
- Bechtel Power Corporation letter from A. Sanders, Bechtel Power Corporation, to T. Y. Chuang, Lawrence Livermore National Laboratory, December 9, 1981.
- Bechtel Power Corporation letter BPC/SCE-81-204 from A. Sanders, Bechtel Power Corporation, to A. Blaschke, Southern California Edison Company, August 7, 1981.

APPPENDIX B

GRAFT FOR GOMMENT

FAULT TREE DEVELOPMENT

This appendix contains the followings:

- o Top levels of the San Onofre Unit 1 AFWS fault tree. (Figure 1)
- Upper level of development for gate of insufficient flow to the steam generator (SAFA). (Figure 2)
- o Minimal cut sets of order 2 for SONGS-1 AFWS. (Table 1)

The remainings are on file at LLNL. The model includes the AFWS as well as those portions of other systems (condensate storage, auxiliary steam supply, electric power, and service water and fire protection) which interface with the SONGS-1 AFWS. No fault tree analysis of Zion-1 was initiated at the time the project was terminated.



Figure 1. Top level of SONGS-1 AFWS fault tree

-120-

٠.





Figure 2. Upper level of development for gate SAF



as shown in Figure 1.

<u>،</u>

for SONGS-					•																																							
order 2																																												
ut sets of																																												
Minima] c													-																							0	0	0	0.0		<	2		1
Table 1.						MVD1M/10H0	HVD1H#1500	MAD : M916M	MUDING 199104	HVAIMUZOMIAVH	MEGM. DISH	MSEC. MOIM	HSEC.CSGM.	SORVALVES	INVELSS 1 JUN	IND ISSISAU	HV01551200	MVD15512NI	MVD15/1800	NUDISEI SUI EDI	MVD1S#16M	MVD15616M	HV015/16H	MUALSHZBM	MARC SRIM	HSEC. S92M	HSEC. SAIM.	MSEC. CS7M.	NP D L D D D D D D D D D D D D D D D D D	MPALDBRSM	SORVALVES	MVG1SS180	NULL SCIEN	UCISSIONE	MV015512M	MV015#180	MUDISFIBM	MV0158160	MAD156161	NUDISAL6M	MUALS#20M	MSEC.SSIM	3 - 1	× 21
	:14					MPB10005ME	3MS 000 1 H JM	MPBIDBOSHE	MPBIDBDSHE	MPRIDEBSME	MPB10005ME	MPDIDBDSME	MPBLODDSME	HP B L B G UHOO	MPB1B2DH00	MPRI DROTHOO	MP B LUBDHOO	MPBIDBUHOO	NP B 1 B G B HOO	MPRI BUBNOO	MP B 1 800H00	NP B L & B FIHOD	MP B I B B DHOO	MF B L B B B HOO	MPRINE NEW NOO	MPU LOGATIOO	MP II L D B D HOO	MP 0 1 0 9 0 H 100	MPRI DRUGHDO	MP II LEDDHOO	MPUIDBUHOG	MP B L G B DHOG	MPBIBBBBC	MPRIMUMO	MP B L D D D HOG	MPB1080H05	MPBIBBHOG	MP B L D D D HOG	HPB1000H0G	MP R L R R D N O G	MPBIBBBHOG	MP8188MOG		
	1982 18:38				MIN CUT SET NO.	286	200	209	162	262	293	295	296	262	862	100	381	382	303	1 200	386	337	380	500	115	312	313	410	315	317	318	319	328.	125	323	324	325	326	128	025	338	331	•	
	FEB 86	61187	3438											j																								-				0		
6 E E D	N SAT.	LICANTS -	569			SORVALVES MVG1SS1000	HVG1SS10M0	INGISSIBND	HVD1SS12ND	HV01591000	DM812210NH	HVD15616MG	MVD15916MC	HVD1S816M	SURVALVES	ING I SS I BAU	HVGISSIOMO	NV01551200	HVD1SS12MC	NUDICE I CON	NV01581601	HV015/16M0	MV015916M	HVDISBI6M	MUCICCINO	HVG1SS18MG	MAG1SS10H	NVD1SS1200	INDI COLONN	HVD15610M	NVD158160	HVD15916H	MVD1S/116M	COBUAL VEC	14VG1551801	MVG1SS18M	NVG1SS10M	MVD1551201	MVD1SS12M	Malasiani	MV0159.60	HV015816H		
VSTEM CODE	DATE OF RU	UHBER OF INF	5F . 1	SIN		HV01H0160C	NVD1MD190C	MVD1H#100C	HVD1HB180C	HV01H18180C	NVD I NUT BOC	NVD1 NG100C	HVDINGIBOC	MVD1NG180C	MUDING 10HIO	HVD IND IND DING	MVD 1H01 6H0	MV01M010HI0	MUDINGI BHO	W/DINGIDIO	MUDINICHO	MV01N010H0	MVD I MU I PHO	MUDING TOWNO	MUDINGI DINC	MVD1M018MC	HVD1H010HC	HVD1H010HC	MUCLINGI DEIC	MV01101014C	MVD 1 M01 BMC	MVD1MJ16MC	MUDING I BINC	MUDIMUTERS	MVD1M610M8	MV01N016MB	MV01M016M3	HADING 18H8	MV01N018MG	MVD 1 NUT 1 DIAD	MVD I MATCHO	HVDIM818110		
- 111LE -	TUDIANTH	TOTAL NI	· DADER	. IMPLICA	· NIN CUT	- 14	0	* 1	n va	2		10	11 .	21	2.2		.91	17		20	12	22	53	24	52	27	20	52	10	32	33	. 10	57	00	00	60	UV VII	41	24	54	45	. 46 .		

AFWS

2 for SOMSS-1 MTMS	DRAFT FOR COMMENT
order	
ts of	
ut se	
(cont.) (
Table 1.	
MSEC - 5//3/MJ MSEC - 5//3/MJ MSEC - 5//3/MJ MSEC - 5//3/MJ MSEC - 5//1/MJ MSEC - 5//1/MJ MPB1 ///2/8//2/MJ MPB1 ///2/8//2/MJ MPB1 //2//2//2/MJ MVD1 5//1 //2/MJ MVD1 5//1 //2/MJ	MSEC.581MJ MSEC.581MJ MSEC.581MJ MSEC.581MJ MSEC.581MJ MSEC.581MJ MSEC.581MJ MSEC.581MJ MSEC.581MJ MSEC.581MJ MSEC.581MJ MP016051600 MV01551600 MV01551600 MV01551600 MV01551600 MV01551600 MV01551600 MV01551600 MV01551600 MV01551600 MV01551600 MV01551600 MV01551700 MV01551600 MV01551600 MV015517000 MV01551700 MV015551700 MV015551700 MV015551700 MV015551700 MV015551700 MV015551700 MV015551700 MV015551700 MV015551700 MV0155500 MV0155500 MV0155500 MV0155500 MV0155500 MV0155500 MV0155500 MV0155500 MV0155500 MV0155500 MV0000 MV0000 MV0000 MV00000 MV00000 MV00000 MV000000 MV0000000 MV00000000
MP B 1 8850H0G MP B 1 8750H0G	МР В 1 89.0 МИС МР В 1 80.0 МИС МС В 1 80.0 МИС В 1 80.0 МИС
MVD15616MD MVD15616MD S0RVALVES MVD15816MA S0RVALVES MVG1551800 MVG1551800 MVD1551800 MVD1551800 MVD1561800 MVD15616MD MVD15616MD MVD15616MD MVD15616MD MVD15516MD MVD15518000 MVD15518000 MVD15518000 MVD15518000 MVD15518000 MVD15518000 MVD1551200	MVD1591600 MVD1551800 MVD1591600 MVD1501600 MVD1501600 M
MVD I MAI BHAI BHA MVD I MAI BHA MVD I MAI BHA MVD I MAI BHA MVD I MAI 600 MVD 1000 MVD 10000 MVD 100000 MVD 1000000000000000000000000000000000000	MVD1.M01.6010 MVD1.802.6010 MVD1.802.2010
**************************************	200 200 200 200 200 200 200 200 200 200

100	HVATHOZOHA	HVGISSIBHD	393	I VOIEWAAMO	MTALACSTMA	Table	1. 11	inimal	cut :	sers o	i order	2 101	SOMP2-1 VI-WS
109	MVALMOZOHA	HVD1551200	394	I VD1FWAAHD	NSEC COLMI		10	ont.)					
110	HVAIMØZEHA	HVD1SS12ND	395	I VIDIEVAAHO	HELLACETHY								
111	HVA1M828HA	HVD150100C	396	I TALDEVENU	NYVICCACNO					1 - N			
112	MVAING20HA	HVDISBIBMC	207	TALBEVOWN	HUDICEROOD					1.1			
113	NVA1M028HA	HV01591600	300	LINIRSVAMM	MADIC20000								
114	· NVALHD25HA	AVGICALOUD	390	LIAIRSVEMM	MVDICS88MB					1.0			
115	HVALLIGSOMA	NU01501000	393	LTAIRSVRMM	MTAIBCSTMM								
110	EUA INTROCEDA	NVUISPIEMO	400	LTAIRSVRMM	HSEC.CSIMJ								
1 5 7	TIVA IND ZUMP	NVDISHIGMA	401	LTAIRSVAMM	MFILBESTMK								
110	PIVATHDZEMA	MVAISEZOMA	402	LSEC.F5XMJ	MXXICSJ6MD								
110	MSEC.SSINJ	NVDINDIGOC	403	LSEC.F5XHJ	MVDICSDOOD								
119	M256.221M3	MVDINØISMO	404	LSEC.F5XMJ	MV010S06MD								
120	MSEC.SSINJ	HADINGIONC	405	LSEC.F5XMJ	MTALOCSTMM						1. A. M.		
123	MSEC.SSIMJ	NVDINDIOND	406	LSEC.F5XMJ	MSEC.CSIM.)								
122	MSEC.SSIMJ	HVDINGIGOD	407	LSEC. ESXMJ	MELLACSTAR								
123	MSEC.SSIMJ	MVD1MØ1GMO	400	LSEC ENTMA	HAVAICCOCHD								
124	MSEC.SSIMJ	NVDIMUIGMD	001	LSEC ENTING	MUDICEUDOD								
125	MSEC.SSIMJ	HVDINDIGHA	410	LSEC EDINI	NUOICSDOUD								
126	MSEC.SSINJ	HVALMEZOMA	411	LSEC.FD/MJ	MADICZUNNO								
127	MSEC. SO3NJ	HVDINGIOOC	114	LARC. PUTHU	MINICUSIMM								
120	HSEC, SUTHI	MVDLMULDMO	912	LSEC.FD/MJ	MALC. CSIMJ								
129	MSEC SADUL	LUDINGLONG	413	LSEC.F07MJ	MFILØCSTMK								
130	NCCC 50310	HVDI HDI UML	414	LSEC. FDSHJ	MXXICSDGMD								1
131	HICE. 50310	NVDIMUIUMU	415	LSEC.F#5MJ	MVD1CS0000								
1.3.7	1126.203MJ	NADIMAIPOD	416	LSEC.FOSMJ	MVDICSDOMD								
132	Marc. Shama	MADIHAIQNO	417	LSEC.FUSMJ	MTAIOCSTMM								(and)
133	MSEC.SU3MJ	NVDINDIGMD	410	LSEC.FØ5HJ	MSEC.CSIMJ								ali
134	MSEC.S03MJ	HV01M016MA	419	LSEC.FD5HJ	MELLECSTMK								E
135	MSEC.S03MJ	HVAIMAZOMA	420	LSEC.FØ4MJ	MXXICSOGMD								alian .
136	MSEC.SOZMJ	HVDIN#100C	421	LSEC.FØ4MJ	MV01CS080D								
137	MSEC. SUZIAJ	HVD1HJ18HO	422	LSEC. FD4HJ	MVDICSOMD								distant
130	MSEC.SOZMJ	MVD1H818MC	423	LSEC FRAMA	MTALACSTUM								1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
139	MSEC.SU2HJ	HVDIMUIOMO	424	LSEC EGAMA	MCEC CCIMI								GRUE :=*1
110	MSEC.SOZMJ	MVD1H9160D	425	ISEC EDAMA	MELLACCIMU								and
141	MSEC. SO2NJ	HVDINGI6MO	425		MANAICCOCHO								612.2)
142	MSEC, SBZIAJ	MVDIMALGMD	420		HUDICEMOND								and d
143	MSEC. SOZMJ	MUDIHUISPA	120		101650000								
144	MSEC. SU2HJ	MVA1H0200A	420		HTALOCCTUN								ATTENT
145	MSEC. SOUND	MVD1H0100C	429	LSEC.FUSHU	MIAIDESIMM								Va el
146	MSEC SALMA	MVDINGIAMO	430	LSEC.F#3HJ	MSEC.CSIMJ								C. J
147	NEEC CALLAN	INVO THE TONG	431	LALLINGMU	METIDESIMK							1. 199	and a
1.40	HELC FOLMS	NUDIPIDIUMC	432	LFTTRSVRIK	MXXICS06MD								Line. The
140	MSEC.SDIMJ	NVUINUIBNI	433	LFIIRSVRMK	HVDICSØ80D								States ind
143	MSEC. SUINJ	11401101000	434	LFIIRSVRMK	HVDICSDOMD								et and to
1.210	MSEC.SUIMJ	HVD1N016MO	135	LFIIRSVRMK	MTALOCSTMM								1
151	MSEC. SAINJ	MVDIHØIGMD	436	LFIIRSVRMK	NSEC.CS1MJ								Garage 1
152	MSEC.SOINJ	MVDIMPIGMA	437	LFIIRSVRMK	MFILØCSTMK								statt 2.13
153	MSEC.SØINJ	MVAINGZEMA	438	BECIWIRAMK	SORVALVES								e
154	MSEC.NO3MJ	SORVALVES	439	DECIVIRAMK	MVGISSIGOD								
155	· MSEC.MO3MJ	MVGISSICOD	448'	BECIWIRAMK	MVGISSIAMO								
156	MSEC.MH3HJ	MVG1SS10MO	441	BECIWIRAMK	MVGISSIAMD								
157	MSEC.HIJJHJ	HVGISSIBND	442	BECIVIRAMK	MV01551200								
150	MSEC.MØDHJ	MVD1551200	443	RECIVIRAM	MVDISSI2MD								
150	MSEC. MO3MJ	NV015512M0	444	RECIVIDANC	MVD1501000								
160	MSEC.MORMA	MVDISEIROC	445	BECILLIDAMY	MUNISCIONC								
161	MSEC MORNA	HVDISGIOMC	. 445	BECINIDAM	MUDISCIONC								
162	MSEC MODUL	NVDISCISON	440	DECIWIRAMK	101501600								
167	MSEC MODIAL	HV01501000	44/	DECIWIRAMK	HVDISUIGMO								
164	MSEC MODIAL	14101501610	440	DECIWIRAMK	MVDISUIGMD								
165	MSEC Magua	MUDISDIONU	449	BECIWIRAMK	MUDISUISMA								
165	MSEC MODING	NVALCORNA	450	UECIWIRAMK	MVAISHIJMA								
100	Hace. MUJHJ	HVAI SUZUMA	451	BECIWIRAMK	MSEC.SSIMJ								

and the second of the second second

Acres in the

. .

ALTER																																																				
SONGS-1																				and and		CK.	22	14		1	1.100	. uno	3	3	Case	3	131	W.	-	- March	a a a	a line	5													
for																																																				
2																																																				
Irder																																																				
of o												1																																								
ets c						•																																							•							
ut si															*																																					
al ci	-																						1																													
Intern	cont																																																			
H .	(c	•																																																		
able 1	•	-																																																		
JT	2	2	~	0	0			0	10	0	a	0		50			. <	V	-	-	2					2 14		0	0	0	-			0	0		i a	2	2		2 "	0	0			-	0	0	00			
MEBS	S 82M	MIBS	CS7M	OSEN	0500	× SBB	HS BB	CIRD	Hals	S1 AM	\$120	S12M	0019	001 a	W I KW	1918	ELGM.	020M	MISS	NEBS	SUZM	NI IS	たいろう	00000	N N N N N N N N N N N N N N N N N N N	HS DD	LVES	S100	S L BH	SI BH	0715	00110	HB IB	6160	816M	NO I D	HE2BH	25 134	MEBS	SUZM	CS7M	03BB	Ha SO	HSDA	MSDH	C 1 80	S18H	S1BH	S120	001 H	MBIB	
SEC.	SEC.	SEC.	SEC.	0101	9184	7818	P1010	2125	V615	V615	VD 1 S	STON	SIGA	SIDA	STON	SIGA	SIGN	VA15	SEC.	SEC.	SEC.	50	225	「日本の日日	おいられ	0100	ORVA	VGIS	VG15	VGIS	210A	STON	VDIS	VOIS	VDIS	2100	VAIS	SEC.	· 235	220		p l g l	6104	6184	PB18	NCIC	VG15	VG15	Vols	SION	Ver 3	1
K N	K N	K X	K M	K N	K N	×:	E U	2 X	2	モウ	N .	2 3	E :	2 2			1	11 0	2 7	E	E :	21	2 2	5 2	2 2 1	N N	s n	N	5 12	E .	5.3	2 2 2	E C	N D	N C	2 2	. E	2 14	5	5 2	2 22	N N	5 14	1 .	E u	2	Ξ. 	C M	E I	. x.	E U	
IRAM	IRAM	NA.	1RAM	NYN!	IRAM	INAM .	DALAN	STR. 1 M	0314	BBIN	HI DB	MICO	M188	MI DD	第二日間	王二二代	03103	M181	06114	M100	H109	N 1 2 C	0100	11104	ALL DAY	MI BD	IAAM	IAAM	I AAM	1 AAN	AAM	LAAM	I L NM	IAAM	IAAM	I A A IA	AAM	1 AAM	I.A.A.M	I AAU	I AAM	IAAH	I AAM	INAN	I JEW	1 7 6.0	1254	12534	125M	1254	125H	
ECIU	ECIV	ECIV	ECIU	ECIW	ECIW	HI23	N L L L	101 D3	EC I B	EC18	ECIE	EC18	11111	5110		1123	ECIS	8133	ECIO	ECID	ECIN	10103		11111		ECIB	CALB	CAID	CALB	CALB	CALI	CAID	CALB	CAIB	CALD	CALD	CALD	CAIB	CALB	CALB	CALD	CALB	CALB	CAIR	CALB	CALL	CALL	CALL	CALL	CALL	CALL	
8	0	10	0	10	0	0.4	D 63	5 410	1.60	0	62.3		2.0		0 10	1.45	0	10	62	69	0.0	(3. s	36	а с		, ca	0	0	0	(C) 1	3 6	2 6		0		0.0	5 63	0	£0 5	2.0	3 63		0		0 6	a 5		63		-		
452	E54	454	455	456	153	158	10.1	191	462	E9¥	494	465		199	469	A7B	471	472	173	474	115	0/4	047	0	DUA	104	×02	EOF	404	504	000	40.0	409	49.8	164	264	464	495	964	164	561	SBN'	1.8%	285	203	100	586	507	500	218	211	
2	2	2	0		0	0 0	2 0				0 4	0 6		t 4	1		2			0	0.6			2 4		0	0	0	V	< 1	2 5	22	2	c	0	2 0	0	0	0.	5 8		N	2	2:	2	9	0	9	0.0	20	2	
SSIN	NEBS.	SB2H	SULM	S3N?	2100	HETS'	UCI S	S12H	8180	818H	B160	810M	1010	B2BN	SSIH	HED'S	S02H	SBIN	LVES	S BC	NETS.	CE IN	101010	00122	NI EN	0916	9161	1910	0101	1282	1000	1282	Salp	3180	19191	101101	19160	1910H	1919	ULDIN U	HDAP	40261	ERIA	NB21	ALDIA I	190	SIBH	SIBH	5120	#10C	1818	
SEC.	SEC.	src.	SEC.	ORVA	VGIS	219A	CI SA	2104	210A	VDIS	STUN	VD10	STON NOT	VAIS	SEC.	SEC.	SEC.	SEC.	ORVA	2	VGIS	010D	C I UN	2100	VD1S	1015	V015	VDIS	VDIS	VALS		SEC.	SEC.	VD IN	MION	AL DA	VDIM	VOIM	MION	VULH	VDIC	VALH	SEC.	235	SEC.	ST DA	VG15	VGIS	SIDA	VOIS	VOIS	
2 2	E	X.	H P	2	X	23	2 2	X	N	E :	2 2	2 2		: X . ~	N. D	R D	N N	W	S	5 : 	5.0	2 2 2				10	4 N	E	E D	E :	5.3	E E	2	2	X I	5 3	2	2	д : Э,	2 2		N.	H ?		E P	N C	10	E	E Z	. x.	S H	
FIG3X	までのよ	MEBN	MEBH	M2BH	MBZN	H2BW	H2BN	HIZ BY	H6 2M	MZGW	M2.BM	MC UN	MG DW	M20H	H20H	MOZH	HOZH	M2 BH	MICH	N. C.	E I BY	NUCH	AL 1 2212	112121	NIDN	MIGW	HIDH	HIDH	HIDH	MIOW	NI LON	MULH	MIGH	CS7M	CS JM	エトレレ	CS7H	C57M	CS7H	1122	CS7M	CSTIN	C57H	CS7H	2012	CSSM	C S 6H	C 5 6 M	CSGN	CSGN	CS6H	
HSEC.	MSEC.	MSEC.	MSEC.	HSEC.	MSEC.	MARC.	MSEC.	MSEC.1	MSEC.	WSEC.	NSEC.	NOTON	MCCC	MSEC.	MSEC.	MSEC.	PISEC.	MSEC.	MSEC.	MSEC.	. Jacc				NSEC.	NSEC.	HSEC.	HSEC.	MSEC.	NSEC.	NALC.	ASEC.	MSEC.	MSEC.	MSEC.	MARC.	MSEC.	MSEC.	MSEC.	NACC.	MSEC.	MSEC.	HSEC.	NSEC.	MORC.	MSEC.	MSEC.	MSEC.	MSEC.	MSEC.	MSEC.	
167	168	69	170	12	21	12	15	76	177	10	6/ 1	181	102	681	104	1 05	1.0.6	107	00	501	101	201	101	101	195	36	101	190	661	200	202	203	101	205	200	2016	503	510	112	212	514	212	216	112	010	228	221	222	522	225	226	
								2																																												

221	3	MSEC.CS6MJ	HVD1S#16HO	512	BCALLIZSMC	MV ISHIGOD	Table	1.	Minimal	cut	sets	of	order	2 for	SONGS-1 AITWS
221	9	MSEC.CS6M3	MVDISGI6MD	513	BCATTIZSHC	MVDISHIGMO	10010		(cont')						
231	σ	MSEC.CS6MJ	HVDISALAMA	514	OCALLIZSMC	NVDISØI6MD			(conc.)						
23	1	MSEC.CS6MJ	NVDICSGADD	515	BCALLIZSMC	MVDISHIGMA	1. A.								
23	2	HSEC.CSGMJ	HVDICSALHD	510	BCATTIZSMC	HVA SUZUMA									
231	3	MSEC CS6MJ	MVAI CO20MA	5.0	BCATTIZSMC	MSEC.SSINJ					1				
23		HEEC CEGMI	HEEC CCIMI	510	BCATTIZSMC	MSEC.S03MJ									
231		NEEC CECHI	NECC COMM	519	BCAILISMC	MSEC. SØ2MJ									
221	2	NCCC CCCUT	Macc.su3MJ	520	UCATITIZSMC	MSEC.SØIMJ									
271	7	NEEP PECHI	HECC SALAN	521	BCA11125MC	MSEC.CS7MJ									
201		HEEF PEEKS	11260.501110	522	BCAILISMC	MPBIDHASOO									
234		MOLC CCOMI	NUDICCIADE	523	BCA11125MC	MPBIBEBSOG									
211	T	MCEC CCCSSHS	MADICZIDON	524	BCALLIZERC	MPBIDDDSMG							1.8.101		
24	î	MEEC CEAN	HVDICSIMMI	525	ECALIZENC	MPDIBUDSME						1.14			
24	,	MCCC CCAUS	HVDICSIGUU	526	BCAILIZAMC	SORVALVES									
24	5	HOLC CCOM	NVUICSIGMB	527	BCAIIIZIMC	INVGISSIOOD									
24	3	MSEC. CSJNJ	MVDICSZZON	520	BCA11123MC	MVGISSIUMO									
200	9	MSEC.CS3MJ	MVDICSZZMB	529	BCA11123HC	MVG1SS10MD									
203	5	MPUIDDBSOO	HADTHEIBOC	530	BCAIIIZ3MC	MVD1SS1200									
241	5	MPBIDDDSOO	UNG LONI DVN	531	BCA11123MC	MVD1SS12MD									
24	/	MPOIDDESOO	HVDIHUIGMC	532	BCA11123MC	MVDISGIBOC									
241	3	MPBINDUSOO	HVDIMEIUMB	533	DMC211123MC	MVD1SHIAMC									
249	9	MPDI000500	14VD1N#1600	534	BCALLIZ3MC	MADISATEOD									
256	π	MPRIDODSOO	HVD1HØ16HO	535	BCA1112314C	MVDISHIGHO									
25	1	MPBIJJJJJSOO	HVD1HJ16MD	536	ACALLIZ THC	NUDICALAND									
257	2	MPBIDUDSOO	HVD . HOLGMA	537	0001112300	WOI SUI CHA									Parteria
25:	3	MPUIDDDSOO	HVALMEZEMA	530	BCALLIZAMC	HUAL SPIDNA									Curry .
25	1	MPBIDDESOO	NSEC . HARM.	530	DCALLIZINC	MATSEZDMA			(1997) - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997						in a
251	5	MPBLØØØSOO	HSEC. MOZIAJ	5.4.0	DCALLIZ 3MC	MSEC.SSIMJ									14 mar 10
251	5	NPD LOOUSOO	HSEC NOLMI	540	DEATTIZAME	MISEC. SHJMJ									End Land
25	7	MPILLAAASOO	NCEP CECNI	541	BEATTIESME	MSEC. SHZMJ									
251		MPBIDDDSCO	HUD LUGLOOC	542	BCAIIIZIMC	MSEC.SAIMJ									BARRADY. J
. 251	ŝ	MPRINANCOC	HVDINFIOUL	543	BCAIIIZIMC	HSEC.CS7HJ									
201	7	HP01000500	INVOIN6: BMO	544	BCAIIIZIMC	MPULBHOSOO									Mariave
201		HADLAGAROC	MVDIMBIONC	545	BCAILIZIMC	MPBIBBBBSOG									Amazza.
201		MPUIDDDSOG	нуртыятене	546	BCAILIZJHC	MPBIBUBSMG									CLUBIC T
1.20	5	MPUIDUDSOG	MVD1MU1600	547	BCA11123MC	MPB1000SME									inited
200.	3	MPBINDDSOG	MVD1HØ1GNO	548	BCALILIAMC	SORVALVES									
204	1	MPBIDDDSOG	MADIHAIQND	549	BCAIIIIBMC	MVGISSIBOD									(ame)
265	>	MPBINBBSOG	HVDIHØIGMA	550	BCAILLIBMC	MVG1SS10MO									6-22.4
266	3	MPBIODDSOG	MVAIMEZOMA	551	BCAILLIAMC	MVGISSIØMD	1.14								Contral .
267	/	MPBIDØØSOG	MSEC.HØ3MJ	552	BCAIIIIOMC	HVD1SS1200									Call Store
260)	MP3100050G	NSEC.HØ2MJ	553	BCALILIOMC	MV01SS12MD									Silvator IS
265)	MPUIDDDSOG	NSEC. HOIMJ	554	BCALLLIMMC	MVD1S#180C									and the
276	Ţ	MPBIDDBSOG	MSEC.CS6MJ	555	BCALLLINMC	HVDISHIAMC									Man 17 Mag
271		MPB100USHG	HV01M# 00C	556	BCALLLEMC	MVDISHIGOD									La cua
277	2	MPBLUBUSHG	MVDIMØIGNO	557	BCALLLEMAC	MVD1S416MO									C
273	1	MPDIDDDSMG	NVD1M010MC	550	BCALLALEMC	MVD1S016HD									time
271	1	MPBLOODSING	MVD1M010M0	550	BCALLSURIAC	MVD1S416MA									
275	5	MPBIERDSMG	MAD11401600	568.	BCALLLINIAC	AVAICUZUUA									
276		MPRINGOSHC	MVD1M016MD	500.	DCALLLIONC	HAND SUCONA									
277	7	MPRIAMASMC	MVDINGIEND	501	DCATTIONC	MSEC.SSIMJ									
278		MPDIGAGEMC	NVDIMOICHA	. 502	BCATTITAME	MSEC.SUJMJ		÷.,							
. 270		MADICODSHG	NVUINUIGMA	503	BCATTIENC	MSEC.SØZMJ									
200		MI DIDADSHG	MVAIMHZBMA	564	BCAILIEMC	MSEC.SOIMJ									
200	<u>.</u>	MPBIDOUSHG	MSEC.HUJMJ	565	BCAIIIIBMC	MSEC.CS7MJ									
201		MPBIDDDSMG	MSEC.MOZMJ	566	BCAILIBMC	MPBIOOBSOO									
1202		, MPBIDDDSMG	MSEC.MOIMJ	567	BCAIIII8MC	MPB100050G									
• 203		MPBIBBBSMG	MSEC.CS6MJ	560	BCAILIBMC	MPBIBBBBBBG									
1 204		MPBIDODSME	MVDIMØIBOC	569	BCAILIBMC	MPBIØØØSME									
285		MPBIBBBSME	WADIWAIAWO		4.										
A					· · · · · · · · · · · · · · · · · · ·										
						- 141									
14.		a state of the second second		the second second second second											

÷.

APPENDIX C

DRAFT FOR COMMENT

INCOMPLETE TASKS

C1. INTRODUCTION

This appendix contains discussions and results of the tasks pertinent to the San Onofre Nuclear Generating Station Unit 1 (SONGS-1) Auxiliary Feedwater System (AFWS) Project which were incomplete, and had made a significant progress at the time the project was terminated. Section C2 presents the description and results of piping models and the methodology used in response computation. The earthquake occurrence model and the ground motion model are described in Sections C3 and C4, respectively. Section C5 contains the beta-factor of pipe components which relate the fragility of individual piping components to a master pipe component. Finally, the SONGS-1 structural fragility development is briefly outlined in Section C6.

C2. PIPING MODELS

Fourteen dynamic piping models have been generated. The natural frequencies and mode shapes for these fourteen models have been computed by the computer program, SAP4. The pseudostatic mode with multisupport input motion approach was planned for computing the piping responses.

DRAFT FOR GOMMENT

C2.1 PIPING SYSTEM DESCRIPTION

The required piping information on the SONGS Unit 1, AFWS were used to develop the mathematical models for 14 piping systems by the state-of-the-art techniques. Near the completion of the modeling process, some information required for one of the fourteen dynamic piping models (namely, the service water suction lines) was found to be insufficient. Therefore, certain service water piping properties were estimated in order to complete the frequency analysis.

Once the piping models were developed, the pseudostatic-mode method with multisupport input motion will be employed as our analytical method to estimate the piping responses. For a complete description of this analytical method, it is referred to Section 4 of the Volume 6 of the SOMRP Phase I report.¹

The following piping systems were identified as within the system boundary of the auxiliary feedwater system (AFWS) for the response analysis.

- Auxilizry Feedwater and Condensate System: Ten models (Figs. 1 through 10) consisting of suction piping that runs from the condensers and condensate storage tank to the auxiliary feedwater (AFW) pumps and discharge piping from the AFW pump to the steam generators.
- 2. <u>Auxiliary Steam Supply</u>: Two models were generated (Figs. 11 and 12). They are: main steam from the steam generators to the main stop valves and structural anchor of auxiliary steam supply, and the structural anchor to AFW pump turbine. The piping of the main steam was modeled up to and including the first anchor after the downstream check valve.

-134-

19.9



(VEETICAL)

Ser

Figure 1. Auxiliary feedwater piping model piping--SG E-1A to CP-3A.



Z (VERTICAL) (SOUTH)

Figure 2. Auxiliary feedwater piping model--SG E-1B to CP C-3C.

*





Figure 4. Auxiliary feedwater piping model--CP C-3A to IA-1.

-



Z (VERTICAL)



1.8 3

12.2

.



Z (VERTICAL) * (SOUTH)

Figure 6. Auxiliary feedwater piping model--CP C-3B to IA-3.

10 0



Z(VERTICAL) (SOUTH)

Figure 7. Auxiliary feedwater discharge piping model--valve trees between intermediate anchors.



Figure 8. Auxiliary feedwater piping model--IA-1 to AFW pump G-10.
CRAFI FOR COMMENT









CONDENSATE -STORAGE TANK D-2

.

18.0

10.0



Figure 10. Auxiliary feedwater suction piping model.



= (VERTICAL)

(Sout H)

Figure 11. Main steam piping model.

1

78 8



2 (VERTICAL)

< x (SOUTH)

Figure 12. Auxiliary steam supply piping model.

- : * 6 -

3. <u>Service Water and Fire Protection System</u>: The fire protection system is supplied with water from the service water reservoir by two fire pumps. The service water system also serves as a secondary water supply and path to the auxiliary feedwater system. Two models were created for this system (Figs. 13 and 14). They are the suction and discharge of fire water pumps and runs from the fire water pumps to the service water reservoir and two structural anchors. Note that the piping system of Fig. 14 does not terminate at the service water reservoir. It only extends to an assumed intermediate wall anchor, beyond that point no information was pursued at the time the project was terminated.

The assumptions made in the development of piping models are as follows:

- o Piping systems were assumed to be linear elastic.
- Piping supports, including rigid hangers, snubbers, etc. were assumed to be rigid.
- Spring hangers were not included due to their relatively low stiffness compared to the stiffness of other restraints.

The pipe elements of the SAP4 were used to define straight and curved pipes and equipments (if modeled). The boundary elements of SAP4 were used to simulate supports and restraints. The effect of internal pressure on bend flexibility factor was included in the stiffness formulation of the elbow/pipe bend in the SAP4 code.



= (VERTICAL)

< , (SOUT H)

Figure 13. Fire protection discharge piping model.



T (VERTICAL) <, x (SOUT H)

Figure 14. Fire protection suction piping model.

C2.2 TECHNICAL RESULTS

An eigenvalue analysis of the fourteen piping models were completed. Table 1 shows a list of the piping fundamental frequencies. Two piping models require a little more explanation as follows.

1. The main steam piping model (from the steam generators to the main stop valves) has a fundamental frequency of 1.2 Hz. This frequency seems low. However, a more in-depth study showed that this fundamental frequency had occurred at the relief valve manifold where a conglomeration of heavy valves (9 total) are located. By the fact that frequency is inversely proportional to the square root of weight, the calculated fundamental frequency was found to be quite valid.

Livit I FOR COMEN

2. The condensate storage piping model (from the auxiliary feedwater pumps to the condensate storage tank and condensers) contains a section of line which has a fundamental frequency at 1.0 Hz. This is because of the on-line rubber expansion joint (with a relatively low stiffness) is existed in the AFW pumps suction line

In the next stage of analysis, the critical components are selected to compute piping response. The critical piping components are tees, nozzles, elbows/pipe bends, and etc. The responses of these selected components were intended to be computed by SMACS. Selections of these pipe components were completed for all piping models, however, only the component selection data for seven (out of fourteen) models were completed. They are also shown in Table 1.

	91111 · · · ·	Fundamental Frequency	Number of Components	Component Selection Data Completes	
System	Description	(Hz)	Selected		
Auxiliary Steam Supply	 Main steamfrom steam generators to main stop valves, and structural and of auxiliary steam supply. 	1.2	133	No	
	 Structural anchor to AFW pump turbine 	5.6	22	Yes	
Auxiliary Feedwater	3. Steam Generator E-1A to Containment Penetration C	5.5 -3A	8	Yes	
	4. Steam Generator E-1B to Containment Penetration C	12.6 -3A	8	Yes	
	5. Steam Generator E-1C to Containment Penetration C	5.6 -3B	8	No	
	 Containment Penetration C to Intermediate Anchor-1 (Line No. 381A) 	:-3A 7.8	18	Yes	
	 Containment Penetration C to Intermediate Anchor-2 (Line No. 381B) 	C-3C 12.7	18	Yes	
	 Containment Penetration (to Intermediate Anchor-3 (Line No. 381C) 	с-зв 4.8	18	No	
	9. Intermediate Anchors to Intermediate Anchors via the Valve Tree	6.7	76	Yes	
	10. Intermediate Anchors to Turbine Driven AFW Pump	8.5	28	No	
	11. Intermediate Anchors to Motor Driven AFW Pump	6.8	22	No	

Table 1. Pertinent data for the 14 piping models.

System	Description	Fundamental Frequency (Hz)	Number of Components Selected	Component Selection Data Complete	
Condensate Storage	12. AFW Pumps to Condensate Storage Tank D-2, and Condensers to AFW Pump (AFW Pump Suction)	1.0	71	Yes	
Service Water 1 and Fire Protection	13. Fire Water Pumps Discharge	5.3	48	No	
	14. Fire Water Pumps Suction	1.4	24	No	
TOTAL			502		

. .

28.8

1 22 1

Table 1 (Cont.) Pertinent data for the 14 piping models.

LICA: FOR SUMMER

C3. Earthquake Occurrence Model for the SONGS Site

The region of Southern California and Baja California that adjoins the SONGS site is a highly seismic area. For this region, the methodology for constructing the earthquake occurrence model for the site is divided into the following:

- Geometric specifications of local seismic regions. This step is based on the geology and historic seismicity of the region. Sources are identified as line sources (faults) or area sources (zones). The largest earthquake associated with each source is established from the historic seismicity and the state-of-the-art knowledge about the geology and the fault-magnitude relationships.
- Description of past seismicity in terms of earthquake occurrence. The recurrence of earthquakes of various magnitudes is based primarily on the historic seismicity. A straight line or set of straight lines is fitted to the data using regression analysis.

In this manner, the assessment of active faults and maximum credible earthquakes for the Southern California - Northern Baja California region adjoining the SONGS site has been made. The result of this study² is being published. The appended tables and figures² (maps included) of this study summarized the data and the findings of the supplemental fault maps for Southern California and Northern Baja California adjoining the SONGS site. The best estimates of fault slip-rate and recurrence interval estimates for analysis for determining the slope of the earthquake recurrence relationship in the region were also presented.

C3.1 Regional Setting and Data Base

The regional setting of the SONGS site is summarized in a report by Woodward-Clyde Consultants.³ Publications on regional seismic, tectonic, and geologic settings can be found in several reports.^{4,5,6}

Lasti I This aberline.

The faults of this region appear to have branching relations between the transverse ranges and the northern San Andreas fault system on the north and the Salton Trough-Gulf of California region on the south. The transverse range province is characterized by thrust or reverse-slip displacement on east-west faults and right-slip offset on northwest-trending faults. The overall model constructed on these interrelationships is generally consistent with fault slip-rate models based on the papers by Anderson⁶ and Atwater,⁷ and the fault slip-rate data of Woodward-Clyde Consultants.

The Anderson model⁶ is based on the continuity of fault slip transferred northwestward on a branching system of faults that originate in the Gulf of Celifornia. This general model for the strike-slip faults is used for the analysis. The pattern of faults in this region is shown in Plates 1 and 2 of Ref. 2. The plates are compiled from a variety of sources; the main sources are the fault map of California⁸, offshore faults^{9,10} and the geologic maps of Baja California.^{11,12}

C3.2 Date Base

It is essential that credible seismic hazard analysis has an accurate and current seismicity data base. In the probabilistic seismic hazard analysis, the accurate and current data base is even more essential because earthquakes of all sizes contribute to the hazard.

There are several specific ways in which uncertainty or unreliability in the seismic data base will influence the results of a probabilistic seismic hazard analysis. First, and most important, is the uncertainty in the number of unassociated earthquake events that are contained in the host region (that is the source region containing the site in question). It is generally the case that this so-called background seismicity is a major contributor to the seismic hazard. Second, the uncertainty in the location of events, in particular the larger historical earthquakes, drives uncertainty in the seismic zonation of the area and this in turn drives the uncertainty in the proximity of nearby active source regions. Third, whether for host regions or

UNATI FUR COMMENT

18.5

2.26 2

for other source regions, the historical record provides the only quantitative basis for assessing the frequency of large events in any region. At the probabilities relevant to our study $(10^{-3} \text{ to } 10^{-4})$, a credible model for the occurrence of these earthquake events is most significant. In order to develop as consistent and accurate a seismic data base as possible, three individual seismic data bases were integrated into one as shown in Table 2. Emphasis has been given to selected individual bases within the region of southern California and porthwestern Mexico.

Base	Time Coverage	Area Coverage		
Algermissen	Pre-1900 AD	Entire United States		
CDMG*	1900 - 1974	Entire California		
USGS**	1974 - 1981	Southern California		

Note: *CDMG: **USGS: California Division of Mines and Geology, Sacramento, CA. United States Geological Survey and California Institute of Technology, Seismological Laboratory, Pasadena, CA.

Table 2. Seismic data bases for the region surrounding the SONGS site.

C3.3 Seismicity and Focal Mechanisms

The regional seismicity provided by the available seismic maps of the Southern California - Baja California regions defines some of the major fault zones. The main continuous or semi-continuous zones include the San Andreas fault system from the Salton Trough northward, most of the San Jacinto fault, and the southern portion of the Elsinore fault zone. The instrumental seismicity record is too brief to confirm many of the major structures defined by the geologic data.

DRAFT FOR COMMENT

The focal mechanism and geodetic data for Southern California and Northern Baja California are generally consistent with the seismotectonic models of Refs. 2, 3, and 6. Most of the focal mechanisms indicate a north-south orientation for the compression azis, which is consistent with current models for North American and Pacific plate interactions. These data are also compatible with geodetic data for the region.

Aftershock data and the focal mechanism for the main earthquake of the 1933 Long Beach event show a right-slip displacement for a 30 km segment of the Newport-Inglewood section of the Offshore Zone of Deformation (OZD). The section of the OZD south of the 1933 Long Beach earthquake epicenter has been characterized by only minor, scattered historic earthquake activity, although one local zone of activity was recorded in late 1981.

C3.4 Random, "Detection Level", or "Floating" Earthquakes

In seismic or weakly seismic regions, the background earthquake activity includes infrequent events that may not be associated with known surface or subsurface faults. These earthquakes are commonly referred to as "floating earthquakes" and appear to occur in random locations or patterns that do not coincide with apparent faults. The epicentral region is commonly oval in shape and the aftershocks do not follow an elongate or planar distribution. These earthquakes have been referred to as "detection level" earthquakes. The maximum magnitude for this type of earthquake in the eastern and central United States is about 5.75 to 6 for the historic record. The earthquake data¹³ compiled by Liu and Kanemori show intraplate earthquakes within many stable parts of the North American plate, in the Atlantic Ocean, and in intraplate settings in other parts of the world. The data show most larger earthquakes of these intraplate settings to have a range in magnitude of 5.8 to 6.4. Accordingly, this range in magnitude appears to be a very conservative estimate for scattered, pon-predictable earthquakes in the Southern California region.

POART FOR COMMENT

C3.4 Determination of Active Faults and Maximum Earthquakes

The evaluation of active faults within the Southern California and Northern Baja California region is at once a problem of detecting, delineating, and defining the character of potential seismogenic faults and assessing their maximum earthquakes. No component of the above three D's (detection, delineation, or definition) is complete for the region surrounding the SONGS site. On the basis of the literature search and the application of the state-of-the-art knowledge about the geology and tectonics of the region, the zones of seismogenic areas associated with active faults and fault zones were established. For the region surrounding the SONGS site, the most probable seismic hazard was determined that it comes from earthquake activities associated with the Offshore Zone of Deformation (OZD).

The determination of maximum credible earthquakes for fault zones can be made either by qualitative or quantitative methods.²

Qualitative methods², ³, ¹⁴ were suggested for estimating the maximum credible earthquake for capable fault zones:

- Maximum Historic Earthquake Method: This method is for non-representative earthquake, or short earthquake histories.
- Fault Rupture Length Method: This method is for areas with poor-to-fair field data for total rupture length during paleoseismic earthquakes.
- Total Displacement Method: This method is for total amount of fault displacement during the present seismotectonic regime.

 <u>Degree of Deformation Method</u>: This method is for assessing the size or degree of deformation along a fault zone in geologically young materials.

Quantitative measures of fault activity that can provide an estimate of maximum credible earthquakes for a fault include:

- Maximum Historic Earthquake Method: This method is for faults with a sufficiently long historic record that the maximum credible earthquake has occurred.
- Total Fault Length Method: Empirical data for strike-slip faults indicate that this method provides an indication of maximum credible earthquakes for strike-slip faults.
- Fault Segment, or Fractional Rupture Length Method: This method is applicable where there is good structural, stratigraphic and geomorphic data for definition of rupture elements.
- 4. Fault Movement Magnitude with Fractional Rupture Length Method: This method is combined use of moment magnitude with fractional fault rupture length application.

C3.6 <u>Summary: Maximum earthquake magnitude</u>, fault slip-rate, and recurrence interval

In this subsection, Table 3 summarized the estimated fault slip-rate and recurrence interval estimates for computer analysis for determining b-values and to provide a basis for comparison between geologic and seismologic information on earthquake frequency, maximum earthquake values and recurrence intervals between large earthquakes. Table 3. Estimated maximum earthquake magnitude, fault slip rate and recurrence interval for zones and faults of the southern California - Baja California region. Superscripts indicate the following references: a. Woodward-Clyde Consultants (1979 and 1980); b. Anderson (1979); c. Slemmons and others, in this report; and d. Shieh (1978).

	ZONE OR FAULT	MAX. M	AGNITUDE (M	4s)	FAULT	SLIP RATE	S	RECURRENC	E INTERVAL	IN YEARS
NU.	ZONE ON THOSE	Low, Nax. Historic	Preferred Est.	Hlgh	Low P	referred Est.	Hlgh	Shortest	Preferred Est.	Longest
			0.0.0	9.°C	aha .	378	41 ^a	160 ^d	160 ^d	357 ^c
10	Central San Andreas f.	z. 8.25	0125	0.5 7.5b	1.0	250	253	10 ^c	21°	115 ^c
15*	Southern San Andreas f	.z. 6.5°	6.9	1.5	15	25	2.5			
2	Transverse Ranges Regl	on		 b				ra ^C	98 ^C	344C
3	San Jacinto f.z.	7.1ª	'7.1°	7.5	5	8-	15	52	21.2C	25.200
5	Whitler-Elsinor f.z.	6.0=	7.1 ^c	8.00	1.8	2.3	2.3	40-	342	2333
5	Slerra Juarez-San Pedr		. 7 ^c	7.5 ^c						
	nartii 1.2.									
6	Coast Kanges Frovince									
7	Offshore Zone of Deformation: includ Newport-Inglewoodw to Rose Canyon f.z.	ing f.z. 6.3 ^a	7.0 ^c	7.5 ^b	0.4 ^a	0.5 ^a	0.7 ^c	235 ^c	1294 ^c	4300 ^c
8	Northwestern Baja California Region	6.8 ^a	6.8 ^c	7.0 ^c						
9	Palos Verdes-Coronado Banks f.z.		7.0 ^c	7.5 ^b	0.5 ^c	1.0 ^c	1.5 ^c	431°	647 ^c	3440°
10	San Pedro-San Diego Trough-Coronado		6.9 ^c	7.5 ^c	0.5 ^c	1.0 ^c	1.5°	355 ^c	532 ^c	3440°
	Escarpment f.z.	4. TT 62				c	, .c	431C	647 ^c	9141°
11	San Clemente f.z.		7.00	8.0°	0.5	1.0 b	2.50	3330	431C	2285 ^c
12	Agua Blanca f.z.	`	7.3	8.05	2.0	2.1	3.5	332		
13	Southern San Clemente Maximos-San Isidro	f.z	7.0 ^c	7.5 ^c	2.0 ^c	2.7 ^c	3.5°	185 ^c	240 ^C pecial facto	860 ^c
ŵ	Geologic observation influence this fau	s Indicates It zone.	the recurre	ence in	tervals	to be mu				

aliter a

BUTTEL BUT

.

1. Sources of Data for Table 3

The primary sources of data are the Woodward-Clyde Consultants report,³ their response in Southern California Edison Company's response to NRC Question 361.45¹⁴, including Tables 361.45-2 and 3, and Anderson's results.⁶

CATIFAL COMMENT

Earthquake Magnitude estimates are for the lowest, generally based on the maximum historic earthquake. The preferred or selected value, is generally based on Plates 1 and 2, the U.S. Nuclear Regulatory Commission's Safety Evaluation Report for San Onofre¹⁵, in NUREG-07-12), or the maximum historic earthquake for cases where it is assumed that the maximum historic magnitude approximates the maximum credible event (for the Central San Andreas fault zone and the San Jacinto fault zone).

The fault slip-rates are based on Woodward-Clyde Consultants³ and Anderson.⁶ The field observations of Sieh¹⁶ are used for fault slip-rate and earthquake recurrence estimates for the Central San Andreas fault zone.

2. Results

The estimation of earthquake recurrence interval is obtained by use of the extreme magnitudes listed under the columns of "MAX. MAGNITUDE (M_S) " and the extreme values under the columns of "FAULI SLIP RATES" for the longest and shortest estimated recurrence intervals between maximum earthquakes. The preferred or selected estimate uses the preferred estimates of these two parts of the table.

The method of estimation of the recurrence interval is obtained by use of the new fault relationships of Slemmons and $\operatorname{Chung}^{17}$ of the logarithm of maximum fault displacement, log D = A + B (M_S), where D is in meters and A = 5.831 and B = 0.849. The maximum displacement is converted to average fault displacement, to obtain the earthquake recurrence interval for a given section of a fault, by the empirical relation that the average displacement is approximately 50 percent of the maximum. No adjustment is made for the fractional length that is involved in the above estimates. Accordingly, the above estimates may be too high by factors of two to four times.

C4.1 General Form of the Model

The object of grour' motion model development is to generate a model of prediction of the maximum peak acceleration which could occur at the SONGS site.

The methodology for developing seismic hazard curves is already well established. Consequently, this imposes the general form of our ground motion model, and by using the now well accepted combination of theoretical considerations and actual earthquake data the ground motion model is finalized.

Following Joyner, et al.¹⁸ and Joyner and Boore¹⁹ we choose the general form of the acceleration to be:

$$y = \frac{k}{r} e^{-qr}$$
(1)

GRAFT FOR COMME

where k is a function of the magnitude M; q is a constant; and r is a measure of the distance from the recording station to some significant point : * associated with the source. Eq. (1) corresponds to a single point-source geometric spreading with constant - Q anelastic attenuation. Although the rupture surface is not a point source, it is very likely that the maximum peak acceleration can be associated with the rupture of a limited area of the rupture surface, thus the assumption of a point source. Most of the data from earthquakes is at distances greater than 10 km from the fault zone and for magnitudes less than 7. However, as discussed in the section on development of the earthquake occurrence model, the SONGS site is located very close to a major fault zone. This introduces general complications into ground motion modeling. Firstly, good estimates are required for the ground motion very close to the fault zone where there is little data. Secondly, estimates for the ground motion from earthquakes significantly larger than magnitude 7 are also required. Finally, at larger magnitudes (around 7 to 8) various magnitude scales tend to saturate. The scope of work for the SONGS-1 AFWS Project was towards addressing these issues.

-161-

In order to improve upon the Joyner - Boore¹⁹ model in the near-field, weighting schemes were introduced and alternative measures of distance were explored. Hopefully, alternative weighting schemes would also lead to an improved capability to predict the ground motion for large magnitude events.

wasti i road building h

C4.2 The Data

The most complete and representative set of data available at the time of the study was presented in Joyner, et al.¹⁸ This set of data was used, but it was also recognized in limitations with respect to the intended use of the ground motion model. This expansion of the data set has been almost completed at the time the project was stopped. Thus, what follows is only for the Joyner, et. al.¹⁸ data set.

Basically, the data were taken from Ref. 20. The sources for the more recent data include Porter²¹, Procella²², Procella, et al.²³, Brady, et al.²⁴ and Boore and Procella.²⁵

The main limitation in this set of data resides in the fact that the maximum value of both horizontal components was selected as the data point for each recording. This is not current practice in the engineering profession, and it is not realistic since the actual direction of the maximum peak occurs in a random direction. The net effect of this choice (of the maximum component) is a conservative ground motion model. Campbell²⁶ examined this question for a similar data set and found that when only the maximum component was used, it lead to results that were 13 percent higher on the average than when both components were used.

Another limitation appears, especially among the recent data, when one realizes that some of the data were provided by stations close to the faults. As the stations come closer and closer to the fault, the problem of defining the distance, r, of Eq. (1) becomes more and more difficult. Ideally, one would work with the distance to the point on the rupture that contributes the maximum peak motion, but it would be difficult to determine the location of that point for most earthquakes and practically impossible for past earthquakes. Furthermore, it is not sure that the maximum peak is created by

167.

the rupture of a single zone. Joyner, et al.¹⁸ used the closest distance to the surface projection of the fault rupture as the horizontal component of the station distance, and the vertical component is an empirical value which is determined by a minimization process.

beard readerments

(3)

Another undesirable aspect of this data set is the uneven (non-uniform) distribution of the data points in the sample space. This is a general characteristic of all earthquake catalogs and has been the reason for many different approaches by researchers. Joyner and Boore¹⁹, Campbell²⁶, Askins and Cornell.²⁷ A list of the data set used in our analysis is available in Joyner, et al.¹⁷

C4.3 Fit of the Ground Motion Model to the Data

Several forms of the general form Eq. 1 were actually studied, but in all cases the type of material (Soil vs. Rock) was neglected as an independent variable since Joyner, et al.¹⁷ have concluded that the ground quality was insignificant.

The regressions performed in the following analyses were all linear regression with independent identically distributed (i.i.d.) residuals.

The various equations considered for the regressions were as follows:

$$\log a = b_1 + b_2 M + b_2 \log r + b_1 R$$
(2)

 $\log a = b_1 + b_2M + b_3 \log r$

where:

M has been successively taken as the moment magnitude and the local magnitude.

- r has been successively taken as the distance defined above by Joyner, et al. 1981, and the distance to the center of energy, whenever it was possible to do so.
- b₃ has been set to -1 in a series of calculations, as per Eq.
 (1), and set free in others.

Two types of regressions-analyses were performed. In the first type, the method developed by Joyner, et al.¹⁸, was exactly duplicated. This method

-167

(4)

consists of a series of two successive regressions. In the first regression, the quantity $(b_1 + b_2M)$ is lumped into a single value, c_i , constant for each earthquake. That is all data points associated with the i-th earthquake have a constant, γ_i , to be determined in the first regression. In the second regression the equation: $b_1 + b_2M$ is fitted to the set of c's as per Eq. (4).

 $c = b_1 + b_2 M$

In their study, Joyner, et al.¹⁸, had first considered a quadratic equation for Eq. (4) but finally concluded that the second degree term in M was insignificant and discarded it. The net result is to actually decouple magnitude from distance. This technique has the effect of weighting equally each earthquake with respect to the determination of the magnitude dependence.

In the second type of regressions, a single regression was performed with several types of weighting to try to alleviate on the one hand, the lack of data in some regions of the sample space, the abundance of it in others, and the paucity of data points associated with some earthquake as opposed to the large number for others (for example, Daly City 1957 vs San Fernando, 1971)... In the case of the "earthquake weighting," the weight was simply the inverse of the number of records for a particular earthquake. For the "Distance weighting," the distance axis was divided into four adjacent bands: 0-20 km, 20-100 km, 100-200 km, and greater than 200 km. The weight associated to a data point, a_i , whose distance was in the j-th band (j = 1,2,3,4) was the inverse of the total number of data points whose distance fell into that same band.

Both earthquake and/or distance weighting were analyzed. In the analyses that were performed here with the Joyner, et al.¹⁸ technique, the earthquakes to which only one data point was associated were eliminated, as in the case of the Joyner,¹⁸ study. This then obliged us to perform regression with this same truncated set in the second type of analysis also. Thus, two analyses were performed with the single regression analysis: one with the single record earthquake, and one without.

All the results of these analyses are presented in Tables 4, 5 and 6. They are shown below.

LHARI FUN GUMMENI

Eq	b1	b2	53	b4	σ1	σ2	٥
LOLM			1	Noment Mag			
2	-1.02	.249	-1	00255	.222	.134	.259
2	95	.258	-1.096	00209	.222	.134	.259
3	56	.231	-1.322	0	.228	.122	.258
				Local Mag			
2	-1.48	.336	-1	00299	.216	.142	.259
2	-1.43	.343	-1.075	00261	.217	.142	.259
3	85	.288	-1.340	0	.226	.125	.258

Distance to Center of Energy

Eq form	b1	b2	p3	t4	1	2	
			Мо	ment Mag			
2	-1.02	.251	-1.	00246	.228	.144	.270
2	97	.259	-1.078	00209	.228	.144	.270
3	59	.236	-1.316	0	.234	.138	.272

- σ1 is the standard deviation of the residuals due to the first regression
- O2 is the standard deviation of the residuals due to the second regression.

o is the standard deviation of the residuals after both regressions combined.

The regressions were performed with two alternative definitions of magnitude (i.e., Moment magnitude and local magnitude) and two definitions of distances (i.e., Closest Distance and Distance to Center of Energy).

Table 4. Results for Joyner, et al. - Method Analyses Closest Distance.

Lauri I Fur LLanden

Weighting	w	Distance	^b 1	b2	b3	
64	w/u					
W1	W	Closest	-1.82	.462	-1.37	000899
W1	W	En. Center	-1.88	.477	-1.39	000947
W1	W/O	Closest	-1.69	.427	-1.29	00122
W1	W/O	En. Center	-1.75	.448	-1.33	0012
W2	W	Closest	-1.68	.437	-1.38	000889
W2	W	En. Center	-1.82	.469	-1.39	00103
W2	W/O	Closest	-1.58	.371	-1.11	00193
W2	W/O	En. Center	-1.73	.406	-1.13	00204
W3	W	Closest	-1.24	.327	-1.19	00116
W3	w	En. Center	-1.46	.393	-1.29	00124
W3	w/0	Closest	-1.18	.313	-1.17	00125
W3	W/O	En. Center	-1.41	.381	-1.26	00133

Eq. fitted Log $a = b_1 + b_2M + b_3 \log R + b_4R$

Key: W1 = weighting by No. Recds in R band and No. Recds in R band for each Eq. W2 = No. of Recds in R band and No. of Recds in Eq. W3 = No. of Recds in the R band.

W = with the single-record earthquakes

W/O = single-record earthquakes are discarded.

Table 5. Results for the Single Regression Analyses.

GEAFT FOR COMMENT

Eq Form	W W/O	Distance	b1	b2	23	b4	
2	W	Closest	-1.13	.271	-1	00207	.246
2	W	Closest	-1.05	.271	-1.071	00166	.247
2	W/O	Closes:	-1.01	.253	-1.004	00191	.230
2	W	En. Center	-1.45	.357	-1.104	00213	.254
3	W	Closest	72	.251	-1.27	0	.251
3	W	En. Center	-1.07	.342	-1.37	0	.261

For definition of symbols see Table 3.

Table 6. Results for the single regression analyses, without weighting and with Local Magnitude.

C5. BETA-FACTORS FOR PIPE COMPONENTS

Table 7 through 18 contain load scale factors (beta-factors) for use in relating the fragility of individual piping components to the fragility of the master (reference) piping component. A 5 in. schedule 160 carbon-steel butt weld pipe joint represents the master component. The load scale factors are defined as:

EDAFT FOR COMMENT

beta = Capacity of reference pipe component Capacity of pipe component under consideration

The fragility of the master pipe component is represented by a cumulative distribution function of percent probability of failure as a function of resultant moment capacity with log-normal parameters:

median = 2.03 x 10^5 ft-lbs β = .42 PIPING LOAD SCALE (BETA) FACTORS SCHEDULE 10 CARBON STEEL

1+10

(F) 500	451.1430 256.1220 156.98067 156.98067 19.5577 19.5577 19.5577 19.5577 19.5577 19.5577 19.5577 19.5577 19.5577 19.5577 19.5577 19.55777 19.55777 19.55777 19.55777 19.55777 19.55777 19.55777 19.55777 19.55777 19.557777 19.5577777777777777777777777777777777777
STRAIGHT EMPERATURE 300	429, 7986 122, 2729 132, 2729 152, 2729 152, 2729 152, 2729 152, 2729 152, 2729 152, 2729 160, 26140 00, 26140 00, 26140 00, 26140 00, 26140 00, 26140
1001	358 203.050 203.050 223.06445 223.06445 223.06792 223.0596 0.05355 0.055555 0.0555555 0.055555 0.0555555 0.0555555 0.0555555 0.0555555 0.0555555 0.0555555 0.05555555 0.0555555 0.0555555 0.0555555 0.05555555 0.05555555 0.055555555
(F) 500	773 8500 4553 4933 866 4343 245 4933 245 4933 245 4933 2444 25 7594 1477 25 7594 1477 25 7594 1455 0 1455 0 1455
ELDOW MPERATURE 300	7002.2400 385.2460 772.15594 185.7579 185.7579 19594 22.94932 22.94932 22.94932 22.94932 22.94932 22.94932 22.94932 22.94932 22.94932 22.94932 22.94932 22.94932 22.94932 23.7494 23.7494 23.7494 23.7494 23.7494 23.7494 23.7494 23.7494 23.7494 23.7494 23.7494 23.7494 23.7494 23.7494 23.7494 24.7497 24.74977 24.749777 24.7497777777777777777777777777777777777
100	20555 204 6050 204 6050 204 6050 204 6050 204 6050 20505 20505 20505 20505 20505 109200 55055 109200 55055 109200 55055 109200 10900 55055 10900 55055 10900 55055 100000 55055 100000 55055 100000 55055 100000 55055 100000 55055 100000000
(F) 500	2552 2552 2552 2552 2552 2552 2552 255
BUTT WELD MPERATURE 300	2017 2289 2017 2289 2017 2289 2017 2289 2018 229 2018 228 2018 2018 2018 2018 2018 2018 2018 2018 2018 2018 2018 2018 2018
100 TE	5777 520 520 520 520 5000 520 600 10 520 5000 5272 00 5272 00 5272 00 5272 00 5272 00 5272 00 5272 00 5272 00 5272 00 5272 00 5272 00 5272 00 50 50 50 50 50 50 50 50 50 50 50 50
NOMI NAL	00000000000000000000000000000000000000

FACTORS

BETA) STEEL

SCALE (CARBON

E 40

PLPING

-

Table

TEMPERATURE TEMPERATURE 300 300 1281.35800 1285.35900 1285.35900 1285.35900 1285.35900 1285.35900 1285.35900 12891 0.86391 0.02190 0.02190 0.02390 0.02430 0.02243 0.02243 100 20030 20030 20030 81782 81785 81785 81785 81785 81785 81785 81785 81785 81785 81785 81785 81 N----0000---000007000 0000--00000700 4 FELATURE 7407 74 1001 0000000-00000000 500 E 0 000 30000 30000 30000 30000 100000 100000 100000 10000 100000 100000 10000000 1000000 1 ā.

DRAFT FOR COMMENT

FACTORS

(BETA)

SCALE (CARBON

E 60

CHEDULI

0.0

o

Tohlo

200	00000000000000000000000000000000000000
(F)	82
TRAIGHT TPERATURE	2555.8725 151.2168 16.5226 16.5266 16.5266 16.5266 16.5266 16.5266 16.5266 16.5276 17.5276 17.5276 17.5276 17.5276 17.5276 17.5276 17.5276 17.5276 17.5276 17.5276 17.5276 17.5276 17.5276 17.5276 17.5276 17.5776 17.
TEI 100	213.1250 136.6957 157.2227 157.2223 167.2223 167.2223 167.2223 167.2223 167.2223 167.2223 167.2223 167.223 167.223 167.2323 177.2323 177.2
(F) 500	2152 2122 2132 2132 2132 2132 2132 2132
RPERATURE 300	418.0000 2558.4758 161.60371 77.72953 16.73595 25795 00.25555 00.25555 00.25555 00.25555 00.25555 00.25555 00.25555 00.25555 00.25555 00.25555 00.25555 00.25555 00.25555 00.25555 00.25555 00.2555555 00.255555 00.255555 00.255555 00.255555 00.255555 00.255555 00.255555 00.255555 00.255555 00.255555 00.255555 00.255555 00.255555 00.2555555 00.255555 00.255555 00.255555 00.255555 00.255555 00.255555555 00.2555555 00.255555 00.25555555555
100	2396 4584 246 17320 256 7320 257570 2517 2570 25813 25833 25813 25813 25833 25813 25833 25813 25833 25813 25833 25813 25833 25813 25833 25813 25833 25833 25813 25833 25833 25833 25833 25833 25833 25833 25833 25833 25833 25833 25833 25833 25833 258533 2583 258
(F) 500	233 1250 233 1250 233 2455 233 2455 233 2455 233 2455 233 2455 265555 265555 265555 265555 265555 265555 265555 2655555 2655555 2655555 2655555555
BUTT WELD	2406.0834 244.1513 240.0290 259.0296 2.02962 2.02962 0.02952 0.02956 0.02956 0.02956 0.02956 0.02958 0.00000000000000000000000000000000000
100 TEI	2243 7500 22243 7500 2343 75770 255 75770 255 75770 255 75770 255 75770 255 75770 255 75770 255 75770 255 75770 255 659 250 8793 250 8793 200 8794 200 8794
NOMINAL	00-00400000000000000000000000000000000

-

SCHEDULE 00 CARDON STEEL

" In In.

(F) 500	134, 5659	14.6592	1.0273	0.15556	0.0430
MPERATURE	136.7404	6.0624	1.0439	0.2386	0.0437
100 TE	123.6079	12.6313	0.8944	0.1427 0.0958	0.00305
(F) 500	429,9166 282,2672 191,6395	17.9549	2.9041	0.5542 0.3887 0.3887	0.0245
EMPERATURE 300	233.7282 233.7282	33.3090	2.4149	0.6994	0.0666
100	370.0278 214.0662	29.1289	4.7456	0.5267	0.02020
(F) 500	217.0462	23.6439 9.6229	4.2034	0.25099	0.0694
BUTT WELD MPERATURE	379.0111	23.6439	4.2034	0.25099	0.0694
100 TEI	320.8334	20.3731	3.5010	0.1545	0.0388
DI AM (IN)	0.5	- 200	2000	0000	18.0 20.00 24.0

PIPING LOAD SCALE (BETA) FACTORS SCHEDULE 120 CARBON STEEL

7661011

	1555 1555
	STRAIGHT TEMPERATURE 100 100 100 100 100 100 100 100 120 100 120 100 120 10 100 120 10 100 10
PIPING LOAD SCALE (BETA) FACTORS SCHEDULE 160 CARBON STEEL	TEMPERATURE (F) TEMPERATURE (F) 100 100 100 100 100 100 100 10
11-110 D.	TEMPERATURE (F) TEMPERATURE (F) TEMPER
	NDMINAL 01.51 00.55 00.55 00.55 00.55 160.00

.

(F) -000--00 -00000--000--00 -000000--000--00 (F) TEMPERATURE 912.0000 912.0000 912.0000 912.0000 912.0000 933.7265 703798 10.0000 1723 0.1723 0.1723 0.1723 0.1723 0.1723 0.1723 000--V08400--000 000--V08400--000 000--V086-00-000 0000-000-00000--000000 (F)

AM (1N) AM (1N

(F) 500 372.7215 173.7215 173.7215 173.7215 173.6499 155.66729 25.57482 1.72482 25.57482 0.57192 0.57192 0.55348 0.0372 0.0372 0.0372
2441GHT 365.4400 2445 153.8301 153.8301 153.8301 153.8301 152.1924 25.1924 1.12214 0.21924 0.21928 0.1193 0.03155
239.0000 239.0000 239.0000 239.0000 239.0000 239.000 240.00 240
(F) 500 550 550 5500 5500 5500 5000 5000
MPERATURE 300 500.00000 500.00000 521.14108 40.35334 177000 65.70000 65.70000 65.70000 65.70000 1770000 65.70000 66.729000 1770000 66.729000 67.720000 67.729000 67.729000 72.729000 72.729000 72.729000 72.729000 72.729000 72.729000 72.729000 72.729000 72.729000 72.729000 72.7290000 72.7290000000000000000000000000000000000
2550.0000 2988.16026 2988.16026 2799.16026 22.722000 122.50000 122.50000 122.50000 122.50000 122.50000 122.50000 122.50000 122.50000 0.50062 0.5007 0
(F) 500 600 -000 600 4000 600 4000 600 4000 12 0000 12 0000 11 1000 22 00000 12 1100 00 5700 00 2514 00 2514 00 0600
BUTT WELD MPERATURE 300 560,4185 21,9600 34600 0,94600 0,46506 0,46506 0,46506 0,46506 0,46506 0,46506 0,1893
100 100 100 100 100 100 100 100 100 100
DI AN UNAL NOMINAL NOMINAL 1000000000000000000000000000000000000

(BETA) FACTORS ESS STEEL

μZ SCALI

E 40

PIPING L

1

9 9

Tat

PIPING LOAD SCALE (BETA) FACTORS SCHEDULE 60 STAINLESS STEEL	(F) 500 375,5769 2375,5769 12,7076 12,7076 12,7076 12,3393 12,7076 12,116 0,35685 0,53022 0,15588 0,15788 0,057888 0,05788 0,05788 0,05788 0,057888 0,05788 0,05788 0,05788 0,0578888888 0,0578888 0,05788888888 0,0578888888888 0,05788888888888888888888888888888888888
	MFERATURE MFERATURE 357.8077 2508.6622 120.52455 10.52455 10.52455 0.0238 0.0238 0.0238
	200 2007 200 100 100 100 100 100 100 100 100 100
	F) 500 644.2308 4307.2325 307.2325 307.2325 51834 51.1700 55.16334 55.16344 55.16344 55.16334 55.16344 55.16344 55.16344 55.16344 55.16344 55.16344 55.16344 55.16344 55.1645 55.26444 55.264444 55.2644444444444444444444444444444444444
	PERATURE 584.6154 3566.6634 3566.6634 267.93661 20.93661 24.9428 10.99428 10.99428 10.99428 10.99428 10.99428 10.99428 10.99428 10.2485 0.24856 0.14422 0.14421 0.0487
	7554 5554 5356 5326, 55972 5326, 55972 5326, 55972 532696 1977599 1977599 1977599 1977599 1977599 1977599 1977599 1977599 19775 1975
e 15.	
Taul	(F) 500 2005 2005 2005 2005 2005 2005 2005
	MPERATURE 300 201 2009 201 2009 16 7056 16 7056 16 7056 15 7056 0 3524 0 3524 0 3524 0 3524 0 3524 0 3524 0 3524 0 35275 0 352755 0 35275 0 35775 0 37775 0 37775 0 0 37775 0 00000000000000000000000000000000
	100 100 100 100 100 100 100 100
	DI AM (11N) 0.3 0.3 0.0 0.3 0.0 0.3 0.0 0.3 0.0 0.3 0.0 0.3 0.0 0.3 0.0 0.0

SCALE (BETA) FACTORS STAINLESS STEEL E 10 PIPING I 2 Tuble

ACTORS

TFI

EF. STRAIGHT TEMPERATURE 302:25000 196:38800 196:38800 24:1720 24:1720 0.1205 00.1205 00.1205 00.1205 00.1205 00.1205 00.04843 211 00000-40-000000 00000-40-000000 L) 22.25571 20.2566229 20.2566229 20.256571 20.05278 20.256571 20.05278 20.05778 20.057778 20.057778 20.0 N040-000-000000 EMPER ANOUND-0000000 -000-000000-0000000 (F) NOON 00 0000000-00000000 -0007-1 NIN 00-004000040004 AMC 5:

0000000-500 NOO L 000000-000000 500 2000 2 F TEMPERATURE 0 22222 22222 22222 22222 22225 22225 22225 22225 22225 22225 22225 22225 22225 22225 22225 22225 2225 2225 2225 2225 2225 2225 2225 2225 2225 2225 2225 2225 2225 2255 25555 25555 25555 25555 25555 25555 25555 25555 25555 25555 25555 4%-INAL 00000000000000000 NOM I A0000400000000040004 õ

A) FACTORS STEEL

× s

NLESS

SCALE STAIN

E 120

CHEDULI

20

17

5

141

1

	(F) 500 325,5000 202,0124 125,0733 125,0733 125,0733 125,0733 125,0733 125,0733 125,0733 0,01242 0,01242 0,01242 0,0124
	TRAIGHT MPERATURE 302.4000 17.01000 17.01000 17.01000 17800 0.1780 0.1197 0.0197 0.0197 0.0120
	248.0000 55.7211 55.322000 154.0741 55.32200 1.08100 1.24600 0.02480 0.0112 0.0112 0.0112
FACTORS	0:0400-0-0000000000
NLESS ST	P 000000000000000000000000000000000000
E 160 STAL	MP ELBOW 492 25900000 25900000 27770000 27770000 27770000 277700000 277700000000
PIPING 1	760 2480 2260 2260 220000 2322 00 23220 00 23220 00 23220 00 23220 00 23220 00 23220 00 23220 00 23220 00 23220 00 23220 00 23220 00 00 23220 00 00 00 00 00 00 00 00 00 00 00 00
Table 18	500 525: 8254 500 522: 8254 202: 20000 502: 8254 20: 95050 00: 2555 00: 25555 00: 2555 00: 2555 00: 2555 00: 2555 00: 25
	MPERATURE 300 2554.00000 2554.00000 277.00000 4.57000 4.57000 4.57000 1.9593 1.9593 0.0190 0.0190
	154.30695 3.10000 3.10000 1.240.0000 3.10000 1.136 0.01135 0.01135 0.01412 0.01412
	DI AM MON MON MON MON MON MON MON MON MON MON
1	

.

TEEL FACTORS (BETA) ESS STE UZ Z SCAL E 80 I P I NG 0.0 ~0 hir

2

C6. STRUCTURAL FRAGILITIES

The evaluation of the potential seismic failure modes of a system as complex as those at the SONGS Unit 1 involves consideration of a great many items such as strengths and building response characteristics. In most cases, values of many of the parameters affecting structural seismic capacity levels are not known exactly and substantial dispersion may exist. This dispersion can result from sources of inherent randomness and from uncertainty concerning the values of the sources. Randomness is considered to represent those sources of dispersion which cannot be reduced by additional analysis or more data. Uncertainty can be considered to be the result of lack of knowledge of such parameters as material properties, as well as approximations in analytical modeling.

Structural fragilities are defined by estimated median seismic capacities and their variabilities due to randomness and uncertainty. The median capacities and variabilities account for structural strength and inelastic energy absorption capabilities. Estimation of these quantities is dependent to a significant degree of engineering judgement as well as available test data. To determine the earthquake level at which structural failure occurs, structural capacity is compared to estimates of seismic response which account for damping, modal combination, earthquake directional components, and soil-structue interaction. Structural strength and ductility are assumed to be lognormally distributed since this distribution seems to provide a good representation of the sources of structural variability. The lognormal distribution is also mathematically convenient for definging fragility curves. SONGS-1 structures included in the fragilities evaluation are: reactor

building, containment sphere, sphere enclosure building, control-administration building, diesel generator building, turbine-generator pedestal, north turbine extension, west feedwater heater platform, and the fuel storage building. Structural failure is defined as occurring when inelastic seismic structural deformations are of sufficient magnitude to potentially interfere with the operability of attached equipment. These deformation limits correspond to the onset of significant structural damage. Potential failure modes were identified for each of the SONGS-1 structures

177-

WART FUR COMMENT

included in this study by establishing the seismic load-paths and comparing expected load distributions to available capacities for the elements of each load-path. Particular attention was given to possible weak links and details. The more likely failure modes were screened for more detailed investigation.

Determination of median capacities for fragility curve formulation is dependent on estimates of structural response due to seismic excitation. Final results from the SONGS-1 structure model analyses were not yet available at the time the project was stopped. These analytical results were to provide the correlation between earthquake input and structural failure. Median structure strengths and variabilities for the identified failure modes were only partially completed at the time the project was stopped. These median strengths account for median material properties estimated from actual plant-specific test data where available or by comparison to other data bases. Predictive models derived from actual test data were used whenever possible to estimate median element strengths. These models eliminate design conservatism normally associated with building code requirements. Reference 28 provides more details. REFERENCES

 L. C. Shieh, T. Y. Chuang, and W. J. O'Connell, <u>Seismic Safety Margins</u> <u>Research Program, Phase I Final Report-Subsystem Response (Project V)</u>, Lawrence Livermore National Laboratory report UCRL-53021, Vol. 6., NUREG/CR-2015, Vol. 6., Livermore, CA (July 1981).

GRAFT FOR COMMENT

- D. B. Slemmons, P. Omalley, R. A. Whitney, D. H. Chung, and D. L. Bernreuter, <u>Assessment of Active Faults for Maximum Credible Earthquakes</u> of the Southern California - Northern Baja Region, Lawrence Livermore National Report UCID-19125, Livermore, CA (1982).
- Woodward-Clyde Consultants, "Report of the Evaluation of Maximum Earthquake and Site Ground Motion Parameters Associated with the Offshore Zone of Deformation, San Onofre Nuclear Generating Station," as amended in response to U.S. NRC Question 361.55 (June 1979).
- Abbott and Elliott, editors, Earthquakes and Other Perils of the San Diego Region (1979).
- Growell and Sylvester, editors, <u>Tectonics of the Juncture between the San</u> <u>Andreas Fault System and the Salton Trough, Southeastern California</u>, (1979).
- Anderson, J. G., "Estimating the Seismicity from Geological Structure for Seismic-Risk Studies," <u>Seismological Society of America Bulletin</u>, b. 69, p. 135-158 (1979).
- Atwater, Tanya, "Implications of Plate Tectonics for the Cenozoic Tectonic Evolution of Western North America," <u>Geological Society of America</u> Bulletin, v. 81, p. 3513-3536 (1970).

3 7 8

 Jennings, C. W., "Fault Map of California with Locations of Volcanoes Thermal Springs, and Thermal Wells," California Division of Mines and Geology Data Map Series Map No. 1, scale 1:750,000 (1975).

LEANT FOR CREMTNY

- 9. Legg, M. R., and Kennedy, M. P., "Faulting Offshore San Diego and Northern Baja California," in <u>Earthquakes and Other Perils of the San</u> <u>Diego Region</u>, Abbott, P. L., and Elliot, W. J., eds., San Diego Association of Geologists for the Geological Society of America, Field Trip Guidebook, p. 29-46, (1979).
- 10. Green, H. G., Bailey, K. A., Clarke, S. H., Ziony, J. I., and Kennedy, R. P., "Faulting Offshore San Diego and Northern Baja California," in <u>Earthquakes and Other Perils of the San Diego Region</u>, Abbott, P. L., and Elliot, W. J., eds., San Diego Association of Geologists for the Geological Society of America, Field Trip Guidebook, p. 21-28 (1979).
- 11. Gastile, R. G., Phillips, R. P., and Allison, E. C., "Reconnaissance Geology of the State of Baja California," <u>Geological Society of America</u> Memoir 140, p. 170 with maps (1975).
- 12. Gastile, R. G., Kies, R., and Melius, D. J., "Active and Potentially Active Faults, San Diego County and Northwesternmost Baja California," in <u>Earthquakes and Other Perils of the San Diego Region</u>, Abbott, P. L., and Elliott, W. J., eds., San Diego Association of Geologists for the Geological Society of America, Field Trip Guidebook, p. 47-60 (1979).
- 13. Liu, H. L., and Kanamori, H., "Determination of Source Parameters of Mid-Plate Earthquakes from the Waveforms of Body Waves," <u>Seismological</u> Society of America Bulletin, v. 70, p. 1989-2004 (1980).
- 14. Southern California Edison Company, "Response to US NRC Questions 361.37 through 361.68: San Onofre Nuclear Generating Station Units 2 and 3," (1980).

-176-

- 15. U.S. Nuclear Regulatory Commission, <u>Safety Evaluation Report for San</u> Onofre, NUREG-07-12 (1980).
- 16. Sieh, K. E., "Slip along the San Andreas Fault Associated with the Great 1857 Earthquake," <u>Seismological Society of America Bulletin</u>, v. <u>68</u>, p. 1421-1448 (1978).

LAF FRA CAME

- 17. D. B. Slemmons and D. H. Chung, <u>Maximum Credible Earthquake Magnitudes</u> for the Calaveras and Hayward Fault Zones, California, Lawrence Livermore National Laboratory Report UCRL-86219 (1982), to be published in Earthquake Hazards in the East Bay Area (in press).
- 18. Joyner, W. B., Boore, D. M., Procella, R. L., (1981), Peak Horizontal Acceleration and Velocity from Strong-Motion Records Including Records from the 1979 Imperial Valley, California Earthquake. USGS Open-file Report 81-365, March 1981.
- 19. Joyner, W. B. and Boore, D. M. (1981), Peak Horizontal Acceleration and Velocity from Strong Motion Records Including Records from the 1979 Imperial Valley, California, Earthquake, BSSA 71, pp. 2011-2018.
- 20. Hudson, Strong Motion Earthquakes, Vol. I, CIT.
- 21. Porter, L. D. (1978). Compliation of strong-motion records recovered from the Santa Barbara earthquake of August 13, 1978, California Div. Mines and Geol. Prelim. Report 22, p. 43.
- 22. Procella, R. L., ed. (1979). Seismic Engineering Program Report, U.S. Geol. Surv. Circular 818-A, p. 20.
- Procella, R. L., Matthiesen, R. B., McJunkin, R. D., and Ragsdale, J. T., (1979). Compilation of strong motion records from the August 6, 1979
 Coyote Lake earthquake, U.S. Geol. Surv. Open-File Report 79-385, p. 71.

- 24. Brady, A. G., Mork, P. N., Perez, V., and Porter, L. D., (1980). Processed data from the Gilroy array and Coyote Creek records, Coyote Lake, California earthquake August 6, 1979, U.S. Geol. Surv. Open-File Report 81-42, p. 171
- 25. Boore, D. M., and Procella, R. L., (1981). Peak horizontal ground motions from the 1979 Imperial Valley earthquake: comparison with data from previous earthquakes, in The Imperial Valley, California earthquake of October 15, 1979, U.S. Geol. Surv. Prof. Paper, in press.
- Campbell, K. W., (1981). Near-source attenuation of peak horizontal acceleration, Bull. Seism. Soc. Am., v. 71, pp. 2039-2070.
- 27. Askins, R. C. and Cornell, A. C., (1979). SHA-based Attenuation Model Parameter Estimation Proceedings, US National Eathquake Engineering Conference, Stanford, CA, August 1979.
- 28. D. A. Wesley and P. S. Hashimoto, <u>Seismic Structural Fragility</u> <u>Investigation for the San Onofre Nuclear Generating Station</u>, <u>Unit 1</u>, Seismic Safety Margins Research Program, Livermore, CA, UCRL-in print, (1982)