

Donald C. Shelton
Vice President - Nuclear
Davis-Besse

300 Madison Avenue
Toledo, OH 43652-0001
(419) 249-2300

Docket Number 50-346

License Number NPF-3

Serial Number 1843

March 18, 1991

United States Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Subject: License Amendment Application to Revise Technical Specifications
3.0.3 and 3.0.5, Limiting Conditions For Operation - Applicability

Gentlemen:

Enclosed is an application for an amendment to the Davis-Besse Nuclear Power Station (DBNPS) Unit Number 1 Operating License Number NPF-3, Appendix A, Technical Specifications. The proposed changes involve Technical Specifications (TS) 3.0.3 and 3.0.5, Limiting Conditions for Operation - Applicability.

The proposed changes affect TS 3.0.3 and 3.0.5 by revising the allowable time interval for achieving Hot Standby (Mode 3). Specifically, a change is proposed to Technical Specification 3.0.3 to increase the time interval allowed for reaching Hot Standby from six hours to seven hours once TS 3.0.3 has been entered. A minor editorial correction is also proposed to this Technical Specification. Corresponding changes have been proposed to Technical Specification Bases 3.0.3. A similar change is proposed to Technical Specification 3.0.5 to increase the time interval from six hours to eight hours allowed for reaching Hot Standby once Technical Specification 3.0.5 has been entered.

These proposed Technical Specification changes are based on the guidance provided by the Standard Technical Specifications for Babcock and Wilcox Pressurized Water Reactors, NUREG-0103, Revision 4, and are consistent with model Technical Specification 3.0.3 provided in Generic Letter 87-09, Sections 3.0 and 4.0 of the Standard Technical Specification (STS) on the Applicability of Limiting Conditions for Operating and Surveillance Requirements, dated June 4, 1987 (Toledo Edison letter Log Number 2326). The proposed changes to Bases 3.0.3 are similar to the wording in the Westinghouse Standard Technical Specifications, NUREG-0452, Revision 4.

9103210006 910318
PDR ADQCK 05000346
P PDR

Operating Companies
Cleveland Electric Illuminating
Toledo Edison


200017

ADD 11

Docket Number 50-346
License Number NPF-3
Serial Number 1848
Page 2

Toledo Edison requests that the Nuclear Regulatory Commission Staff issue this amendment by October 15, 1991. If you have any questions regarding this application, please contact Mr. R. W. Schrauder, Manager - Nuclear Licensing, at (419) 249-2366.

Very truly yours,



KAS/mmb

Enclosure

cc: P. M. Byron, DB-1 NRC Senior Resident Inspector
A. B. Davis, Regional Administrator, NRC Region III
D. C. Di Ianni, DB-1 NRC Senior Project Manager
General J. Williams, Chief of Staff, Ohio Adjutant General's Office
State of Ohio
Utility Radiological Safety Board