

DALE ROGERS, MANAGER, REACTOR OP  
PE BOX 89  
COLLEGE STA. TX 77843

Western Union Mailgram



4-0494775354 12/20/82 ICS IPBRNGZ CSP FTWC  
7138457551 MGM TDRN COLLEGE STATION TX 187 12-20 0348P EST

MR BILL CROSSMAN  
OFFICE OF INSPECTIONS & ENFORCEMENT  
REGION 4, US NUCLEAR REGULATORY COMMISSION 611  
RYAN PLAZA, SUITE 1000  
ARLINGTON TX 76012

50-59

REF: REACTOR OPERATION IN EXCESS OF LICENSE POWER LEVEL OF 1 MEGAWATT  
A POWER CALORIMETRIC PERFORMED 12-4-82 FOLLOWING A CORE CHANGE  
INDICATED THAT THE REACTOR POWER WAS 30 PERCENT LOW. SINCE THE DATA  
APPEARED TO BE CORRECT AND ALL PROCEDURES WERE FOLLOWED, THE  
DETECTORS WERE ADJUSTED. A SUBSEQUENT CALORIMETRIC PERFORMED ON  
12-10-82 INDICATED THAT ACTUAL POWER BASED ON POOL HEATUP WAS IN  
EXCESS OF INDICATED POWER, AND TO VERIFY THIS A SERIES OF  
CALORIMETRICS WERE PERFORMED ON 12-13-82 AND 12-16-82. BASED ON THE  
RESULTS OBTAINED IT WAS DECIDED ON 12-16-82 THAT THE NSCR COULD  
POSSIBLY HAVE OPERATED IN EXCESS OF ITS LICENSE POWER BY  
APPROXIMATELY 35 PERCENT. NRC REGION 4 WAS CONTACTED BY PHONE ON  
12-16-82 TO DISCUSS THE SITUATION FURTHER. CALLS OF IMPROPER  
CALORIMETRIC DATA ON 12-4-82 IS THOUGHT TO BE WITH THE THERMOCOUPLE  
MEASURING INSTRUMENT. THIS, HOWEVER, HAS NOT YET BEEN CONFIRMED.  
REPORT TO FOLLOW.

DALE ROGERS, MANAGER, REACTOR OPERATIONS, NUCLEAR SCIENCE CTR,  
TEXAS A&M UNIVERSITY  
PE BOX 89  
COLLEGE STA. TX 77843

1550 EST

MGMCMR MGM

12831

8301250328 821220  
PDR ADOCK 05000059  
S PDR

TO REPLY BY MAILGRAM MESSAGE, PHONE WESTERN UNION ANYTIME, DAY OR NIGHT:

FOR YOUR LOCAL NUMBER, SEE THE WHITE PAGES

OF YOUR LOCAL TELEPHONE DIRECTORY

OR

DIAL (TOLL-FREE) 800-257-2241

(EXCEPT IN NEW JERSEY 800-632-2271)

OR DIAL WESTERN UNION'S COMPUTER DIRECTLY:

FROM TELEX I ..... 6161 FROM TELEX II (TWX®) ..... 910-420-1212