

Docket File



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001
April 21, 1994

Docket Nos. 50-277, 50-278, 50-352,
and 50-353

Mr. George A. Hunger, Jr.,
Director-Licensing, MC 52A-5
PECO Energy Company
Nuclear Group Headquarters
Correspondence Control Desk
P.O. Box No. 195
Wayne, Pennsylvania 19087-0195

Dear Mr. Hunger:

SUBJECT: GENERIC LETTER 92-01, REVISION 1, "REACTOR VESSEL STRUCTURAL INTEGRITY," PEACH BOTTOM ATOMIC POWER STATION (PBAPS), UNITS 2 AND 3, AND LIMERICK GENERATING STATION (LGS), UNITS 1 AND 2 (TAC NOs. M83495, M83496, M83477, AND M83478)

By letters dated July 10, 1992, November 16, 1992, July 28, 1993, and November 29, 1993, PECO Energy Company (PECO) responded to Generic Letter (GL) 92-01, Revision 1. The GL is part of the staff's program to evaluate reactor vessel integrity for Pressurized Water Reactors (PWRs) and Boiling Water Reactors (BWRs). The information provided in response to the GL, along with previously docketed information, is being used to confirm that licensees satisfy the requirements and commitments necessary to ensure reactor vessel integrity for their facilities. The staff has determined that you have provided the information requested in the GL. However, in order to close out this issue, the staff is performing plant-specific followup efforts as discussed below.

A substantial amount of information was provided to the staff in response to the GL. This information has been entered into a data base designated as the Reactor Vessel Integrity Database (RVID). The RVID contains the following tables: A pressurized thermal shock (PTS) table for PWRs, a pressure-temperature limit table for BWRs and an upper-shelf energy (USE) table for PWRs and BWRs. Enclosure 1 provides your facilities' pressure temperature tables, Enclosure 2 provides your facilities' USE tables, and Enclosure 3 provides a key for the nomenclature used in the tables. The tables include the data necessary to perform USE, pressure-temperature limit, and RT_{pts} evaluations. This information was taken from PECO's responses to the GL and previously docketed information. References to the specific source of the data are provided in the tables.

Regarding PBAPS, Unit 2, and LGS, Units 1 and 2, our review has identified an open issue for each plant. The initial RT_{NDT} values determined by General Electric's (GE) initial methodology have not been validated and the BWR Owners Group report, GE-NE-523-109-0893, "Basis for GE RT_{NDT} Estimation Method," did not resolve the issue. GE is in the process of validating its methodology for resolving the initial RT_{NDT} determination issue and will document the results

9405040314 940421
PDR ADDCK 05000277
P PDR

020028

NRG FILE CENTER COPY

DF01

in a topical report. The BWR Owners Group is obtaining approval from its members to provide the GE topical report to the NRC staff for review and approval. We request that you submit, within 30 days of receipt of this letter, a commitment to the BWR Owners Group effort or a schedule for a plant-specific analysis to resolve this issue. Further, we request that you provide confirmation of the plant-specific applicability of the topical report, NEDO-32205, Revision 1, (as specified in Appendix B of that report) and submit a request for approval of the topical report as the basis for demonstrating compliance with 10 CFR Part 50, Appendix G, Paragraph IV.A.1. Additionally, we request you review the enclosures and verify that the information you have provided for your facilities has been accurately entered in our data base. If no comments are made in your response to the last request, the staff will use the information in the tables for future NRC assessments of your reactor pressure vessel.

Once you have (1) confirmed the applicability of the topical report, NEDO-32205, Revision 1, to your plants, (2) submitted the request for approval, and (3) provided your commitment to the BWR Owners Group effort or a satisfactory schedule for providing a plant-specific analysis, the staff will consider your actions (for the above plants) related to the GL to be complete. Plant-specific licensing actions will be initiated to resolve these issues.

For PBAPS, Unit 3, we request that, within 30 days of receipt of this letter, you provide confirmation of the plant-specific applicability of the topical report, NEDO-32205, Revision 1, (as specified in Appendix B of that report) and submit a request for approval of the topical report as the basis for demonstrating compliance with 10 CFR Part 50, Appendix G, Paragraph IV.A.1. This review will be a plant-specific licensing action. We further request that you review the enclosures and verify that the information you have provided for your facility has been accurately entered in our data base. If no comments are made in your response to the last request, the staff will use the information in the tables for future NRC assessments of your reactor pressure vessel. Once your confirmation of the topical report applicability and request for approval are received, the staff will consider your actions (for PBAPS, Unit 3) related to the GL to be complete.

The information requested by this letter is within the scope of the overall burden estimated in the GL. The estimated average number of burden hours is 200 person hours for each addressee's response. This estimate pertains only to the identified response-related matters and does not include the time

Mr. George A. Hunger, Jr.

- 3 -

April 21, 1994

required to implement actions required by the regulations. This action is covered by the Office of Management and Budget Clearance Number 3150-0011, which expires June 30, 1994.

Sincerely,

Sincerely,

Original signed by:

Frank Rinaldi, Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Original signed by:

Stephen Dembek, Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. Pressure-Temperature Limit Tables
2. Upper-Shelf Energy Tables
3. Nomenclature Key

cc w/enclosures:
See next page

DISTRIBUTION:

Docket File
NRC & Local PDRs
PDI-2 Rdg.
SVarga
JCalvo
CMiller
MO'Brien
SDembek
FRinaldi
DMcDonald
SSheng
OGC
ACRS(10)
EWenzinger, RI
CAnderson, RI

OFFICE	LA:PDI-2	PM:PDI-2	D:PDI-2	PM:PDI-2	
NAME	MO'BRIEN	SDEMBEK:tlc	CMILLER	FRINALDI	
DATE	4/13/94	4/18/94	4/12/94	4/19/94	1/1

OFFICIAL RECORD COPY
FILENAME: A:\PB83495.LTR


Mr. George A. Hunger, Jr.

- 3 -

April 21, 1994


required to implement actions required by the regulations. This action is covered by the Office of Management and Budget Clearance Number 3150-0011, which expires June 30, 1994.

Sincerely,



Frank Rinaldi, Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Sincerely,



Stephen Dembek, Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. Pressure-Temperature Limit Tables
2. Upper-Shelf Energy Tables
3. Nomenclature Key

cc w/enclosures:
See next page

Mr. George A. Hunger, Jr.
PECO Energy Company

Peach Bottom Atomic Power Station,
Units 2 and 3
Limerick Generating Station,
Units 1 and 2

cc:

J. W. Durham, Sr., Esquire
Sr. V.P. & General Counsel
PECO Energy Company
2301 Market Street, S26-1
Philadelphia, Pennsylvania 19101

Mr. Rich R. Janati, Chief
Division of Nuclear Safety
Pennsylvania Department of
Environmental Resources
P.O. Box 8469
Harrisburg, Pennsylvania 17105-8469

PECO Energy Company
ATTN: Mr. G. R. Rainey, Vice President
Peach Bottom Atomic Power Station
Route 1, Box 208
Delta, Pennsylvania 17314

Board of Supervisors
Peach Bottom Township
R. D. #1
Delta, Pennsylvania 17314

PECO Energy Company
ATTN: Regulatory Engineer, A1-2S
Peach Bottom Atomic Power Station
Route 1, Box 208
Delta, Pennsylvania 17314

Public Service Commission of Maryland
Engineering Division
Chief Engineer
6 St. Paul Centre
Baltimore, MD 21202-6806

Resident Inspector
U.S. Nuclear Regulatory Commission
Peach Bottom Atomic Power Station
P.O. Box 399
Delta, Pennsylvania 17314

Mr. Richard McLean
Power Plant and Environmental
Review Division
Department of Natural Resources
B-3, Tawes State Office Building
Annapolis, Maryland 21401

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Mr. Rod Krich, 52A-5
PECO Energy Company
955 Chesterbrook Boulevard
Wayne, Pennsylvania 19087-5691

Mr. Roland Fletcher
Department of Environment
201 West Preston Street
Baltimore, Maryland 21201

Mr. David R. Helwig, Vice President
Limerick Generating Station
P.O. Box A
Sanatoga, Pennsylvania 19464

Carl D. Schaefer
External Operations - Nuclear
Delmarva Power & Light Company
P.O. Box 231
Wilmington, DE 19899

Mr. Robert Boyce
Plant Manager
Limerick Generating Station
P.O. Box A
Sanatoga, Pennsylvania 19464

Mr. George A. Hunger, Jr.
PECO Energy Company

Peach Bottom Atomic Power Station,
Units 2 and 3
Limerick Generating Station,
Units 1 and 2

Mr. Craig L. Adams
Superintendent - Services
Limerick Generating Station
P. O. Box A
Sanatoga, Pennsylvania 19464

Mr. Neil S. Perry
Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 596
Pottstown, PA 19464

Mr. James L. Kantner
Regulatory Engineer
Limerick Generating Station
P. O. Box A
Sanatoga, Pennsylvania 19464

Library
U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

Mr. Larry Hopkins
Superintendent-Operations
Limerick Generating Station
P. O. Box A
Sanatoga, Pennsylvania 19464

Mr. John Doering, Chairman
Nuclear Review Board
PECO Energy Company
955 Chesterbrook Boulevard
Mail Code 63C-5
Wayne, Pennsylvania 19087

Mr. James A. Muntz
Superintendent - Technical
Limerick Generating Station
P.O. Box A
Sanatoga, Pennsylvania 19464

Summary File for Pressure-Temperature Limits

Plant Name	Beltline Ident.	Heat No. Ident.	ID Neut. Fluence at EOL/EFPY	IRT _{max}	Method of Determin. IRT _{max}	Chemistry Factor	Method of Determin. CF	%Cu	%Ni
Limerick 1 EOL: 10/26/2024	Shell Course #1, 14-1	C7688-1	1.73E18	10°F ¹	Plant specific	81.2	Table	0.12	0.51
	Shell Course #1 14-2	C7698-2	1.73E18	10°F ¹	Plant specific	72.8	Table	0.11	0.48
	Shell Course #1 14-3	C7688-2	1.73E18	10°F ¹	Plant specific	81.2	Table	0.12	0.51
	Shell Course #2 17-1	C7689-1	1.73E18	10°F ¹	Plant specific	72.8	Table	0.11	0.48
	Shell Course #2 17-2	C7677-1	1.73E18	20°F ¹	Plant specific	73	Table	0.11	0.50
	Shell Course #2 17-3/	C7698-1	1.73E18	10°F ¹	Plant specific	72.8	Table	0.11	0.48
	Axial Welds	662A746	1.73E18	-20°F ¹	Plant specific	41	Table	0.03	0.88
	Axial Welds	1P421B	1.73E18	-50°F ¹	Plant specific	82	Table	0.06	0.89
		07L857/ B101A27A	1.73E18	-6°F ¹	Plant specific	41	Table	0.03	0.97
		09N057/ C109A27A	1.73E18	-32°F ¹	Plant specific	41	Table	0.03	0.89
	Circ. Weld	640892/ J424B27AE	1.73E18	-60°F ¹	Plant specific	122	Table	0.09	1.00
	Circ. Weld	5P6756	1.73E18	-60°F ¹	Plant specific	108	Table	0.08	0.96

Reference for Limerick 1

Plate Cu, P, Ni; IRT, and fluence data are from Table 5.3-5 of FSAR enclosed in November 11, 1992 letter (Supplemental response to GL 92-01, Rev. 1) to NRC. Weld Cu and P, and IRT data are from the same table.

¹Additional information required to confirm value.

Summary File for Pressure-Temperature Limits

Plant Name	Beltline Ident.	Heat No. Ident.	ID Neut. Fluence at EOL/EPY	IRT _{min}	Method of Determin. IRT _{min}	Chemistry Factor	Method of Determin. CF	XCu	XNi
Limerick 2 EOL: 10/26/2024	Shell Course #1 14-1	B3312-1	1.73E18	10°F ¹	Plant specific	90.4	Table	0.13	0.58
	Shell Course #1 14-2	B3416-1	1.73E18	40°F ¹	Plant specific	101.25	Table	0.14	0.65
	Shell Course #1 14-3	C9621-2	1.73E18	22°F ¹	Plant specific	110	Table	0.15	0.60
	Shell Course #2 17-1	C9569-2	1.73E18	10°F ¹	Plant specific	73.1	Table	0.11	0.51
	Shell Course #2 17-2	C9526-1	1.73E18	10°F ¹	Plant specific	73.6	Table	0.11	0.56
	Shell Course #2 17-3	C9526-2	1.73E18	10°F ¹	Plant specific	73.6	Table	0.11	0.56
	Axial Welds	432A2671/ H019A27A	1.73E18	-12°F ¹	Plant specific	54	Table	0.04	1.08
	Axial Welds	661A746/ H013A27A	1.73E18	-20°F ¹	Plant specific	41	Table	0.03	0.88
	Circ. Weld	07L857/ B101A27A	1.73E18	-6°F ¹	Plant specific	41	Table	0.03	0.97
	Circ. Weld	09M057/ C109A27A	1.73E18	-32°F ¹	Plant specific	41	Table	0.03	0.89
	Circ. Weld	03M014/ C118A27A	1.73E18	-34°F ¹	Plant specific	20	Table	0.01	0.94
	Circ. Weld	640892/ J424B27AE	1.73E18	-60°F ¹	Plant specific	122	Table	0.09	1.00

Reference for Limerick 2

Cu, Ni, and P; fluence, and IRT data are from Table 5.3-5 of the FSAR enclosed in November 11, 1992 letter (Supplemental response to GL 92-01, Rev. 1) to NRC.

¹Additional information required to confirm value.

Summary File for Pressure-Temperature Limits

Plant Name	Beltline Ident.	Heat No. Ident.	ID Wout. Fluence at EOL/EPY	IRT _{min}	Method of Determin. IRT _{min}	Chemistry Factor	Method of Determin. CF	XCu	XNI
Peach Bottom 2 EOL: 1/31/2008	Lower Shell	C2791-2	8.0E17	-8°F ¹	Plant specific	81.4	Table	0.12	0.52
	Lower Shell	C2761-1	8.0E17	-14°F ¹	Plant specific	73.4	Table	0.11	0.54
	Lower Shell	C2873-2	8.0E17	-20°F	Plant specific	82.4	Table	0.12	0.57
	Lower Int. Shell	C2894-2	8.0E17	-20°F	Plant specific	85.6	Table	0.13	0.42
	Lower Int. Shell	C2873-1	8.0E17	-6°F ¹	Plant specific	82.4	Table	0.12	0.57
	Lower Int. Shell	C2761-2	8.0E17	-20°F	Plant specific	73.4	Table	0.11	0.54
	Axial Welds	37C065	8.0E17	-45°F	generic	109.25	Table	0.21	0.21
	Circ. Weld	8-3986	8.0E17	-32°F ¹	Plant specific	82	Table	0.06	0.97

Reference for Peach Bottom 2

Fluence, chemical composition, and IRT data are from July 10, 1992, letter from G. J. Beck (PECO) to USNRC Document Control Desk, subject: Response to Generic Letter 92-01, Revision 1, "Reactor Vessel Structural Integrity, 10 CFR 50.54(f)"

¹Additional information required to confirm value.

Summary File for Pressure-Temperature Limits

Plant Name	Beltline Ident.	Heat No. Ident.	ID Neut. Fluence at EOL/EFY	IRT _{min}	Method of Determin. IRT _{min}	Chemistry Factor	Method of Determin. CF	%Cu	%Ni
Peach Bottom 3 EOL: 1/31/2008	Lower Shell 6-146-1	C4689-2	7.2E17	-10°F	Plant specific	82.2	Table	0.12	0.56
	Lower Shell 6-146-3	C4684-2	7.2E17	-20°F	Plant specific	90.4	Table	0.13	0.58
	Lower Shell 6-146-7	C4627-1	7.2E17	-20°F	Plant specific	82.4	Table	0.12	0.57
	Lower Int. Shell 6-139-10	C2773-2	7.2E17	10°F	Plant specific	103.95	Table	0.15	0.49
	Lower Int. Shell 6-139-11	C2775-1	7.2E17	10°F	Plant specific	86.8	Table	0.13	0.46
	Lower Int. Shell 6-139-12	C3103-1	7.2E17	10°F	Plant-specific	100	Table	0.14	0.60
	Int. Shell 6-146-5	C4608-1	7.2E17	10°F	Plant specific	82	Table	0.12	0.55
	Int. Shell 6-146-6	C4689-1	7.2E17	10°F	Plant specific	82.2	Table	0.12	0.56
	Int. Shell 6-146-2	C4654-1	7.2E17	10°F	Plant specific	73.5	Table	0.11	0.55
	Lower to Lower Int. Shell Circ. Weld (DE)	3P4000	7.2E17	-50°F	Plant specific	27	Table	0.02	0.96
	Int. to Lower Int. Shell Circ. Weld (EF)	1P4217	7.2E17	-50°F	Plant specific	147.2	Table	0.11	0.96
	Axial Welds D1/3, E1/3, F1/3	37C065	7.2E17	-45°F	generic	109.25	Table	0.21	0.21

Reference for Peach Bottom 3

Fluence, chemical composition, and IRT data are from July 10, 1992, letter from G. J. Beck (PECo) to USNRC Document Control Desk, subject: Response to Generic Letter 92-01, Revision 1, "Reactor Vessel Structural Integrity, 10 CFR 50.54(f)"

Summary File for Upper Shelf Energy

Plant Name	Beltline Ident.	Weld No.	Material Type	1/4T USE at EOL/EFY	1/4T Neutron Fluence at EOL/EFY	Unirrad. USE	Method of Determin. Unirrad. USE
Limerick 1 EOL: 10/26/2024	Shell Course #1, 14-1	C7688-1	A 5338-1	EMA ²	1.2E18	EMA ²	---
	Shell Course #1 14-2	C7698-2	A 5338-1	EMA ²	1.2E18	EMA ²	---
	Shell Course #1 14-3	C7689-2	A 5338-1	EMA ²	1.2E18	EMA ²	---
	Shell Course #2 17-1	C7689-1	A 5338-1	EMA ²	1.2E18	EMA ²	---
	Shell Course #2 17-2	C7677-1	A 5338-1	EMA ²	1.2E18	EMA ²	---
	Shell Course #2 17-3/	C7698-1	A 5338-1	EMA ²	1.2E18	EMA ²	---
	Axial Welds	662A746	Flux type unknown, SMAW	EMA ²	1.2E18	EMA ²	---
	Axial Welds	1P4218	Linde 124, SAW	EMA ²	1.2E18	EMA ²	---
	Circ. Weld	07L857/ 8101A27A	Flux and weld type unknown	EMA ²	1.2E18	EMA ²	---
	Circ. Weld	09W057/ C109A27A	Flux and weld type unknown	EMA ²	1.2E18	EMA ²	---
	Circ. Weld	640892/ J424827AE	Flux and weld type unknown	EMA ²	1.2E18	EMA ²	---
	Circ. Weld	5P6756	Flux and weld type unknown	EMA ²	1.2E18	EMA ²	---
	<u>Reference for Limerick 1</u>						
Plate Cu, P, Ni; W/SE; and fluence data are from Table 5.3-5 of FSAR enclosed in November 11, 1992 letter to NRC (Supplemental to GL 92-01 response). Weld Cu and P, and IRT data are from the same table.							

²Licensee must confirm applicability of Topical Report NEDO-32205, Rev. 1

Summary File for Upper Shelf Energy

Plant Name	Belitline Ident.	Heat No.	Material Type	1/4T USE at EOL/EPY	1/4T Neutron Fluence at EOL/EPY	Unirrad. USE	Method of Determin. Unirrad. USE
Limerick 2 EOL: 10/26/2024	Shell Course #1 14-1	B3312-1	A 5338-1	EMA ²	1.2E18	EMA ²	---
	Shell Course #1 14-2	B3416-1	A 5338-1	EMA ²	1.2E18	EMA ²	---
	Shell Course #1 14-3	C9621-2	A 5338-1	EMA ²	1.2E18	EMA ²	---
	Shell Course #2 17-1	C9569-2	A 5338-1	EMA ²	1.2E18	EMA ²	---
	Shell Course #2 17-2	C9526-1	A 5338-1	EMA ²	1.2E18	EMA ²	---
	Shell Course #2 17-3	C9526-2	A 5338-1	EMA ²	1.2E18	EMA ²	---
	Axial Welds	432A2671/ N019A27A	SMAW	EMA ²	1.2E18	EMA ²	---
	Axial Welds	661A746/ N013A27A	SMAW	EMA ²	1.2E18	EMA ²	---
	Circ. Weld	07L857/ B101A27A	SMAW	EMA ²	1.2E18	EMA ²	---
	Circ. Weld	09N057/ C109A27A	SMAW	EMA ²	1.2E18	EMA ²	---
	Circ. Weld	03N014/ C118A27A	SMAW	EMA ²	1.2E18	EMA ²	---
	Circ. Weld	640892/ J424B27AE	SMAW	EMA ²	1.2E18	EMA ²	---
	<p><u>Reference for Limerick 2</u></p> <p>Cu, Ni, and P; fluence, and UUSE data are from Table 5.3-5 of the FSAR enclosed in November 11, 1992 letter to NRC (Supplemental to GL 92-01 response).</p>						

²Licensee must confirm applicability of Topical Report NEDO-32205, Rev. 1

Summary File for Upper Shelf Energy

Plant Name	Beltline Ident.	Heat No.	Material Type	1/4T USE at EOL/EFY	1/4T Neutron Fluence at EOL/EFY	Unirrad. USE	Method of Determin. Unirrad. USE
Peach Bottom 2 EOL: 1/31/2008	Lower Shell	C2791-2	A 302B Mod.	EMA ²	5.5E17	EMA ²	---
	Lower Shell	C2761-1	A 302B Mod.	EMA ²	5.5E17	EMA ²	---
	Lower Shell	C2873-2	A 302B Mod.	EMA ²	5.5E17	EMA ²	---
	Lower Int. Shell	C2894-2	A 302B Mod.	EMA ²	5.5E17	EMA ²	---
	Lower Int. Shell	C2873-1	A 302B Mod.	EMA ²	5.5E17	EMA ²	---
	Lower Int. Shell	C2761-2	A 302B Mod.	74	5.5E17	82	65%
	Axial Welds	37C065	Flux type unknown, SAW	EMA ²	5.5E17	EMA ²	---
	Circ. Weld	S-3986	Linde 124, SAW	EMA ²	5.5E17	EMA ²	---

Reference for Peach Bottom 2

Fluence, chemical composition, and UUSE data are from July 10, 1992, letter from G. J. Beck (PECo) to USNRC Document Control Desk, subject: Response to Generic Letter 92-01, Revision 1, "Reactor Vessel Structural Integrity, 10 CFR 50.54(f)"

PR_EDB has no UUSE or IUSE for both the surveillance plate and weld

²Licensee must confirm applicability of Topical Report NEDO-32205, Rev. 1

Summary File for Upper Shelf Energy

Plant Name	Seitline Ident.	Heat No.	Material Type	1/4T USE at EOL/EPY	1/4T Neutron Fluence at EOL/EPY	Unirrad. USE	Method of Determin. Unirrad. USE
Peach Bottom 3 EOL: 1/31/2008	Lower Shell 6-146-1	C4689-2	A 302B Mod.	EMA ^a	5.0E17	EMA ^a	---
	Lower Shell 6-146-3	C4684-2	A 302B Mod.	EMA ^a	5.0E17	EMA ^a	---
	Lower Shell 6-146-7	C4627-1	A 302B Mod.	EMA ^a	5.0E17	EMA ^a	---
	Lower Int. Shell 6-139-10	C2773-2	A 302B Mod.	EMA ^a	5.0E17	EMA ^a	---
	Lower Int. Shell 6-139-11	C2775-1	A 302B Mod.	EMA ^a	5.0E17	EMA ^a	---
	Lower Int. Shell 6-139-12	C3103-1	A 302B Mod.	79	5.0E17	89	65%
	Int. Shell 6-146-5	C4608-1	A 302B Mod.	EMA ^a	5.0E17	EMA ^a	---
	Int. Shell 6-146-4	C4689-1	A 302B Mod.	EMA ^a	5.0E17	EMA ^a	---
	Int. Shell 6-146-1	C4654-1	A 302B Mod.	EMA ^a	5.0E17	EMA ^a	---
	Lower to Lower Int. Shell Circ. Weld (DE)	3P4000	Linde 124, SAW	88	5.0E17	97	10°F data
	Int. to Lower Int. Shell Circ. Weld (EF)	1P4217	Linde 124, SAW	62	5.0E17	71	10°F data
	Axial Welds D1/3, E1/3, F1/3	37C065	Flux unknown, SAW	82	5.0E17	99	Direct

Reference for Peach Bottom 3

Fluence, chemical composition, and LUSE data are from July 10, 1992, letter from G. J. Beck (PECo) to USMRC Document Control Desk, subject: Response to Generic Letter 92-01, Revision 1, "Reactor Vessel Structural Integrity, 10 CFR 50.54(f)"

²Licensee must confirm applicability of Topical Report NEDO-32205, Rev. 1

PRESSURE-TEMPERATURE LIMIT TABLES AND USE TABLES FOR ALL BWR PLANTSNOMENCLATURE

Pressure-Temperature Limits Table

- Column 1: Plant name and date of expiration of license.
 Column 2: Beltline material location identification.
 Column 3: Beltline material heat number; for some welds that a single-wire or tandem-wire process has been reported, (S) indicates single wire was used in the SAW process, (T) indicates tandem wire was used in the SAW process.
 Column 4: End-of-life (EOL) neutron fluence at vessel inner wall; cited directly from inner diameter (ID) value or calculated by using Regulatory Guide (RG) 1.99, Revision 2 neutron fluence attenuation methodology from the quarter thickness (T/4) value reported in the latest submittal (GL 92-01, PTS, or P/T limits submittals).
 Column 5: Unirradiated reference temperature.
 Column 6: Method of determining unirradiated reference temperature (IRT).

Plant-Specific

This indicates that the IRT was determined from tests on material removed from the same heat of the beltline material.

MTEB 5-2

This indicates that the unirradiated reference temperature was determined from following MTEB 5-2 guidelines for cases where the IRT was not determined using American Society of Mechanical Engineers Boiler and Pressure Vessel Code, Section III, NB-2331, methodology.

Generic

This indicates that the unirradiated reference temperature was determined from the mean value of tests on material of similar types.

- Column 7: Chemistry factor for irradiated reference temperature evaluation.
 Column 8: Method of determining chemistry factor

Table

This indicates that the chemistry factor was determined from the chemistry factor tables in RG 1.99, Revision 2.

Calculated

This indicates that the chemistry factor was determined from surveillance data via procedures described in RG 1.99, Revision 2.

Column 9: Copper content; cited directly from licensee value except when more than one value was reported. (Staff used the average value in the latter case.)

No Data

This indicates that no copper data has been reported and the default value in RG 1.99, Revision 2, will be used by the staff.

Column 10: Nickel content; cited directly from licensee value except when more than one value was reported. (Staff used the average value in the latter case.)

No Data

This indicates that no nickel data has been reported and the default value in RG 1.99, Revision 2, will be used by the staff.

Upper Shelf Energy Table

Column 1: Plant name and date of expiration of license.

Column 2: Beltline material location identification.

Column 3: Beltline material heat number; for some welds that a single-wire or tandem-wire process has been reported, (S) indicates single wire was used in the SAW process. (T) indicates tandem wire was used in the SAW process.

Column 4: Material type; plate types include A 533B-1, A 302B, A 302B Mod., and forging A 508-2; weld types include SAW welds using Linde 80, 0091, 124, 1092, ARCOS-B5 flux, Rotterdam welds using Graw Lo, SMIT 89, LW 320, and SAF 89 flux, and SMAW welds using no flux.

Column 5: EOL upper-shelf energy (USE) at T/4; calculated by using the EOL fluence and either the copper value or the surveillance data. (Both methods are described in RG 1.99, Revision 2.)

EMA

This indicates that the USE issue may be covered by the approved equivalent margins analysis in the BWR Owners Group Topical Report: NEDO-32205, Revision 1.

Column 6: EOL neutron fluence at T/4 from vessel inner wall; cited directly from T/4 value or calculated by using RG 1.99, Revision 2 neutron fluence attenuation methodology from the ID value reported in the latest submittal (GL 92-01, PTS, or P/T limits submittals).

Column 7: Unirradiated USE.

EMA

This indicates that the USE issue may be covered by the approved equivalent margins analysis in the BWR Owners Group Topical Report: NEDO-32205, Revision 1.

Column 8: Method of determining unirradiated USE

Direct

For plates, this indicates that the unirradiated USE was from a transverse specimen. For welds, this indicates that the unirradiated USE was from test date.

65%

This indicates that the unirradiated USE was 65% of the USE from a longitudinal specimen.

Generic

This indicates that the unirradiated USE was reported by the licensee from other plants with similar materials to the beltline material.

NRC generic

This indicates that the unirradiated USE was derived by the staff from other plants with similar materials to the beltline material.

10, 30, 40, or 50 °F

This indicates that the unirradiated USE was derived from Charpy test conducted at 10, 30, 40, or 50 °F.

Surv. Weld

This indicates that the unirradiated USE was from the surveillance weld having the same weld wire heat number.

Equiv. to Surv. Weld

This indicates that the unirradiated USE was from the surveillance weld having different weld wire heat number.

Sister Plant

This indicates that the unirradiated USE was derived by using the reported value from other plants with the same weld wire heat number.

Blank

indicates that there is insufficient data to determine the unirradiated USE. These licensees will utilize Topical Report NEDO-32205, Revision 1 to demonstrate USE compliance to Appendix G, 10 CFR Part 50.