

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 P A S E S 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5

CONT

01 REPORT SOURCE L 6 0 5 0 0 0 3 8 7 7 1 2 1 7 8 2 8 0 1 1 4 8 3 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 During operation in the Startup Testing Program, one HPCI Steam line
03 sensor setpoint was found out of the allowable value range. This is
04 reportable per 6.9.1.9.b. No adverse consequences existed, in that,
05 alternate detection equipment was functional which could have iso-
06 lated the HPCI Steam Supply Line.
07 Similar Events: 82-036
08

09 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
S F 11 X 12 Z 13 I N S T R U 14 E 15 Z 16
17 LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
8 2 0 7 7 0 3 L 0
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER 26
E 18 Z 19 Z 20 Z 21 0 0 0 0 N 23 N 24 N 25 B 0 8 0 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 The instrument drifted out of the allowable value range despite in-
11 creasing the surveillance frequency from quarterly to monthly. Re-
12 vised setpoints for the instrument were determined and the surveillance
13 procedure changed. Further, final tolerances were revised to more
14 accurately reflect instrument performance capability.

15 FACILITY STATUS % POWER OTHER STATUS 30 METHOD OF DISCOVERY DISCOVERY DESCRIPTION 32
B 28 0 4 5 29 N/A A 31 Surveillance

16 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36
Z 33 Z 34 N/A N/A

17 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39
0 0 0 37 Z 38 N/A

18 PERSONNEL INJURIES NUMBER DESCRIPTION 41
0 0 0 40 N/A

19 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION 43
Z 42 N/A

20 PUBLICITY ISSUED DESCRIPTION 45
N 44 N/A

8301260379 830114 PDR ADOCK 05000387 S PDR

NRC USE ONLY

NAME OF PREPARER D.G. Mitchell

PHONE: (717)542-2181X524