



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

January 21, 1983

JAMES P. McGAUGHY, JR.  
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 3100  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Fire Barriers Opened to Route  
Cables for Modifications to  
the Transient Test System  
LER 82-176/99 X-0  
AECM-83/50

On December 15, and 17, 1982, fire barriers were opened to route cables used for modifications to the transient test system. An hourly fire watch was established in accordance with Technical Specification 3.7.7. Attached is Special Report LER 82-176/99 X-0.

Yours truly,

*J.P. McGaughy*  
for J. P. McGaughy

JPM:sap  
Attachment

cc: Mr. N. L. Stampley (w/a)  
Mr. R. B. McGehee (w/o)  
Mr. T. B. Conner (w/o)  
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk (w/a)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

8301260382 830121  
PDR ADOCK 05000416  
S PDR

OFFICIAL COPY  
*TE 22*