



# MISSISSIPPI POWER & LIGHT COMPANY

*Helping Build Mississippi*

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

January 20, 1983

JAMES P. McGAUGHY, JR.  
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 3100  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Fire Door 1A230 Open With No  
Fire Watch Established  
LER 82-075/99 X-1  
AECM-83/44

On September 15, 1982, during routine surveillance for non-nuclear heatup, fire door 1A230 was found open with no fire watch established as required by Technical Specification 3.7.7. The door could not be closed due to cables (being used for maintenance activity in the steam tunnel) installed in the doorway. This revision is being made to clarify corrective action taken. Attached is LER 82-075/99 X-1.

Yours truly,

*J.P. McGaughy*  
for J.P. McGaughy

JPM:sap  
Attachment

cc: Mr. N. L. Stampley (w/a)  
Mr. R. B. McGehee (w/o)  
Mr. T. B. Conner (w/o)  
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk (w/a)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

8301260428 830120  
PDR ADOCK 05000416  
S PDR

Member Middle South Utilities System

OFFICIAL COPY

*IE 22*