

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 M S G G S 1 2 00-000000-000 34 11111 4 5
7 8 9 14 15 25 26 30 57 CAT 58

CON'T
01 REPORT SOURCE L 6 05000416 7 010883 8 012183 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
02 On January 8, 1983, a Limiting Condition for Operation was entered under T.S.3.3.1 due
03 to the IRM Functional Test not being performed within the required time period in
04 T.S. Table 4.3.1.1-1. Channels were not placed in the tripped condition as required
05 by T.S.3.3.1.b as the surveillance was being performed. The event had no effect on
06 the health and safety of the public and did not constitute a threat to plant safety.
07 This is reported pursuant to T.S.6.9.1.12.b.

08 _____
7 8 9

SYSTEM CODE I B (11) CAUSE CODE A (12) CAUSE SUBCODE A (13) COMPONENT CODE Z Z Z Z Z Z Z (14) COMP. SUBCODE Z (15) VALVE SUBCODE Z (16)

LER/RO REPORT NUMBER (17) 83 (21) (22) SEQUENTIAL REPORT NO. 003 (24) OCCURRENCE CODE G 1 (28) REPORT TYPE T (30) REVISION NO. 0 (32)

ACTION TAKEN X (18) FUTURE ACTION Z (19) EFFECT ON PLANT Z (20) SHUTDOWN METHOD Z (21) HOURS 0000 (22) ATTACHMENT SUBMITTED Y (23) NPRD-4 FORM SUB. N (24) PRIME COMP. SUPPLIER Z (25) COMPONENT MANUFACTURER Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
10 The cause of the late surveillance was due to personnel error. Personnel were made
11 aware of the error, the surveillance was completed, and the LCO was lifted at 1350
12 hours on January 8, 1983. This is submitted as a final report.
13 _____
14 _____

FACILITY STATUS G (28) % POWER 000 (29) OTHER STATUS NA (30) METHOD OF DISCOVERY B (31) DISCOVERY DESCRIPTION Surveillance Test (32)

ACTIVITY CONTENT
RELEASED OF RELEASE Z (33) Z (34) AMOUNT OF ACTIVITY NA (35) LOCATION OF RELEASE NA (36)

PERSONNEL EXPOSURES
NUMBER 000 (37) TYPE Z (38) DESCRIPTION NA (39)

PERSONNEL INJURIES
NUMBER 000 (40) DESCRIPTION NA (41)

LOSS OF OR DAMAGE TO FACILITY
TYPE Z (42) DESCRIPTION NA (43)

PUBLICITY
ISSUED DESCRIPTION N (44)
8301260451 830121 PDR
ADOCK 05000416 S PDR
NRC USE ONLY

NAME OF PREPARER Original Signed by Ron Byrd

PHONE _____

SUPPLEMENTARY INFORMATION TO
LER 83-003/01 T-0

Mississippi Power & Light Company
Grand Gulf Nuclear Station - Unit 1
Docket No. 50-416

Technical Specification Involved: 3.1.1
Reported Under Technical Specification: 6.9.1.12.b

Event Narrative:

Surveillance 06-OP-1C51-V-0002 (IRM Functional Test) was due to be performed January 6, 1983. This test is required to be performed on a weekly basis by Technical Specification Table 4.3.1.1-1. The test would be considered late after January 7, 1983.

In addition to the testing requirements of Technical Specification 4.3.1.1-1 the procedure also includes control rod block instrumentation surveillance requirements of Technical Specification 4.3.6-1. However, these test are only required in Modes 2 and 5, (Startup and Refueling). The plant was in Mode 4 (Cold Shutdown) at the time.

Personnel performing the surveillance on January 6, 1983, stopped the test at the rod block portions and the surveillance was placed on hold. The surveillance should have continued until all applicable portions were completed. However, the surveillance was not continued until January 8, 1983.

Shift Superintendents were made aware of this problem. In addition, more detail is being included in the weekly schedules pertaining to specific surveillance requirements.