NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 0 | C T H N P 1 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)

LICENSEE CODE | LICENSE NUMBER | LICENSE TYPE | CAT

CON'T

0 1 | REPORT SOURCE L (6) | 0 5 0 - 0 2 1 3 (7) | 1 0 1 5 8 2 (8) | 1 1 0 9 8 2 (9)

DOCKET NUMBER | EVENT DATE | REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During a watch tour, operator observed pinhole leak on the body of the "B" charging

0 3 | pump recirculation throttle valve CH-V-275. In service charging train was shifted to

0 4 | the "A" unit for investigation and repair. There was no hazard to the public as

0 5 | the small release of radioactive coolant was confined to the primary auxiliary

0 6 | building with closed, filtered ventilation.

0 7 |

0 8 |

0 9 | SYSTEM CODE C (11) | CAUSE CODE E (12) | CAUSE SUBCODE B (13) | COMPONENT CODE Z Z Z Z Z Z (14) | COMP. SUBCODE Z (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 8 2 | — | SEQUENTIAL REPORT NO. 0 0 9 | / | OCCURRENCE CODE 0 3 | REPORT TYPE L | — | REVISION NO. 1

ACTION TAKEN B (18) | FUTURE ACTION X (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0 0 0 0 (22) | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER Z (25) | COMPONENT MANUFACTURER Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | With the leak isolated by valving out the "B" charging train, weld repair was

1 1 | completed. The charging train was tested and returned to service the same working

1 2 | day as the event. Engineering is reviewing the failure for possible indication

1 3 | that redesign would be appropriate for long term reliability.

1 4 |

1 5 | FACILITY STATUS S (28) | % POWER 1 0 0 (29) | OTHER STATUS (30) N/A | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Operator observation.

1 6 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) N/A | LOCATION OF RELEASE (36) N/A

PERSONNEL EXPOSURES

1 7 | NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) N/A

PERSONNEL INJURIES

1 8 | NUMBER 0 0 0 (40) | DESCRIPTION (41) N/A

LOSS OF OR DAMAGE TO FACILITY (43)

1 9 | TYPE Z (42) | DESCRIPTION N/A

8301260463 830112
PDR ADOCK 05000212
S PDR

PUBLICITY

2 0 | ISSUED N (44) | DESCRIPTION (45) N/A | NRC USE ONLY

NAME OF PREPARER R. Z. Test PHONE (203) 267-2556

GPO 917-325