



ARKANSAS POWER & LIGHT COMPANY  
POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 (501) 371-4000

December 29, 1982

2CAN128220

Mr. Norman M. Haller, Director  
Office of Management & Program Analysis  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

SUBJECT: Arkansas Nuclear One - Unit 2  
Docket No. 50-368  
License No. NPF-6  
Monthly Operating Report  
(File: 2-0520.1)

Gentlemen:

Our Monthly Operating Report submitted December 15, 1982, (by letter 2CAN128211) contained typos in the operating summary. Attached is a corrected operating summary to replace the incorrect summary.

Very truly yours,

John R. Marshall  
Manager, Licensing

JFM: SAB: sc

Attachment

cc: Mr. John T. Collins  
Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region IV  
611 Ryan Plaza Drive, Suite 1000  
Arlington, TX 76011

Mr. Richard C. DeYoung  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555

IE24

8301270228 821229  
PDR ADOCK 05000368  
R PDR

NRC MONTHLY OPERATING REPORT  
OPERATING SUMMARY - NOVEMBER 1982  
UNIT II

Unit 2 began the month in Mode 5 continuing outage #82-11 for refueling. On November 10 the reactor was brought critical for low power physics testing and was tripped on November 12 for more testing. The reactor was returned to criticality on November 12 for continued physics testing. On November 15, the reactor tripped from .79% power when power supply (PS-12) in "B" Channel PPS failed. On November 16 the unit was placed on line; however, later that day the reactor tripped on high steam generator level. The unit was placed back on line. On November 18 the unit was tripped during cooldown for work on incore detectors and a MSR safety valve. On November 22 the unit was tied on line and reached 50% power on November 23. Power was maintained at 50% for physics testing until November 27 when the unit tripped on low DNB. The unit was returned to power later that day and operated at 50% power through the end of the month.

8301270237 82:229  
PDR ADOCK 05000368  
R PDR