

VIRGINIA ELECTRIC AND POWER COMPANY

SURRY POWER STATION

MONTHLY OPERATING REPORT

REPORT NO. 82-11

APPROVED BY: \_\_\_\_\_

*J. Wilson*

STATION MANAGER

<u>Section</u>	<u>Page</u>
Operating Data Report - Unit #1	1
Operating Data Report - Unit #2	2
Unit Shutdowns and Power Reductions - Unit #1	3
Unit Shutdowns and Power Reductions - Unit #2	5
Load Reductions Due to Environmental Restrictions - Unit #1	6
Load Reductions Due to Environmental Restrictions - Unit #2	7
Average Daily Unit Power Level - Unit #1	8
Average Daily Unit Power Level - Unit #2	9
Summary of Operating Experience	10
Amendments to Facility License or Technical Specifications	13
Facility Changes that did not require NRC Approval (Corrected Oct. copy)	14
Facility Changes Requiring NRC Approval	15
Facility Changes That Did Not Require NRC Approval	16
Tests and Experiments Requiring NRC Approval	17
Tests and Experiments That Did Not Require NRC Approval	17
Other Changes, Tests and Experiments	18
Chemistry Report	19
Description of All Instances Where Thermal Discharge Limits Were Exceeded	20
Fuel Handling	21
Procedure Revisions That Changed the Operating Mode Described in the FSAR	22
Description of Periodic Tests Which Were Not Completed Within the Time Limits Specified in Technical Specifications	23
Inservice Inspection	24
Reportable Occurrences Pertaining to Any Outage or Power Reductions	25
Maintenance of Safety Related Systems During Outage or Reduced Power Periods - Unit #1 - Mechanical Maintenance	26
Maintenance of Safety Related Systems During Outage or Reduced Power Periods - Unit #2 - Mechanical Maintenance	28

<u>Section</u>	<u>Page</u>
Maintenance of Safety Related Systems During Outage or Reduced Power Periods - Unit #1 - Electrical Maintenance	29
Maintenance of Safety Related Systems During Outage or Reduced Power Periods - Unit #2 - Electrical Maintenance	31
Maintenance of Safety Related Systems During Outage or Reduced Power Periods - Unit #1 - Instrument Maintenance	32
Maintenance of Safety Related Systems During Outage or Reduced Power Periods - Unit #2 - Instrument Maintenance	34
Health Physics Summary	36
Procedure Deviations reviewed by Station Nuclear Safety and Operating Committee after Time Limits Specified in T. S.	37

OPERATING DATA REPORT

BUCKET NO. 50-260  
 DATE 08 DEC 82  
 COMPLETED BY VIVIAN JONES  
 TELEPHONE 804-357-3184

OPERATING STATUS

1. UNIT NAME	SURREY UNIT 1
2. REPORTING PERIOD	110182 TO 113082
3. LICENSED THERMAL POWER (MWT)	2441
4. NAMEPLATE RATING (GROSS MWE)	847.5 [NET]
5. DESIGN ELECTRICAL RATING (NET MWE)	788
6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE)	811
7. MAXIMUM DEPENDABLE CAPACITY (NET MWE)	775
8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS	N/A
9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE)	N/A
10. REASONS FOR RESTRICTIONS, IF ANY	N/A

THIS MONTH YR-TO-DATE CUMULATIVE

11. HOURS IN REPORTING PERIOD	720.0	8016.0	87144.0
12. NUMBER OF HOURS REACTOR WAS CRITICAL	684.0	7133.2	53167.7
13. REACTOR RESERVE SHUTDOWN HOURS	33.7	33.7	3765.2
14. HOURS GENERATOR ON-LINE	667.5	7035.9	52110.7
UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	3736.2
15. GROSS THERMAL ENERGY GENERATED (MWE)	1515045.7	16581165.0	120914431.4
17. GROSS ELECTRICAL ENERGY GENERATED (MWE)	482550.0	5224670.0	39043883.0
18. NET ELECTRICAL ENERGY GENERATED (MWE)	456878.0	4949680.0	37026916.0
19. UNIT SERVICE FACTOR	92.7 %	87.8 %	59.8 %
20. UNIT AVAILABILITY FACTOR	92.7 %	87.8 %	64.1 %
21. UNIT CAPACITY FACTOR (USING MEC NET)	81.9 %	79.7 %	54.8 %
22. UNIT CAPACITY FACTOR (USING DER NET)	80.5 %	78.4 %	53.9 %
23. UNIT FORCED OUTAGE RATE	7.3 %	4.4 %	23.2 %
24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH)	2-1-83 - 74 DAYS-REFUELLING-10YR.		

25. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATE DATE OF STARTUP

26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION)

	FORECAST	ACHIEVED
--	----------	----------

INITIAL CRITICALITY  
 INITIAL ELECTRICITY  
 COMMERCIAL OPERATION

OPERATING DATA REPORT

TICKET NO. 50-281  
 DATE 06 DEC 82  
 COMPLETED BY VIVIAN JONES  
 TELEPHONE 804-357-3184

OPERATING STATUS

1. UNIT NAME	SURRY UNIT 2		
2. REPORTING PERIOD	110182 TO 113082		
3. LICENSED THERMAL POWER (NET)	2441	-----	
4. NAMEPLATE RATING (GROSS MWE)	647.5	NOTED	
5. DESIGN ELECTRICAL RATING (NET MWF)	788		
6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE)	811		
7. MAXIMUM DEPENDABLE CAPACITY (NET MWF)	775		
8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS	N/A		
9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE)	N/A		
10. REASONS FOR RESTRICTIONS, IF ANY	N/A		
	THIS MONTH YR-TO-DATE CUMULATIVE		
11. HOURS IN REPORTING PERIOD	720.0	8016.0	84024.0
12. NUMBER OF HOURS REACTOR WAS CRITICAL	720.0	7447.8	52308.5
13. REACTOR RESERVE SHUTDOWN HOURS	0.0	0.0	0.0
14. HOURS GENERATOR ON-LINE	720.0	7374.4	51486.1
15. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	0.0
16. GROSS THERMAL ENERGY GENERATED (MWH)	1751066.6	17092074.2	120369360.1
17. GROSS ELECTRICAL ENERGY GENERATED (MWH)	575785.0	5526650.0	39203229.0
18. NET ELECTRICAL ENERGY GENERATED (MWH)	546960.0	5227572.0	37156287.0
19. UNIT SERVICE FACTOR	100.0 %	92.0 %	61.3 %
20. UNIT AVAILABILITY FACTOR	100.0 %	92.0 %	61.3 %
21. UNIT CAPACITY FACTOR (USING MDC NET)	98.0 %	84.1 %	57.1 %
22. UNIT CAPACITY FACTOR (USING DER NET)	96.4 %	82.8 %	56.1 %
23. UNIT FORCED OUTAGE RATE	0.0 %	2.5 %	15.5 %
24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH)	FALL MAINT. - DEC. 7, 1982-8 DAYS N		
25. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATE DATE OF STARTUP			
26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION)	FORECAST	ACHIEVED	
	INITIAL CRITICALITY		
	INITIAL ELECTRICITY		
	COMMERCIAL OPERATION		

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-280  
 UNIT NAME Surry 1  
 DATE 12-07-82  
 COMPLETED BY Vivian H. Jones  
 TELEPHONE (804) 357-3184x477

REPORT MONTH November, 1982

No.	Date	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	License: Event Report #	System Code <sup>4</sup>	Component Code <sup>5</sup>	Cause & Corrective Action to Prevent Recurrence
82-27	11-04-82	F	41.3	A	3	82-110/03L-0	RC	FUEL XX	Loss of "A" Main transformer causing generator trip. Due to initiation of fire water spray down of transformer causing a ground fault.
82-28	11-18-82	F	1.5	A	1	82-111/03L-0 82-112/03L-0	RB PC	XXXXXX PUMP XX	Generator taken off line to remove disconnect G105 from service due to overheating.
82-29	11-19-82	F	0.0	A	1				Generator output reduced to 600 MW due to disconnect G108 overheating.

<sup>1</sup>  
 F: Forced  
 S: Scheduled

<sup>2</sup>  
 Reason:  
 A-Equipment Failure (Explain)  
 B-Maintenance or Test  
 C-Refueling  
 D-Regulatory Restriction  
 E-Operator Training & License Examination  
 F-Administrative  
 G-Operational Error (Explain)  
 H-Other (Explain)

<sup>3</sup>  
 Method:  
 1-Manual  
 2-Manual Scram.  
 3-Automatic Scram.  
 4-Other (Explain)

<sup>4</sup>  
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NURLG-0161)

<sup>5</sup>  
 Exhibit I - Same Source

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH November, 1982

DOCKET NO. 50-280  
 UNIT NAME Surry 1  
 DATE 12-07-82  
 COMPLETED BY Vivian H. Jones  
 TELEPHONE (804) 357-3184x477

No.	Date	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Licensee Event Report #	System Code <sup>4</sup>	Component Code <sup>5</sup>	Cause & Corrective Action to Prevent Recurrence
82-30	11-23-82	F	0.0	A	1				Generator output reduced to 600 MW due to disconnect G108 overheat/ g.
82-31	11-29-82	F	9.7	A	3	82-117/03L-0	RC	FUEL XX	Reactor trip due to "A" Reactor Coolant pump. Loss of pump was caused by a relay failure (33X7-V590) while performing PT-8.3A.

<sup>1</sup>  
 F: Forced  
 S: Scheduled

<sup>2</sup>  
 Reason:  
 A-Equipment Failure (Explain)  
 B-Maintenance or Test  
 C-Refueling  
 D-Regulatory Restriction  
 E-Operator Training & License Examination  
 F-Administrative  
 G-Operational Error (Explain)  
 H-Other (Explain)

<sup>3</sup>  
 Method:  
 1-Manual  
 2-Manual Scram.  
 3-Automatic Scram.  
 4-Other (Explain)

<sup>4</sup>  
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

<sup>5</sup>  
 Exhibit I - Same Source

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH November, 1982

DOCKET NO: 50-281  
 UNIT NAME: Surry II  
 DATE: 12-07-82  
 COMPLETED BY: Vivian H. Jones  
 TELEPHONE: (804) 357-3184x477

No.	Date	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Licensee Event Report #	System Code <sup>4</sup>	Component Code <sup>5</sup>	Cause & Corrective Action to Prevent Recurrence
82-39	11-27-82	S	0.0	H	I				Reduced power to load follow on orders of the system operator.

5

<sup>1</sup>  
 F: Forced  
 S: Scheduled

<sup>2</sup>  
 Reason:  
 A-Equipment Failure (Explain)  
 B-Maintenance or Test  
 C-Refueling  
 D-Regulatory Restriction  
 E-Operator Training & License Examination  
 F-Administrative  
 G-Operational Error (Explain)  
 H-Other (Explain)

<sup>3</sup>  
 Method:  
 1-Manual  
 2-Manual Scram.  
 3-Automatic Scram.  
 4-Other (Explain)

<sup>4</sup>  
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NURIG-0161)

<sup>5</sup>  
 Exhibit I - Same Source

(1/77)



LOAD REDUCTIONS DUE TO ENVIRONMENTAL RESTRICTIONS

UNIT NO. 1

MONTH: November, 1982

<u>DATE</u>	<u>TIME</u>	<u>HOURS</u>	<u>LOAD, MW</u>	<u>REDUCTIONS, MW</u>	<u>MWH</u>	<u>REASON</u>
NONE DURING THIS REPORTING PERIOD.						
MONTHLY TOTAL						

LOAD REDUCTIONS DUE TO ENVIRONMENTAL RESTRICTIONS

UNIT NO. 2

MONTH: November, 1962

<u>DATE</u>	<u>TIME</u>	<u>HOURS</u>	<u>LOAD, MW</u>	<u>REDUCTIONS, MW</u>	<u>MWH</u>	<u>REASON</u>

NONE DURING THIS REPORTING PERIOD.

MONTHLY TOTAL

AVERAGE DAILY UNIT POWER LEVEL

MONTH: NOVEMBER 62

DAY	AVERAGE DAILY POWER LEVEL (MWE-NET)	DAY	AVERAGE DAILY POWER LEVEL (MWE-NET)
1	742.3	16	744.2
2	741.4	17	673.5
3	740.7	18	329.3
4	601.1	19	694.3
5	0.0	20	599.0
6	144.9	21	737.9
7	55.1	22	741.5
8	734.5	23	731.5
9	737.8	24	592.0
10	741.0	25	738.8
11	742.2	26	740.6
12	745.3	27	744.8
13	745.2	28	743.8
14	745.2	29	361.4
15	743.4	30	304.1

DAILY UNIT POWER LEVEL FORM INSTRUCTIONS

ON THIS FORM, LIST THE AVERAGE DAILY UNIT POWER LEVEL IN MWE-NET FOR EACH DAY IN THE REPORTING MONTH. THESE FIGURES WILL BE USED TO PLOT A GRAPH FOR EACH REPORTING MONTH. NOTE THAT BY USING MAXIMUM DEPENDABLE CAPACITY FOR THE NET ELECTRICAL RATING OF THE UNIT, THERE MAY BE OCCASIONS WHEN THE DAILY AVERAGE POWER EXCEEDS THE 100 % LINE (OR THE RESTRICTED POWER LEVEL LINE). IN SUCH CASES, THE AVERAGE DAILY UNIT POWER OUTPUT SHEET SHOULD BE FOLLOTTED TO EXPLAIN THE APPARENT ANOMALY.

REPORT NO 50-291  
 UNIT FURRY II  
 DATE 12-1-82  
 COMPLETED BY VIVIAN H. JONES

AVERAGE DAILY UNIT POWER LEVEL

MONTH: NOVEMBER 82

DAY	AVERAGE DAILY POWER LEVEL (MWE-NET)	DAY	AVERAGE DAILY POWER LEVEL (MWE-NET)
1	754.4	16	759.6
2	755.8	17	758.8
3	761.6	18	756.0
4	759.8	19	760.7
5	755.5	20	766.9
6	756.9	21	766.2
7	759.4	22	764.0
8	761.6	23	763.0
9	762.5	24	766.9
10	763.1	25	763.3
11	763.5	26	764.4
12	763.5	27	710.9
13	761.8	28	762.4
14	762.1	29	763.3
15	762.1	30	759.8

DAILY UNIT POWER LEVEL FORM INSTRUCTIONS

ON THIS FORM, LIST THE AVERAGE DAILY UNIT POWER LEVEL IN MWE-NET FOR EACH DAY IN THE REPORTING MONTH. THESE FIGURES WILL BE USED TO PLOT A GRAPH FOR EACH REPORTING MONTH. NOTE THAT BY USING MAXIMUM EXPENDABLE CAPACITY FOR THE NET ELECTRICAL RATING OF THE UNIT, THERE MAY BE OCCASIONS WHEN THE DAILY AVERAGE POWER EXCEEDS THE 100 % LINE (OR THE RESTRICTED POWER LEVEL LINE). IN SUCH CASES, THE AVERAGE DAILY UNIT POWER OUTPUT SHEET SHOULD BE FOOTNOTED TO EXPLAIN THE APPARENT ANOMALY.

SUMMARY OF OPERATING EXPERIENCE

NOVEMBER, 1982

Listed below in chronological sequence by unit is a summary of operating experiences for this month which required load reductions or resulted in significant non-load related incidents.

UNIT 1

November 1            0001 - Reactor at 100%, 785 MW  
  
                         2052 - On excess letdown, off normal letdown to check non-regenerative heat exchanger for tube leak.

November 2            0310 - Back on normal letdown, no leaks found in heat exchanger.  
  
                         0730 - Isolated component cooling to excess letdown to check for leaks.  
  
                         1730 - Reduced turbine load 15 MW's due to losing level in high pressure drain tank, expecting pump to trip.  
  
                         1755 - Returned to full power, high pressure drain tank level control normal.

November 4            1930 - Reactor trip caused by loss of "A" main transformer.

November 6            0011 - Reactor Critical. Replaced lighting arrestor bushing on "A" phase main transformer.  
  
                         1247 - Generator on line.  
  
                         1400 - Reactor at 35% power, controls in automatic, increasing at 3%/Hr.  
  
                         1900 - Reactor at 50% power.

November 7            1400 - Reactor at 100% power, 785 MW.

November 9            1750 - Established component cooling flow thru excess letdown heat exchanger.

November 10           0948 - Emergency drill commenced.  
  
                         1705 - Emergency drill completed.

November 12 1515 - MOV-CS-102A isolated due to leakage. Start 24 hour clock.  
2330 - MOV-CS-102A returned to service.

November 13 0129 - Chemical addition tank level 96%, below tech. spec. minimum. Start 6 hour clock.  
0146 - Isolated component cooling to excess letdown heat exchanger. Suspect tube leak.  
0350 - Chemical addition tank level 97%, stop 6 hour clock.

November 17 1845 - Commenced ramp down due to disconnect G105 Overheating.  
2130 - Holding reactor power at 50%.  
2240 - Commenced ramp down to get disconnect out of service.

November 18 0032 - Generator off the line.  
0200 - Generator on the line, disconnect G105 removed from service.  
0310 - Holding power at 35% for chemistry.  
0415 - Commenced power increase at 3%/Hr.  
1720 - Holding power at 69% to evaluate disconnect G108 temperature increase.  
1930 - Commenced power increase at 3%/Hr.

November 19 0605 - Reactor at 100% power - 780 MW.  
1854 - Commenced power decrease at 150 MW/HR. Disconnect G108 overheating.  
2015 - Holding power at 79% to evaluate disconnect G108.

November 20 1518 - Start power increase at 3%/Hr. Disconnect G105 returned to service with jumper installed.  
2315 - Reactor at 100% power, 785 MW.

November 23 2225 - Commenced power decrease at 150 MW/Hr. Disconnect G108 overheating.  
2335 - Holding at 80% power - 600 MW.

November 24 1645 - Commenced power increase at 3%/Hr. Jumper installed on disconnect.

November 25 0100 - Reactor at 100% power 780 MW.

November 29 1022 - Reactor trip on loss of "A" Reactor coolant pump. Pump tripped due to faulty relay while performing PT 8.3A.

1238 - Reactor critical.

2007 - Generator on line.

2155 - Holding at 46.5% power. Delta flux out of band for over two hours.

November 30 2100 - Commenced slow power increase due to boron recovery tank volume.

UNIT II

November 1 0001 - Reactor at 83% power, increasing power.

0127 - Reactor at 100% power.

November 9 0845 - Vent, vent, gas release. Component cooling head tank level column hose blew off - 30% tech. specs.

November 10 0948 - Emergency drill commenced.

1705 - Emergency drill completed.

November 22 1715 - Feedwater PH 8.24 action level I. Start 12 hour clock.

1815 - Feedwater PH 8.85 (in spec.). Stop clock.

November 27 0032 - Power decrease - load follow.

0214 - Stop decrease - 72% power, 580 MW.

0553 - Power increase - 150 MW/Hr.

0748 - Reactor at 100% power.

AMENDMENTS TO FACILITY LICENSE OR TECHNICAL SPECIFICATIONS

NOVEMBER, 1982

None during this reporting period.



FACILITY CHANGES REQUIRING  
NRC APPROVAL

NOVEMBER, 1982

None during this reporting period.

FACILITY CHANGES THAT  
DID NOT REQUIRE NRC APPROVAL

NOVEMBER, 1982

	<u>UNIT</u>
DC 81-36 <u>Replacement of Restricting Orifice 4303 &amp; 3303</u>	1 & 2

The noise from the restricting orifices was above acceptable noise limits when a condensate siphon is recycled (prior to service) to a condenser connection. This design change installed a series of three orifice plates that will cause a more gradual drop in system pressure to reduce the noise.

SUMMARY OF SAFETY ANALYSIS

There are no safety implications as a result of this design change. The modification will bring the noise down to an acceptable limit for station employees.

NOVEMBER, 1982

TESTS AND EPERIMENTS REQUIRING  
NRC APPROVAL

None during this reporting period.

TESTS AND EXPERIMENTS THAT  
DID NOT REQUIRE NRC APPROVAL

None during this reporting period.

OTHER CHANGES, TESTS AND EXPERIMENTS

NOVEMBER, 1982

None during this reporting period.

SURRY POWER STATION

CHEMISTRY REPORT

November 19 82

T.S. 6.6.3.d

PRIMARY COOLANT ANALYSIS	UNIT NO. 1			UNIT NO. 2		
	MAXIMUM	MINIMUM	AVERAGE	MAXIMUM	MINIMUM	AVERAGE
Gross Radioact., $\mu\text{Ci/ml}$	$6.04^0$ (A)	$1.15^0$ (A)	$3.11^0$ (A)	$4.39^{-1}$	$1.69^{-1}$	$2.52^{-1}$
Suspended Solids, ppm	0.1	0.1	0.1	0.1	0.1	0.1
Gross Tritium, $\mu\text{Ci/ml}$	$1.07^{-1}$	$2.81^{-2}$	$5.25^{-2}$	$1.96^{-1}$	$1.55^{-1}$	$1.80^{-1}$
Iodine-131, $\mu\text{Ci/ml}$	$4.71^0$ (A)	$5.13^{-2}$ (A)	$9.17^{-1}$ (A)	$3.57^{-3}$	$5.92^{-4}$	$1.57^{-3}$
I-131/I-133	.7599	.3999	.5557	1.7500	.2131	.6947
Hydrogen, cc/kg	37.1	25.3 (B)	29.7	45.8	31.0	37.6
Lithium, ppm	1.00	.34 (C)	.68	1.25 (D)	1.05	1.18
Boron-10, ppm +	88.98	20.78	39.18	95.26	79.97	85.76
Oxygen-16, ppm	.000	.000	.000	.000	.000	.000
Chloride, ppm	<.05	<.05	<.05	<.05	<.05	<.05
pH @ 25°C	7.40	6.60	7.16	6.91	6.79	6.85

+ Boron-10 = Total Boron x 0.196

(E)  
NON-RADIOACTIVE CHEMICAL  
RELEASES, POUNDS  
T.S. 4.13 A.6

Phosphate	-	Boron	915
Sulfate	-	Chromate	0.0
50% NaOH	-	Chlorine	0.0

REMARKS: (A) Values reflect suspected failed fuel. (B) Low hydrogen concentration following unit ramp 11/79 increase in VCT pressure recommended. (C) LiOH added to increase Li concentration: 390 gms on 11/4, 1070 gms on 11/8, 470 gms on 11/12 390 gms on 11/16 and 360 gms on 11/19. (D) Cation bed placed in service 11/79 to lower Li concentration. (E) The levels of these chemicals should create no environmental impact.

DESCRIPTION OF ALL INSTANCES WHERE  
THERMAL DISCHARGE LIMITS WERE EXCEEDED

NOVEMBER, 1982

Due to the impairment of the circulating water system on the following days, the thermal discharge limits were exceeded as noted.

November 1, 1982	-	Exceeded 15°F ΔT across station
November 2, 1982	-	Exceeded 15°F ΔT across station
November 3, 1982	-	Exceeded 15°F ΔT across station
November 4, 1982	-	Exceeded 15°F ΔT across station
November 7, 1982	-	Exceeded 15°F ΔT across station
November 8, 1982	-	Exceeded 15°F ΔT across station
November 9, 1982	-	Exceeded 15°F ΔT across station
November 10, 1982	-	Exceeded 15°F ΔT across station
November 11, 1982	-	Exceeded 15°F ΔT across station
November 12, 1982	-	Exceeded 15°F ΔT across station
November 13, 1982	-	Exceeded 15°F ΔT across station
November 14, 1982	-	Exceeded 15°F ΔT across station
November 16, 1982	-	Exceeded 15°F ΔT across station
November 22, 1982	-	Exceeded 15°F ΔT across station
November 23, 1982	-	Exceeded 17.5°F ΔT across station
November 24, 1982	-	Exceeded 17.5°F ΔT across station
November 25, 1982	-	Exceeded 17.5°F ΔT across station
November 26, 1982	-	Exceeded 15°F ΔT across station
November 27, 1982	-	Exceeded 15°F ΔT across station
November 28, 1982	-	Exceeded 15°F ΔT across station
November 29, 1982	-	Exceeded 15°F ΔT across station

\*Indicates dates where station ΔT was less than or equal to 15.0°F across station for some time during the day.

The ΔT excursions were allowable under Technical Specifications 4.14.B.2. There were no reported instances of adverse environmental impact.

The temperature change at the station discharge exceeded 3° per hour on November 4 due to a Unit #1 reactor trip.

The temperature change at the station discharge exceeded 3°F per hour on November 29 due to a Unit #1 reactor trip. The two associated with the reactor trip were allowable in accordance with Technical Specification 4.14.B.1.

There were no reported instances of adverse environmental impact.

FUEL HANDLING

NOVEMBER, 1982

Units One and Two

None during this reporting period.

PROCEDURE REVISIONS THAT CHANGED THE  
OPERATING MODE DESCRIBED IN THE PSAR

November, 1982

None during this reporting period.



DESCRIPTION OF PERIODIC TESTS WHICH WERE NOT  
COMPLETED WITHIN THE TIME LIMITS  
SPECIFIED IN TECHNICAL SPECIFICATIONS

NOVEMBER, 1982

None during this reporting period.

INSERVICE INSPECTION

NOVEMBER, 1982

Units One and Two

None during this reporting period

REPORTABLE OCCURRENCES PERTAINING TO  
ANY OUTAGE OR POWER REDUCTIONS

NOVEMBER, 1982

None during this reporting period.

MAINTENANCE OF SAFETY RELATED SYSTEMS DURING  
OUTAGE OR REDUCED POWER PERIODS

UNIT NO. 1

MECHANICAL MAINTENANCE

UNIT1-12/09/82  
 (MAINTENANCE OF SAFETY RELATED SYSTEMS DURING OUTAGE OR REDUCED POWER PERIODS)

RATE/RVDT	SYS	COMP	MARKNO	SUMMARY	WKPKNF	U	NR	TOTL	WTR
11/04/82	RW	MONITOR	RMS-159	INSTALL QUICK DISCONNECT	FABRICATED AND INSTALLED AS	1	205071246		0
11/04/82	EG	VALVE	1-DC-14	VALVE HAS BODY TO BONNET LEAK	TRIED TO TIGHTEN DOWN ON BODY	1	210191457		0
11/04/82	AG	VALVE	1-RC-68	ADJUST PACKING GLAND	ADJUSTED VARIOUS PACKING	1	210241240		0
11/04/82	MS	BOTTLE	1	CHANGE OUT NITROGEN BOTTLE	COMPLETED	1	210280716		0
11/04/82	MS	VALVE	PCV-MS-102A	OVERHAUL	CHANGED GASKET SET	1	211011501		0
11/04/82	MS	VALVE	PCV-MS-102B	OVERHAUL	CHANGED GASKET SET	1	211011502		0
11/04/82	CH	VALVE	1-CH-107	REMOVE BORIC ACID PLUG	UNCLOGGED LINK INSTALL	1	211031516		0
11/04/82	RW	PIPING	N/A	THREADED FITTING BY 1-RW-15	APPLIED THREAD COMPOUND	1	211032154		0
11/05/82	CS	PUMP	1-CS-T-3A+3B	IMPLEMENT ENG STUDY 81-11	REMOVED 3A + 3B	1	104281109		0
11/05/82	MS	VALVE	1-MS-145	VALVE HAS BODY TO BONNET LEAK	FURNITURED BODY TO	1	210230730		0
11/06/82	MS	VALVE	SOV-MS-102B	VALVE LEAKS BY	REPLACED GASKET SET	1	211051243		0
11/06/82	MS	VALVE	SOV-MS-102A	VALVE LEAKS BY	REPLACED GASKET SET	1	211051244		0
11/17/82	VS	PLUG	1-VS-K-4B	REPLACE ZINC PLUG	REPLACE ZINC AND PLUG	1	211150517		0
11/20/82	FW	BOTTLES	FW-P-2	CHANGE OUT NITRO BOTTLES	REPLACED N2 BOTTLE	1	211091807		0
11/29/82	BD	VALVE	TV-BD-100A	REPAIR TO ORIGINAL HAS BEEN FURNITURED	OVERHAULED VALVE	1	206221536		0
11/29/82	VS	PUMP	1-VS-P-1A	REPAC PUMP	REPACED PUMP USED 6	1	211120132		0
11/29/82	VS	PUMP	1-VS-P-2B	REPAC	DISASSEMBLED PUMP + INSPECTED INTERN	1	211120140		0
11/29/82	CS	VALVE	1-CS-57	VALVE HAS PIPE BROKEN OFF	REMOVED PIPE NIPPLE	1	211162300		0
11/29/82	SW	PUMP	1-SW-P-1A	CLEAN SECTION STRAINER	MANUFACTURED NEW STRAINER	1	211230607		0
11/29/82	FW	BOTTLE	1-FW-P-2	CHANGE N2 BOTTLE	REPLACED N2 BOTTLE AND	1	211280901		0
11/30/82	SW	PUMP	1-SW-P-10B	ADJUST PUMP PACKING	ADJUSTED PACKING	1	211290330		0
DEPT TOTAL									0

MAINTENANCE OF SAFETY RELATED SYSTEMS DURING  
OUTAGE OR REDUCED POWER PERIODS

UNIT NO. 2

MECHANICAL MAINTENANCE

None during this reporting period.

MAINTENANCE OF SAFETY RELATED SYSTEMS DURING  
OUTAGE OR REDUCED POWER PERIODS

UNIT NO. 1

ELECTRICAL MAINTENANCE

UNIT1-12/09/92  
 (MAINTENANCE OF SAFETY RELATED SYSTEMS DURING OUTAGE OR REDUCED POWER PERIODS)

DATE/TIME	SYS	COMP	MARKNO	SUMMARY	WKPERF	U	MR	TOTLWNTN
11/04/82	D4	INSTR	CS-DA-104	6 LEVEL SWITCH STICKS	STRAIGHTENED ROD CN	1	208312359	0
11/05/82	EPH	TRANSFOR	N/A	CHECK A MAIN TRANSFORMER	REPLACED LIGHTENING	1	211042100	0
11/06/82	MS	SOV	SOV-MS-102A	ADJUST LIMIT SWITCHES ON SOV-MS-102A	ADJUSTED LIMITS AND	1	211051837	0
11/06/82	MS	SOV	SOV-MS-102B	ADJUST LIMIT SWITCHES]	FOUND AIR ISOLATED TO	1	211051838	0
11/17/82	CS	MOV	MOV-CS-102A	WGRK WITH OPS	CHANGED TORQUE SETTING	1	211121900	0
11/17/82	SH	VALVE	MOV-SW-102A	MOV-SW-102A CLOSED BOTH A+B LOCKOUT	MOV SW 102A CHECKED OK	1	211160227	0
11/17/82	GW	SWITCH	LS-GW-102B	PROCESS VENT WATER ALERT ALARM	CHECKED OPERATION OF	1	211161112	0
11/17/82	SW	MOV	MOV-SW-102B	ADJUST LIMITS AS NECESSARY	ADJUSTED LIMITS AND	1	211170906	0
11/24/82	EPDC	BATTERY	1 EDC	REPLACE BATTERY	REPLACED BATTERY AND	1	211240700	0
11/30/82	SS	INSTR	TV-SS-106B	CLOSED INDICATING LIGHT	OPERATED VALVE SAT AND	1	211261104	0
DEPT TOTAL								0



MAINTENANCE OF SAFETY RELATED SYSTEMS DURING  
OUTAGE OR REDUCED POWER PERIODS

UNIT NO. 2

ELECTRICAL MAINTENANCE

None during this reporting period.

MAINTENANCE OF SAFETY RELATED SYSTEMS DURING  
OUTAGE OR REDUCED POWER PERIODS

UNIT NO. 1

INSTRUMENT MAINTENANCE

UNITA-12/09/82  
(MAINTENANCE OF SAFETY RELATED SYSTEMS DURING OUTAGE OR REDUCED POWER PERIODS)

DATE	SYS	COMP	MARNO	SUMMARY	WKPFRF	U	MR	TOTLWTH
11/04/82	RC	INSTR	GA6	ROD CONTROL 4S URGENT FAILURE	REPLACED FUSE AND	1	211040705	0
11/05/82	RC	MONITOR	SC1-RC-100B	CORE COOLING MONITOR ERRATIC	RAM PT 2.27 CHECK SAT	1	211041624	0
11/05/82	RM	MONITOR	RI-CW-101	CHECK SOURCE BUTTON BLOWS FUSES	SECURED BRIDGE CIRCUIT	1	211051420	0
11/07/82	RM	MONITOR	RM-CC-105	RESET LTR DOESNT WORK	REPLACED O104 CHECKED SAT	1	211051457	0
11/07/82	RM	MONITOR	RI-CC-105	CHANGE ALARM SETPOINTS	CHANGED SETPOINTS	1	211060655	0
11/17/82	RP	INSTR	F-8	INDICATION ERRATIC INVESTIGATE	REPLACED SIGNAL MODULA	1	211161415	0
11/17/82	RM	DETECTOR	RY-RMS-151	SPIKING	RECALIBRATED DETECTOR	1	211170515	0
11/18/82	RM	PUMP	RM-VC-103/104	EXCESSIVE FLOW RATE	ADJUSTED FLOW TO WITHIN	1	211151545	0
11/30/82	RM	RECORDER	RR-175	REPLACE PULLEYS	RECORDER CHECKED OK	1	211210350	0
11/30/82	FW	INSTR	FR-1-488	RECORDER DOESNT ROTATE	CLEANED AND INSPECTED	1	211230725	0
DEPT TOTAL								0

MAINTENANCE OF SAFETY RELATED SYSTEMS DURING  
OUTAGE OR REDUCED POWER PERIODS

UNIT NO. 2

INSTRUMENT MAINTENANCE

DEPT=INST

9 DEC 82 \* 9:41 AM PAGE 1

UNIT2-12/09/82  
(MAINTENANCE OF SAFETY RELATED SYSTEMS DURING OUTAGE OR REDUCED POWER PERIODS)

DATE/TIME	SYS	COMP	MAN/NO	SUMMARY	WKPERF	U	MR	TOT/WTM
11/27/82	RP	INSTR	F-06	CHECK CALIBRATION	ALIGNED INDICATOR	2	211270531	J -- 0
DEPT TOTAL								0

HEALTH PHYSICS

NOVEMBER, 1982

There was no single release of radioactivity or radiation exposure specifically associated with an outage that accounted for more than 10% of the allowable annual values in 10CFR20.

PROCEDURE DEVIATIONS REVIEWED BY STATION NUCLEAR  
SAFETY AND OPERATING COMMITTEE AFTER TIME LIMITS  
SPECIFIED IN TECHNICAL SPECIFICATIONS

November, 1982

<u>Procedure No.</u>	<u>Unit</u>	<u>Title</u>	<u>Date Deviated</u>	<u>Date SNSOC Reviewed</u>
MMP-C-G-061.2	1	Repairs to Gast Vacuum Pumps	10-20-82	11-12-82
MMP-C-G-84	1	Repair or Replacement of Worn or Defective Pump Internals Ingersoll-Rand Inliner pumps	09-13-82	11-12-82
EMP-C-FP-43	1	Sealing of Fire Stops using Dow Corning Q3-6548 Silicone RTV Foam	10-28-82	11-12-82