



Northern States Power Company

414 Nicollet Mall  
Minneapolis, Minnesota 55401-1927  
Telephone (612) 330-5500

May 13, 1994

NRC Bulletin No. 90-01  
Supplement 1

U S Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

PRAIRIE ISLAND NUCLEAR GENERATING PLANT  
Docket Nos. 50-282 License Nos. DPR-42  
50-306 DPR-60

Additional Information Related to NRC Bulletin No. 90-01, Supplement 1  
Loss of Fill-oil in Transmitters Manufactured by Rosemount

On March 1, 1993, we responded to NRC Bulletin No. 90-01, Supplement 1, Loss of Fill-oil in Transmitters Manufactured by Rosemount. In that response, one of our commitments was:

Three Spare transmitters for the reactor protection trip systems, ESF actuation systems, or ATWS systems that have a normal operating pressure greater than or equal to 500 psi and less than or equal to 1500 psi will be returned to Rosemount for refurbishment.

Since then we have been asked by NRC Staff if that action has taken place. This letter documents that we did send the three transmitters back to Rosemount for refurbishment in 1993. We subsequently have received two refurbished transmitters from Rosemount and the third has not been received yet.

We have made no new NRC commitments in this letter.

230012


9403230109 940513  
PDR ADDCK 05000282  
Q PDR

IE39  
1/0

US NRC  
May 13, 1994  
Page 2

Northern States Power Company

Please contact Jack Leveille (612-388-1121, Ext. 4662) if you have any questions related to this letter.

A handwritten signature in cursive script, appearing to read "M D Wadley".

M D Wadley  
Plant Manager  
Prairie Island

c: Regional Administrator - Region III, NRC  
Senior Resident Inspector, NRC  
NRR Project Manager, NRC  
J E Silberg

Attachment: Affidavit

UNITED STATES NUCLEAR REGULATORY COMMISSION

NORTHERN STATES POWER COMPANY

PRAIRIE ISLAND NUCLEAR GENERATING PLANT      DOCKET NO. 50-282  
50-306

LOSS OF FILL-OIL IN TRANSMITTERS  
MANUFACTURED BY ROSEMOUNT

Northern States Power Company, a Minnesota corporation, with this letter is submitting information requested by NRC Bulletin 90-01, Supplement 1.

This letter contains no restricted or other defense information.

NORTHERN STATES POWER COMPANY

By

*M D Wadley*  
M D Wadley  
Plant Manager  
Prairie Island

On this 13<sup>th</sup> day of May 1994 before me a notary public in and for said County, personally appeared M D Wadley, Plant Manager, Prairie Island, and being first duly sworn acknowledged that he is authorized to execute this document on behalf of Northern States Power Company, that he knows the contents thereof, and that to the best of his knowledge, information, and belief the statements made in it are true and that it is not interposed for delay.

*Marcia K LaCore*

