LICENSEE EVENT REPORT

	CONTROL BLOCK: PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION
0 1	I L D R S 2 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 1 4 5 5 CAT 58
O I	SOURCE L 6 0 5 0 0 0 2 3 7 7 1 2 3 1 8 2 3 0 1 2 5 8 3 9
0 2	During normal operation, Valve A02-1001-55 closed without operator action. This event
0 3	is of minimum safety significance since the valve failed closed and valves A02-1601-
0 4	56 and A02-1601-21 were isolated as required by Tech. Spec. 3.7.D.2. There was no
0 5	effect to the public health or safety. Past occurrence reported by R.O. 81-50 on
0 6	Docket 50-237.
0 7	
7 8	9
0 9 7 3	SYSTEM CAUSE CAUSE SUBCODE SUB
	LER/RO EVENT YEAR SEQUENTIAL OCCURRENCE REPORT NO. CODE TYPE NO.
	A 18 Z 19 Z 20 Z 2 3 SUBMITTED FORM SUB. SUPPLIER MANUFACTURER A 6 1 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
110	The cause of the event was due to a deteriorated diaphragm in the solenoid on the air
11	Loperator. The solenoid was replaced (ASCO Valve Number 8317A29) and the valve provent
1 2	loperable. Surveillance Test (DOS 1600-1) will continue to be performed quarterly to
1 3	verify system operability.
14	
	30 METHOD OF DISCOVERY DESCRIPTION 32 N/A Operator Observation 32
	CITIVITY CONTENT LEASED OF RELEASE AMOUNT OF ACTIVITY 35 Z 33 Z 32 N/A N/A LOCATION OF RELEASE 36
1 7	NUMBER TYPE DESCRIPTION 39 N/A N/A
1 3	PERSONNEL INJURIES 13 NUMBER DESCRIPTION 41 N/A
	LOSS OF OR DAMAGE TO FACILITY 43 TYPE DESCRIPTION N/A
3	#UBLICITY SSUED DESCRIPTION 45 PDR ADDCK 05000237 NRC USE ONLY PDR
- 1	David Tang Wee 815-942-2920, X-422