LICENSEE EVENT REPORT

7000	CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
7 8	M I D C C 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 1 4 57 CAT 58
O 1	SOURCE L 6 0 5 0 0 0 3 1 5 7 1 2 2 7 8 2 3 0 1 2 6 8 3 9
0 2	DURING NORMAL PLANT OPERATION, A SECURITY OFFICER ON TOUR FOUND THE CO2 SWITCH FOR
0 3	THE UNIT 1 4KV SWITCHGEAR ROOM IN THE ISOLATE POSITION WITH NO ONE IN THE ROOM. THES
0 4	IS NON-CONSERVATIVE WITH RESPECT TO THE REQUIREMENTS OF T.S.3.7.9.3. THE CONDITION
0 5	EXISTED FOR TWENTY (20) MINUTES. THE FIRE DETECTION SYSTEM WAS OPERABLE DURING THIS
0 6	PERIOD PUBLIC HEALTH AND SAFETY WERE NOT AFFECTED. PREVIOUS OCCURRENCES WERE REPORTED
G 7	VIA RO NOS. (UNIT I): 315/82-037, 044, 045, 049, 068, 081 & 082 - AND (UNIT II):
0 3	316/82-054, 062, 076, 058, 074 and 084.
0 9	SYSTEM CAUSE SUBCODE COMPONENT CODE SUBCODE SU
	LER RO EVENT YEAR SEQUENTIAL REPORT NO. CODE TYPE NO. NO. NO.
110	ACTION FUTURE SEFECT SHUTDOWN METHOD ACTION ON PLANT SHUTDOWN METHOD SUBMITTED SUBMITT
	QUESTING A SECURITY GUARD AT THE ISOLATION SWITCH AND VERIFYING THAT THE SWITCH WAS
1121	RETURNED TO NORMAL WHEN ALL PERSONNEL HAD LEFT THE AREA. A PROCEDURE CHANGE HAS
	BEEN ISSUED WHICH CLEARLY DEFINES THE PERSON RESPONSIBLE FOR ASSURING THAT PROPER
	L PROCEDURES ARE FOLLOWED.
7 8	ACILITY STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32 DISCOVERY DESCRIPT
	ILEASED OF PELEASE N.A. LOCATION OF PELEASE 36
1 7	PERSONNEL EXPOSURES NUMBER 10 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
1 8	PERSONNEL INJURIES NUMBER DESCRIPTION (41) 0 0 (40) N.A.
1 9	DOSS OF OR DANIAGE TO FACILITY (4) PDR ADOCK 05000315 T/42 S 9302040086 830126 PDR ADOCK 05000315 PDR
2 0	PUBLICITY SSUED DESCRIPTION (45) NAC USE ONLY NAA.
-	B. A. SVENSSON NAME OF PREPARER B. A. SVENSSON PHONE: 616-465-5901