

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 M I D C C 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40

CON'T
0 1 REPORT SOURCE L 6 0 5 0 0 0 3 1 5 7 0 1 0 3 8 3 8 0 1 2 6 8 3 9
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

0 2 | DURING NORMAL OPERATION OF UNIT #1, FIRE DOOR #385 WOULD NOT LATCH EVERY TIME UPON
0 3 | CLOSING. THIS CONSTITUTED AN INOPERABLE PENETRATION FIRE BARRIER, CONTRARY TO T.S.
0 4 | 3.7.10. ACTION STATEMENTS WERE MET, PUBLIC HEALTH AND SAFETY WERE NOT AFFECTED.
0 5 |
0 6 |
0 7 |
0 8 |

0 9 SYSTEM CODE A B 11 CAUSE CODE E 12 CAUSE SUBCODE Z 13 COMPONENT CODE X X X X X X 14 COMP SUBCODE Z 15 VALVE SUBCODE Z 16
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40

17 LER NO REPORT NUMBER 8 3 21 22 SEQUENTIAL REPORT NO. 0 0 3 24 26 OCCURRENCE CODE 0 3 28 29 REPORT TYPE L 30 31 REVISION NO. 0 32
ACTION TAKEN B 18 33 FUTURE ACTION Z 19 34 EFFECT ON PLANT Z 20 35 SHUTDOWN METHOD Z 21 36 HOURS 0 0 0 0 37 40 ATTACHMENT SUBMITTED N 23 41 NRC-4 FORM SUB. N 24 42 PRIME COMP. SUPPLIER A 25 43 COMPONENT MANUFACTURER X 9 9 9 26 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

1 0 | THE DOOR KNOB SPINDLE WAS FOUND BENT, PREVENTING LATCHING OF THE DOOR. CAUSE OF
1 1 | DAMAGE COULD NOT BE DETERMINED. THE KNOB SPINDLE WAS REPLACED. THE DOOR CLOSER WAS
1 2 | ADJUSTED AND THE DOOR OPERATED SATISFACTORILY.
1 3 |
1 4 |

1 5 FACILITY STATUS E 26 10 POWER 1 0 0 29 13 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 45 DISCOVERY DESCRIPTION OPERATOR OBSERVATION 32
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40

1 6 ACTIVITY CONTENT Z 33 10 RELEASED OF RELEASE Z 34 11 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40

1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 11 TYPE Z 38 12 DESCRIPTION NA 39
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40

1 8 PERSONNEL INJURIES NUMBER 0 0 0 40 11 DESCRIPTION NA 41
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40

1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 10 DESCRIPTION NA 43
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40

2 0 PUBLICITY ISSUED DESCRIPTION LN 44 10
8302040100 830126
PDR ADOCK 05000315
S PDR
NRC USE ONLY