

Omaha Public Power District
344 South 16th Street Mall
Omaha, Nebraska 68102-2247
402/636-2000

April 1, 1991
LC-91-112R

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Station P1-137
Washington, DC 20555

- References:
1. Docket No. 50-285
 2. Letter from OPPD (W. G. Gates) to NRC (Document Control Desk) dated January 14, 1991 (LIC-91-0022)
 3. Letter from NRC (A. Bournia) to OPPD (W. G. Gates) dated November 14, 1990
 4. Letter from OPPD (W. G. Gates) to NRC (Document Control Desk) dated February 21, 1990 (LIC-89-1203)

Gentlemen:

SUBJECT: Modification Schedule to Resolve Fire Area 34B Cable Routing Concern

In Reference 2, Omaha Public Power District (OPPD) committed to provide a schedule for implementation of a modification to the wide range nuclear instrumentation (NI) cable passing through Fire Area 34B. Modification MR-FC-90-68 will relocate an NI cable to insure that the applicable physical separation requirement of 10 CFR 50.48, Appendix R are met.

OPPD plans to complete this modification by December 31, 1992. As noted in Reference 2, compensatory measures will remain in effect, per Safety Analysis for Operability (SAO) 90-13-00 until modification MR-FC-90-68 is completed.

If you should have any questions, please contact me.

Sincerely,

W. G. Gates

W. G. Gates
Division Manager
Nuclear Operations

WGG/sel

- c: LeBoeuf, Lamb, Leiby & MacRae
R. D. Martin, NRC Regional Administrator, Region IV
W. C. Walker, NRC Project Manager
R. P. Mullikin, NRC Senior Resident Inspector

A006
1/0