

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | I | L | D | R | S | 3 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 4 | 1 | 1 | 1 | 1 | 1 | _____

CON'T
01 | REPORT SOURCE | L | 0 | 5 | 0 | 0 | 0 | 2 | 4 | 9 | 0 | 1 | 0 | 5 | 8 | 3 | 0 | 2 | 0 | 2 | 8 | 3 | _____

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES

02 | During normal unit operation, after starting Rx water cleanup system, a pin-hole leak
03 | was found on the connecting pipe weld between 3-1201-10 inch A and 3-1292-2 inch A
04 | line. The line is located outside of primary containment and all the leakage was con-
05 | tained in Rx building floor drain system. The health and safety of the public was
06 | not endangered. A similar event was reported by R.O. 82-58/03L-0 on Docket 050-237.
07 |
08 |

09 | SYSTEM CODE | C | G | CAUSE CODE | E | CAUSE SUBCODE | B | COMPONENT CODE | P | I | P | E | X | X | COMP. SUBCODE | C | VALVE SUBCODE | Z |

17 | LER/RO REPORT NUMBER | 8 | 3 | EVENT YEAR | 8 | 3 | SEQUENTIAL REPORT NO. | 0 | 1 | 0 | 3 | OCCURRENCE CODE | 0 | 3 | REPORT TYPE | L | REVISION NO. | 0 |
ACTION TAKEN | Z | FUTURE ACTION | B | EFFECT ON PLANT | Z | SHUTDOWN METHOD | Z | HOURS | 0 | 0 | 0 | 0 | ATTACHMENT SUBMITTED | N | NPRO-4 FORM SUB. | Y | PRIME COMP. SUPPLIER | N | COMPONENT MANUFACTURER | G | O | 8 | 0 |

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS

10 | The cause of the pin-hole is undetermined. The leak will be repaired (W.R. 25009)
11 | during next outage of sufficient length. Exact nature of the problem will be deter-
12 | mined after repair. A supplemental report will be issued when additional information
13 | is available.
14 |

15 | FACILITY STATUS | E | % POWER | 0 | 9 | 9 | OTHER STATUS | N/A | METHOD OF DISCOVERY | A | DISCOVERY DESCRIPTION | Operator Observation |

16 | ACTIVITY CONTENT | Z | RELEASED OF RELEASE | Z | AMOUNT OF ACTIVITY | N/A | LOCATION OF RELEASE | N/A |

17 | PERSONNEL EXPOSURES NUMBER | 0 | 0 | 0 | TYPE | Z | DESCRIPTION | N/A |

18 | PERSONNEL INJURIES NUMBER | 0 | 0 | 0 | DESCRIPTION | N/A |

19 | LOSS OF OR DAMAGE TO FACILITY TYPE | Z | DESCRIPTION | N/A |

20 | PUBLICITY ISSUED | N | DESCRIPTION | 8302080356 830202 PDR ADOCK 05000249 S PDR

NAME OF PREPARER Sang Rhee PHONE: 815-942-2920, X-548