

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKET NOS. 50-338 AND 50-339VIRGINIA ELECTRIC AND POWER COMPANYNOTICE OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSES

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment Nos. 45 and 28 to Facility Operating License Nos. NPF-4 and NPF-7 issued to the Virginia Electric and Power Company (the licensee) for operation of the North Anna Power Station, Units No. 1 and No. 2 (the facility) located in Louisa County, Virginia. The amendments are effective as of the date of issuance.

The amendments revise the Technical Specifications for the North Anna Power Station, Unit Nos. 1 and 2 based upon the licensee's reanalysis for the Loss-of-Coolant Accident-Emergency Core Cooling System performance assuming seven (7) percent steam generator tube plugging. The licensee's reanalysis has been determined to meet the criteria of 10 CFR 50.46 and the reanalysis was performed in accordance with 10 CFR Part 50, Appendix K.

The application for the amendments complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in these license amendments. Prior public notice of these amendments was not required since these amendments do not involve a significant hazards consideration.


- 2 -

The Commission has determined that the issuance of the amendments will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of these amendments.

For further details with respect to this action, see (1) the application for amendment dated August 16, 1982 (Serial No. 490); (2) Amendment Nos. 45 and 28 to Facility Operating License Nos. NPF-4 and NPF-7 and (3) the Commission's related Safety Evaluation. These items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D. C. 20555 and at the Board of Supervisors Office, Louisa County Courthouse, Louisa, Virginia 23093 and at the Alderman Library, McIntosh Department, University of Virginia, Charlottesville, Virginia 22904. A copy of items (2) and (3) may be obtained upon request to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland this 27th day of January, 1983.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing