



Duquesne Light

Nuclear Construction Division
Robinson Plaza, Building 2, Suite 210
Pittsburgh, PA 15205

2NRC-3-004

(412) 787-5141

(412) 923-1960

Telecopy (412) 787-2629

January 28, 1983

United States Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, PA 19406


ATTENTION: Mr. R. C. Haynes
Regional Administrator

SUBJECT: Beaver Valley Power Station - Unit No. 2
Docket No. 50-412
IE Bulletin 82-04
"Deficiencies in Primary Containment Electrical Penetration Assemblies"

Gentlemen:

Beaver Valley Power Station Unit No. 2 (BVPS-2) has reviewed IE Bulletin 82-04 titled "Deficiencies in Primary Containment Electrical Penetration Assemblies" for applicability to BVPS-2. Our review indicates that Bunker Ramo electrical penetration assemblies are not used in BVPS-2, nor are they planned to be installed in any BVPS-2 safety-related systems. The electrical penetration assemblies for BVPS-2 are supplied by Westinghouse. This information is supplied to you in response to Item 5a of the Bulletin, which states that if no Bunker Ramo electrical penetration assemblies which use the hard epoxy module design are installed or planned to be installed in safety-related systems, no further action is required. Therefore, this is our final response to IEB 82-04.


DUQUESNE LIGHT COMPANY

By 
E. J. Woolever
Vice President

SDH/wjs

cc: Mr. G. Walton, NRC Resident Inspector
Ms. L. Lazo, Project Manager
U. S. Nuclear Regulatory Commission, %Document Control Desk, Washington DC,
20555

SWORN AND SUBSCRIBED TO ME THIS 28th DAY
OF January, 1983.


Notary Public

ANITA ELAINE REITER, Notary Public
ROBINSON TOWNSHIP, ALLEGHENY COUNTY
MY COMMISSION EXPIRES OCTOBER 20, 1986

8302100329 830128
PDR ADOCK 05000412
PDR
Q

IE11

