

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1
7	8

REPORT SOURCE

L	6	0	5	0	-	0	2	9	3	7	0	1	0	5	8	3	8	0	1	2	7	8	3	9
60	61	DOCKET NUMBER					68	69	EVENT DATE					74	75	REPORT DATE					80			

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | On 1/5/83, during surveillance test 8.M.2-1.5.1, the inboard reactor water sample
0 3 | isolation valve A0-220-44 did not close. The redundant valve was immediately
0 4 | verified closed and tagged per T.S. Section 3.7.D.2. Because of the T.S. actions,
0 5 | the required surveillance timing tests cannot be performed on the subject valve or
0 6 | the redundant in-line valve (A0-220-45). NRC was notified via ENS. This event
0 7 | created no threat to the public health and safety.

0	8	
7	8	9

7 8 9 10 11 12 13 14 15 16

(17) LER/RO REPORT NUMBER [EVENT YEAR
[8][3]
21 22] [23] SEQUENTIAL REPORT NO. [0][0][1]
24 26] [27] OCCURRENCE CODE [0][3]
28 29] [30] REPORT TYPE [L]
31] [32] REVISION NO. [0]
33]

ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUT-DOWN METHOD		HOURS				ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER			
X	18	B	19	Z	20	Z	21	0	0	0	0	N	23	N	24	N	25	H	0	3	5
33		34		35		36		37			40	41		42		43		44			

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Cause and corrective action will be determined when valve can be investigated at the

1 1 next outage of sufficient duration to allow a drywell entry. The valve is a Hammel-

1 2 Dahl 1" Globe valve.

1	3	
1	4	

FACILITY STATUS (28) 1 5 0 E
% POWER 1 0 0 0 (29)
OTHER STATUS (30) N/A
METHOD OF DISCOVERY (31) B
DISCOVERY DESCRIPTION (32) Surveillance Test

ACTIVITY CONTENT
RELEASED OF RELEASE

1 6 2 33 34

7 8 9 10 11

AMOUNT OF ACTIVITY (35)

N/A

LOCATION OF RELEASE (36)

N/A

PERSONNEL EXPOSURES

NUMBER			TYPE	DESCRIPTION
1	7	0	(37) Z	(38) N/A

PERSONNEL INJURIES		DESCRIPTION
1	8	N/A

7		8		9		10		11		12	
LOSS OF OR DAMAGE TO FACILITY						(43)					
TYPE						DESCRIPTION					
1		9		Z		(42)					

7 8 9 10
PUBLICITY
ISSUED DESCRIPTION (45)
3 2 1 14
8302100395 830127
PDR ADOCK 05000293
S PDR
N/A
NRC USE ONLY

7 8 9 10 N/A 68 69 70 71 72 73 74 75 76 77 78 79 80

NAME OF PREPARER G.G. Whitney

PHONE: 617-746-7900