NRC FOR (7-77)	U. S. NUCLEAR REGULATORY COMMISSION
	CONTROL BLOCK:
0 1 7 8	N C B E P 2 0 0 - 0 0 0 - 0 0 0 0
CON'T	REPORT L 6 0 5 0 - 0 3 2 4 7 0 1 0 3 8 3 8 0 2 0 2 8 3 9 SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80 9 EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10
0 2	Following a reactor scram caused by a group one isolation, the suppression pool level
03	was noted to be out of specification high at a level of -26.5 inches. The high limit]
04	for the suppression pool is -27 inches. This event did not affect the health or
05	safety of the public.
06	
0 7	
08	Technical Specifications 3.6.2, 6.9.1.9b
09 7 8	SYSTEM CODE 9 10 CODE SUBCODE
	Image: Note of the second se
	ACTION FUTURE EFFECT SHUTDOWN HOURS 22 ATTACHMENT NPRD-4 PRIME COMP. COMPONENT TAKEN ACTION DELANT METHOD HOURS 22 ATTACHMENT FORM SUB. SUBPLIER MANUFACTURER X 18 34 3 35 36 37 40 41 23 142 42 43 44 47
1.101	CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) [The high level in the suppression pool was caused by the operation of HPCI and the
10	
1 1	safety relief valves for level and pressure control during the event. The level was
12	restored to its normal operating band. This is considered a normal operating
13	transient and no further action is planned.
1 4 7 8	9 80
15	FACILITY STATUS S POWER OTHER STATUS 30 METHOD OF DISCOVERY DISCOVERY DESCRIPTION 32 C 28 0 0 0 0 29 NA B 31 Operator Surveillance 80
	9 10 12 13 44 45 46 80 CTIVITY CONTENT ELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)
7 8	9 10 11 44 45 80 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)
1 7 7 8	9 PEDSONNEL INIURIES 13 80
18	
7 8	LOSS OF OR DAMAGE TO FACILITY (4) B302140012 B30202 TYPE DESCRIPTION DESCRIPTION
7 8	
20	
7 8	0 10 68 69 60 67 NAME OF PREPARER R. M. Poulk, Jr. PHONE: 919-457-9521 6 6