



# MISSISSIPPI POWER & LIGHT COMPANY

*Helping Build Mississippi*

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

February 3, 1983

JAMES P. McGAUGHY, JR.  
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 3100  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Fire Doors OC409 and 1A203  
Blocked Open to Support  
Planned Maintenance  
Activities  
LER 83-008/99 X-0  
AECM-83/78

On January 4, 1983, a fire door in the Control Building and a fire door in the Auxiliary Building were blocked open to support planned maintenance activities. Both doors were required to be operable by Technical Specification 3.7.7. Attached is Special Report, LER 83-008/99 X-0.

Yours truly,

*J.P. McGaughy*  
for J.P. McGaughy

JPM:sap  
Attachment

cc: Mr. N. L. Stampley (w/a)  
Mr. R. B. McGehee (w/o)  
Mr. T. B. Conner (w/o)  
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk (w/a)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

8302140030 830203  
PDR ADOCK 05000416  
S PDR

Member Middle South Utilities System

OFFICIAL COPY

*IE 22*