DCS MS-016

Docket No. 50-368

Mr. William Cavanaugh, III Senior Vice President, Energy Supply Arkansas Power & Light Company P. O. Box 551 Little Rock, Arkansas 72203

Dear Mr. Cavanaugh:

By letter from A. E. Scherer (CE) to R. C. DeYoung (NRC), dated August 4, 1982, the staff was notified of a core protection calculator (CPC) software discrepancy in certain CE designed plants, including Arkansas Nuclear One, Unit 2. Subsequently, by letter of August 30, 1982, from J. R. Marshall (AP&L) to W. C. Seidle (NRC), the staff received Arkansas Nuclear One, Unit 2. Licensee Event Report No. 82-026/03L-0, which indicated that AP&L had been notified of the discrepancy by Combustion Engineering on August 2, 1982. In that report AP&L indicated that the CPC functional inconsistency was related to the penalty factors (PF) associated with failed Control Element Assembly Calculators (CEAC) Under certain conditions a large Departure from Nucleate Boiling Ratio (DNBR) PF and a large Low Power Density (LPD) PF should be applied to the CPCs. However, under these conditions only the large DNBR PF is apriled. Even though this condition is not in accordance with the design specifications, the report indicated that CE has concluded that there is adequate protection provided by CPC reactor trip logic to permit plant operation with the CPC software error. CE's justification is based on the supposition that DNBR trips would occur prior to any LPD trips that might be initiated when applying the LPD PF.

The staff has not reviewed this justification and doubts that the evaluation can be thorough, though the conclusion is probably true. The nature of the CPC software protection logic is not amenable to an evaluation or test program which can provide complete assurance that all circumstances requiring LPD trip protection have been adequately analyzed. Even if the conclusion is valid, the staff believes that the error degrades the protection provided by the CPCs by effectively eliminating one software trip path to the protection circuit.

In your LER No. 82-026/93L-0, you indicated that no corrective action would be taken at that time, but, to restore consistency with the original functional requirements and to assure compatibility with licensing documentation, the CPC software would be corrected at the time of the next software update. While the safety concern does not appear serious enough to warrant plant shutdown until the correction is implemented, the staff believes that the software should be corrected as soon as practical without impairing operation. For this reason, you are requested to provide us with a schedule within 30 days of your receipt of this letter, reflecting correction of the error at the

8302170063 830206 PDR ADOCK 05000368

OFFICIAL RECORD COPY

The information requested in this letter affects fewer than ten respondents; therefore OMB clearance is not required under P.L. 96-511.

Sincerely,

Original signed by:

Robert A. Clark, Chief Operating Reactors Branch #3 Division of Licensing

cc: See next page

DISTRIBUTION
Docket File
Local PDR
ORB #3 Rdg
D.Eisenhut
JHeltemes
RAClark
PKreutzer (3)
OELD
NSIC
E.L. Jordan
J.M.Taylor (1)
ACRS (10)
OLynch
Gray File

			1873			
OFF. EN	ORB#3:DL	ORB#3:DL	AD/CRS	.08B#3-DL	MOOR/	
SURNAME >	PKreutzer	OLypch:dd	AD/CRS LRumenstein	RACIARK	GLanas	
DATE	241 /83	2/1/83	2/4/85	216.183	1/ 183	
				DECORD O		 L

NRC FORM 318 (10-80) NRCM 0240

OFFICIAL RECORD COPY

cc:

Mr. John Marshall Manager, Licensing Arkansas Power & Light Company P. O. Box 551 Little Rock, Arkansas 72203

Mr. James P. O'Hanlon General Manager Arkansas Nuclear One P. O. Box 608 Russellville, Arkansas 72801

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 220
7910 Woodmont Avenue
Bethesda, Maryland 20814

Nicholas S. Reynolds, Esq. c/o DeBevoise & Liberman 1200 Seventeenth Street, N.W. Washington, D. C. 20036 U.S. Environmental Protection Agency Region VI Office ATTN: Regional Radiation Representative 1201 Elm Street Dallas, Texas 75270

S. L. Smith, Operations Officer Arkansas Nuclear Planning & Response Program P. O. Box 1749 Russellville, Arkansas 72801

Mr. Charles B. Brinkman
Manager - Washington Nuclear
Operations
C-E Power Systems
4853 Cordell Avenue, Suite A-1
Bethesda, Maryland 20014

Regional Administrator Nuclear Regulatory Commission, Region IV Office of Executive Director for Operations 611 Ryan Plaza Drive, Suite 1000 Arlington, Texas 76011

Mr. J. Callan U.S. NRC P. O. Box 2090 Russellville, Arkansas 72801