

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

February 10, 1983

U.S. Nuclear Regulatory Commission  
Region II  
Attn: Mr. James P. O'Reilly, Regional Administrator  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

Dear Mr. O'Reilly:


BELLEFONTE NUCLEAR PLANT UNITS 1 AND 2 - REMOVAL OF ITEMS FROM 10 CFR 50.55(e)  
STATUS 50-438  
50-439

Enclosed for your information and use is a list of items that should be removed from 10 CFR 50.55(e) status in your Bellefonte Nuclear Plant records. These deficiencies have been determined to have no adverse impact on the safety of operations of the plant and were so reported in TVA's final reports for each one. Therefore, they will be removed from our list of open 10 CFR 50.55(e) items.

If you have any questions, please get in touch with R. H. Shell at FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

  
L. M. Mills, Manager  
Nuclear Licensing

Enclosure

cc: Mr. Richard C. DeYoung, Director (Enclosure)  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

8302170342 830210  
PDR ADDCK 05000438  
S PDR

OFFICIAL COPY

IE 27

## ENCLOSURE

BELLEFONTE NUCLEAR PLANT UNITS 1 AND 2  
LIST OF ITEMS TO BE REMOVED FROM  
10 CFR 50.55(e) STATUS

<u>NCR No.</u>	<u>BLRD No.</u>	<u>OIE No.</u>	<u>Title</u>
CEB 79-3	N/A	438/79-01-02 439/79-01-02	Piping Embedded in Structural Concrete
1005	N/A	438/79-13-03 439/79-13-03	Water in Rock Anchor Tendons
PLNBLP8004	N/A	438/81-25-29 439/81-25-29	Air Handling Units in Communication Room
BLNCEB8104	50-438/81-49	438/81-20-05 439/81-20-05	Lock Off Pressure on Post-tensioning System
BLNBLP8129	50-438/82-01 50-439/82-01	438/81-33-06 439/81-33-06	Incorrect Design Temperature for RB Cooler Valves
BLNBLP8127	50-438/81-75 50-439/81-74	438/81-33-04 439/81-33-04	Overpressure Protection in the Decay Heat Removal System
BLNEEB8201	50-438/82-17 50-439/82-16	438/82-06-06 439/82-06-06	Improper Use of Circuit Breakers to Shed Non-IE Loads