

KAISER
ENGINEERS

KAISER ENGINEERS, INC.
P. O. BOX 201
MOSCOW, OHIO 43133

Date: 9-5-78

Standard Test Procedure

Perform Hydrostatic/Pneumatic Test, Test No. BB-25 in accordance
with attached Test Data Sheet and QACMI M-10.

Estimated Date of Test: 9-18-78

Test to be Conducted by: R. WELDER
Test Superintendent

CG&E Const. Approval: _____

Wm. H. Zimmer Nuclear Power Station
Hydrostatic/Pneumatic Test Report
(Page 1)

Test No. PR-25

A. Test Parameters

1. System to be tested REACTOR RECIRCULATION (RR)
Cleanliness Class "B"
2. Bldg. or Location of test R BLDG
3. Orientation and Terminal Points of test SEE ATTACHED P&ID
elevation of high point 553' elevation of low point 534'
el. _____
4. Attached Drawing Numbers & Revision Numbers M-47-1 REV: C7
5. Pipe Fabricator: KEI Other _____
6. Type Test: Hydrostatic ☒ Pneumatic ☐
7. Test Media FYRQUEL EHC HYDRAULIC FLUID
8. Test Plan (Select One) (USE SYSTEM HYDRAULIC UNIT FOR PRESSURE SOURCE.)
Hydrostatic KEI 10-101 ☒ Pneumatic KEI 10-103 ☐
Hydrostatic KEI 10-102 ☐
9. A. Required Test Pressure 3000 P.S.I.G. (minimum at highest elev.)
 1. From S&L Piping Line List
 2. 1.25 times design pressure Ref. ASME Code
 3. 1.5 times design pressure Ref. ANSI B31.1
 4. As specified by CG&E Construction Engineer for Class D Systems only

Signature/Date N/A

B. Maximum pressure to which system can be pressurized 3150 PSIG
(material or component restraint)

Wm. H. Zimmer Nuclear Power Station
Hydrostatic/Pneumatic Test Report
(Page 2)Test No. RR-35C. Gauge location (elevation) 530' expected static pressure reading
10 PSIGD. Specified test pressure (9A + 9C) 2010 PSIGE. Greater of 3/4 test pressure or (design pressure (ASME test only))
2000 PSIGF. Holding test pressure (~~9A + 9E~~) 3000 PSIG10. Test Parameters completed by John J. Pitter 9-5-78
Signature/Date

Verified

9/11/79 9/11/79
KEI Q.A. EngineerB. Test Prerequisites1. Valve Lineup completed by [Signature] 3-5-79
Signature/Date2. Water Analysis Report available N/A
and acceptable. KEI-QA Signature/Date 123. Test Gauges: Note Range shall be more than 1½ times test pressure
but
but less than 4 times test pressure.S/N 106-58 Range 0-5000 Psi Calib. date 10-22-78 Due date 4-23-79S/N 106-102 Range 0-5000 Psi Calib. date 1-22-79 Due date 7-27-79S/N N/A Range ± Psi Calib. date Due date

9/27/79 - RETEST - 106-71 - 0-5000

9/11/79

3/11/80

9/27/79 - RETEST - 106-68 - 0-5000

9/11/79

3/11/80

" " " " TS-1:00

" " " " TR-236

" " " " HT-10 MIN

1. PLOTS ① VALUE B33-F3450. REASON FOR
TIME OF TEST. WERE 245 11)
NOT INSPECTED.

Wm. H. Zimmer Nuclear Power Station
Hydrostatic/Pneumatic Test Report
(Page 3)

Test No. RR-25

C. Test Results

1. Ambient temp. 75° Media temp. 75°
2. Time test started 10:15 AM Time test pressure reached 10:25 AM
Hold time 10 min Time test completed 10:45 AM
Test Gauge Pressure Reading at test 3025 PSIG
3. Test Results & Remarks: No Leaks

4. Test conducted by: Alfredo 3-5-79
Signature/date

5. Remove test tags, remove test equipment, etc.

Alfredo 3-5-79
Signature/date

D. Test Witnessed and Accepted By:

1. IRI Hydrotect Super.
and/or Engineer

Alfredo 3-5-79
Signature/date

2. Quality Assurance Representative

[Signature] 3-5-79
Signature/date WITH 1 EX-100
(NO BACK)

3. CG&E Representative/Ohio Special Insp.

P. L. Wood 3/5/79
Signature/date

4. Authorized Nuclear Inspector

A. A. Chel 3-5-79
Signature/date


HYDROSTATIC TEST VALVE LINE UP Hydro RR-25

VALVE NUMBER	POSITION	COORDINATES	DRAWING NUMBER
1B33F3 ID	Open	4-4	M-47-1
1B33F3 ID	Closed	4-4	M-47-1

Note: Protect all instruments in panels, on racks, etc. from Hydro Test Pressure.

[illegible]

NOT TO BE USED FOR
PHYSICAL CONSTRUCTION




ITEM	HEAT NUMBERS
1	
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	
13	
14	
15	
16	
17	
18	
19	
20	
21	
22	
23	
24	
25	
26	
27	
28	
29	
30	
31	
32	
33	
34	
35	
36	
37	
38	
39	
40	
41	
42	
43	
44	
45	
46	
47	
48	
49	
50	
51	
52	
53	
54	
55	
56	
57	
58	
59	
60	
61	
62	
63	
64	
65	
66	
67	
68	
69	
70	
71	
72	
73	
74	
75	
76	
77	
78	
79	
80	
81	
82	
83	
84	
85	
86	
87	
88	
89	
90	
91	
92	
93	
94	
95	
96	
97	
98	
99	
100	

MATERIAL - TAKE OFF CLASS B ESSENTIAL		2540WZ	
MATERIAL DESCRIPTION & QTY		MATERIAL DESCRIPTION & QTY	
A	24' LF 3/4" DIA. GALV. PIPE	B	24' LF 3/4" DIA. GALV. PIPE
B	4 EA 3/4" DIA. GALV. PIPE	C	4 EA 3/4" DIA. GALV. PIPE
C	1 EA 3/4" DIA. GALV. PIPE	D	1 EA 3/4" DIA. GALV. PIPE
D	1 EA 3/4" DIA. GALV. PIPE	E	1 EA 3/4" DIA. GALV. PIPE
E	1 EA 3/4" DIA. GALV. PIPE	F	1 EA 3/4" DIA. GALV. PIPE
F	1 EA 3/4" DIA. GALV. PIPE	G	1 EA 3/4" DIA. GALV. PIPE
G	1 EA 3/4" DIA. GALV. PIPE	H	1 EA 3/4" DIA. GALV. PIPE
H	1 EA 3/4" DIA. GALV. PIPE	I	1 EA 3/4" DIA. GALV. PIPE
I	1 EA 3/4" DIA. GALV. PIPE	J	1 EA 3/4" DIA. GALV. PIPE
J	1 EA 3/4" DIA. GALV. PIPE	K	1 EA 3/4" DIA. GALV. PIPE

[illegible]

85-11-78
1/2

CLEAN CLASS	B	SEI-MC CLASS	B
DESIGN TEMP	185°F	DESIGN PRESS	3000 PSI
REF SPEC	H-2256	INSULATION	M/A
WELD PROCEDURE			
LINE NO	IRR39AD 3/4"		
MANC'D NO			
PART NO	PR-243-A, B, C, D, E		
USE THIS	M-47-1, M-464-3		
SEE	AA-533 REACTOR BLDG.		
REMARKS	PLS. VERIFY: YES		
	REACTOR REGISTRATION		




20" RECIRCULATING
FLOW CONTROL
BALL VALVE,
#1B33FOGO A

NO	DATE	BY	DESCRIPTION	REVISIONS
WIM. H. ZIMMER NUCLEAR POWER STATION UNIT 1 KAISER ENGINEERS KAISER ENGINEERS INC JONNO TOTO				
TOTAL				1105

KAISER
ENGINEERING

BAISSE ENGINEERS
JOB NO 7010

FOR OFFICIAL USE ONLY
NOT TO BE USED FOR
PHYSICAL CONSTRUCTION



FOR CONT. SEE
DWG M-464-1
LINE NO. IRR46AD-1

ITEM	HEAT NUMBERS
A.	
B.	
C.	
D.	
E.	
F.	
G.	
H.	
I.	
J.	

LINE	DATE	BY	REV	DESCRIPTION	QUANTITY	UNIT	REMARKS
A	12	12	12	505 DEE A21 MAR 20 12 505			
B	12	12	12	315A 2 1/2 WAVELENGTHS 12 505			
C	12	12	12	115A 1 1/2 WAVELENGTHS 12 505			
D	12	12	12	115A 1 1/2 WAVELENGTHS 12 505			
E	12	12	12	115A 1 1/2 WAVELENGTHS 12 505			
F	12	12	12	115A 1 1/2 WAVELENGTHS 12 505			
G	12	12	12	115A 1 1/2 WAVELENGTHS 12 505			
H	12	12	12	115A 1 1/2 WAVELENGTHS 12 505			
I	12	12	12	115A 1 1/2 WAVELENGTHS 12 505			

[illegible]

ALL BENDING PER FIELD
CONSTRUCTION PROCEDURE 2-205
BEND A - 52° - 22'
BEND B - 52° - 0'
BEND C - 87° - 33'
BEND D - AS NOTED

The welding data noted on this ITR shall not apply to groove weld connections to large bore pipes.

CLEAN CLASS	B	SEWING CLASS	B
DESIGN. TEMP	185°F	DESIGN PRESS	3000 PSI
REF. SPEC	H-2256	INSULATION	N/A
WELD PROCEDURE			
LINE NO	14R39AD347		
MANAGER NO			
PIECE NOS			
REF. QUES. M-47-1, M-464-3			
AA-553 REACTOR BLDG			
R/S			
REACTOR RECIRCULATION (R)			

HEAD
DETAIL
RR-3
See Doc# M-2654


10-AL WFL03

WM. H. ZIMMER NUCLEAR POWER STATION UNIT 1

**KAISER
ENGINEERING**

an Engineering, Inc.
AGE NO. 3070

06-07-81-A-209

[illegible]

85-11-78

The welding data noted on this LK shall not apply to groove weld connections to large pipe.

CLEAN CLASS	B
DESIGN TEMP	150°F
DESIGN PRESS	300 PSI
REP SPEC	H-2256
INSULATION	N/A
WELD PROCEDURE	
LINE NO	IRR-4140-00
HANGER NO	012 H6
LINE NOS	RR-443-A, B
M-471 M-464-3 AA-584 REACTOR REACTOR REPLICULA M-464-3-RR-213	

RR-3




TOTAL WEIGHTS


WM. H. ZIMMER NUCLEAR POWER STATION UNIT 1

KAISER
ENGINEERS

WATERBURY, CONNECTICUT, 1970
JOS. M. J. 1070

M-47-1 M-54-2
 AA-544 REACTOR
 FL-5
 REACTOR RECIRCULAT
 M-44-3-22-2





STANDARD TEST PROCEDURE - HEAD SHEET

YES

NO

a. Dates Established

☒☐

b. Package numbered

☒☐

c. Test Conducted

☒☐

A. TEST PARAMETERS - SHEET '1

Items filled in correctly

1. Systems & Class

☒☐

2. Location of Test

☒☐

3. Elevation of Terminal PTs

☒☐

4. Attached Drawings

☒☐

5. Pipe Fabricator Noted

☒☐

6. Type Test Matches A.3

☒☐

7. Test Media

☒☐8. Test Plan (only one) and Revision
Number Noted☒☐

9. a.1. As per S&L

☒☐

a.2. As per CG&E

☒☐

9b. Maximum Pressure

☒☐

9c. Amount of Head Pressure

☒☐

9d. Gauge Location & Elev Correct

☒☐

9e. Initial Test Pressure Correct

☒☐

9f. Holding Test Pressure Correct

☒☐

10. Test Parameters

Completed by: signed and dated correctly

☒☐

Verified by: signed and dated correctly

☒☐

Check list completed and reviewed by

GC FilDate 7/2/50

QUALITY CHECKLIST AND RECORD / HYDROSTATIC TESTING

	YES	NO
F. 1. Valve Line up Signed and Dated	☒	☐
2. Water Analysis Report Signed and Dated	☒	☐
3. Test Gauges Listed	☒	☐
Ranges Acceptable	☒	☐
Calibration Dates Acceptable	☒	☐
C. 1. Temperatures Filled In	☒	☐
2. Time Test Started: Completed	☒	☐
Time Test Reached: Completed	☒	☐
Hold Time Correct	☒	☐
3. Test Results: Completed	☒	☐
D. 1. KEI Supv./or Engineer Signed and Dated	☒	☐
2. Q.A. Representative Signed and Dated	☒	☐
3. CG&E Representative Signed and Dated	☒	☐
4. A.N.I.: Signed and Dated	☒	☐
E. Remove Test Tags, Remove Test Equipment etc. Signed and Dated	☒	☐
F. Hydrostatic Test Valve Line up All Items Complete and Match P.I.D. Boundaries	☒	☐
G. PSK or ISKs Marked with Boundaries and Valves Match Valve List	☒	☐

Check list completed and reviewed by A. C. Fall Date 4/2/80