

# Duquesne Light Company

Beaver Valley Power Station  
P.O. Box 4  
Shippingport, PA 16077-0004

JOHN D. SIEBER  
Vice President - Nuclear Group

April 5, 1991

4121 393 6215

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

Subject: Beaver Valley Power Station, Unit No. 1  
Docket No. 50-334, License No. DPR-66  
Revision 1B to the Inservice Test Program  
(TAC No. 80040)

This submittal forwards, for NRC review and approval, three new relief requests for the Beaver Valley Unit No. 1 Inservice Test (IST) Program. The attached proposed revision 1B is submitted in accordance with Generic Letter No. 89-04, Guidance on Developing Acceptable Inservice Testing Programs, paragraph D. The guidance provided in Attachment 1 to Generic Letter No. 89-04 is not appropriate for these relief requests and as such requires NRC approval as provided in 10 CFR 50.55 a(g).

It is requested that the NRC disposition these relief requests before June 1, 1991, so that appropriate procedure changes and plant controls can be implemented prior to restart from the eighth refueling outage tentatively scheduled to end on June 14, 1991.


Proposed revision 1B adds three new relief requests which would increase the surveillance frequency interval for fifteen river water valves in the flow path to the recirculation spray heat exchangers. This change is required since we intend to place the river water side of the recirculation spray heat exchangers in wet layup prior to plant startup from this refueling outage. Quarterly valve stroking will no longer be possible with the heat exchangers isolated in wet layup conditions.

The following is attached for your review:

- proposed revision approval sheet
- revised valve testing outline sheets (4 pages)
- relief requests 43, 44, and 45

If you have any questions regarding this submittal, please contact Steve Sovick on (412) 393-5211.

Sincerely,

  
J. D. Sieber  
Vice President  
Nuclear Group

9104120349 910405  
PDR ADOCK 05000334  
PDR

cc: Mr. J. Beall, Sr. Resident Inspector  
Mr. T. T. Martin, NRC Region I Administrator  
Mr. A. W. DeAgazio, Project Manager  
Mr. R. Saunders (VEPCO)

110981

A047