

G. Reactor Coolant Leakage2. Leakage Detection Systems (Cont'd)

a. (Continued)

in the reactor vessel and reactor coolant temperature is above 212°F. Further, the primary containment atmosphere particulate radioactivity monitoring system shall be among these ~~three~~ operable systems, or samples shall be obtained and analyzed at least once each 4 hours.

two

d. From and after the date that any two of the four systems identified in Table 3.2-10, note c are made or found to be inoperable, but with the primary containment atmosphere particulate radioactivity monitoring system ~~inoperable~~, reactor power operation may continue for the succeeding 30 days provided the primary containment atmosphere particulate radioactivity monitoring system reading is checked and recorded at least once each 4 hours.

operable

c. From and after the date that any two of the four systems, including the primary containment atmosphere particulate radioactivity monitoring system, identified in Table 3.2-10, note c are made or found to be inoperable, reactor power operation may continue for the succeeding 30 days provided samples of the containment atmosphere are obtained and analyzed at least once each 4 hours.

G. Reactor Coolant Leakage2. Leakage Detection Systems (Cont'd)

a. (Continued)

in the reactor vessel and reactor coolant temperature is above 212°F. Further, the primary containment atmosphere particulate radioactivity monitoring system shall be among these two operable systems, or samples shall be obtained and analyzed at least once each 4 hours.

b. From and after the date that any two of the four systems identified in Table 3.2-10, note c are made or found to be inoperable, but with the primary containment atmosphere particulate radioactivity monitoring system operable, reactor power operation may continue for the succeeding 30 days provided the primary containment atmosphere particulate radioactivity monitoring system reading is checked and recorded at least once each 4 hours.

c. From and after the date that any two of the four systems, including the primary containment atmosphere particulate radioactivity monitoring system, identified in Table 3.2-10, note c are made or found to be inoperable, reactor power operation may continue for the succeeding 30 days provided samples of the containment atmosphere are obtained and analyzed at least once each 4 hours.