

ISHAM, LINCOLN & BEALE  
COUNSELORS AT LAW

DOCKETED  
1/31/83

THREE FIRST NATIONAL PLAZA  
CHICAGO, ILLINOIS 60602  
TELEPHONE 312 558-7500  
TELEX 2-5288

'83 FEB 17 11:01

EDWARD S. ISHAM, 1872-1902  
ROBERT T. LINCOLN, 1872-1889  
WILLIAM G. BEALE, 1885-1923

WASHINGTON OFFICE  
1120 CONNECTICUT AVENUE, N.W.  
SUITE 840  
WASHINGTON, D.C. 20036  
202 633-9730

OFFICE OF THE  
DOCKETING & SERVICE  
BRANCH

February 14, 1983

In the Matter of )  
 )  
CONSUMERS POWER COMPANY )  
 )  
(Midland Plant, Units 1 )  
and 2) )

Docket Nos. 50-329-OM  
50-330-OM  
50-329-OL  
50-330-OL

Charles Bechhoefer, Esq.  
Atomic Safety & Licensing  
Board Panel  
U.S. Nuclear Regulatory Com-  
mission  
Washington, D. C. 20555

Dr. Jerry Harbour  
Atomic Safety & Licensing  
Board Panel  
U.S. Nuclear Regulatory Com-  
mission  
Washington, D. C. 20555

Dr. Frederick P. Cowan  
6152 N. Verde Trail  
Apt. B-125  
Boca Raton, Florida 33433

Dear Administrative Judges:

In my letter dated February 3, 1983 I listed 10 items of information which, during the evidentiary hearings held in November and December, 1982, Applicant had agreed to provide (or consider providing). Item Number 10 was a list of all underground piping protected by the galvanic protection system, which Ms. Stamiris requested. The enclosures constitute Applicant's response to this request. In addition, I include Applicant's proposed transcript corrections for the November and December hearings.

DS03

The first enclosure is a handwritten list of "Lines Protected by Cathodic Protection" which was compiled by Scott Woodby at my request. Mr. Woodby, the Board will recall, was a witness in the November hearings.

When I reviewed the list, I had difficulty relating it to Applicant's previous testimony on underground piping. Accordingly, I asked Wesley Kinnear, a legal assistant at IL&B, to write a letter to Bechtel asking for their help. Mr. Kinnear's letter is the second enclosure.

The third enclosure is Bechtel's response, which includes at the end (Attachment 2) a four-page list of lines protected or to be protected by the galvanic protection system. This list should be regarded as the authoritative response, where it differs from Mr. Woodby's list.


To summarize our response to Ms. Stamiris' question: all "Q listed" or Category I underground piping is designed to be protected by the galvanic protection system. I am informed that this will be field-verified before the plant starts operation. During the construction period, the underground lines are not necessarily installed at the same time as the nearest anodes in the galvanic protection system. For example, Mr. Woodby testified in November that the galvanic protection system is being expanded substantially this Spring.

In addition, Bechtel states that the galvanic protection system is also designed to protect all non-Q, non-Category I underground piping used for plant operation. The only lines which will not be protected by the galvanic protection system are lines used only for construction purposes, and of course, all aboveground lines.

The first three enclosures to this letter are communications between CPCo's employee, its consultant, and its lawyers. By providing these documents Applicant does not make any general waiver of the attorney-client or work product privileges as to other such communications. Nor, of course, do we concede that any further evidentiary presentation on the galvanic protection system or potential corrosion of underground piping is necessary or appropriate.

I also include Applicant's proposed transcript corrections for the November and December evidentiary hearings. This was a more difficult job than usual and some guesswork was involved. I hope the Board and the other parties will use independent judgment in reviewing these proposed corrections. I include one group of references where I was uncomfortable even guessing what was actually said; I think in most of these cases the Staff will be able to straighten things out.

Respectfully submitted,

  
Philip P. Steptoe

PPS:es  
enc.  
cc service list

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

DOCKETED  
USNRC

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD


'83 FEB 17 AM 11:01

In the Matter of:	)	Docket Nos. 50-329 OM
	)	50-330 OM
CONSUMERS POWER COMPANY	)	Docket Nos. 50-329 OL
(Midland Plant, Units 1 & 2)	)	50-330 OL

OFFICE OF SECRETARY  
DOCKETING & SERVICE  
BRANCH

CERTIFICATE OF SERVICE

I, Rebecca J. Lauer, one of the attorneys for Consumers Power Company, hereby certify that copies of the enclosed February 14, 1983 letter from Philip P. Steptoe to the Administrative Judges, together with the galvanic protection system enclosures and proposed transcript corrections, was served upon all persons shown in the attached service list by deposit in the United States mail, first class, this 14th day of February, 1983; except where service was made as otherwise indicated.

  
Rebecca J. Lauer

Isham, Lincoln & Beale  
Three First National Plaza  
Suite 5200  
Chicago, Illinois 60602  
(312) 558-7500

SERVICE LIST

Frank J. Kelley, Esq.  
Attorney General of the  
State of Michigan  
Carole Steinberg, Esq.  
Assistant Attorney General  
Environmental Protection Div.  
720 Law Building  
Lansing, Michigan 48913

Cherry & Flynn  
Suite 3700  
3 First National Plaza  
Chicago, Illinois 60602

\*Mr. Wendell H. Marshall  
4625 S. Saginaw Road  
Midland, Michigan 48640

\*Charles Bechhoefer, Esq.  
Atomic Safety & Licensing  
Board Panel  
U.S. Nuclear Regulatory Comm.  
Washington, D.C. 20555

\*Dr. Frederick P. Cowan  
6152 N. Verde Trail  
Apt. B-125  
Boca Raton, Florida 33433

James E. Brunner, Esq.  
Consumers Power Company  
212 West Michigan Avenue  
Jackson, Michigan 49201

Mr. D. F. Judd  
Babcock & Wilcox  
P. O. Box 1260  
Lynchburg, Virginia 24505

\*Barbara Stamiris  
5795 North River Road  
Route 3  
Freeland, Michigan 48623

Steve Gadler  
2120 Carter Avenue  
St. Paul, Minnesota 55108

Atomic Safety & Licensing  
Appeal Panel  
U. S. Nuclear Regulatory Comm.  
Washington, D.C. 20555

Mr. C. R. Stephens  
Chief, Docketing & Services  
U.S. Nuclear Regulatory Comm.  
Office of the Secretary  
Washington, D.C. 20555

\*Ms. Mary Sinclair  
5711 Summerset Street  
Midland, Michigan 48640

\*William D. Paton, Esq.  
Counsel for the NRC Staff  
U.S. Nuclear Regulatory Comm.  
Washington, D. C. 20555

Atomic Safety & Licensing  
Board Panel  
U.S. Nuclear Regulatory Comm.  
Washington, D.C. 20555

\*Jerry Harbour  
Atomic Safety & Licensing  
Board Panel  
U.S. Nuclear Regulatory Comm.  
Washington, D.C. 20555

Lee L. Bishop  
Harmon & Weiss  
1725 "I" Street, N.W. #506  
Washington, D.C. 20006

\*Personally served on February 14, 1983

LINES PROTECTED BY CATHODIC PROTECTION PER E-522

SH/A Rev 1

DOMESTIC WATER  
3" OYSG-1

(NQ)

FIRE WATER  
12" OYSF-1  
8"  
6"

(NQ)

SERVICE WATER

26" OHBC-20	(Q)	26" OHBC-16	(Q)
26" OHBC-19	(Q)	26" OHBC-15	(Q)

LINES FOR

STRAINED SIZES	IT 60	18" IHCB-1, 18" IHCB-2, 4" IHCB-33, 4" IHCD-166	(Q)
	ZT 60	18" ZHCB-1, 18" ZHCB-2, 4" ZHCB-33, 4" ZHCD-166	(Q)
	OT 15	4" OHCD-571, 4" OHCD-572, 3" OHCD-743, 1" OHCD-741	?
	OT 54	3" OHCD-703, 4" OHCD-774, 4" OHCD-775, 3" OHCD-575, 1 1/2" OHCD-750, 6" OHCD-755, 4" OHCD-745	

LINES FOR TANKS OT 15 AND OT 54 ARE CONSIDERED CLASS II SYSTEMS. WHOSE FAILURE WOULD NOT RESULT IN A RELEASE OF RADIOACTIVITY AND WOULD NOT PREVENT SAFE REACTOR SHUT DOWN IN A DESIGN BASE ACCIDENT.



SH 1B REV 1

DOMESTIC WATER

WG

SERVICE WATER

26" OHBC-15

CC

26" OHBC-16

CC

26" OHBC-19

CC

26" OHBC-20

CC

FIRE WATER

12" OKSF-1

WG

6"

WG

8" OKSF-5

WG

SH 1C Rev 1

CIRC WATER

96" - 2YBS-4

(NQ)

96" - 2YBS-3

(NQ)

72" - 1YBS-4

(NQ)

72" - 1YBS-3

(NC)

12" - 0YBS-13

(NC)

SERVICE WATER

26" - OHBC-54

(Q)

26" - OHBC-53

(Q)

26" - OHBC-56

(Q)

26" - OHBC-55

(Q)

26" - 2SBD-1

?

26" - 2SBD-2

FIRE WATER

12" - OKSF-1

(NQ)



SH ID Rev 1

DIESEL GENERATOR FUEL STORAGE TANKS

2T-78A

1T-78A

2T-78B

1T-78A

FIRE WATER

12"-OKSF-1

SERVICE WATER

26"-OHBC-54

26"-OHBC-53

26"-OHBC-56

26"-OHBC-55

26"-OHBC-19

26"-OHBC-20

26"-OHBC-15

26"-OHBC-16

CIRC WATER

72"-14BS-1

72"-14BS-2

96"-24BS-1

96"-24BS-2

SH 2A REV 0

FIRE WATER

12" - OKSF - 1

6"

4"

8"

OT- 117 (OIL TANK)

1" - OHBD - 851

1" - OHBD - 864

3" - OHBD - 868 (VENT)

CONDENSATE RETURN LINES (Dew)

STAINLESS  
STEEL

18" - OHCD - 974

6" - OHCD - 419

1" - OYDD - 17

SH2B REV0

FIRE WATER

12" - OKSF - 1

6" -

4" -

8" - OKSF - 28

8" - OKSF - 25

8" - OKSF - 27

6" - OKSF - 11

CA

CA

SHZC REV 0

FIRE WATER

12" - OKSF-1

8" - OKSF -

NE

2

SH 3 REV 1

DOMESTIC WATER  
8" DUCTILE IRON

N/C

NOTE. MAGNESIUM SACRIFICIAL ANODES USED TO  
PROTECT THIS PIPE.

January 25, 1982

FEDERAL EXPRESS

Mr. Donald Lewis  
Bechtel Power Corporation  
777 E. Eisenhower Parkway  
Ann Arbor, Michigan 48106

Dear Mr. Lewis:

Phil Steptoe asked me to write you in connection with Consumers' commitment to provide to the Licensing Board more information about the cathodic protection system.

Scott Woodby of Consumers has given us a list of lines which he has determined are protected by the cathodic system (enclosed). I have spoken with him, but we still have a few important questions.

1. Are all Q lines protected by the galvanic protection system? I have compared Table UP-1 of your testimony of February, 1982 (enclosed) with Mr. Woodby's list but I am not able to find all the Q lines you list on Scott Woodby's list. I mark these unaccounted for lines on the two lists with a question mark. If these lines are in fact protected by the system, please so indicate.
2. We need a correspondence of label numbers in order to know which number goes with which pipe. That is, it seems that sometimes lines are referred to by the tank which they serve (e.g. 1T60, on page 1 of Mr. Woodby's list) and sometimes by a pipe number (e.g. 18" - 1HCB-1, same reference). I may have confused the system of labels, but in any case we need to be clear what is referred to so that we can make a reliable statement to the Licensing Board.

3. Finally, we need a description or listing of lines, especially Q lines, not protected by the galvanic protection system and an explanation of why they are not protected. (That they are non-Q would probably be adequate justification.) For example, it appears from Mr. Woodby's list that the diesel generator fuel oil lines are not protected by the cathodic system. Is this true, and, if so, why?

To summarize, what we need to know is: are all Q lines protected by the cathodic system; and what lines are not protected and why. If you could provide this information either by marking up the two lists I enclose or by creating a new list, we would be most grateful. We have promised to inform the Licensing Board in the very near future, so we would ask that if at all possible you provide the necessary information to us within a week. If this proves impossible or there is any other difficulty, please contact Phil Steptoe or me.

Thank you very much for your assistance.

Sincerely,

Wesley Kinnear  
Legal Assistant

WK:sc

Enclosure

cc: Scott Woody



TABLE UP-1  
SEISMIC CATEGORY I LINES

A. Service Water Lines

8"-1HBC-310	}	26"-OHBC-53 ✓
8"-2HBC-81		26"-OHBC-54 ✓
8"-1HBC-81		26"-OHBC-55 ✓
8"-2HBC-310		26"-OHBC-56 ✓
8"-1HBC-311		26"-OHBC-15 ✓
8"-2HBC-82		26"-OHBC-16 ✓
8"-1HBC-82		26"-OHBC-19 ✓
8"-2HBC-311		26"-OHBC-20 ✓
10"-OHBC-27		36"-OHBC-15
10"-OHBC-28		36"-OHBC-16
	36"-OHBC-19	
	36"-OHBC-20	

B. Diesel Fuel Oil Lines

1-1/2"-1HBC-3 - ?	2"-1HBC-497 - ?
1-1/2"-1HBC-4 - ?	2"-1HBC-498 - ?
1-1/2"-2HBC-3 - ?	2"-2HBC-497 - ?
1-1/2"-2HBC-4 - ?	2"-2HBC-498 - ?

C. Borated Water Lines

- 18"-1HCB-1 ✓
- 18"-1HCB-2 ✓
- 18"-2HCB-1 ✓
- 18"-2HCB-2 ✓

D. Control Room Pressurization Lines

- 4"-ODBC-1 - ?
- 1"-OCCC-1 - ?

# Bechtel Associates Professional Corporation

104472 777 East Eisenhower Parkway  
Ann Arbor, Michigan

Mail Address: P.O. Box 1000, Ann Arbor, Michigan 48106



Isham, Lincoln & Beale  
Three First National Plaza  
Chicago, Illinois 60602

Attention: Mr. P. Steptoe

Subject: Midland Plant Units 1 and 2  
Consumers Power Company  
Bechtel Job 7220  
CATHODIC PROTECTION SYSTEM  
Reference: Isham, Lincoln & Beale  
Letter to Bechtel,  
W. Kinnear to D. Lewis,  
1/25/83 (Com 102693)

This is in response to the referenced letter from your Mr. W. Kinnear requesting additional information about the cathodic protection system. The following paragraphs are numbered to correspond to the questions in the reference.

1a. Are all Q lines protected by the galvanic protection system?

All buried Seismic Category I piping (as well as all buried non-Seismic Category I piping) is protected by the cathodic protection system in accordance with Bechtel Drawing 7220-E-40.

1b. Not all the Q lines listed in the testimony of Lewis, et al., February 1982 are on Scott Woodby's list.

Mr. Woodby's list should be amended in accordance with Attachment 2 to this letter. Attachment 2 is consistent with the Seismic Category I piping listed in the February 1982 testimony as supplemented by the May 3, 1982, submittal to the NRC (Attachment 1). In each case where Mr. Woodby's list did not address a line or tank, the Bechtel electrical discipline reviewed the design documents to confirm that the particular line or tank was protected by the cathodic protection system.

# Bechtel Associates Professional Corporation

104472

Letter to Isham, Lincoln & Beale

Page 2

2. We need a correspondence of label numbers in order to know which number goes with which pipe.

The correspondence of label numbers you requested is provided in Attachment 2.

- 3a. A description or listing of lines, especially Q lines, not protected by the galvanic protection system was requested.

Aboveground piping is not protected by the cathodic protection system.

- 3b. It appears from Mr. Woodby's list that the diesel generator fuel oil lines are not protected by the cathodic system. Is this true and, if so, why?

Drawing 7220-E-40, Section 1.4c indicates that diesel fuel storage tanks and associated piping are to be provided with cathodic protection. Our review confirmed that the diesel fuel oil lines are, in fact, shown on the design drawings as being protected by the cathodic protection system.

If you have any further questions, please contact us.

Very truly yours,

*E.M. Hughes for*  
E.M. Hughes  
Ann Arbor  
Project Engineer

DFL/RLR/jsh\*(LS)

- Attachments: 1. CPGO Letter Serial 16881 to NRC, J. Mooney for J. Cook to H. Denton, 5/3/82 (Com 069372)  
2. Cathodic Protection of Seismic Category I and Other Buried Piping and Tanks

cc (all w/a):

J. Brunner (CPGO)  
W. Kinnear (IL&B)  
M. Puschell (CPGO)  
S. Woodby (CPGO)

Written Response Requested: No

0298c



69372  
Consumers  
Power  
Company 104472

James W Cook  
Vice President - Projects, Engineering  
and Construction

General Offices: 1945 West Parnall Road, Jackson, MI 49201 • (517) 788-0453

May 3, 1982

Harold R Denton, Director  
Office of Nuclear Reactor Regulation  
Division of Licensing  
US Nuclear Regulatory Commission  
Washington, DC 20555

MIDLAND PROJECT  
MIDLAND DOCKET NO 50-329, 50-330  
UNDERGROUND PIPING INFORMATION REQUESTED DURING APRIL 16, 1982 MEETING  
FILE: 0485.16 SERIAL: 16881

- REFERENCES:
- (1) J W COOK LETTER TO H R DENTON,  
SERIAL 16269, DATED MARCH 16, 1982
  - (2) J W COOK LETTER TO H R DENTON,  
SERIAL 16638, DATED APRIL 15, 1982

- ENCLOSURES:
- (1) TABLE 1.0 MONITORING STATION OVALITY  
AND CORRESPONDING STATION
  - (2) BURIED CATEGORY 1 LINES AND TANKS
  - (3) ADDITIONAL GEOTECHNICAL INFORMATION

The purpose of this letter is to provide confirmatory information regarding several issues discussed during a meeting between the NRC Staff and Consumers Power Company. The meeting was held in Bethesda on April 16, 1982.

Enclosure 1 is an expansion of the table previously submitted by our letter, Serial 16638, dated April 15, 1982. Additional information is provided specifying the future allowable strain based on an acceptance criteria and technical specification limit of 0.48% strain. The number of strain gages has also been specified in the table. The number of gages were determined by reviewing the pipe elevation profiles for abrupt inflection points and critical buckling zones. The strain gages are to be mounted one pipe diameter apart at a given monitoring station.

At the April 16 meeting a concern arose about the accuracy of the vibrating wire strain gages. In a telephone conference with the Irad Gage Company, they indicated the instrument is accurate to 10 (4)inch/inch) as a worst case condition for any type of vibrating wire gage. This includes accounting for inaccuracies in installation and calibrations. This accuracy is an order of magnitude greater than the accuracy required for the strain measurements to be taken (.0001 in/in vs .00001 in/in).

1044 A clarification on the technical specification limits and requirements proposed in the pipe monitoring program submitted March 16, 1982 is necessary. Our intention is to use the 4% ovality (equivalent .0048 inch/inch strain) which includes appropriate safety factors as the technical specification unless we can justify a higher value at a later date. If the specified limit is reached we would immediately notify the NRC Staff and increase the monitoring frequency to one month intervals. In parallel with the Staff notification an engineering evaluation of the situation would be performed. This evaluation would consider the remedial action necessary to restore the safety function and reliability of the service water system to overall plant operations. The actions necessary may very well include excavation of the piping in the affected zone for visual examination and possible replacement or sleeving.


*Q lines* The NRC Staff asked Consumers Power Company to verify that no other buried Category 1 pipes remain unidentified. Enclosure 2 is a current table of all the buried seismic Category 1 lines and tanks. The pressurization lines and tanks have been added to the list of buried Category 1 piping. The control room pressurization lines and tanks were installed during the summer 1981, and therefore not subjected to the soils settlement problems. The penetration pressurization lines and tanks have not been installed; however appropriate procedures for soil settlement will be followed. The list does not include the 48-inch diameter (48-OHBC-2) discussed in Enclosure 3 of our letter, Serial 16638, dated April 15, 1982.

*this line was  
subsequently  
reclassified  
as non-Q*

The NRC Staff expressed a concern regarding the margins for future settlement at the wall penetration of pipeline 26-OHBC-15. Our investigations indicate that there is a 90° elbow fitting in this line immediately upon exiting the building. Any bending moment developed due to soils settlement will be transformed to an equal torque value. This load transformation causes the vertical deflection due to settlement to change to an angle of twist on the pipe at the penetration. This angle of twist has no effect on the annulus clearance of the wall penetration and therefore the only real clearance we need to assure is the seismic rattlespace (0.3693 inch). The margin we presently have is 0.6307 inches which is a factor of 1.7 times the conservative estimate of seismic rattlespace.

The NRC Geotechnical Branch requested information concerning soils and its relation to buried utilities. Enclosure 3 addresses the concerns expressed about the prediction of maximum future settlement for plant life (3.0 inches) and the isolated sand pocket near the diesel fuel tanks. A concern was also expressed about the soil properties used in estimating the soil forces required to deform condensate line (20-1HCD-169) into its present configuration. We have responded by separately providing the Structural Mechanics Associates calculations estimating the soil capacity at Midland.

10/6/72  
We believe the information supplied satisfies the concerns the NRC Staff expressed during the recent April meeting.



J A Mooney  
Executive Manager  
Midland Project Office

For J W Cook

JWC/WJC/mkh

CC Atomic Safety and Licensing Appeal Board, w/o  
CBechhoefer, ASLB, w/o  
PChen, ETEC, w/a  
FCherney, NRC, w/a  
MMCherry, Esq, w/o  
FPCowan, ASLB, w/o  
RJCook, Midland Resident Inspector, w/o  
RSDecker, ASLB, w/o  
SGadler, w/o  
JHarbour, ASLB, w/o  
DSHood, NRC, w/a (2)  
JDKane, NRC, w/a  
FJKelley, Esq, w/o  
RBLandsman, NRC Region III, w/a  
WHMarshall, w/o  
WDPaton, Esq, w/o  
BStamiris, w/o

104472

BURIED SEISMIC CATEGORY I LINES AND TANKS

## A. Service Water Lines

8"-1HBC-310	26"-OHBC-53
8"-2HBC-81	26"-OHBC-54
8"-1HBC-81	26"-OHBC-55
8"-2HBC-310	26"-OHBC-56
8"-1HBC-311	26"-OHBC-15
8"-2HBC-82	26"-OHBC-16
8"-1HBC-82	26"-OHBC-19
8"-2HBC-311	26"-OHBC-20
10"-OHBC-27	36"-OHBC-15
10"-OHBC-28	36"-OHBC-16
	36"-OHBC-19
	36"-OHBC-20

## B. Diesel Fuel Oil Lines and Tanks

1-1/2"-1HBC-3	2"-1HBC-497	1T-77A
1-1/2"-1HBC-4	2"-1HBC-498	1T-77B
1-1/2"-2HBC-3	2"-2HBC-497	2T-77A
1-1/2"-2HBC-4	2"-2HBC-498	2T-77B

## C. Borated Water Lines

18"-1HCB-1  
 18"-1HCB-2  
 18"-2HCB-1  
 18"-2HCB-2

## D. Control Room Pressurization Lines and Tanks

4"-ODBC-1	OVT <sup>2</sup> 8A
1"-OCCC-1	OVT 8B

## E. Penetration Pressurization Lines and Tanks

1"-1CCB-45	1T-114
1"-2CCB-45	2T-114



10447 CATHODIC PROTECTION OF SEISMIC CATEGORY I AND OTHER BURIED PIPING AND  
TANKS

<u>Line No.</u>	<u>Q Listed</u>	<u>E-40 Reference</u>	<u>Woodby Listed</u>	<u>Bechtel Review(6)</u>
<u>BWST and Lines</u>				
1T60 (BWST)	Yes	1.3 (sim.)(1)	No	Not required(2)
2T60 (BWST)	Yes	1.3 (sim.)(1)	No	Not required(2)
18"-1HCB-1	Yes	1.4d	Yes	
18"-1HCB-2	Yes	1.4d	Yes	
18"-2HCB-1	Yes	1.4d	Yes	
18"-2HCB-2	Yes	1.4d	Yes	
4"-1HCB-33	Yes	1.4d	Yes	
4"-2HCB-33	Yes	1.4d	Yes	
4"-1HCD-166	No	1.4d	Yes	
4"-2HCD-166	No	1.4d	Yes	
<u>Service Water System</u>				
36"-OHBC-15	Yes	1.4a	No	Yes
36"-OHBC-16	Yes	1.4a	No	Yes
36"-OHBC-19	Yes	1.4a	No	Yes
36"-OHBC-20	Yes	1.4a	No	Yes
26"-OHBC-15	Yes	1.4a	Yes	
26"-OHBC-16	Yes	1.4a	Yes	
26"-OHBC-19	Yes	1.4a	Yes	
26"-OHBC-20	Yes	1.4a	Yes	
26"-OHBC-53	Yes	1.4a	Yes	
26"-OHBC-54	Yes	1.4a	Yes	
26"-OHBC-55	Yes	1.4a	Yes	
26"-OHBC-56	Yes	1.4a	Yes	
26"-2JBD-1	No	1.4a	Yes	
26"-2JBD-2	No	1.4a	Yes	
10"-OHBC-27	Yes	1.4a	No	Yes
10"-OHBC-28	Yes	1.4a	No	Yes
8"-1HBC-81	Yes	1.4a	No	Yes
8"-2HBC-81	Yes	1.4a	No	Yes
8"-1HBC-82	Yes	1.4a	No	Yes
8"-2HBC-82	Yes	1.4a	No	Yes
8"-1HBC-310	Yes	1.4a	No	Yes
8"-2HBC-310	Yes	1.4a	No	Yes
8"-1HBC-311	Yes	1.4a	No	Yes
8"-2HBC-311	Yes	1.4a	No	Yes

104472

<u>Line No.</u>	<u>Q Listed</u>	<u>E-40 Reference</u>	<u>Woodby Listed</u>	<u>Bechtel Review(6)</u>
<u>Domestic Water System</u>				
2"-OYSG-1	No	1.4e	Yes	
8"-Ductile Iron	No	1.4e	Yes	Sacrificial anodes
<u>Fire Water System</u>				
12"-OKSF-1	No	1.4g	Yes	
8"-OKSF-5	No	1.4g	Yes	
8"-OKSF-25	No	1.4g	Yes	
8"-OKSF-27	No	1.4g	Yes	
8"-OKSF-28	No	1.4g	Yes	
6"-OKSF-27	No	1.4g	Yes	
<u>Utility and Primary Water Storage System</u>				
OT-15 (UWST)	No	1.3 (sim.)(1)	No	Not required(2)
OT-54 (PWST)	No	1.3 (sim.)(1)	No	Not required(2)
4"-OHCD-571	No	1.4d	Yes	
4"-OHCD-572	No	1.4d	Yes	
3"-OHCD-743	No	1.4d	Yes	
1"-OHCD-741	No	1.4d	Yes	
3"-OHCD-703	No	1.4d	Yes	
4"-OHCD-774	No	1.4d	Yes	
4"-OHCD-775	No	1.4d	Yes	
3"-OHCD-575	No	1.4d	Yes	
1-1/2"-OHCD-750	No	1.4d	Yes	
6"-OHCD-755	No	1.4d	Yes	
4"-OHCD-745	No	1.4d	Yes	
<u>Circulating Water System</u>				
96"-2YBJ-1	No	1.4a	Yes	
96"-2YBJ-2	No	1.4a	Yes	
96"-2YBJ-3	No	1.4a	Yes	
96"-2YBJ-4	No	1.4a	Yes	
72"-1YBJ-1	No	1.4a	Yes	
72"-1YBJ-2	No	1.4a	Yes	
72"-1YBJ-3	No	1.4a	Yes	
72"-1YBJ-4	No	1.4a	Yes	
12"-OYBJ-13	No	1.4a	Yes	

104472

<u>Line No.</u>	<u>Q Listed</u>	<u>E-40 Reference</u>	<u>Woodby Listed</u>	<u>Bechtel Review(6)</u>
<u>Diesel Fuel Oil System</u>				
1T-78A	Yes	1.4c	Yes	
1T-78B	Yes	1.4c	Yes	
2T-78A	Yes	1.4c	Yes	
2T-78B	Yes	1.4c	Yes	
1-1/2"-1HBC-3	Yes	1.4a, c	No	Yes
1-1/2"-1HBC-4	Yes	1.4a, c	No	Yes
1-1/2"-2HBC-3	Yes	1.4a, c	No	Yes
1-1/2"-2HBC-4	Yes	1.4a, c	No	Yes
2"-1HBC-497	Yes	1.4a, c	No	Yes
2"-1HBC-498	Yes	1.4a, c	No	Yes
2"-2HBC-497	Yes	1.4a, c	No	Yes
2"-2HBC-498	Yes	1.4a, c	No	Yes
<u>Yard Lighting Diesel Fuel Oil System</u>				
OT-117	No	(3)	No	Yes
1"-OHBD-851	No	1.4a	Yes	
1"-OHBD-864	No	1.4a	Yes	
3"-OHBD-868	No	1.4a	Yes	
<u>Condensate Return Lines</u>				
18"-OHCD-974	No	1.4d	Yes	
6"-OHCD-419	No	1.4d	Yes	
1"-OYDD-17	No	1.3	Yes	
<u>Control Room Pressurization System</u>				
OVT-28A	Yes	(4)	No	Yes
OVT-28B	Yes	(4)	No	Yes
4"-ODBC-1	Yes	1.4a	No	Yes
1"-OCCC-1	Yes	1.4d	No	Yes
<u>Penetration Pressurization System</u>				
1T-114	Yes	(4)	No	(5)
2T-114	Yes	(4)	No	(5)
1"-1CCB-45	Yes	1.4d	No	(5)
1"-2CCB-45	Yes	1.4d	No	(5)

NOTES:

- 104472
- (1) sim. = similar; these tanks are similar to the condensate storage tanks which are specifically addressed in Section 1.3 of Drawing 7220-E-40.
  - (2) Cathodic protection is not required for aboveground tanks. They receive some incidental protection in accordance with Section 1.3 of Drawing 7220-E-40.
  - (3) Yard lighting diesel fuel oil storage tank is a buried tank for diesel fuel storage, similar to those included in Section 1.4c of Drawing 7220-E-40.
  - (4) These are buried alloy steel tanks. They do not fall into any of the Section 1.4 categories of structures to be protected. However, Bechtel's review indicates protection has been provided in the design documents.
  - (5) These tanks and lines have not yet been installed. The design documents place cathodic protection in the proposed location of this system.
  - (6) This column shows the results of Bechtel's review of items not indicated by Woodby as being protected. Bechtel's review provided either a reason why it was not protected or confirmed that a design document shows the protection to be provided.