



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640 JACKSON, MISSISSIPPI 39205

February 24, 1983

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Division 2 Diesel Shutdown Due
to Tachometer Going
Downscale while Speed was
Being Increased
LER 83-038/03 L-0
AECM-83/0123

On January 25, 1983, while conducting a seismic qualification vibration test on the Division 2 Diesel Generator, the tachometer went downscale while speed was being increased. The diesel was then shutdown. This is being reported pursuant to Technical Specification 6.9.1.13.b as required by Technical Specification 4.8.1.1.3. Attached is LER 83-038/03 L-0.

Yours truly,

J.P. McGaughy
for J. P. McGaughy

JPM:sap
Attachment

- cc: Mr. N. L. Stampley (w/a)
- Mr. K. B. McGehee (w/o)
- Mr. T. B. Conner (w/o)
- Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8303010178 830224
PDR ADOCK 05000416
S PDR

83 FEB 25 AIO: 33
GENERAL RECORDS
ATLANTA MISSISSIPPI

OFFICIAL COPY
IE 22