NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

(2) LICENSEE CODE: NCBEP2 | LICENSE NUMBER: 00-00000-00 | (3) | (4) LICENSE TYPE: 4111 | CAT 58 | (5)

CON'T

REPORT SOURCE: L (6) | DOCKET NUMBER: 050-0324 (7) | EVENT DATE: 012083 (8) | REPORT DATE: 021883 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

During steady state plant operation, the "RHR Reactor Pressure Low" annunciation was received. An immediate check of plant operating parameters found no abnormalities. This annunciation receives its input from reactor steam dome pressure low instruments, 2-B21-PJ-N021A-D, which provides input for the RHR and ECCS Core Spray Systems' LPCI function. This event did not affect the health and safety of the public.

Technical Specifications 3.3.3, 3.5.3.1, 3.5.3.2, 6.9.1.9b

SYSTEM CODE (11)	CAUSE CODE (12)	CAUSE SUBCODE (13)	COMPONENT CODE (14)	COMP. SUBCODE (15)	VALVE SUBCODE (16)
SF	E	A	INSTRU	S	Z

(17) LER/RO REPORT NUMBER: EVENT YEAR 83 — SEQUENTIAL REPORT NO. 011 — OCCURRENCE CODE 03 — REPORT TYPE L — REVISION NO. 0

ACTION TAKEN	FUTURE ACTION (18)	EFFECT ON PLANT (19)	SHUTDOWN METHOD (20)	HOURS (21)	ATTACHMENT SUBMITTED (22)	NPRD-4 FORM SUB. (23)	PRIME COMP. SUPPLIER (24)	COMPONENT MANUFACTURER (25)
C	Z	Z	Z	0000	N	Y	N	R369 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

An electrical resistor and relay in instrument N021C had failed causing the instrument to initiate the annunciation. The instrument, Model No. 510DU2, was replaced, calibrated, and returned to service. As this event is isolated, no further corrective action is planned.

FACILITY STATUS (28)	% POWER (29)	OTHER STATUS (30)	METHOD OF DISCOVERY (31)	DISCOVERY DESCRIPTION (32)
E	080	NA	A	Operational Event

ACTIVITY RELEASED (33)	CONTENT OF RELEASE (34)	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
Z	Z	NA	NA

PERSONNEL EXPOSURES

NUMBER (37)	TYPE (38)	DESCRIPTION (39)
000	Z	NA

PERSONNEL INJURIES

NUMBER (40)	DESCRIPTION (41)
000	NA

LOSS OF OR DAMAGE TO FACILITY (43)

TYPE (42)	DESCRIPTION
Z	NA

PUBLICITY

ISSUED (44)	DESCRIPTION (45)
N	NA

8303010197 830218
PDR ADOCK 05000324
S PDR

NRC USE ONLY

NAME OF PREPARER M. J. Pastva, Jr. PHONE: 919-457-9521

GPO 917-926