

LICENSEE EVENT REPORT

CAR 1417

CONTROL BLOCK: \_\_\_\_\_ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | N Y R E G 1 | 2 | 0 0 - 0 0 0 0 0 - 0 0 | 3 | 4 1 1 1 1 | 4 | \_\_\_\_\_ | 5

CON'T  
01 | REPORT SOURCE | L | 6 | 0 5 0 0 0 2 4 4 | 7 | 0 1 1 7 8 3 | 8 | 0 2 1 6 8 3 | 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)  
02 | Following a unit trip on 1/17/83 from 100% power, the water level in the pressurizer |  
03 | dropped below 12% level. The level reached 10.6% when automatic letdown isolation |  
04 | occurred. This was a LCO based on Tech. Specs. 3.1.1.5. |  
05 | \_\_\_\_\_ |  
06 | \_\_\_\_\_ |  
07 | \_\_\_\_\_ |  
08 | \_\_\_\_\_ |

09 | SYSTEM CODE | C B | 11 | CAUSE CODE | X | 12 | CAUSE SUBCODE | Z | 13 | COMPONENT CODE | V E S S E L | 14 | COMP. SUBCODE | B | 15 | VALVE SUBCODE | Z | 16

10 | LER/RO REPORT NUMBER | 8 3 | 17 | EVENT YEAR | 8 3 | 21 22 | SEQUENTIAL REPORT NO. | 0 0 7 | 24 26 | OCCURRENCE CODE | 0 3 | 28 29 | REPORT TYPE | L | 30 | REVISION NO. | 0 | 32

11 | ACTION TAKEN | X | 18 | FUTURE ACTION | Z | 19 | EFFECT ON PLANT | Z | 20 | SHUTDOWN METHOD | Z | 21 | HOURS | 0 0 0 0 | 22 37 | ATTACHMENT SUBMITTED | N | 3 | 41 | NPRD-4 FORM SUB. | N | 24 | 42 | PRIME COMP. SUPPLIER | N | 25 | 43 | COMPONENT MANUFACTURER | W I Z O | 26 47

12 | CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)  
10 | The pressurizer level decreased due to the cooldown of the RCS following the |  
11 | trip. The level was returned to 19.5%, normal no-load level within 15 minutes. |  
12 | \_\_\_\_\_ |  
13 | \_\_\_\_\_ |  
14 | \_\_\_\_\_ |

15 | FACILITY STATUS | X | 28 | % POWER | 0 0 0 | 29 | OTHER STATUS | NA | 30 | METHOD OF DISCOVERY | A | 31 | DISCOVERY DESCRIPTION | Operator Awareness | 32

16 | ACTIVITY RELEASED | Z | 33 | CONTENT OF RELEASE | Z | 34 | AMOUNT OF ACTIVITY | NA | 35 | LOCATION OF RELEASE | NA | 36

17 | PERSONNEL EXPOSURES | 0 0 0 | 37 | Z | 38 | 39 | NA

18 | PERSONNEL INJURIES | 0 0 0 | 40 | 41 | NA

19 | LOSS OF OR DAMAGE TO FACILITY | Z | 42 | 43 | NA

20 | PUBLICATION ISSUED | N | 44 | 4 | 4 | NA

8303010470 830216  
PDR ADOCK 05000244  
S PDR

NRC USE ONLY

NAME OF PREPARER J. C. Bodine

PHONE: (315) 524-4446

917-925