

FEB 07 1983

Florida Power and Light Company
ATTN: Dr. R. E. Uhrig, Vice President
Advanced Systems and Technology
P. O. Box 14000
Juno Beach, FL 33408

Gentlemen:

SUBJECT: REPORT NO. 50-335/82-43

This refers to the routine safety inspection conducted by Mr. G. N. Huffman of this office on November 24, 1982, of activities authorized by NRC License No. DPR-67 for the St. Lucie facility. Our preliminary findings were discussed with Mr. J. H. Barrow, Operations Superintendent, at the conclusion of the inspection. NRC concerns relating to the findings were discussed in an Enforcement Conference in Atlanta on December 17, 1982, between Mr. L. W. Williams, Vice President, Nuclear Energy and Mr. R. D. Martin, Deputy Regional Administrator, Region II.

Areas examined during this inspection included emergency preparedness. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspector.

During the inspection, an emergency preparedness program deficiency was observed with regard to the state of operational readiness of the Technical Support Center due to ongoing construction activity. Although this matter had been identified by your staff, corrective and preventive measures were not promptly implemented until additional attention was focused on the issue as a result of extensive discussions between our staffs. In that corrective actions were completed shortly after that, no response to this letter is required. However, it is expected that continued management attention will be applied to this area, so as to preclude recurrence.

In accordance with 10 CFR 2.790(a), a copy of this letter and the enclosure will be placed in the NRC's Public Document Room unless you notify this office, by telephone, within ten days of the date of this letter and submit written application to withhold information contained therein within thirty days of the date of this letter. Such application must be consistent with the requirements of 2.790(b)(1).

8303010640 830207
PDR ADOCK 05000335
Q PDR

IE01

Should you have any questions concerning this letter, we will be glad to discuss them with you.

Sincerely,

James P. O'Reilly
Regional Administrator

Enclosure:
Inspection Report No.
50-335/82-43

cc w/encl:
C. M. Wethy, Plant Manager
N. Weems, Assistant QA
Construction Manager

bcc w/encl:
NRC Resident Inspector
Document Management Branch
State of Florida
G. R. Bailey, FP&L
F. G. Pagano, Jr., DEP:HQ

*Non-Concur
(See) Note Attached
JRF*

EPOS:RII

mlh
GNHuffman:mlh
02/1/83

EPOS:RII

GRJenkins
02/ /83

PS
EPOS:RII

JPS tohr
02/2/83

PRP:RII

KOV
KDLandis
02/3/83

PRP:RII

Y
RCLewis
02/4/83

ORA:RII

1st
JPO Reilly
02/7/83

PS:RII

me for
CEAlderson
2/4/83