

FEB 22 1983

DISTRIBUTION:

Docket File

NRC PDR

L PDR

ORB#4 Rdy

Docket No. 50-302

Gray File

DEisenhut

RIIngram

MFairtile

OELD

AEOD

IE-Harmon & Jordan

ACRS-10

Hornstein

EBlackwood

BDLiaw, MTEB

Mr. John A. Hancock
Vice President, Nuclear Operations
Florida Power Corporation
ATTN: Manager, Nuclear Licensing
& Fuel Management
P. O. Box 14042; M.A.C. H-2
St. Petersburg, Florida 33733

Dear Mr. Hancock:

Your letter of August 27, 1982, requested relief from the 1974 edition of the ASME Boiler and Pressure Vessel Code, Section XI, Tables IWB-2500 and -2600, regarding the requirements for visual and volumetric inspection of the reactor vessel and head cladding at Crystal River Unit 3. You stated that this relief is based on the later requirements of Section XI, Summer 1976 Addenda, Tables IWB-2500 and -2600 which delete these inspection requirements. We have no objection to your use of the Summer 1976 Addenda. Our rule, 10 CFR 50.55a, in Paragraph G, also requires, when using later code editions, that you also meet, "all related requirements", from that later edition.

Sincerely,

*ORIGINAL SIGNED BY
JOHN F. STOLZ*

John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

cc:
See next page

8303020214 830222
PDR ADOCK 05000302
Q PDR

OFFICE	ORB#4:DL	MTEB/DE	C-ORB#4:DL			
SURNAME	MFairtile	BDLiaw	JFStolz			
DATE	2/18/83:cb	2/18/83	2/18/83			

Crystal River Unit No. 3
Florida Power Corporation

50-302

cc w/enclosure(s):
Mr. S. A. Brandimore
Florida Power Corporation
Vice President and General Counsel
P. O. Box 14042
St. Petersburg, Florida 33733

Mr. Wilbur Langely, Chairman
Board of County Commissioners
Citrus County
Iverness, Florida 36250

Regional Radiation Representative
EPA Region IV
345 Courtland Street, N.E.
Atlanta, Georgia 30308

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 220, 7910 Woodmont Avenue
Bethesda, Maryland 20814

Mr. Tom Stetl, Resident Inspector
U.S. Nuclear Regulatory Commission
Route #3, Box 717
Crystal River, Florida 32629

Nuclear Plant Manager
Florida Power Corporation
P. O. Box 219
Crystal River, Florida 32629

Bureau of Intergovernmental Relations
660 Apalachee Parkway
Tallahassee, Florida 32304

Administrator
Department of Environmental Regulation
Power Plant Siting Section
State of Florida
2600 Blair Stone Road
Tallahassee, Florida 32301

Attorney General
Department of Legal Affairs
The Capitol
Tallahassee, Florida 32304

Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission, Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

FEB 22 1983

Docket No. 50-302

Mr. John A. Hancock
Vice President, Nuclear Operations
Florida Power Corporation
ATTN: Manager, Nuclear Licensing
& Fuel Management
P. O. Box 14042; M.A.C. H-2
St. Petersburg, Florida 33733

Dear Mr. Hancock:

Your letter of August 27, 1982, requested relief from the 1974 edition of the ASME Boiler and Pressure Vessel Code, Section XI, Tables IWB-2500 and -2600, regarding the requirements for visual and volumetric inspection of the reactor vessel and head cladding at Crystal River Unit 3. You stated that this relief is based on the later requirements of Section XI, Summer 1976 Addenda, Tables IWB-2500 and -2600 which delete these inspection requirements. We have no objection to your use of the Summer 1976 Addenda. Our rule, 10 CFR 50.55a, in Paragraph G, also requires, when using later code editions, that you also meet, "all related requirements", from that later edition.

Sincerely,

A handwritten signature in cursive script that reads "John F. Stolz".

John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

cc:
See next page