



# Omaha Public Power District

1623 HARVEY ■ OMAHA, NEBRASKA 68102 ■ TELEPHONE 536-4000 AREA CODE 402

February 28, 1983  
LIC-83-052

Mr. Robert A. Clark, Chief  
U. S. Nuclear Regulatory Commission  
Office of Nuclear Reactor Regulation  
Division of Licensing  
Operating Reactors Branch No. 3  
Washington, D.C. 20555

Reference: Docket No. 50-285

Dear Mr. Clark:

License Amendment Application for the  
Fort Calhoun Station  
Cycle 8 Reload

The subject application, submitted to the Commission on November 22, 1982, provided supporting analyses based upon a Cycle 7 fuel burnup of 10,500 MWD/T. This burnup was consistent with an expected refueling outage start date of January 4, 1983. However, as a result of a main turbine-generator failure, the Fort Calhoun Station refueling commenced a month earlier than anticipated, at a Cycle 7 burnup of 9,725 MWD/T. The lower Cycle 7 burnup required the District to verify the existing analyses to ensure that they were still bounding for Cycle 8. This verification process identified the need for a change to the subject application, as related to the Technical Specification limit on the total planar radial peaking factor. Accordingly, please find attached the District's replacement pages 1-2, 2-57a, and Figure 2-9 to the November 22, 1982 application. A supplemental justification for these changes in also provided.

Sincerely,

W. C. Jones  
Division Manager  
Production Operations

WCJ/TLP:jmm

Attachment

cc: LeBoeuf, Lamb, Leiby & MacRae  
1333 New Hampshire Avenue, N.W.  
Washington, D.C. 20036

Mr. L. A. Yandell, NRC  
Senior Resident Inspector

8303090204 830228  
PDR ADOCK 05000285  
PDR

App 1