


CENTRAL FILE
MECHANICAL EQUIPMENT
QUALIFICATION PROGRAM
M-SNUB
Hydraulic Snubbers

| | | | | | |
|---|---------|----------------------------|-----|------|------|
| 1 | 2/2/83 | See Revision Control Sheet | MRL | CHK | PDB |
| 0 | 1/21/83 | Issued for use | MRL | CHK | PDB |
| No. | DATE | REVISIONS | BY | CH'K | APPR |
|  | | JOB NO. CPC-09-16 | | | |
| | | SPEC/DES GUIDE No. REV. | | | |
| | | Mechanical M-SNUB 1 | | | |

REVISION CONTROL SHEET

TITLE: Hydraulic Snubber

REPORT NUMBER: M-SNUB

M. P. Lee / Consultant
NAME / TITLE

MPL
INITIALS

C. W. Allen / CONSULTANT
NAME / TITLE

CWA
INITIALS

W. R. Kelly / PROJECT ENGINEER
NAME / TITLE

WRK
INITIALS

H. M. F. / PROJECT MANAGER
NAME / TITLE

HMF
INITIALS

P. D. B. / ENGINEERING MANAGER
NAME / TITLE

PDB
INITIALS

| PAGE(S) | REV | PREPARED BY / DATE | ACCURACY CHECK BY / DATE | CRITERIA CHECK BY / DATE | REMARKS |
|---------|-----|-----------------------|-----------------------------|-----------------------------|--|
| 1 | 1 | | | | Revised qualification status to thirty (30) day post accident |
| 2 | 1 | | | | Revised CDES for thirty (30) day post accident and revised accident radiation |
| 4 | 1 | | | | Revised MEEQS (2) for thirty (30) day post accident and revised accident radiation |
| 10-23 | 1 | | | | Revised MEEQRFs to include additional design and test data including a thirty (30) day post accident operability |
| 27-30 | 1 | MPL 2/2/83 | CWA 2/2/83 | WRK 2/2/83 | Revised Appendix A to include a thirty (30) day post accident operability period |

TABLE OF CONTENTS

I. QUALIFICATION PROGRAM

- A. Mechanical Equipment File Cover Summary Sheet (MEFCSS)
- B. Component Data and Environment Sheet (CDES)
- C. Mechanical Equipment Environmental Qualification
Sheets (MEEQS)
- D. Equipment Applicability Evaluation Sheet (EAES)
- E. Component/Part Summary Sheet (C/PSS)
- F. Mechanical Equipment Environmental Qualification
Review Form (MEEQRF)
- G. Maintenance and Surveillance Recommendations
- H. Appendix A
- I. References and Additional Data
- J. Generic Figures

II. REFERENCES

Mechanical Equipment File Cover Summary Sheet

Equipment Type: Hydraulic Snubber

MEQ Prog No.: M-SNUB

Manufacturer/Model No: ITT Grinnell/Miller Cylinders Model 52 and Model 90

Safety Function:

The primary function of the Hydraulic Snubber is to protect fluid systems and components important to safety from the effects of seismic disturbances and other types of transient dynamic loadings such as water hammer, steam hammer, pipe whip and relief valve actuation while permitting minimal restraint against thermal expansion.

Operation:

Hydraulic Snubbers generally consist of an assembly of a double-acting hydraulic cylinder, a reservoir, and a flow control device, e.g., orifice valves on the ends of cylinder ports. Ideally, under slow movement due to thermal expansion, the system or components supported by snubbers will move freely as if the snubbers do not exist because the hydraulic fluid inside the cylinder flows through one of the valves into the reservoir and then flows into the other end of the cylinder until the imposed force is balanced. When a body or internal force is applied suddenly with the flow restricted by the flow control device, snubbers will limit dynamic responses so the supported system will not be overstressed.

Qualification Status:

The ITT Grinnell Hydraulic Snubbers are qualified for a forty (40) year service period and a thirty (30) day post accident condition provided that periodic inservice inspection and functional test of the hydraulic snubbers and replacement of the hydraulic seals and fluid are performed according to the surveillance and maintenance recommendation developed in Section G.

MIDLAND UNITS 1 AND 2

EQUIPMENT QUALIFICATION SUMMARY

COMPONENT DATA AND ENVIRONMENT SHEET

| EQUIPMENT ID NUMBER Generic | PARAMETER | Normal | LOCA | MSLB | |
|--|---|---|--|--|--|
| DESCRIPTION: Hydraulic Snubber SERVICE: Reactor Coolant Pump Support MANUFACTURER: ITT Grinnell MODEL NO: Miller Cylinder Model 52/90 SYSTEM: N/A PO NO: M-SNUB EEQS NO: M-SNUB ROOM NO: 105A BLDG: R1 ELEVATION: 614' OPERATING CYCLES: N/A NONSEISMIC VIBR: N/A RESPONSE SPECTRUM FIG: Future use LOCA: Yes MSLB: SAFE SD: Hot, Cold HELD OUTSIDE RD: N/A NOTES: | OPERABILITY PERIOD SAFETY FUNCTION A. TEMPERATURE (F) B. PRESSURE C. HUMIDITY (PERC RH) D. RADIATION (RADS) E. SPRAY F. SUBMERGENCE G. ACCURACY H. RESPONSE TIME | 40 years Dynamic restraint 50-120 ATM 0-100 1.6E07 N/A N/A N/A N/A | 30 days Dynamic restraint F-1 F-1 100 1.53E06 T-1 N/A N/A N/A | 30 days Dynamic restraint F-2 F-2 100 Env by LOCA T-1 N/A N/A N/A | |
| EQUIPMENT ID NUMBER Generic | PARAMETER | Normal | LOCA | MSLB | |
| DESCRIPTION: Hydraulic Snubber SERVICE: Reactor Coolant Pump Support MANUFACTURER: ITT Grinnell MODEL NO: Miller Cylinder Model 52/90 SYSTEM: N/A PO NO: M-SNUB EEQS NO: M-SNUB ROOM NO: 105A BLDG: R2 ELEVATION: 614' OPERATING CYCLES: N/A NONSEISMIC VIBR: N/A RESPONSE SPECTRUM FIG: Future Use LOCA: Yes MSLB: Yes SAFE SD: Hot, Cold HELD OUTSIDE RD: N/A NOTES: | OPERABILITY PERIOD SAFETY FUNCTION A. TEMPERATURE (F) B. PRESSURE C. HUMIDITY (PERC RH) D. RADIATION (RADS) E. SPRAY F. SUBMERGENCE G. ACCURACY H. RESPONSE TIME | 40 years Dynamic restraint 50-120 ATM 0-100 1.6E07 N/A N/A N/A N/A | 30 days Dynamic restraint F-1 F-1 100 1.53E08 T-1 N/A N/A N/A | 30 days Dynamic restraint F-2 F-2 100 Env by LOCA T-1 N/A N/A N/A | |
| EQUIPMENT ID NUMBER | PARAMETER | | | | |
| DESCRIPTION: SERVICE: MANUFACTURER: MODEL NO: SYSTEM: PO NO: EEQS NO: ROOM NO: BLDG: ELEVATION: OPERATING CYCLES: NONSEISMIC VIBR: RESPONSE SPECTRUM FIG: LOCA: MSLB: SAFE SD: HELD OUTSIDE RD: NOTES: | OPERABILITY PERIOD SAFETY FUNCTION A. TEMPERATURE (F) B. PRESSURE C. HUMIDITY (PERC RH) D. RADIATION (RADS) E. SPRAY F. SUBMERGENCE G. ACCURACY H. RESPONSE TIME | | | | |

MECHANICAL EQUIPMENT ENVIRONMENTAL QUALIFICATION SHEET (1)

TYPE OF EQUIPMENT: Hydraulic Snubbers

MANUFACTURER: ITT Grinnell Corporation

PROGRAM NO.: M-SNUB

MODEL NO.: Miller Cylinder Model 52/Model 90

EQUIPMENT APPLICABILITY:

Model Qualified, Configuration and Interfaces Match Installation

ACCEPTANCE

Y

REF.

Apdx. 14

PAGE(S)

-

EXTERNAL NORMAL OPERATING CONDITIONS

| | REQUIRED | QUALIFIED | ACCEPT. | METHOD(1) | REF. | PAGE(S) |
|-------------------|----------|-----------|---------|-----------|--------------------------|---------|
| QUALIFIED LIFE(2) | 40 years | 40 years | Y | AN | Apdx. A No. 1 | - |
| RESPONSE TIME | N/A | N/A | N/A | N/A | N/A | N/A |
| ACCURACY | N/A | N/A | N/A | N/A | N/A | N/A |
| TEMPERATURE, MIN. | 50°F | 50°F | Y | AN | Apdx. A No. 2 | - |
| TEMPERATURE, MAX. | 120°F | 120°F | Y | AN, PC | Apdx. A No. 2 | - |
| TEMPERATURE, AVE. | N/A | N/A | N/A | N/A | N/A | N/A |
| PRESSURE | ATM | ATM | Y | AN | Apdx. A No. 3 | - |
| HUMIDITY, MAX. | 100% | 100% | Y | TC | Apdx. A No. 4 Ref. 10 | 2, 3 |
| TID (RADS) | 1.6E07 | 1.6E07 | Y | TC | Ref. 10 | 2, 3 |
| OPERATING CYCLES | N/A | N/A | N/A | N/A | N/A | N/A |

(1) Qualification Method Symbols: TT-Type Test, PT-Partial Type Test, TC-Test of Vital Components, OE-Operating Experience, AN-Analysis

(2) Qualified _____ without exception X with exception (See MEFCSS)

MECHANICAL EQUIPMENT ENVIRONMENTAL QUALIFICATION SHEET (2)

| ACCIDENT ENVIRONMENT: | | LOCA Yes | MSLB Yes | HELB OUTSIDE RB N/A | PROGRAM NO.: M-SNUB | |
|--|---------------|---------------|-----------------|---------------------|---------------------|----------|
| | REQUIRED | QUALIFIED | ACCEPT- ANCE | METHOD (1) | REF. | PAGE (S) |
| OPERATING TIME | 30 days | 30 days | Y | AN | Apdx. A No. 6 | |
| RESPONSE TIME | N/A | N/A | N/A | N/A | N/A | N/A |
| ACCURACY | N/A | N/A | N/A | N/A | N/A | N/A |
| TEMPERATURE | F-1, F-2 | F-2 | Y | AN | Apdx. A No. 2 | |
| PRESSURE | F-1, F-2 | F-1 | Y | AN | Apdx. A No. 3 | |
| TID (2) (RADS) ϵ/β | 3.9E07/1.3E08 | 3.9E07/1.3E08 | Y | AN | Apdx. A No. 7 | |
| SPRAY | T-1 | T-1 | Y | AN | Apdx. A No. 8 | |
| SUBMERGENCE | N/A | N/A | N/A | N/A | Apdx. A No. 13 | |
| LONG TERM FAILURE OF SHORT-TERM USE EQUIP. WAS ADDRESSED | N/A | N/A | N/A | N/A | Apdx. A No. 12 | |

ACCELERATED AGING TIME/TEMPERATURE 72hrs/268°F (References 10 & 16)

(1) Qualification Method Symbols: TT-Type Test, PT-Partial Type Test, TC- Test of Vital Components, OE-Operating Experience, AN-Analysis

(2) Includes the dose acquired under normal operating conditions over the equipment qualified life.

EQUIPMENT APPLICABILITY EVALUATION SHEET

EQUIPMENT: Hydraulic Snubbers

PROGRAM NO.: M-SNUB

[illegible]

COMPONENT/PART SUMMARY SHEET A

EQUIPMENT: Hydraulic Snubbers

COMPONENT: Cylinder Assembly

PROGRAM NO.: M-SNUB

| NON-METALLIC PART DESCRIPTION | ESSENTIAL FOR FUNCTION | REF. DOC. | MATERIAL | REF. DOC. | REPLACE- MENT INTERVAL | BASIS (1) | REF. DOC. | REQUIRE- MENTS MET | REF. DOC. | REMARKS |
|-------------------------------------|------------------------------|--------------|------------------------------------|--------------|------------------------------|--------------|--------------|--------------------------|--------------|----------------------------------|
| O Ring Fill Port Plug | Y | 1 | EPDM Federal Mogul E-50 | 4 | 5 years | OE, AN | 4,15, 16 | N/A | N/A | Appendix A No. 10 |
| O Ring Fill Port Plug | Y | 1 | EPDM Federal Mogul E-50 | 4 | 5 years | OE, AN | 4,15, 16 | N/A | N/A | Appendix A No. 10 |
| External Bearing Seal | Y | 11 | EPDM Acushnet E17018 | 4 | 5 years | OE, AN | 4,15, 16 | N/A | N/A | Apdx A, No. 10 Mod 52 only |
| O Ring-End Seal | Y | 1 | EPDM Acushnet E17018 | 4 | 5 years | OE, AN | 4,15, 16 | N/A | N/A | Appendix A No. 10 |
| Piston Seal | Y | 1 | EPDM W.H. Salis- bury, 80154 | 4 | 5 years | OE, AN | 4,15, 16 | N/A | N/A | Appendix A No. 10 |
| Rod Wiper | Y | 1 | EPDM Mn. Rubber No. 559-EQ | 4 | 5 years | OE, AN | 4,15, 16 | N/A | N/A | Appendix A No. 10 |
| Rod Seal | Y | 1 | EPDM Mn. Rubber No. 559-EQ | 4 | 5 years | OE, AN | 4,15, 16 | N/A | N/A | Appendix A No. 10 |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |

(1) Replacement Interval Basis Abbreviations: OE-Operating Experience, AN-Analysis, MR-Manufacturers Recommendation

COMPONENT/PART SUMMARY SHEET B

EQUIPMENT: Hydraulic Snubbers

COMPONENT: Reservoir Assembly

PROGRAM NO.: M-SNUB

| NON-METALLIC PART DESCRIPTION | ESSENTIAL FOR FUNCTION | REF. DOC. | MATERIAL | REF. DOC. | REPLACE- MENT INTERVAL | BASIS (1) | REF. DOC. | REQUIRE- MENTS MET | REF. DOC. | REMARKS |
|-------------------------------------|------------------------------|--------------|-------------------------------|--------------|------------------------------|--------------|--------------|--------------------------|--------------|----------------------|
| O Ring Outlet Adapter | Y | 1 | EPDM Federal Mogul E-50 | 4 | 5 years | OE, AN | 4,15 16 | N/A | N/A | Appendix A No. 10 |
| O Ring Filter Adapter | Y | 1 | EPDM Federal Mogul E-50 | 4 | 5 years | OE, AN | 4,15 16 | N/A | N/A | Appendix A No. 10 |
| O Ring Drain Adapter | Y | 1 | EPDM Federal Mogul E-50 | 4 | 5 years | OE, AN | 4,15 16 | N/A | N/A | Appendix A No. 10 |
| O Ring Mtg. Studs | Y | 1 | EPDM Federal Mogul E-50 | 4 | 5 years | OE, AN | 4,15 16 | N/A | N/A | Appendix A No. 10 |
| O Ring Class Gauge | Y | 1 | EPDM Federal Mogul E-50 | 4 | 5 years | OE, AN | 4,15 16 | N/A | N/A | Appendix A No. 10 |
| O Ring Cap | Y | 1 | EPDM Federal Mogul E-50 | 4 | 5 years | OE, AN | 4,15 16 | N/A | N/A | Appendix A No. 10 |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |

(1) Replacement Interval Basis Abbreviations: OE-Operating Experience, AN-Analysis,
MR-Manufacturers Recommendation

COMPONENT/PART SUMMARY SHEET C

EQUIPMENT: Hydraulic Snubbers

COMPONENT: Valve

PROGRAM NO.: M-SNUB

| NON-METALLIC PART DESCRIPTION | ESSENTIAL FOR FUNCTION | REF. DOC. | MATERIAL | REF. DOC. | REPLACE- MENT INTERVAL | BASIS (1) | REF. DOC. | REQUIRE- MENTS MET | REF. DOC. | REMARKS |
|---|------------------------------|--------------|-------------------------------|--------------|------------------------------|--------------|--------------|--------------------------|--------------|----------------------|
| Valve Stem Thread Seal | Y | 1 | EPDM Federal Mogul E-50 | 4 | 5 years | OE, AN | 4,15 16 | N/A | N/A | Appendix A No. 10 |
| Velocity Adjust- ment Screw Thread Seal | Y | 1 | EPDM Federal Mogul E-50 | 4 | 5 years | OE, AN | 4,15 16 | N/A | N/A | Appendix A No. 10 |
| O Ring - Valve Male Connector | Y | 1 | EPDM Federal Mogul E-50 | 4 | 5 years | OE, AN | 4,15 16 | N/A | N/A | Appendix A No. 10 |
| O Ring - Valve Retainer Plate | Y | 1 | EPDM Federal Mogul E-50 | 4 | 5 years | OE, AN | 4,15 16 | N/A | N/A | Appendix A No. 10 |
| O Ring - Circle Seal Valve | Y | 1 | EPDM Federal Mogul E-50 | 4 | 5 years | OE, AN | 4,15 16 | N/A | N/A | Appendix A No. 10 |
| O Ring - Circle Seal Valve | Y | 1 | EPDM Federal Mogul E-50 | 4 | 5 years | OE, AN | 4,15 16 | N/A | N/A | Appendix A No. 10 |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |

(1) Replacement Interval Basis Abbreviations: OE-Operating Experience, AN-Analysis,
MR-Manufacturers Recommendation

MECHANICAL EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW FORM

| | |
|---|---|
| COMPONENT: Cylinder Assembly | PAGE <u>1</u> OF <u>14</u> |
| MFGR.: ITT Grinnell | PROGRAM NO.: M-SNUB |
| DWG./DOC. NO.: PHD-5222-SK-51, PHD-5222-SK-52 | MODEL NO.: <u>Miller Cylinder</u> <u>52/90</u> |
| of Ref 1, Pages 32,33 | LOCATION: RB, Rm 105A, 614FT |

SAFETY RELATED: YES X NO

DISCUSSION:

The cylinder assembly is a double-ended piston rod design. The end connectors connect the hydraulic cylinder to the attachments of the supporting structure/component. The hydraulic fluid flows into/out of the cylinder through the cylinder fill ports and valves to absorb the displacements due to the thermal expansion and compression. For a sudden dynamic load due to the incompressibility of hydraulic fluid and the velocity limitation of the valve, the cylinder containing hydraulic fluid acts as a dynamic restraint of the supported component/system.

PART DESCRIPTION: O Ring- Fill Port Plug, item 24, PHD-5222-SK-52 of Ref 1

FUNCTION: To prevent leakage of hydraulic fluid through fill port.

SAFETY RELATED: YES X NO

Seal failure results in a loss of hydraulic fluid and hence a loss of the restraint function of hydraulic snubber to a dynamic load.

MFGR.: Federal Mogul

MODEL NO.: E-50

MATERIAL: Ethylene Propylene

REFERENCE(S): 4

| DESIGN RATING(S) | REFER- ENCE(S) | REQUIREMENTS | DEMONSTRATED BY | ACCEPT- ABLE | REFER- ENCE(S) |
|---------------------|-------------------|--|--|-----------------|-------------------|
| 3.0E07 Rads | 4 | Radiation 2.63E07 | Material Analysis | Y | Ref. 4 |
| | | Rads (5 year plus 30 day post accident | and vital cor- ponent test | | Apdx. A No. 7 |
| 3500F | 4 | 321°F-maximum | Surface tempera- | Y | Ref. 4, 17 |
| | | surface temp- erature | ture analysis and vital com- ponent test | | Apdx. A, No. 2 |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

| MEEQRF (CONT.) | | PAGE <u>3</u> OF <u>14</u> | | PROGRAM NO.: M-SNUB | |
|--|--------------|----------------------------|--------------------|---------------------|--------------|
| PART DESCRIPTION: O Ring - End Seal, Item 14, PHD-5222-SK-51 of Ref.1 | | | | | |
| FUNCTION: To prevent leakage of hydraulic fluid from hydraulic cylinder. | | | | | |
| SAFETY RELATED: YES <u>X</u> NO <u> </u> | | | | | |
| Seal failure results in a loss of hydraulic fluid and hence a loss of the restraint function of hydraulic snubber to a dynamic load. | | | | | |
| MFGR.: Acushnet | | | MODEL NO.: E-17018 | | |
| MATERIAL: Ethylene Propylene | | | REFERENCE(S): 4 | | |
| DESIGN RATING(S) | REFERENCE(S) | REQUIREMENTS | DEMONSTRATED BY | ACCEPT-ABLE | REFERENCE(S) |
| 3.0E07 Rads | 4 | Radiation - | Material analy- | Y | Ref. 4 |
| | | 2.63E07 Rads | sis and vital | | Apdx. A |
| | | (5 year plus | component test | | No. 7 |
| | | 30 day post | | | |
| | | accident) | | | |
| 350°F | 4 | 321°F-maximum | Surface temp- | Y | Ref.4,17 |
| | | surface temp- | erature analy- | | Apdx. A |
| | | erature | sis and vital | | No. 2 |
| | | | component test | | |
| | | | | | |
| | | | | | |
| PART DESCRIPTION: Piston Seal, Item 2, PHD-5222-SK-51 of Ref. 1 | | | | | |
| FUNCTION: To prevent leakage of hydraulic fluid from hydraulic cylinder. | | | | | |
| SAFETY RELATED: YES <u>X</u> NO <u> </u> | | | | | |
| Seal failure results in a loss of hydraulic fluid and hence a loss of the restrain function of hydraulic snubber to a dynamic load. | | | | | |
| MFGR.: W. H. Salisbury | | | MODEL NO.: 80154 | | |
| MATERIAL: Ethylene Propylene | | | REFERENCE(S): 4 | | |
| DESIGN RATING(S) | REFERENCE(S) | REQUIREMENTS | DEMONSTRATED BY | ACCEPT-ABLE | REFERENCE(S) |
| 3.0E07 Rads | 4 | Radiation - | Material analy- | Y | Ref. 4 |
| | | 2.63E07 Rads | sis and vital | | Apdx. A |
| | | (5 year plus | component test | | No. 7 |
| | | 30 day post | | | |
| | | accident | | | |
| 350°F | 4 | 321°F-maximum | Surface temp- | Y | Ref.4,17 |
| | | surface temp- | erature analy- | | Apdx. A |
| | | erature | sis and vital | | No. 2 |
| | | | component test | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

| MEEQRF (CONT.) | | PAGE <u>4</u> OF <u>14</u> | | PROGRAM NO.: M-SNUB | |
|--|-------------------|----------------------------|--------------------|---------------------|-------------------|
| PART DESCRIPTION: Rod Wiper, Item 15, PHD-5222-SK-51 of Ref. 1 | | | | | |
| FUNCTION: To prevent leakage of hydraulic fluid from cylinder. | | | | | |
| SAFETY RELATED: YES <u>X</u> NO <u> </u> | | | | | |
| Seal failure results in a loss of hydraulic fluid and hence a loss of the safety function of hydraulic snubber to restrain a dynamic load. | | | | | |
| MFGR.: Minnesota Rubber | | | MODEL NO.: 559-EQ | | |
| MATERIAL: Ethylene Propylene | | | REFERENCE(S): 4 | | |
| DESIGN RATING(S) | REFER- ENCE(S) | REQUIREMENTS | DEMONSTRATED BY | ACCEPT- ABLE | REFER- ENCE(S) |
| 3.0E07 Rads | 4 | Radiation - | Material analy- | Y | Ref. 4 |
| | | 2.63E07 Rads | sis and vital | | Apdx. A |
| | | (5 year plus | component test | | No. 7 |
| | | 30 day post | | | |
| | | accident) | | | |
| 350°F | 4 | 321°F-maximum | Surface temp- | Y | Ref. 4, 17 |
| | | surface temp- | erature analy- | | Apdx. A |
| | | erature | sis and vital | | No. 2 |
| | | | component test | | |
| | | | | | |

| PART DESCRIPTION: Rod Seal, Item 6, PHD-5222-SK-51 of Ref. 1 | | | | | |
|--|-------------------|---------------|--------------------|-----------------|-------------------|
| FUNCTION: To provide a seal between the cylinder and the rod bushing assembly. | | | | | |
| SAFETY RELATED: YES <u>X</u> NO <u> </u> | | | | | |
| Seal failure results in a loss of hydraulic fluid and hence a loss of the safety function of hydraulic snubber to restrain a dynamic load. | | | | | |
| MFGR.: Minnesota Rubber | | | MODEL NO.: 559-EQ | | |
| MATERIAL: Ethylene Propylene | | | REFERENCE(S): 4 | | |
| DESIGN RATING(S) | REFER- ENCE(S) | REQUIREMENTS | DEMONSTRATED BY | ACCEPT- ABLE | REFER- ENCE(S) |
| 3.0E07 Rads | 4 | Radiation - | Material analy- | Y | Ref. 4 |
| | | 2.63E07 Rads | sis and vital | | Apdx. A |
| | | (5 year plus | component test | | No. 7 |
| | | 30 day post | | | |
| | | accident) | | | |
| 350°F | 4 | 321°F-maximum | Surface temp- | Y | Ref. 4, 17 |
| | | surface temp- | erature analy- | | Apdx. A |
| | | erature | sis and vital | | No. 2 |
| | | | component test | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

MECHANICAL EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW FORM

| | |
|---|------------------------------|
| COMPONENT: Reservoir Assembly | PAGE <u>5</u> OF <u>14</u> |
| MFGR.: ITT Grinnell | PROGRAM NO.: M-SNUB |
| DWG./DOC. NO.: PHD-5222-5K-63, PHD-5222-5K-85 | MODEL NO.: Oil-Rite |
| of Ref. 1, Page 44 & 46 | LOCATION: RB, Rm 105A, 614FT |

SAFETY RELATED: YES X NO

DISCUSSION:

The reservoir attached to the hydraulic cylinder compensates the volume change and allows the piston to freely extend or retract resulting from the thermal expansion and contraction of the hydraulic fluid or the safety related fluid system/components restrained by the hydraulic snubber. The sight glass assembly of reservoir provides the accessibility of the hydraulic fluid level. Any leakage due to the seal failure may compromise the fluid integrity of the hydraulic system and be injurious to the hydraulic snubber's safety function.

PART DESCRIPTION: O-Ring-outlet adapter, Item 9, PHD-5222-SK-63 of Ref. 1

FUNCTION: To prevent leakage of hydraulic fluid from the reservoir outlet adapter.

SAFETY RELATED: YES X NO

Seal failure results in a loss of hydraulic fluid and hence a loss of the safety function of hydraulic snubber to restrain a dynamic load.

MFGR.: Federal Mogul

MODEL NO.: E-50

MATERIAL: Ethylene Propylene

REFERENCE(S): 4

| DESIGN RATING (S) | REFER- ENCE (S) | REQUIREMENTS | DEMONSTRATED BY | ACCEPT- ABLE | REFER- ENCE (S) |
|----------------------|--------------------|---|--|-----------------|--------------------------------|
| 3.0E07 Rads | 4 | Radiation - 2.63E07 Rads (5 year plus 30 day post accident) | Material analy- sis and vital component test | Y | Ref. 4 Apdx. A NO. 7 |
| 350°F | 4 | 321°F-maximum surface temp- erature | Surface tempera- ture analysis and vital com- ponent test | Y | Ref. 4, 17 Apdx. A NO. 2 |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

| MEEQRF (CONT.) | | PAGE <u>6</u> OF <u>14</u> | | PROGRAM NO.: M-SNUB | |
|--|--------------|----------------------------|------------------|---------------------|--------------|
| PART DESCRIPTION: O-Ring-Filter Adapter, Item 15, PHD-5222-SK-63 of Ref. 1 | | | | | |
| FUNCTION: To prevent leakage of hydraulic fluid from the reservoir. | | | | | |
| SAFETY RELATED: YES <u>X</u> NO <u> </u> | | | | | |
| Seal failure results in a loss of hydraulic fluid and hence a loss of the restraint function of hydraulic snubber. | | | | | |
| MFGR.: Federal Mogul | | | MODEL NO.: E-50 | | |
| MATERIAL: Ethylene Propylene | | | REFERENCE(S): 4 | | |
| DESIGN RATING(S) | REFERENCE(S) | REQUIREMENTS | DEMONSTRATED BY | ACCEPT-ABLE | REFERENCE(S) |
| 3.0E07 Rads | 4 | Radiation - | Material analy- | Y | Ref. 4 |
| | | 2.63E07 Rads | sis and vital | | Apdx. A |
| | | (5 year plus | component test | | No. 7 |
| | | 30 day post | | | |
| | | accident) | | | |
| 350°F | 4 | 321°F-maximum | Surface tempera- | Y | Ref. 4, 17 |
| | | surface temp- | ture analysis | | Apdx. A |
| | | erature | and vital com- | | No. 2 |
| | | | ponent test | | |
| | | | | | |
| | | | | | |
| PART DESCRIPTION: O-Ring-Drain Adapter, Item 5, PHD-5222-SK-63 of Ref. 1 | | | | | |
| FUNCTION: To provide a seal between the drain adapter and the reservoir. | | | | | |
| SAFETY RELATED: YES <u>X</u> NO <u> </u> | | | | | |
| Seal failure results in a loss of hydraulic fluid and hence a loss of the safety function of hydraulic snubber to restrain a dynamic load. | | | | | |
| MFGR.: Federal Mogul | | | MODEL NO.: E-50 | | |
| MATERIAL: Ethylene Propylene | | | REFERENCE(S): 4 | | |
| DESIGN RATING(S) | REFERENCE(S) | REQUIREMENTS | DEMONSTRATED BY | ACCEPT-ABLE | REFERENCE(S) |
| 3.0E07 Rads | 4 | Radiation - | Material analy- | Y | Ref. 4 |
| | | 2.63E07 Rads | sis and vital | | Apdx. A |
| | | (5 year plus | component test | | No. 7 |
| | | 30 day post | | | |
| | | accident) | | | |
| 350°F | 4 | 321°F-maximum | Surface temp- | Y | Ref. 4, 17 |
| | | surface temp- | erature analy- | | Apdx. A |
| | | erature | sis and vital | | No. 2 |
| | | | component test | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

[illegible]

MECHANICAL EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW FORM

| | |
|---|------------------------------|
| COMPONENT: Valves | PAGE <u>9</u> OF <u>14</u> |
| MFGR.: ITT Grinnell | PROGRAM NO.: M-SNUE |
| DWG./DOC. NO.: PHD-5222-SK-55, PHD-5222-SK-70, of Ref 1, Pages 36 and 47 | MODEL NO.: N/A |
| | LOCATION: RB, Rm 105A, 614FT |

SAFETY RELATED: YES X NO

DISCUSSION:

The valves at each end of cylinder ports provide the channel of hydraulic fluid from reservoir to cylinder. Under slow movement due to thermal expansion or contraction, the hydraulic fluid flows through the valves into the reservoir or cylinder to balance the imposed force. When a body force or internal force is applied suddenly, the valves cannot carry the excessive fluid velocity, the hydraulic snubber therefore acts as a restraint to the supported safety related component/fluid system.

PART DESCRIPTION: Valve Stem Thread Seal, Items 9, PHD-5222-SK-55 of Ref. 1

FUNCTION: To prevent leakage of hydraulic fluid through valve stem thread

SAFETY RELATED: YES X NO

Seal failure results in a loss of hydraulic fluid and hence a loss of the designed safety function of hydraulic snubber.

MFGR.: Federal Mogul

MODEL NO.: E-50

MATERIAL: Ethylene Propylene

REFERENCE(S): 4

| DESIGN RATING(S) | REFER- ENCE(S) | REQUIREMENTS | DEMONSTRATED BY | ACCEPT- ABLE | REFER- ENCE(S) |
|---------------------|-------------------|---|--|-----------------|--------------------------------|
| 3.0E07 Rads | 4 | Radiation - 2.63E07 Rads (5 year plus 30 day post accident) | Material analy- sis and vital component test | Y | Ref. 4 Apdx. A No. 7 |
| 350°F | 4 | 321°F-maximum surface temp- erature | Surface temp- erature analy- sis and vital component test | Y | Ref. 4, 17 Apdx. A No. 2 |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

| MEEQRF (CONT.) | | PAGE <u>10</u> OF <u>14</u> | | PROGRAM NO.: M-SNUB | |
|--|--------------|---|---|---------------------|--------------------------------|
| PART DESCRIPTION: O-Ring-Valve Retainer Plate, Item 13, PHD-5222-SK-55 of 1 Ref. 1 | | | | | |
| FUNCTION: To prevent leakage of hydraulic fluid through the valve retainer plate | | | | | |
| SAFETY RELATED: YES <u>X</u> NO <u> </u> | | | | | |
| Seal failure results in a loss of hydraulic fluid and hence a loss of the safety function of hydraulic snubber to restrain a dynamic load. | | | | | |
| MFGR.: Federal Mogul | | | MODEL NO.: E-50 | | |
| MATERIAL: Ethylene Propylene | | | REFERENCE(S): 4 | | |
| DESIGN RATING(S) | REFERENCE(S) | REQUIREMENTS | DEMONSTRATED BY | ACCEPT-ABLE | REFERENCE(S) |
| 3.0E07 Rads | 4 | Radiation - 2.63E07 Rads (5 year plus 30 day post accident) | Material analysis and vital component test | Y | Ref. 4 Apdx. A No. 7 |
| 350°F | 4 | 321°F-maximum surface temperature | Surface temperature analysis and vital component test | Y | Ref. 4, 17 Apdx. A No. 2 |

| PART DESCRIPTION: o Ring-Circle Seal Valve, Item 38, PHD-5222-SK-55 of 1 Ref. 1 | | | | | |
|--|--------------|---|---|-------------|--------------------------------|
| FUNCTION: To prevent leakage of hydraulic fluid through valve. | | | | | |
| SAFETY RELATED: YES <u>X</u> NO <u> </u> | | | | | |
| Seal failure results in a loss of hydraulic fluid and hence a loss of the safety function of hydraulic snubber to restrain a dyanmic load. | | | | | |
| MFGR.: Federal Mogul | | | MODEL NO.: E-50 | | |
| MATERIAL: Ethylene Propylene | | | REFERENCE(S): 4 | | |
| DESIGN RATING(S) | REFERENCE(S) | REQUIREMENTS | DEMONSTRATED BY | ACCEPT-ABLE | REFERENCE(S) |
| 3.0E07 Rads | 4 | Radaition - 2.63E07 Rads (5 year plus 30 day post accident) | Material analy-sis and vital component test | Y | Ref. 4 Apdx. A No. 7 |
| 350°F | 4 | 321°F-maximum surface temp-erature | Surface temp-erature analy-sis and vital component test | Y | Ref. 4, 17 Apdx. A No. 2 |

| MEEQRF (CONT.) | | PAGE <u>11</u> OF <u>14</u> | | PROGRAM NO.: M-SNUE | |
|--|--------------|---|---|---------------------|--------------------------------|
| PART DESCRIPTION: Velocity Adjustment Screw Thread Seal, Items 5, PHD-5222-SK-55 of Ref. 1 | | | | | |
| FUNCTION: To prevent leakage of hydraulic fluid through velocity adjustment screw | | | | | |
| SAFETY RELATED: YES <u>X</u> NO <u> </u> | | | | | |
| Seal failure results in a loss of hydraulic fluid and hence a loss of the safety function of hydraulic snubber to restrain a dynamic load. | | | | | |
| MFGR.: Federal Mogul | | | MODEL NO.: E-50 | | |
| MATERIAL: Ethylene Propylene | | | REFERENCE(S): 4 | | |
| DESIGN RATING(S) | REFERENCE(S) | REQUIREMENTS | DEMONSTRATED BY | ACCEPT-ABLE | REFERENCE(S) |
| 3.0E07 Rads | 4 | Radiation - 2.63E07 Rads (5 year plus 30 day post accident) | Material analysis and vital component test | Y | Ref. 4 Apdx. A No. 7 |
| 350°F | 4 | 321°F-maximum surface temperature | Surface temperature analysis and vital component test | Y | Ref. 4, 17 Apdx. A No. 2 |
| PART DESCRIPTION: O-Ring - Valve Male Connector, Item 19, PHD-5222-SK-55, Of Ref. 1 | | | | | |
| FUNCTION: To prevent leakage of hydraulic fluid through connector | | | | | |
| SAFETY RELATED: YES <u>X</u> NO <u> </u> | | | | | |
| Seal failure results in a loss of hydraulic fluid and hence a loss of the safety function of hydraulic snubber to restrain a dynamic load. | | | | | |
| MFGR.: Federal Mogul | | | MODEL NO.: E-50 | | |
| MATERIAL: Ethylene Propylene | | | REFERENCE(S): 4 | | |
| DESIGN RATING(S) | REFERENCE(S) | REQUIREMENTS | DEMONSTRATED BY | ACCEPT-ABLE | REFERENCE(S) |
| 3.0E07 Rads | 4 | Radiation - 2.63E07 Rads (5 year plus 30 day post accident) | Material analysis and vital component test | Y | Ref. 4 Apdx. A No. 7 |
| 350°F | 4 | 321°F-maximum surface temperature | Surface temperature analysis and vital component test | Y | Ref. 4, 17 Apdx. A No. 2 |

MECHANICAL EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW FORM

| | |
|--|-------------------------------|
| COMPONENT: Rod End Connector/End Connector | PAGE <u>13</u> OF <u>14</u> |
| MEGR.: ITT Grinnell | PROGRAM NO.: M-SNUB |
| DWG./DOC. NO.: PHD-5222-SK-51, PHD-5222-SK-52, of Ref. 1, Pages 32 and 33 | MODEL NO.: RB, Rm 105A, 614FT |
| | LOCATION: |

SAFETY RELATED: YES X NO

DISCUSSION:

The rod end connector/end connector connects the hydraulic cylinder and the fluid system or components important to safety.

There are no non-metallic parts contained in the connector assembly. Therefore, a Component/Part Summary Sheet is not required.

PART DESCRIPTION:

FUNCTION:

SAFETY RELATED: YES NO

MEGR.:

MODEL NO.:

MATERIAL:

REFERENCE(S):

| DESIGN RATING (S) | REFER- ENCE (S) | REQUIREMENTS | DEMONSTRATED BY | ACCEPT- ABLE | REFER- ENCE (S) |
|----------------------|--------------------|--------------|--------------------|-----------------|--------------------|
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

MECHANICAL EQUIPMENT ENVIRONMENTAL QUALIFICATION REVIEW FORM

| | |
|---------------------------------|------------------------------|
| COMPONENT: Hydraulic Fluid | PAGE <u>14</u> OF <u>14</u> |
| MFGR.: General Electric Company | PROGRAM NO.: M-SNUB |
| DWG./DOC. NO.: N/A | MODEL NO.: SF-1154 |
| | LOCATION: RB, Rm 105A, 614FT |

SAFETY RELATED: YES X NO

DISCUSSION:

The hydraulic fluid used in the hydraulic snubber is a major load carrying member. The GE SF-1154 fluid is a copolymer containing both methyl and phenyl units. It has high temperature stability and can be used from -56°F to +540°F (Reference 3). It has radiation resistance up to 5.0E08 rads (Reference 3). The compatibility of SF-1154 to the EPDM based seals used in ITT hydraulic snubbers was demonstrated in Reference 10.

PART DESCRIPTION: Hydraulic fluid

FUNCTION: To carry the sudden dynamic load

SAFETY RELATED: YES X NO

Degradation of hydraulic fluid will hinder the operability of hydraulic snubber.

MFGR.: GE

MODEL NO.: SF-1154

MATERIAL: Methyl phenyl polysiloxane fluid REFERENCE(S): 3

| DESIGN RATING(S) | REFER- ENCE(S) | REQUIREMENTS | DEMONSTRATED BY | ACCEPT- ABLE | REFER- ENCE(S) |
|---------------------|-------------------|---|--|-----------------|----------------------------|
| 5.0E08 Rads | 3 | Radiation - 2.63E07 Rads (3 year plus 30 day post accident) | Material analy- sis and vital component test | Y | Ref. 4 Apdx. A No. 7 |
| 540°F | 3 | 120°F-maximum environmental temperature | Material design rating | Y | Ref. 3 |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

HYDRAULIC SNUBBERS
MAINTENANCE AND SURVEILLANCE RECOMMENDATIONS
M-SNUB

| <u>Frequency</u> | <u>Requirement</u> | <u>Action</u> |
|--|---|---|
| Every refueling outage or the scheduled inspection periods (attached on page 3) whichever is earlier | <p>Inservice visual inspection of</p> <ol style="list-style-type: none"> 1. Any indication of damage or impaired operability. 2. Attachments to the foundation or supporting structure are secure. 3. The snubber has freedom of movement and is not frozen up. 4. Any external signs of leakage or any other conditions which may compromise the operability of the hydraulic system. 5. An adequate reservoir fluid volume is available for operation. | Any unit which fails to pass visual inspection shall be removed from service and subject to functional testing restored or replaced by an operational unit. |
| At least every 18 months or shutdown | <p>Functional test to verify that</p> <ol style="list-style-type: none"> 1. Activation (restraining action) is achieved within the specified range of velocity in both tension and compression. 2. Snubber bleed, or release rate, where required, is within the specified range in compression or tension. For snubbers specifically required to not displace under continuous load, displacement shall be verified. | For the snubber found inoperable, an engineering evaluation shall be performed to determine whether or not the snubber mode of failure has imparted a significant effect or degradation on the supported component or system. |

HYDRAULIC SNUBBERS
MAINTENANCE AND SURVEILLANCE RECOMMENDATIONS
M-SNUB (Continued)

| <u>Frequency</u> | <u>Requirement</u> | <u>Action</u> |
|-------------------|--|--|
| | 3. The snubber has freedom of movement and is not frozen up. | All snubbers of the same design shall be functionally tested. |
| Every five years* | Normal maintenance | Replace all the seals listed on CPSS and the following parts: Hydraulic Fluid Rod Wave Spring Piston Wear Ring Rod Wiper Rod Bushing Rod Seal Cage Rod Pressure Ring Retainer Screws |

* This maintenance program follows the manufacturer's recommendation per Reference 1.

HYDRAULIC SNUBBERS
MAINTENANCE AND SURVEILLANCE RECOMMENDATION
M-SNUB (Continued)

The first inservice visual inspection of snubbers shall be during the first COLD SHUTDOWN exceeding 24 hours after four months of power operation and shall include all snubbers. If less than two (2) snubbers are found inoperable during the first inservice visual inspection, the second inservice visual inspection shall be performed 12 months + 25% from the date of the first inspection. Otherwise, subsequent visual inspections shall be performed in accordance with the following schedule:

| <u>No. of Inoperable Snubbers</u> <u>per Inspection Period</u> | <u>Subsequent Visual</u> <u>Inspection Period*</u> |
|---|---|
| 0 | 18 months <u>+</u> 25% |
| 2 | 6 months <u>+</u> 25% |
| 3,4 | 124 days <u>+</u> 25% |
| 5,6,7 | 62 days <u>+</u> 25% |
| 8 or more | 31 days <u>+</u> 25% |

- * The inspection interval shall not be lengthened more than one step at a time.

APPENDIX A

1. The only non-metallic parts of the ITT Grinnell Hydraulic Snubbers are hydraulic fluid and seals at various locations. The operating experience (Pages 84 and 86, Reference 4) and supporting analysis (References 3, 16) have demonstrated that the 5-year life of seals and hydraulic fluid is a conservative projection. With appropriate maintenance and surveillance schedules, developed in the Maintenance and Surveillance Recommendation Section, the qualified life of the Hydraulic Snubber is determined to be in excess of 40 years including a 30 day post accident condition.
2. The hydraulic fluid used in the ITT Grinnell Hydraulic Snubbers is GE SF-1154 silicone fluid which has excellent high temperature stability. It can be used from -56 to +540°F which envelops both the normal and post-accident environmental temperatures (Reference 3). The seal material used in ITT Grinnell Hydraulic Snubbers, EPDM, in general maintains its elastomeric character over a broad temperature range. Typical service temperature range for continuous usage is from -70°F to 350°F (Page 2, Reference 4) which envelops the normal service temperature of the hydraulic snubbers used in the Midland Units 1 & 2. The maximum surface temperature which the hydraulic snubber seals will experience during an MSLB is determined by supporting analysis in Reference 17 to be 321°F since the EPDM has demonstrated performance at temperatures up to 350°F, the qualification is acceptable.
3. The Ethylene Propylene base material used in this seal application can withstand very high pressure environments. In similar applications, EPR seals and O-Rings were exposed to LOCA Simulation Testing (See MEQ Program M.118) with temperatures up to 358°F and pressures up to 45 psig. The seals in the hydraulic snubber are designed to maintain a high pressure differential

(in excess of several thousand pounds) between the internal hydraulic fluid and external pressure. Any increases of environmental pressure actually decreases the pressure differential of internal fluid pressure and external pressure. Pressure qualification is acceptable.

4. The humidity requirement for the hydraulic snubbers is 100% RH as a maximum value. This value does not change for accident conditions. A test of Vital Components - Seals has been included in Reference 10 where the seals were exposed to a 100% RH conditions without remarkable changes in materials properties. Therefore, the humidity qualification is acceptable.
5. The primary function of the hydraulic snubber is to ensure the thermal behavior and the frequency response level of the Reactor Coolant Pump System so that the induced reactions and the resultant stresses at the reactor coolant pumps are within allowable limits. Since carrying nonseismic vibration load is part of the hydraulic snubber's safety function, the qualification is acceptable.
6. The required operating period for a hydraulic snubber is 30 days to maintain the reactor coolant pump integrity for a small LOCA. The non-metallic constituents of the hydraulic snubbers have been evaluated against the postulated environmental conditions over a 30 day post-accident period (See No. 2 and 7 of this Appendix and Reference 17) and found acceptable.
7. The total integrated dose requirement of $1.69E08$ rads is for the surface of equipment in a radiation environment of $1.3E08$ rads beta and $2.3E07$ rads gamma for 30 days post-accident (from EQ Submittal, Rev. 1, Table 1-6) and $1.6E07$ rads for a 40 year normal service. Replacement of the seals and hydraulic fluid on a 5-year basis decreases the radiation dose requirement to $1.55E08$ rads ($2.5E07$ rads gamma and $1.3E08$ rads beta).

NRC IE Bulletin 79-01B states that the beta surface dose would be reduced by approximately a factor of ten within 30 mils of the surface of equipment. An additional 40 mils of thickness results in another factor of 10 reduction in dose. There are several static seals whose surface is directly exposed to the beta dose field. The rest of the seals are shielded by the metal parts which are much thicker than 70 mils. The thickness of the smallest size of those seals exposed to the air is 0.087 inch (Item 16, Page 26, Reference 4), which is equivalent to 221 mils. Considering that these seals are static seals, loss of one third of seal material ($70/221 = 1/3$) is unlikely to damage its sealing function. Therefore, the total radiation dose with a 5 year replacement interval can be reduced to $1.3E06$ beta ($1.3E08/(10 \times 10) = 1.3E06$) and $2.5E07$ gamma. This results in a $2.63E07$ total radiation dose which is enveloped by $3.0E07$ gamma dose tested. The tests were conducted by ITT Grinnell on all the seals used in the hydraulic snubber for a total dose of $3.0E07$ rads gamma (Reference 10) and sufficient resiliency is maintained in all cases to provide adequate sealing. Therefore, the radiation qualification is acceptable.

The GE SF-1154 Hydraulic Fluid has excellent radiation resistance and is capable of absorbing up to $5.0E08$ rads before gellation, which is much higher than $2.63E07$ Rads. The radiation qualification is acceptable.

8. The required project chemistry is given in T-1. The EPDM has demonstrated an excellent chemical stability (Reference 4, Page 2). In addition, Midland EQ Programs E22A and E22B have demonstrated that the Ethylene Propylene Rubber material is qualified for a spray chemistry which is more severe than the required Midland spray chemistry. Spray chemistry qualification is acceptable.

9. The Rod End Connector/End Connector is a totally metallic part and is not affected by the environmental conditions imposed during a LOCA or MSLB.
10. Seals made of EPDM have lasted 5 years under working conditions and still maintained its safety function (Pages 84 and 89, Reference 4). A test conducted by ITT Grinnell on its hydraulic snubber seals demonstrates that the seals maintain sufficient resiliency to provide adequate sealing after 72-hours of exposure at 268°F. With Arrhenius Methodology a 5-year service life at 120°F is determined in Reference 16. The seal was tested with the GE SF-1154 Hydraulic Fluid. The compatibility of EPDM and the hydraulic fluid has been demonstrated. Therefore, 5 years of replacement interval is adequate for qualifying hydraulic snubber.
11. As stated in No. 2, 7, and 10, GE SF-1154 has an excellent stability against temperature and radiation. The 5-year projected life is conservative.
12. The hydraulic snubber is qualified for a long term 30 day operability period as described in this Appendix. Therefore this category is not applicable.
13. Because all the hydraulic snubbers are located at the level of 614 ft. which is higher than the flood level of 603 ft., both normal and accidental submergence are not considered for snubber qualification. Thus this category is not applicable.
14. The hydraulic snubber subjected to analysis as described in this program is identical to the hydraulic snubber installed at the Midland plant, Units 1 & 2 as noted in References 1, 4.

REFERENCES AND ADDITIONAL DATA

PAGE 1 OF 3

PROGRAM NO.: M-SNUB

1. ITT Grinnell Co., "Technical Manual for Maintenance Large Bore Hydraulic Snubbers", Report No. PHD-5222-1MBM, January 9, 1979.
2. Letter from Earl Tomlinson of W. H. Salisbury & Co. Linemens Rubber Protective Devices, Subject: Mechanical Properties of Compound #80154, dated December 8, 1982.
3. G.E. "Silicone Fluids in Radiation Environments", G.E. technical information CDS-4176, January 1981.
4. ITT Grinnell Co., "Final Report - Consumers Power Company Contract for Consulting Service for the Reactor Coolant Pump Snubber Seal Study for the Midland Plant", Report No. SPS-ZPR-8014-5, December 24, 1981.
5. ASME Boiler and Pressure Vessel Code, Section III, Division 1, Subsection NF.
6. EPRI, "A Review of Equipment Aging Theory and Technology", Report EPRI NP-1558, September 1980.
7. Federal Mogul Co., "Comparison - National Compound E50-70 to ASTM D200 Specifications 4CA715A25B44EA14F19G21 and 3DA715A26B36EA14F19G21" National O-Rings Technical Report, April 26, 1982.

REFERENCES AND ADDITIONAL DATA

PAGE 2 OF 3

PROGRAM NO.: M-SNUB

8. Federal Mogul Co., "Comparison Compound E50-70 to TACO Inc./ Underwriters Laboratories UL 778 Requirements" National O-Rings Technical Report, April 26, 1982.

9. Acushnet Co. Laboratory Report No. 4034 for Compound E-17018, page 2.

10. ITT Grinnell Co., "Radiation and Environmental Test of Seal and Fluid materials for Snubbers" Report No. PHD-5347-2R, Revision 1, July 23, 1977.

11. ITT Grinnell Co., "Radiation and Environmental Test of Seal Materials for Snubbers", Report No. PHD-7569-1, Revision 1, July 23, 1977.

12. ITT Grinnell Co., Engineering Parts List MB-5222-31, Revision 3, October 28, 1981.

13. ITT Grinnell Co., Engineering Parts List MB-5222-45, Revision 3, October 28, 1981.

14. EPRI, "Radiation Effects on Organic Materials in Nuclear Plants" Report EPRI NP-2129, November 1981.

15. ITT Grinnell Co. Drawing PHD-5222-5, PHD-5222-6, PHD-5222-7 and PHD-5222-8.

REFERENCES AND ADDITIONAL DATA

PAGE 3 OF 3

PROGRAM NO.: M-SNUB

16. M.R. Lee, "Replacement Interval Calculation for the ITT Grinnell Hydraulic Snubber Seals and Hydraulic Fluid Based on the Thermal Degradation", NUTECH Calculation CPC-09-E.041, January 1983.


17. M.R. Lee, "Surface Temperature Analysis for the ITT Grinnell Hydraulic Snubbers", NUTECH Calculation CPC-09-E.040, January 1983.

18. Midland Plant, Units 1 & 2 Environmental Qualification Report, Vol. I, Revision 1, December 1982.

GENERIC FIGURES

F-1 and F-2: Reactor Building Temperature and Pressure
vs Time after LOCA and MSLB Accidents

T1 : Present Spray Chemistry




**CONSUMERS POWER COMPANY
 MIDLAND UNITS 1 AND 2**

REACTOR BUILDING PRESSURE AND
 TEMPERATURE VS TIME AFTER LOCA

FIGURE F-1

EO Report Revision 1
 12/82



**CONSUMERS POWER COMPANY
MIDLAND UNITS 1 AND 2**

REACTOR BUILDING PRESSURE AND
TEMPERATURE VS TIME AFTER MSLB

FIGURE F-2

EQ Report Revision 1
12/82

EQUIPMENT QUALIFICATION REPORT MIDLAND PLANT UNITS 1 AND 2 T1 PRESENT SPRAY CHEMISTRY

TIME POST-DBA

| | <u>0 - 60 MINUTES</u> | <u>60 - 121 MINUTES</u> | <u>121 MINUTES - 30 DAYS</u> |
|-----------------------|-------------------------------|--|----------------------------------|
| pH | 4.5 - 4.6 | Increasing | 7.0 - 7.5 |
| Boric Acid | 13,000 - 14,130 ppm | 13,000 - 14,130 ppm | 13,000 - 14,130 ppm |
| Hydrazine | Maintained at 50 - 110 ppm | Maintained at 50 - 110 ppm | Maintenance Stopped |
| Disodium Phosphate | None | Addition Begun to Control pH to 7.0 - 7.5 at 120 Minutes | Maintain pH to 7.0 - 7.5 |

ITT GRINNELL CORPORATION
PIPE HANGER DIVISION
RESEARCH, DEVELOPMENT AND
ENGINEERING DEPARTMENT

PHD-5222-1MBM

TECHNICAL MANUAL
FOR MAINTENANCE
LARGE BORE HYDRAULIC SNUBBERS

CONSUMER POWER CO.
MIDLAND PLANT UNITS 1 & 2

JANUARY, 1979

REVISION 3

TECHNICAL MANUAL PHD-5222-1MBM







PREPARED BY: David H. Francis DATE 1/19/79
Engineer

APPROVED BY: S. P. Brown DATE 1/19/79
Sect. Mgr.

APPROVED BY: Carl H. Brown DATE 1/19/79
Dept. Mgr.

TECHNICAL MANUAL PHD-5222-1MBM

REV. SHEET

| <u>NO.</u> | <u>DATE</u> | <u>REV.</u> | <u>BY</u> | <u>APPR.</u> | <u>APPR.</u> |
|------------|-------------|--|-----------|---|---|
| 1 | 2/10/81 | General Revision | DSS |  |  |
| 2 | 5/14/81 | General Revision | DSS |  |  |
| 3 | 7/21/81 | Added Note After 7.12.1 and Added Section 7.12.2 | DSS |  |  |

| <u>Section</u> | <u>Index</u> | <u>Pg.</u> |
|----------------|---|------------|
| 1.0 | Maintenance Procedure | 1 |
| 2.0 | Teardown for Replacement of Seals in Miller Cylinder Model 90 PHD-5222-SK 51 | 3 |
| 3.0 | Teardown for Replacement of Seals in Miller Cylinders Model 90 - Short Stroke - PHD-5222-SK 51 | 11 |
| 4.0 | Teardown for Replacement of Seals in Miller Cylinders Model 52 - PHD-5222-SK 52 | 13 |
| 5.0 | Teardown for Replacement of Seals in Miller Cylinders Model 52 - Short Stroke - PHD-5222-SK 52 | 14 |
| 6.0 | Teardown for Replacement of Seals in Miller Cylinders Model 52 - Short Stroke - PHD-5222-SK 53 Assembly J1 | 15 |
| 7.0 | Teardown Procedure Snubber Valves PHD-5222-SK 55 & 56 | 16 |
| 8.0 | Torque Requirements - Cylinders | 23 |
| 9.0 | Teardown for Replacement of Seals - Oil-Rite Reservoirs PHD-5222-SK 63 & SK 64 | 27 |
| 10.0 | Fluid Requirements | 29 |
| 11.0 | Spare Parts List | 30 |
| | TABLE I | 25 |

1.0 MAINTENANCE PROCEDURE (14" - 20" HYDRAULIC SNUBBERS)

Maintenance of the Midland Plant Unit 1 & 2 snubbers should be conducted during every normal maintenance or shutdown period.

Maintenance need only consist of the following:

- 1.1 Check cylinder head and cap, valves, fluid line connections and reservoir for signs of fluid leakage. If it is necessary to remove valve covers, procedures contained in the installation manual PHD-5222-2MBI should be followed.
- 1.2 If leakage is evident at any connections, check for proper tightness. (Ref; PHD-5222- SK 55 and SK 56)
 - 1.2.1 Tighten fractional tube adapter (20) Cajon Fitting, to a torque of 18 ft. lbs.
 - 1.2.2 Tighten fittings (21) and (23) in the following manner. Back off fitting until it can be retightened by hand. Retighten by hand. Tighten fitting by turning 1 1/4 turns.
 - 1.2.3 All other fittings shall be tightened in the following fashion. Back off fitting nut until it can be tightened by hand. Secure nut hand tight and then tighten with a wrench by turning the fitting 1 1/4 turns. If this does not stop leakage, replace fitting - refer to Section 7.0.
- 1.3 If leakage is evident at valve mounting surface, check torque of valve mounting bolts (18) drawing PHD-5222-SK 55 & 56. Torque on these bolts should be 35 ft. lbs. Torque bolts to this value if required. If this does not stop leakage, refer to Sections 7.0 and 8.0 for inspection or replacement of seals.
- 1.4 If leakage is evident at any of the following points refer to Section 7.0 for Valve Teardown.

1.4 Cont'd

(Refer to PHD-5222-SK 55 and 56)

a. Velocity adjustment screw (6)

b. Orifice valve stem (2)

c. Between valve body (1) and retainer plate (12)

1.5 If leakage is evident at the valve adjustment screws (See Para. 1.4 a. and b.), any type of modification could result in unit's calibration being affected. (See Section 7.0 for Teardown).

1.6 If leakage is evident at any of the cylinder components, refer to Section 2.0 thru 6.0 for replacement of seals or components.

1.7 Check the fluid level in the reservoir. If the level has dropped below the required level, replenish with GE Silicone Fluid SF-1154. This should be done now only if reservoir is not to be torn down.

1.8 If leakage is evident at any of the reservoir fittings, refer to Section 9.0 for replacement of seals or adjustment.

1.9 Clean exposed portion of piston rod using a non-petroleum based solvent* and clean with a lint free cloth. After cleaning, wipe with a light coat of GE SF-1154 fluid.

1.10 The elastomeric seals used in the snubber assembly can be expected to last for approximately 5 years. Seals should be replaced after this period or at the shutdown preceeding the shutdown which will exceed 5 years.

NOTE: Seals may remain on the shelf for up to five (5) years prior to installation. Once installed and compressed, seal life is five (5) years.

* AVAILABLE NON PETRO BASED SOLVENTS THAT HAVE BEEN USED ARE ZYLENE, ALCOHOL, ETC.

2.0 TEARDOWN FOR REPLACEMENT OF SEALS IN MILLER CYLINDER MODEL 90

PHD-5222-SK 51

This Section covers the following snubbers:

D1, D3, E1B, E3B, F1, B5, B3, B6 & B4

- 2.1 Disconnect remote reservoir feed tube(s)* from reservoir connection assembly and remove cylinder assembly by reversing the installation procedure as described in PHD-5222-2MBI, to an area where all grime may be removed from external surfaces utilizing a non-petroleum based solvent. Clean exposed threads on tie rods using a wire brush. (*PARALLEL UNITS ARE JOINED TO A COMMON RESERVOIR)
- 2.2 Units should now be moved to an area that is free of all dust and dirt for disassembly and replacement of seals.
- 2.3 During disassembly all units shall be cleaned using a non-petroleum based solvent. All seals and wave spring (16) shall be discarded and replaced using new material. Seal and seal cavities shall be wet with clean fresh fluid: Type GE SF-1154 silicone fluid.
- 2.4 With unit in horizontal position and valves in the top mounted position, remove valves as described in Section 7.0 from the cylinder body and set aside. Pour fluid out of cylinder into a suitable container and discard fluid. Stroking unit will speed this process.
- 2.5 With the unit still in a horizontal position, the torque on the clevis attachment at the end of the piston rod should be broken.
- 2.6 Place unit in a (fixture) in the vertical position with piston rod (1) up.
- 2.7 Remove Clevis Attachment from end of piston rod (1).

2.8 Disassemble cylinder for seal or component replacement as follows:

2.8.1 Removal of Rod Bushing Assembly

2.8.1.1 Remove rod wiper retainer (30) by first removing clip (32) around the retainer screws (21) then washer (31) and then the rod wiper retainer (30).

2.8.1.2 Loosen and remove retainer screws (21) and washers (33) which hold rod bushing (8) and retainer plate (7) to cylinder head (3).

2.8.1.3 Lift retainer plate (7) from cylinder head (3) and remove existing parts from cylinder in the following sequence: (Ref; PHD-5222 SK 54):

Rod Wiper (15) - to be discarded

Rod Bushing (8)

Rod Seal (6) - to be discarded

Rod Pressure Ring (12)

Rod Wave Spring (16) - to be discarded

Rod Seal Cage (13)

2.8.2 Disassembly of Cylinder

2.8.2.1 Loosen and remove tie rod nuts (9) at piston rod (1) end of cylinder.

2.8.2.2 Thread lifting eye rod into threaded holes provided in cylinder head and attach a sling to eye rods. Using an overhead hoist, slowly lift cylinder head (3) above tie rods (11); tapping on the underside of the head (3) with a rubber mallet, while lifting, will aid in freeing the

2.8.2.2 Cont'd

head (3) from the cylinder tube (5) and tie rods (11).

2.8.2.3 Thread a male eye attachment into piston rod (1) end and again using a sling and hoist, slowly raise piston/piston rod (1) from cylinder tube (5), using caution not to bind piston in cylinder tube (5) resulting in damaged components. Place assembly to one side, remove eye attachments and disassemble piston parts as follows:

- 2.8.2.3.1 Remove piston retaining ring (18) from one side of piston (1). Using a needlenose plier or other suitable means, grasp piston retaining ring (18) and remove from groove in piston (1).
- 2.8.2.3.2 Slide anti roll ring (17) from piston (1)
- 2.8.2.3.3 Remove piston seal (2) from piston (1) and discard.
- 2.8.2.3.4 Remove piston seal back-up ring (10) from piston (1).
- 2.8.2.3.5 Proceed to remove seals on other side in like manner.
- 2.8.2.3.6 If scored or severely worn, remove piston wear ring (19). Using snap ring pliers, or other expanding tool,

2.8.2.3.6 Cont'd

expand piston wear ring (19) and
slide off piston (1).

2.8.2.4 Remove cylinder tube (5) from cylinder cap (4).

2.8.2.5 Remove cylinder tie rods (11) using vise grips,
or other suitable tools. Protect tie rods (11)
by wrapping with protective tape, cloth or
other methods that will insure tie rods (11)
will not be severely scored.

2.8.2.6 Remove cylinder cap (4) from fixture

2.8.2.7 Remove cylinder end seals (14) from O-ring
grooves on inner face of cylinder head (3) and
cylinder cap (4). Discard seals.

2.8.2.8 Remove fill port plug (23) from cylinder head
(3) and cylinder cap (4) and discard O-rings (24).

2.9 Cleaning

2.9.1 Clean all cylinder components using a non-petroleum base
solvent and blow dry using oil-free air.

2.9.2 Wire brush all threads and clean thoroughly.

2.10 Inspection

2.10.1 Inspect piston rod (1). If any nicks or scratches are
evident on piston rod (1) the vendor shall be notified
so that a representative may be present to evaluate the
severity of the damage and make recommendation to either
rework or replace piston rod.

2.10.2 Inspect additional components for wear that may result in
damaged seals or hamper the operation of the units.
Replace as required.

2.11 Reassembly of Cylinder

2.11.1 Replacement of Seals

- 2.11.1.1 Wet all seals and seal cavities with hydraulic fluid (use only type GE SF-1154) prior to installing seals.
- 2.11.1.2 Insert new O-ring (24) in fill port and replace fill port plug (23)
- 2.11.1.3 Insert new cylinder end seals (14) into O-ring grooves in the inner-face of the cylinder head (3) and cylinder cap (4).
- 2.11.1.4 If removed, install a new piston wear ring (19) onto piston (1). Using snap ring pliers or other expanding tool, expand piston wear ring (19) and slide into place on piston (1).
- 2.11.1.5 Replace piston seal parts (items 2-new, 10, 17, 18)
 - 2.11.1.5.1 Install piston seal back-up ring (10) on piston (1) so that it seats against shoulder.
 - 2.11.1.5.2 Place a new piston seal (2) onto piston (1) flat side of seal to piston seal back-up ring (10)
 - 2.11.1.5.3 Install piston anti-roll ring (17) over piston (1) flat side away from piston seal (2).
 - 2.11.1.5.4 Install piston retaining ring (18) onto piston (1) using needle nose pliers to expand and ensuring that retaining ring (18) seats into groove in piston (1).

2.11.2 Assembly of Components

- 2.11.2.1 Place cylinder cap (4) back into fixture. Single lug attachment down.
- 2.11.2.2 Reinstall tie rods (11)
- 2.11.2.3 Place cylinder tube (5) into groove in cylinder cap (4). Coat tube with a thin layer of GE SF-1154 hydraulic fluid.
- 2.11.2.4 Next place a tapered starting ring or piston ring compressor over piston seal (2) at the end opposite piston rod (1).
- 2.11.2.5 Install eye attachment into piston rod (1). Using a sling and overhead hoist, raise piston/piston rod assembly (1) by use of the lifting eye attachment to a position directly above cylinder tube (5).
- 2.11.2.6 Slowly lower piston/piston rod assembly (1) into cylinder tube (5). When a point is reached where tapered ring or ring compressor interfere, remove from piston (1) and continue lowering assembly into cylinder tube (5). Taking precautions to insure piston assembly (1) does not bind, continue lowering until piston (1) bottoms against cylinder cap (4).
- 2.11.2.7 Remove lifting eye attachment and sling.
- 2.11.2.8 Using sling and hoist, lift cylinder head (3) over piston rod (1) align cylinder head (3) to mate tie rod holes to tie rods (11). Insure that snubber valve ports on cylinder head (3) and cylinder cap (4) are on the same side of the unit.

2.11.2.8 Cont'd

Lower cylinder head (4) onto the unit so that the groove on the inner face of the cylinder head mates to cylinder tube (5).

2.11.2.9 Reinstall tie rod nuts (9), applying molycote to tie rod threads.

2.11.3 Replacement of Rod Bushing Assembly

2.11.3.1 Place rod seal cage (13) over piston rod (1) and into counterbore in cylinder head (3).

2.11.3.2 Install new rod wave spring (16) over piston rod (1) and seat into rod seal cage (13).

2.11.3.3 Place rod pressure ring (12) over piston rod (1) so that its flat side bears against rod wave spring (16).

2.11.3.4 Install new rod seal (6) into seal cavity of bushing (8) making sure that the rod seal (6) is properly seated. Place bushing (8) over piston rod (1) and into bushing cavity in cylinder head (3), rod seal (6) down.

2.11.3.5 Place retainer plate (7) over piston rod (1). Align retainer plate (7) with tapped holes in cylinder head (3).

2.11.3.6 Install washer (33) and retainer screw (21) and torque in accordance with Section 8.0.

2.11.3.7 Install new rod wiper (15) over piston rod, insuring that the wiper (15) is secured behind the retaining lip provided in the rod bushing (8).

2.11.3.8 Install wiper rod retainer over piston rod to keep the rod wiper in place.

- 2.11.4 Remove unit from the fixture and place in a horizontal position.
- 2.11.5 Torque cylinder tie rod nuts (9) in accordance with Section 8.0
- 2.11.6 Attach clevis attachment to end of piston rod (1) and torque to a value of 6,000 ft.lbs.

3.0 TEARDOWN FOR REPLACEMENT OF SEALS IN MILLER CYLINDER MODEL 90 -
SHORT STROKE - PHD-5222-SK 51

This section covers the following snubbers:

D4, I1, I2, E1A, E3A, F2, G1, G2, J2

3.1 Accomplish steps 2.1 thru 2.7, Section 2.0

3.2 Disassemble cylinder for seal or component replacement as follows:

3.2.1 Removal of Rod Bushing Assembly

3.2.1.1 Mount adapter plate with O-ring over valve port in cylinder cap (4). Install four mounting bolts and secure.

3.2.1.2 Remove rod wiper retainer (3) by first removing clip (32) around the retainer screws (21) then washer (31) and then the rod wiper retainer (30).

3.2.1.3 Using an air hose provide 80 psi filtered air to cylinder at the fill port in the cylinder cap (4). This pressure will provide means to fully extend piston rod (1). Maintaining pressure now remove retaining ring (22) from piston rod (1).

3.2.1.4 Decrease air pressure so that the piston rod (1) now retracts and bottoms out against cylinder cap (4).

3.2.1.5 Loosen and remove retainer screws (21) and washers (33) and lift retainer plate (7) from cylinder head (3). Remove existing parts from cylinder head (3) in the following sequence as shown on drawing PHD-5222-11 SK 54:

Rod Wiper (15) - discard

Bushing (8)

3.2.1.5 Cont'd

Rod Seal (6) - discard

Rod Pressure Ring (12)

Rod Wave Spring (16) - discard

Rod Seal Cage (13)

3.3 Accomplish Steps 2.8.2 thru 2.11.2.9 Section 2.0

3.4 Replacement of Rod Bushing Assembly

3.4.1 Provide 80 psi air to cylinder cap (4) to fully extend piston rod. Maintain pressure while installing rod seal parts.

3.4.2 Accomplish step 2.11.3, Section 2.0

3.4.3 Reinstall retainer ring (22) in groove on piston rod (1)

3.4.4 Release air pressure and allow retainer ring (22) to come to rest against rod bushing (8).

3.5 Torque cylinder tie rod nuts (9) in accordance with Section 8.0

3.6 Remove unit from the fixture and place in a horizontal position.

3.7 Attach clevis attachment to end of piston rod (1) and torque to a value of 6,000 ft. lbs.

4.0 TEARDOWN FOR REPLACEMENT OF SEALS IN MILLER CYLINDER MODEL 52

PHD-5222-9K 52

This Section covers snubbers B1 & B2

- 4.1 Accomplish Steps 2.1 thru 2.3, Section 2.0
- 4.2 With cylinder in horizontal position, remove extension piece.
- 4.3 Accomplish Steps 2.4 thru 2.8.1.3, Section 2.0
- 4.4 Removal of External Bearing
 - 4.4.1 Loosen and remove retainer screws (26) and washers (33).
 - 4.4.2 Lift external bearing (25) from cavity in cylinder head (3)
 - 4.4.3 Remove and discard external bearing seal (27)
- 4.5 Accomplish Steps 2.3.2 thru 2.11.2.9, Section 2.0
- 4.6 Replacement of External Bearing
 - 4.6.1 Install new external bearing seal (27) over hub on rear of external bearing (25)
 - 4.6.2 Install external bearing (25) by placing external bearing, seal down, into counterbore in cylinder head (3).
 - 4.6.3 Install retainer screws (26) and washers (33) and torque in accordance with Section 8.0.
- 4.7 Accomplish Steps 2.11.3 thru 2.11.6, Section 2.0
- 4.8 Attach extension piece torquing nuts and bolts in accordance with Section 8.0.

5.0 TEARDOWN FOR REPLACEMENT OF SEALS IN MILLER CYLINDER MODEL 52 SHORT
STROKE, PHD-5222-SK 52

This section covers the following snubbers:

C1, C2, D2, E2, E4, A1, A2, H1 & H2

5.1 Refer to Section 4.0 for the sequence of disassembly and assembly of these particular units.

5.2 The only variation will exist in the removal and replacement of the rod seal parts. Air pressure will again be required for extending and maintaining piston rod position. Refer to Section 3.0, 3.2 and 3.4 for this information.

6.0 TEARDOWN FOR REPLACEMENT OF SEALS IN MILLER CYLINDER MODEL 52 SHORT
STROKE, PHD-5222-SK 53

Assembly # J1

- 6.1 These cylinders have the same basic structural characteristics, and are to be worked the same as those in Section 5.0, with the exception of the cylinder tie rods (11).
- 6.2 As may be noted on procedural drawing PHD-5222-SK 53 the tie rods (11) extend through the cylinder cap (4) and extension Piece (28), threading into the pivot lug attachment (29) rather than threading into the cylinder cap (4) as on other units.
- 6.3 The only additional precautionary measure to be taken on this unit is during reassembly:
 - 6.3.1 Prior to reassembly as stated in Section 5.0, install the pivot lug attachment (29) into the fixture.
 - 6.3.2 Lift extension piece (28) into place on pivot lug (29) and align tie rod holes. Insure proper orientation of pivot lug (29) to extension piece (28).
 - 6.3.3 Lift cylinder cap (4) into place on extension piece (29) assuring correct location for the valve mounting port in relation to pivot lug (29) and extension piece (28).
 - 6.3.4 Reassemble remaining components as stated in Section 5.0.

7.0 TEARDOWN PROCEDURE FOR THE SNUBBER VALVE/PHD-5222-SK 55 & SK 56

- 7.1 Drain reservoir as described in Section 9.0
- 7.2 (Ref; PHD-5222-SK 55) Remove reservoir connection assembly from the valve connection tubing tee (24) by backing off fitting nut (23). Free reservoir connection assembly tee (24) and plug or cap tee (24).
- 7.3 During disassembly all valve fitting, tubing and components except seals shall be cleaned using a non-petroleum based solvent and blown dry using clean oil free air. All seals used shall be discarded. New seals and seal cavities shall be wet with clean fresh GE silicone fluid #SF-1154 just prior to installation.
- 7.4 Removal of Valve from Cylinder
 - 7.4.1 Remove tamperproof cover from valve body (1) as described in procedure PHD-5222-2MBI
- 7.5 Loosen fitting nut (21) located at valve on cap end of cylinder.
- 7.6 Loosen fitting nut (21) located at valve on head end of cylinder.
- 7.7 Loosen and remove valve mounting bolts (18) at valve located at cylinder cap.
- 7.8 Lift valve body (1) free of cylinder cap and connecting tube (22)
- 7.9 Loosen and remove valve mounting bolt (18) at valve located at cylinder head.
- 7.10 Making sure connecting tube (consisting of 21, 22, 23 and 24) does not bend or hang, lift valve body (1) free of cylinder head and connecting tube (22).
- 7.11 Drain snubber valve bodies of fluid. Drain connecting tube (21, 22, 23 and 24) of fluid and place to one side.
- 7.12 Seal and/or Component Replacement: The following disassembly/assembly sequence should be used for replacement of elastomeric seals or components as required.

7.12.1 Disassembly of Valve

NOTE: All parts to be reused should be marked and kept with the valve from which removed. Parts are not to be interchanged.

7.12.1.1 Removal of fittings

7.12.1.1.1 Loosen and remove fractional tube connector (20)

7.12.1.1.2 Remove and discard O'ring (19)

7.12.1.2 Place valve on table with adjustment screws up.

7.12.1.3 Using a screwdriver hold orifice valve stem (2) and loosen jam nut (3).

7.12.1.4 Remove orifice valve stem (2) from valve body (1). The following components shall be removed from the orifice valve stem:

- a. Jam nut (3)
- b. Washer (4)
- c. Thread seal (5), Discard

7.12.1.5 Using an allen wrench secure velocity adjustment screw (6) and loosen jam nut (7).

7.12.1.6 Remove velocity adjustment screw (6) from valve body (1). The following components shall be removed from the velocity screw (6):

- a. Jam Nut (7)
- b. Washer (8)
- c. Thread seal (9), Discard

7.12.1.7 Invert valve body (1)

7.12.1.8 Remove and discard O'ring (10)

7.12.1.9 Loosen and remove retainer plate screws (11).
Lift retainer plate (12) from valve body.

7.12.1.10 The following components shall then be removed in sequence from valve body (1):

- a. O'ring (13)
- b. Valve seat disc (14)
- c. Poppet valve (15)
- d. Spring (16)
- e. Spring Plunger (17)

7.12.1.11 Repeat Steps 7.12.1.1 thru 7.12.1.10 for the second valve

7.12.2 Cleaning of Valve

7.12.2.1 The valve body should be thoroughly rinsed using pressurized filtered Freon TF solvent. All ports, cavities, blind holes, etc. must be flushed of any particles accumulated during use. Filtered air should then be blown through all areas.

7.12.2.2 All parts to be reused in valve should be thoroughly rinsed using pressurized filtered Freon TF solvent then blown dry with filtered air.

7.12.3 Assembly of Valve (NOTE: All Seals and Mating Valve Surfaces are to be Wet with GE SF-1154 Silicone Fluid Before Installation)

7.12.3.1 Place the valve block (1) inverted on the bench with large hole facing up.

7.12.3.2 Install plunger (17) into the body (1) with the flat side of the plunger (17) facing down.

7.12.3.3 Install spring (16) into the body (1) so it seats over the short stem on the plunger (17).

7.12.3.4 Install valve poppet (15) into the body with hex end facing down and so the short stem on the poppet seats in the spring (16).

7.12.3.5 Slide the valve seat disc (14) over the long stem on the poppet and seat the disc (14) in the valve body (1). (NOTE: The Chamfer Must Face the Poppet).

7.12.3.6 Install retaining plate (12) as follows:

7.12.3.6.1 Set -125 O'ring (13) in place on top of the valve seat disc (14).

7.12.3.6.2 Push the valve seat disc down (14) until firmly seated.

7.12.3.6.3 Using a small rod, hold the seat disk (14) down against the poppet (15) stem and place the retaining plate (12) in position, aligning the holes with the threaded holes in the valve body.

NOTE: The retaining plate (12) should be placed directly on the valve body (1) during this operation, with minimum sliding between the two. Sliding can affect the proper seating of the O'ring.

7.12.3.6.4 While holding the retaining plate (12) firmly, release the seat disc (14).

7.12.3.6.5 Install the two retaining plate screws (11) and tighten.

7.12.3.6.5 Cont'd

NOTE: The remaining O'ring (10) will be installed when the valve is assembled to cylinder.

7.12.3.7 Invert the assembly so that it sits on the bench with the retaining plate (10) at the bottom.

7.12.3.8 Install the locking velocity screw (6) as follows:

7.12.3.8.1 Screw the 1/4 thread seal (9) on the socket end of the locking velocity screw (6) so that it is approximately 1/4 in. from the socket end of the screw.

7.12.3.8.2 Slide the washer (8) over the socket end of the screw (6) until it is against the thread seal (9).

7.12.3.8.3 Screw the hex nut (7) on the socket end of screw (6) until the socket end of the screw (6) extends 1/8" beyond the edge of the hex nut (7).

7.12.3.8.4 While holding the hex nut (7) fixed on the screw (6), screw the thread seal (9) toward the hex nut (7) until snug against the washer (8) and hex nut (7).

7.12.3.8.5 Screw the velocity locking screw (6) assembly into the body (1) in the threaded hole, over the plunger (17) and spring assembly, until snug.

7.12.3.8.6 While holding the screw (6) with an allen wrench, tighten the hex nut (7) an additional 1/4 turn.

7.12.3.9 Install the orifice stem screw (2) as follows:

7.12.3.9.1 Screw the 1/4 thread seal (5) over the tapered end of the screw to approximately 3/4 in. from the slotted end.

7.12.3.9.2 Fit the washer (4) over the slotted end of the screw (2) until snug against the thread seal (5).

7.12.3.9.3 Screw the hex nut (3) on the slotted end of the screw (2) until snug against the washer (4) and thread seal (5).

7.12.3.9.4 Screw the orifice stem screw (2) assembly into the remaining threaded hole in the valve body (1) until snug.

7.12.3.9.5 While holding the screw (2) with a screwdriver, tighten the hex nut (3) an additional 1/4 turn with a wrench.

7.12.3.10 Repeat Step 7.12.3 for the second snubber valve.

7.13 Replacement of Fitting

7.13.1 Install new O'ring (19) onto fractional tube adapter (20) and thread into valve port on side of valve.

7.13.2 Install tubing (22) onto fractional tube adapter (20) and engage fitting nut (21). Snug fitting nut (21) hand tight.

7.13.3 Repeat Steps 7.13.1 and 7.13.2 for second snubber valve.

7.14 Disassembly/Assembly Procedure Connecting Tubing

7.14.1 Remove the plug from the tee (24) on valve connection tubing.

7.14.2 Connect reservoir connection assembly to valve connection tubing at the tee (24).

7.15 Mounting Valve on Cylinders

7.15.1 Install O'rings (10) into O'ring grooves in valve retainer plates (12). Mount one valve body (1) on the cap end of cylinder so that the valve port and cap mounting port are aligned, and the fractional tube adapter (20) are facing in the direction of the cylinder head.

7.15.2 Install and engage valve mounting bolts (18) loosely.

7.15.3 Place additional valve body (1) on head end of cylinder.

7.15.4 Install and engage valve mounting bolts loosely.

7.15.5 Torque mounting bolts (18) on both valve bodies to 35 ft/lbs.

7.15.6 Tighten fractional tube adapters (20) at both valve connections.

7.15.7 Carefully check all tubing connections for proper engagement and alignment. Once this is completed, tighten all fitting nuts (Ref; Section 1.0)

7.16 The above procedure may be used for installation of the top mounted valve connection assembly (SK. PHD-5222-SK 56).

8.0 TORQUE REQUIREMENTS - CYLINDERS

8.1 Torque - Cylinder Tie Rods

8.1.1 Attached drawings in this section depict the various bolt patterns for the cylinders on this project.

PHD-5222 SK 57 - quantity of 20 tie rods

PHD-5222 SK 58 - quantity of 24 tie rods

PHD-5222 SK 59 - quantity of 28 tie rods

Each sketch shows numbered tie rod locations which is the sequence in which each tie rod shall be snugged down or torqued.

8.1.2 Check to insure that molycode has been applied to all tie rod threads before installation.

8.1.3 Method - Turn of The Nut

8.1.3.1 Pre-torque tie rod nuts to the value specified in Table 1 in the order shown on one of the above drawings.

8.1.3.2 Mark a point on both the cylinder head and tie rod nut where they join (see detail SK 57). Call mark on head point 1 and mark on tie rod nut point 2.

8.1.3.3. Using available angle measuring device mark on head a third and fourth point counterclockwise from point 1 at 50% and 100% of the degrees shown on Table 1

8.1.3.4 Insert allen wrench into socket head nuts and rotate nut clockwise until point 2 is directly in line with point 3.

8.1.3.5 Continue this process in sequence on chart until all tie rod nuts have been tightened to point 3.

8.1.3.6 Repeat Steps 8.1.3.4 and 8.1.3.5 aligning point 2 with point 4 until all tie rod nuts are tightened.

8.2 Torque Circular Retainer

8.2.1 PHD-5222 SK 60 & 61 contained in this section depict the various bolt patterns for the cylinders on this project.

PHD-5222-SK 60 - quantity of 16 retainer screws

PHD-5222-SK 61 - quantity of 20 retainer screws

Each sketch shows numbered retainer screws locations which is the sequence in which each retainer screw shall be snugged down or torqued. These values are shown on Table 1.

8.2.2 Tighten using the methods of Step 8.1.3.

8.3 Torque External Bearing

8.3.1 PHD-5222 SK 62 contained in this section depicts the bolt patterns for the cylinders on this project.

The drawing shows numbered retainer screws locations which is the sequence that each retainer screw shall be snugged down or torqued. These values are shown on Table 1.

8.3.2 Tighten using the methods of Step 8.1.3.

8.4 Torque Extension Piece Nuts and Bolts

8.4.1 Using a torque wrench snug down and torque extension piece nuts and bolts in same sequence as that shown for tie rods (ref. Para. 8.1.1).

8.4.2 Snug all nuts and bolts initially to 100 ft. lbs.

8.4.3 Torque all nuts and bolts initially to 1/3 values shown below in Step 8.4.5 in correct sequence.

8.4.4 Repeat torquing in sequence to 2/3 value and then to full value.

8.4.5 Torque values for extension piece nuts and bolts for units based on pivot pin sizes are as follows:

| <u>Pivot Pin Dia. (in.)</u> | <u>Torque (Ft. Lbs.)</u> |
|-----------------------------|--------------------------|
| 4.5 | 984 |
| 5.0 | 1038 |
| 6.0 | 1061 |
| 9.44 | 1061 |

NOTE: Bolts and nuts may be retorqued and reused at any time unless upon inspection, a defect in either is determined.

| CYL. NO. | MODEL | BORE DIA. | NO. TIE RODS | Tie Rod * 1 1/4-12 Thread | | TURN OF NUT (DEGREES) | Circular Retainer 5/16-24 Thread | | External Bearing (12) 1/2-20 Thread |
|-------------|-------|--------------|-----------------|------------------------------|--|-----------------------------|-------------------------------------|-----------------------|--|
| | | | | TORQUE (FT. LB) | | | NO. SCREWS | TORQUE ** (FT. LB) | TORQUE ** (FT. LB) |
| C1 | 52 | 14 | 20 | 665 | | 197 | 16 | 20 | 80 |
| C2 | 52 | 14 | 20 | 665 | | 197 | 16 | 20 | 80 |
| D1, D3 | 90 | 14 | 20 | 665 | | 122 | 16 | 20 | -- |
| D4 | 90 | 14 | 20 | 665 | | 124 | 16 | 20 | -- |
| I1, I2 | 90 | 14 | 20 | 665 | | 295 | 16 | 20 | -- |
| D2 | 52 | 16 | 20 | 665 | | 151 | 16 | 20 | 80 |
| E1A, E3A | 90 | 16 | 24 | 695 | | 226 | 16 | 20 | -- |
| E1B, E3B | 90 | 16 | 24 | 695 | | 226 | 16 | 20 | -- |
| E2 | 52 | 16 | 24 | 695 | | 224 | 16 | 20 | 80 |
| E4 | 52 | 16 | 24 | 695 | | 224 | 16 | 20 | 80 |
| F1 | 90 | 16 | 24 | 695 | | 156 | 16 | 20 | -- |
| F2 | 90 | 16 | 24 | 695 | | 137 | 16 | 20 | -- |
| G1, G2 | 90 | 16 | 28 | 715 | | 165 | 20 | 20 | -- |
| A1 | 52 | 18 | 28 | 715 | | 168 | 16 | 20 | 80 |
| A2 | 52 | 18 | 28 | 715 | | 168 | 16 | 20 | 80 |
| B5 | 90 | 18 | 28 | 715 | | 149 | 16 | 20 | -- |
| J1 | 52 | 18 | 24 | 695 | | 327 | 16 | 20 | 80 |
| J2 | 90 | 18 | 24 | 695 | | 137 | 16 | 20 | -- |
| B1 | 52 | 20 | 28 | 715 | | 169 | 16 | 20 | 80 |
| B2 | 52 | 20 | 28 | 715 | | 168 | 16 | 20 | 80 |
| B3, B6 | 90 | 20 | 28 | 715 | | 170 | 16 | 20 | -- |
| B4 | 90 | 20 | 28 | 715 | | 156 | 16 | 20 | -- |
| H1 | 52 | 20 | 28 | 715 | | 209 | 16 | 20 | 80 |
| H2 | 52 | 20 | 28 | 715 | | 209 | 16 | 20 | 80 |

* TIE ROD NUT PRETORQUE - 100 FT. LBS (ALL CYLINDERS)

** PRETORQUE TO 50% OF TORQUE VALUES LISTED ABOVE

9.0 TEARDOWN FOR REPLACEMENT OF SEALS, OIL-RITE RESERVOIRS

PHD-5222-SK 63 & 64

- 9.1 This procedure covers reservoirs of 3 gal. capacity (PHD-5222-SK 63) and 5 and 10 gal. capacity (PHD-5222-SK 64) which are essentially identical except for size and mounting brackets.
- 9.2 During disassembly all fittings and components except seals shall be cleaned using a non-petroleum based solvent and blown dry using clean, oil free air. All seals shall be discarded. New seals and seal cavities shall be wet with clean, fresh C.E. silicone fluid # SF-1154 just prior to installation.
- 9.3 Drain reservoir into suitable container by removing pipe plug (7) from drain adapter (4).
- 9.4 Remove steel tubing from 1" NPT male connector (11) by backing off fitting nut (12). Free and secure steel tubing.
- 9.5 Remove 1" NPT male connector (11) .
- 9.6 Remove cover hold down screws (16) and remove cover (3) .
- 9.7 Secure drain adapter (4) on inside of reservoir and remove jam nut (6) . This frees 3 gal capacity reservoir from mounting bracket (2). Drain reservoir of any remaining fluid. Secure mounting bolt and jam nut and discard O'ring (5).
NOTE: The following steps will be accomplished with 3 gal. capacity reservoir removed from mounting bracket.
- 9.8 Secure filter adapter (14) unscrew filter body (20) and remove it and filter (18) from filter adapter (14). Remove jam nut (13). Discard O'ring (15).
- 9.9 Secure tube adapter (8) and remove jam nut (10) . This frees 5 and 10 gal. capacity reservoirs from mounting bracket (2) . Drain reservoir of any remaining fluid. Secure mounting bolt and jam nut and discard O'ring (9) .
- 9.10 Remove two sight glass mounting nuts (17) and remove sight glass assembly (19) .

- 9.11 Disassemble sight glass (ref. Detail PHD-5222-SK 63) as follows:
 - 9.11.1 Unscrew two mounting studs (39) from sight glass body (32). Remove O'rings (33) and discard.
 - 9.11.2 Remove sight glass cap (34). Remove O'ring (38) and discard.
 - 9.11.3 Remove securing screw (35).
 - 9.11.4 Gently pressing inward and upward on sight glass (36) remove it and tap O'ring (37) from sight glass body (32). Discard O'ring.
 - 9.11.5 Remove lower O'ring (37) and discard.
- 9.12 Clean all components and prepare for reassembly as indicated in 9.2.
- 9.13 Assembly of sight glass can be accomplished in reverse order of disassembly with the following noted:
 - 9.13.1 Assure that lower and upper sight glass O'rings (37) are properly seated.
 - 9.13.2 Mounting stud O'rings (33) should be carefully assembled over threads leaving approximately 1/4 inch of thread to be threaded into sight glass body.
- 9.14 Assembly of reservoir can be accomplished in reverse order of assembly making proper assembly to mounting brackets when required.

10.0 FLUID REQUIREMENTS PER SNUBBER

| <u>Snubber</u> | <u>Fluid Required (Gallons)</u> |
|----------------|---------------------------------|
| A1 | 10.38 |
| A2 | 10.38 |
| B1 | 8.45 |
| B2 | 9.53 |
| B3 | 8.37 |
| B4 | 8.65 |
| B5 | 8.08 |
| B6 | 8.37 |
| C1 | 15.04 |
| C2 | 15.02 |
| D1 | 7.21 |
| D2 | 11.73 |
| D3 | 7.21 |
| D4 | 9.19 |
| E1A | 17.78 |
| E1B | 17.78 |
| E2 | 17.87 |
| E3A | 17.78 |
| E3B | 17.78 |
| E4 | 17.87 |
| F1 | 10.71 |
| F2 | 10.23 |
| G1 | 12.42 |
| G2 | 12.42 |
| H1 | 16.80 |
| H2 | 16.80 |
| I1 | 22.90 |
| I2 | 22.90 |
| J1 | 12.74 |
| J2 | 9.92 |

11.0 SPARE PARTS

QTY./SNUBBER

| | |
|----|------------------------------|
| 1 | Cylinder Seal Kit Including: |
| 2 | Piston Seals |
| 1 | Rod Seal |
| 1 | Rod Wiper |
| 2 | Cylinder End Seals |
| 1 | Rod Bushing |
| 1 | Rod Seal Cage |
| 1 | Rod PressureRing |
| 1 | Rod Wave Spring |
| 1 | Piston Wear Ring |
| 16 | Retainer Screws |

THE ABOVE AS SHOWN ON MILLER DWG.# D5689H SHTS. 1 & 2


| | | |
|---|---|---------------|
| 1 | Spherical Bearing 4.5 I.D. | SKF GEZ-408ES |
| 1 | Spherical Bearing 5.0 I.D. | SKF GEZ-500ES |
| 1 | Spherical Bearing 6.0 I.D. | SKF GEZ-600ES |
| 1 | Valve Seal Kit Including: | |
| 4 | Thread Seals | -1/4 |
| 6 | O'ring (2/Valve; 1/Port plate) | -125 |
| 2 | O'ring (male connector) | -916 |
| 2 | O'ring (fill ports) | -908 |
| 2 | O'ring (plug valve) | -211 |
| 1 | O'ring (plug valve) | -113 |
| 3 | Reservoir Assembly Seal Kit (1) 3 Gal., (1) 5 Gal., (1) 10 Gal.) | |
| 6 | O'ring (Mtg. Studs) | -112 |
| 3 | O'ring (Cap) | -015 |
| 6 | O'ring (Sight Glass Gauge) | -109 |

11.0 SPARE PARTS (Cont'd)

| | | |
|---|-----------------------------------|------|
| 3 | O'ring (Outlet Adapter) | -132 |
| 6 | O'ring (Drain and Filter Adapter) | -120 |


10

Sight Glass Assemblies



NOTE: * USED ONLY ON SHORT STROKE CYL.

| | | | | | |
|-----------------------------|--|---------------------------------|-----------------|---|----------------|
| SCALE: N.E. 1/4 IN. = 1 IN. | | LIST OF PARTS | | 1ST General Corporation PVT HANGER DIVISION RESEARCH, DEVELOPMENT & ENGINEERING PROVIDENCE, R.I. | |
| MAT'L SPEC. | | SUPPLIES | | C | VILCH CYLINDER |
| FAB SPEC. | | TOLERANCE EXCEPT AS NOTED | DATE 1-27-70 | REV | 52 |
| WELD SPEC. | | FINISH EXCEPT AS NOTED | DRWN. R.W. | PHD-5222-SK-52 | |
| NOE PROCEDURE | | DEC | CHKD | | |
| FINISH EXCEPT AS NOTED | | AND | APP'D | | |
| G.A. REVIEW | | | | | |



SCALE: NONE. E.P.L.

MATERIAL SPEC.

FAB. SPEC.

WELD SPEC.

NODE PROCEDURE

FINISH EXCEPT AS NOTED

O.A. REVIEW

LIST OF PARTS

SUPPLEMENT

TOLERANCE

EXCEPT AS

NOTED

FAC

DLC

AND

ITT Goodell Corporation
PIPE HANGER DIVISION
RESEARCH DEVELOPMENT & ENGINEERING
PROVIDENCE, R.I.




C MILLER CYLINDER - 1A-12L 52

DATE 1-27-79

DRAWN BY JIA-57

PHD-5222-SK-53

REV



NOTE:


* MODEL 52 UNITS ONLY

** SHORT STROKE UNITS ONLY


PHID

B ROD BUSHING COMPONENTS

PHID-5222-SK-54





| | | |
|---|---|---|
| <p>11T Grinnell Corporation PIPE HANGER DIVISION RESEARCH, DEVELOPMENT & ENGINEERING PROVIDENCE, RI</p> | | <p>DATE B REV. 000001 P40-0000-0005</p> |
| <p>LIST OF PARTS F40-0222-SK-R2 SUPERSEDES</p> | <p>TOLERANCE EXCEPT AS NOTED</p> | <p>DATE</p> |
| <p>SCALE: NONE E.P.L.</p> | <p>MAT'L. SPEC. FAB. SPEC. WELD SPEC. NDE PROCEDURE FINISH, EXCEPT AS NOTED Q.A. REVIEW</p> | <p>DRAWN CHK'D APP'D.</p> |



| | | | | |
|---|--|----------------------------------|------|--------------------------|
| ITT Grinnell Corporation PIPE HANGER DIVISION RESEARCH, DEVELOPMENT & ENGINEERING PROVIDENCE, R.I. | | VALVE CONNECTION TYP. MOUNTED | | PHD-6222-SK95 |
| LIST OF PARTS PHD-6222-SK92 SUPERSEDES | | TOLERANCE EXCEPT AS NOTED | DATE | DRAWN CHK'D APP'D. |
| SCALE: NONE E.P.L. MAT'L. SPEC. FAB. SPEC. WELD SPEC. NDE PROCEDURE FINISH, EXCEPT AS NOTED | | Q.A. REVIEW | | |

| | | | | | |
|------|-------------|----|-------|------|------|
| REV. | DESCRIPTION | BY | APP'D | Q.A. | DATE |
|------|-------------|----|-------|------|------|




DETAIL A

| | | | | | | | |
|-------------------------|--|--------|--|---------------------------|--|---|--|
| SCALE: | | E.P.L. | | LIST OF PARTS | | ITT Grinnell Corporation PIPE HANGER DIVISION RESEARCH, DEVELOPMENT & ENGINEERING PROVIDENCE, R.I. | |
| MAT'L. SPEC. | | | | SUPERSEDES | | | |
| FAB. SPEC. | | | | TOLERANCE EXCEPT AS NOTED | | DATE 1-27-79 | |
| WELD SPEC. | | | | FRAC. DEC. ANG. | | DRAWN <u>KL</u> CHK'D. APP'D. | |
| NDE PROCEDURE | | | | TORQUING SEQUENCE | | A 20 TIE RODS | |
| FINISH, EXCEPT AS NOTED | | | | PHD-5222-SK-57 | | REV. | |
| Q.A. REVIEW | | | | | | | |


| REV. | DESCRIPTION | BY | APP'D | Q.A. | DATE |
|---|-------------|--|-------|---|------|
| | | | | | |
| SCALE: E.P.L. | | LIST OF PARTS SUPERSEDES | | ITT Grinnell Corporation PIPE HANGER DIVISION RESEARCH, DEVELOPMENT & ENGINEERING PROVIDENCE, R.I. | |
| MAT'L. SPEC. _____ FAB. SPEC. _____ WELD SPEC. _____ NDE PROCEDURE _____ FINISH, EXCEPT AS NOTED _____ Q.A. REVIEW _____ | | TOLERANCE EXCEPT AS NOTED DATE 1-27-79 DRAWN <i>RL</i> CHK'D _____ APP'D _____ | | A TORQUING SEQUENCE 24 TIE RODS PHD-5222-SK-58 | |
| | | | | REV. _____ | |

| REV. | DESCRIPTION | BY | APP'D. | Q.A. | DATE |
|---|-------------|--|--------|---|------|
| | | | | | |
| SCALE: E.P.L. | | LIST OF PARTS | | ITT Grinnell Corporation PIPE HANGER DIVISION RESEARCH, DEVELOPMENT & ENGINEERING PROVIDENCE, R.I. | |
| MAT'L. SPEC. _____ FAB. SPEC. _____ WELD SPEC. _____ NDE PROCEDURE _____ FINISH, EXCEPT AS NOTED _____ Q.A. REVIEW _____ | | SUPERSEDES TOLERANCE EXCEPT AS NOTED DATE 1-27-79 FRAC. _____ DEC. _____ ANG. _____ | | A TORQUING SEQUENCE 28 TIE RODS PHD-5222-SK-59 | |
| | | DRAWN <u>RL</u> CHK'D. _____ APP'D. _____ | | REV. _____ | |

| REV. | DESCRIPTION | BY | APP'D. | Q.A. | DATE |
|---|-------------|---|---|---|------|
| | | | | | |
| SCALE: E.P.L. | | LIST OF PARTS | | ITT Grinnell Corporation PIPE HANGER DIVISION RESEARCH, DEVELOPMENT & ENGINEERING PROVIDENCE, R.I. | |
| MAT'L. SPEC. _____ FAB. SPEC. _____ WELD SPEC. _____ NDE PROCEDURE _____ FINISH, EXCEPT AS NOTED _____ Q.A. REVIEW _____ | | SUPERSEDES | | | |
| | | TOLERANCE EXCEPT AS NOTED | DATE 1-27-79 | A TORQUING SEQUENCE CIRCULAR RETAINER-16 SCREWS | |
| | | FRAC. _____ DEC. _____ ANG. _____ | DRAWN <i>RL</i> CHK'D. _____ APP'D. _____ | | |
| | | PHD-5222-SK-60 | | REV. _____ | |

| REV. | DESCRIPTION | BY | APP'D. | Q.A. | DATE |
|---|-------------|---|---|---|------|
|  | | | | | |
| SCALE: <u>E.P.L.</u> | | LIST OF PARTS | | ITT Grinnell Corporation PIPE HANGER DIVISION RESEARCH, DEVELOPMENT & ENGINEERING PROVIDENCE, R.I. | |
| MAT'L. SPEC. _____ FAB. SPEC. _____ WELD SPEC. _____ NDE PROCEDURE _____ FINISH, EXCEPT AS NOTED _____ Q.A. REVIEW _____ | | SUPERSEDES | | | |
| | | TOLERANCE EXCEPT AS NOTED | DATE 1-27-79 | A TORQUING SEQUENCE CIRCULAR RETAINER-20 SCREWS | |
| | | FRAC. _____ DEC. _____ ANG. _____ | DRAWN <u>RL</u> CHK'D. _____ APP'D. _____ | | |
| | | | | PHD-5222-SK-61 | |

| REV. | DESCRIPTION | BY | APP'D | Q.A. | DATE |
|--|-------------|----|--|------|-------------------|
| | | | | | |
| <p>EXTERNAL BEARING HOLE SEQUENCE</p> | | | | | |
| <p>SCALE: E.P.L.</p> | | | <p>LIST OF PARTS</p> | | |
| <p>MAT'L. SPEC. _____</p> <p>FAB. SPEC. _____</p> <p>WELD SPEC. _____</p> <p>NDE PROCEDURE _____</p> <p>FINISH, EXCEPT AS NOTED _____</p> <p>Q.A. REVIEW _____</p> | | | <p>SUPERSEDES</p> | | |
| <p>TOLERANCE EXCEPT AS NOTED</p> | | | <p>DATE 1-27-79</p> | | |
| <p>FRAC. _____</p> <p>DEC. _____</p> <p>ANG. _____</p> | | | <p>DRAWN <u>RL</u></p> <p>CHK'D. _____</p> <p>APP'D. _____</p> | | |
| <p>ITT Grinnell Corporation PIPE HANGER DIVISION RESEARCH, DEVELOPMENT & ENGINEERING PROVIDENCE, R.I.</p> | | | <p>A TORQUING SEQUENCE EXTERNAL BEARING</p> | | |
| <p>PHD-5222-SK-62</p> | | | | | <p>REV. _____</p> |





DETAIL-A
SIGHT GLASS
ASSEMBLY

PARTS LIST: PHD-5222-SK85

| | | | | | |
|-------------------------------|---------------------------------|-------------|---|--|-----------|
| SCALE: E.P.L. | LIST OF PARTS | | ITT Grinnell Corporation PIPE HANGER DIVISION RESEARCH, DEVELOPMENT & ENGINEERING PROVIDENCE, R.I. | | |
| MAT'L. SPEC. _____ | SUPERSEDES | | A OIL-RITE RESERVOIR 3 GAL. CAPACITY | | |
| FAB. SPEC. _____ | | | | | |
| WELD SPEC. _____ | TOLERANCE EXCEPT AS NOTED | DATE | PHD-5222-SK-63 | | |
| NDE PROCEDURE _____ | FRAC. _____ | DRAWN _____ | | | REV. A |
| FINISH, EXCEPT AS NOTED _____ | DEC. _____ | CHK'D _____ | | | |
| Q.A. REVIEW _____ | ANG. _____ | APP'D _____ | | | |

| REV. | DESCRIPTION | BY | APP'D. | DATE |
|------|-------------|----|--------|------|
|------|-------------|----|--------|------|



PARTS LIST; PHD-5222-SK85

| | | | | |
|-------------------------------|---------------------------------|-------------|---|-----------|
| SCALE: E.P.L. | LIST OF PARTS | | ITT Grinnell Corporation PIPE HANGER DIVISION RESEARCH, DEVELOPMENT & ENGINEERING PROVIDENCE, R.I. | |
| MAT'L. SPEC. _____ | SUPERSEDES | | A OIL-RITE RESERVOIR 5 & 10 GAL. CAPACITY | |
| FAB. SPEC. _____ | TOLERANCE EXCEPT AS NOTED | DATE | | |
| WELD SPEC. _____ | FRAC. _____ | DRAWN _____ | PHD-5222-SK-64 | |
| NDE PROCEDURE _____ | DEC. _____ | CHK'D _____ | | |
| FINISH, EXCEPT AS NOTED _____ | ANG. _____ | APP'D _____ | | |
| Q.A. REVIEW _____ | | | | REV. A |

LIST OF PARTS

| ITEM NO. | PART NAME |
|----------|-------------------------------|
| 1 | Reservoir |
| 2 | Mtg. Bracket |
| 3 | Cover |
| 4 | Drain Adapter |
| 5 | "0" Ring 1" I.D. x .103 W |
| 6 | 1" - 14 Jam Nut |
| 7 | Drain Plug |
| 8 | Outlet Adapter |
| 9 | "0" Ring 1 3/4" I.D. x .103 W |
| 10 | 1 3/4" - 12 Jam Nut |
| 11 | 1" x 1 NPT Male Connector |
| 12 | Fitting Nut |
| 13 | 1" - 14 Jam Nut |
| 14 | Filter Adapter |
| 15 | "0" Ring 1" I.D. x .103 W |
| 16 | #6 x 1/4 Fan Hld. Screw |
| 17 | Mounting Nuts |
| 18 | Filter #100 Mesh 1" O.D. x 1" |
| 19 | Site Glass Ass'y |

[illegible]

| | | | | | |
|-------------------------------|--------------|---------------------------------|--------------|---|---------------------------------------|
| SCALE: _____ | E.P.L. _____ | LIST OF PARTS | | ITT Grinnell Corporation PIPE HANGER DIVISION RESEARCH, DEVELOPMENT & ENGINEERING PROVIDENCE, R.I. | |
| MAT'L. SPEC. _____ | | SUPERSEDES | | A | PARTS LIST 3-5 -10 GAL. RESERVOIRS |
| FAB. SPEC. _____ | | TOLERANCE EXCEPT AS NOTED | DATE | | |
| WELD SPEC. _____ | | FRAC. _____ | DRAWN _____ | PI-ID-5222-SK 85 | |
| NDE PROCEDURE _____ | | DEC. _____ | CHK'D. _____ | | |
| FINISH, EXCEPT AS NOTED _____ | | ANG. _____ | APP'D. _____ | | |
| Q.A. REVIEW _____ | | | | REV. _____ | |

| LIST OF PARTS | | | PART NAME |
|---------------|-------------|--|--|
| 1 | NO-5222-21 | | BUT WITHOUT RELIEF VALVE |
| 2 | NO-5222-26 | | ORIFICE STEEL VALVE |
| 3 | C2-3-2 | | 1/4-28 NF HEX JAM NUT |
| 4 | C1-4-1 | | 1/4-SAE STEEL WASHER |
| 5 | | | THREAD-SEAL "64502-1-1/4" |
| 6 | PHD-5222-25 | | ADJUSTMENT SCREW 1/2-28-NFX 1 3/8 LG. |
| 7 | C2-3-2 | | 1/4-28 NF HEX JAM NUT |
| 8 | C1-4-1 | | 1/4-SAE STEEL WASHER |
| 9 | | | THREAD-SEAL "649027-1/4" |
| 10 | | | O-RING DASH 125 |
| 11 | C2-2-6 | | RET PLATE SCREWS 10-32 X 1/2 LG. SOC. HD. CAP SCR. |
| 12 | PHD-5222-27 | | RET. INER PLATE |
| 13 | | | O-RING DASH 125 |
| 14 | PHD-5222-23 | | VALVE SEAT DISC |
| 15 | PHD-5222-22 | | VALVE POPPET |
| 16 | | | SPRING-LEE |
| 17 | PHD-5222-4 | | SPRING PLUNGER |
| 18 | | | MOUNTING BOLTS 3/8-16 X 4 3/8 LG. |
| 19 | | | O-RING DASH 916 |
| 20 | | | MALE CONNECTOR 1" (SWAGelok) |
| 21 | | | FITTING NUT (MALE CONNECTOR) |
| 22 | | | CONNECTING TUBING (1.00 O.D. X .065 WALL) |
| 23 | | | FITTING NUT (UNION TEE) |
| 24 | | | UNION TEE 1" (SWAGelok) |
| 25 | | | ELBOW 1" (SWAGelok) |
| 26 | | | FITTING NUT (ELBOW) |
| 27 | | | PLUG 1" (SWAGelok) |
| 28 | | | VALVE FILTER SCREEN |
| 29 | | | RETAINER RING (TRU-AR) |
| 30 | | | REDUCER 1/2" X 1" (SWAGelok) |

| | | |
|----|--|--------------------------------------|
| 31 | | REDUCER FITTING NUT |
| 32 | | TUBE ADAPTER 1/2" O.D. X 1/2" I.D. |
| 33 | | PLUG VALVE 1/2" O.D. X 1/2" I.D. |
| 34 | | PLUG VALVE BODY |
| 35 | | PLUG VALVE BARREL |
| 36 | | RETAINING RING |
| 37 | | O-RING -211 |
| 38 | | O-RING -115 |
| 39 | | MALE CONNECTOR 1/2" O.D. X 1/2" I.D. |
| 40 | | PLUG 1/2" SWAGelok |

REF.: FOR VALVE CONNECTION SEE DRAWING NO. BPHD-5222-SK-55 or 56

| | | | | | |
|---------------|--|---------------------------------|--|---|------------------------------------|
| SCALE: E.P.L. | | LIST OF PARTS | | ITT Grinnell Corporation PIPE HANGER DIVISION RESEARCH, DEVELOPMENT & ENGINEERING PROVIDENCE, RI | |
| MAT'L SPEC. | | SUPERSEDES | | DATE 4-11-79 | B VALVE CONNECTOR LIST OF PARTS |
| FAB. SPEC. | | TOLERANCE EXCEPT AS NOTED | | | |
| WELD SPEC. | | PHAC. DEC. | | DRAWN BY CHK'D | REV |
| NDE PROCEDURE | | FINISH, EXCEPT AS NOTED | | FHD-5222-SK-70 | |
| Q.A. REVIEW | | APP'D | | | |

| LIST OF PARTS | | | |
|---------------|--|--|-----------------------|
| ITEM NO. | | | PART NAME |
| 1 | | | PISTON-PISTON ROD |
| 2 | | | PISTON SEAL |
| 3 | | | CYLINDER HEAD |
| 4 | | | CYLINDER CAP |
| 5 | | | CYLINDER TUBE |
| 6 | | | ROD SEAL |
| 7 | | | RETAINER PLATE |
| 8 | | | ROD BUSHING |
| 9 | | | TIE ROD NUTS |
| 10 | | | BACK UP RING |
| 11 | | | TIE RODS |
| 12 | | | ROD PRESSURE RING |
| 13 | | | ROD SEAL CAGE |
| 14 | | | CYLINDER END SEALS |
| 15 | | | ROD WIPER |
| 16 | | | ROD WAVE SPRING |
| 17 | | | PISTON ANTI-ROLL RING |
| 18 | | | PISTON RETAINING RING |
| 19 | | | PISTON WEAR RING |
| 20 | | | SPHERICAL BEARING |
| 21 | | | RETAINER SCREWS |
| 22 | | | RETAINING RING |
| 23 | | | FILL PORT PLUG |
| 24 | | | O-RINGS |
| 25 | | | WIPER RETAINER PLATE |
| 26 | | | PUSH NUT |
| 27 | | | 5/16" FLAT WASHER |
| 28 | | | 1/2" FLAT WASHER |

| REV | DESCRIPTION | DCN | BY | APP'D | Q.A. | DATE |
|-----|-------------|-----|----|-------|------|------|
|-----|-------------|-----|----|-------|------|------|

NOTE:
* — USED ON SHORT STROKE CYL. ONLY

| | | | | | |
|-------------------------------|--|---------------------------|--|---|--|
| SCALE: E.P.L. | | LIST OF PARTS | | ITT Grinnell Corporation PIPE HANGER DIVISION RESEARCH, DEVELOPMENT & ENGINEERING PROVIDENCE, R.I. | |
| MAT'L SPEC. _____ | | SUPERSEDES | | B MILLER CYLINDER MODEL 90 LIST OF PARTS | |
| FAB. SPEC. _____ | | TOLERANCE EXCEPT AS NOTED | | | |
| WELD SPEC. _____ | | DATE 4-12-79 | | PHD-5222-SK-71 | |
| NDE PROCEDURE _____ | | DRAWN ADL | | | |
| FINISH, EXCEPT AS NOTED _____ | | DEC. _____ | | | |
| Q.A. REVIEW _____ | | ANG _____ | | REV _____ | |

| LIST OF PARTS | | | |
|---------------|--|--|-----------------------|
| ITEM NO | | | PART NAME |
| 1 | | | PISTON-PISTON ROD |
| 2 | | | PISTON SEAL |
| 3 | | | CYLINDER HEAD |
| 4 | | | CYLINDER CAP |
| 5 | | | CYLINDER TUBE |
| 6 | | | ROD SEAL |
| 7 | | | RETAINING PLATE |
| 8 | | | ROD BUSHING |
| 9 | | | TIE ROD NUTS |
| 10 | | | BACK-UP RING |
| 11 | | | TIE RODS |
| 12 | | | ROD PRESSURE RING |
| 13 | | | ROD SEAL CAGE |
| 14 | | | CYLINDER END SEALS |
| 15 | | | ROD WIPER |
| 16 | | | ROD WAVE SPRING |
| 17 | | | ANTI-ROLL RING |
| 18 | | | PISTON RETAINING RING |
| 19 | | | PISTON WEAR RING |
| 21 | | | RETAINER SCREWS |
| 22 | | | RETAINING RING |
| 23 | | | FILL PORT PLUG |
| 24 | | | O RINGS |
| 25 | | | EXTERNAL BEARING |
| 26 | | | RETAINER SCREWS |
| 27 | | | EXTERNAL BEARING SEAL |
| 28 | | | WAFER RETAINER PLATE |
| 29 | | | PUSH NUT |

| | | |
|----|--|-------------------|
| 32 | | 5/16" FLAT WASHER |
| 33 | | 1/2" FLAT WASHER |

NOTE:
A - USED ON SHORT STROKE CYL. ONLY

| | | | | | |
|-------------------------------|--|---------------------------|--|---|--|
| SCALE: E.P.L. | | LIST OF PARTS | | ITT Grinnell Corporation PIPE HANGER DIVISION RESEARCH, DEVELOPMENT & ENGINEERING PROVIDENCE, R.I. | |
| MAT'L. SPEC. _____ | | SUPERSEDES | | B MILLER CYLINDER MOUNTING LIST OF PARTS PHD-5222-SK-72 | |
| FAB. SPEC. _____ | | TOLERANCE EXCEPT AS NOTED | | | |
| WELD SPEC. _____ | | DATE 4-12-79 | | | |
| NDE PROCEDURE _____ | | DRAWN BY _____ | | | |
| FINISH, EXCEPT AS NOTED _____ | | DEC. _____ | | CHK'D _____ | |
| Q.A. REVIEW _____ | | ANG. _____ | | APP'D _____ | |

| LIST OF PARTS | | | | PART NAME |
|---------------|--|--|--|-----------------------|
| 1 | | | | PISTON-PISTON ROD |
| 2 | | | | PISTON SEAL |
| 3 | | | | CYL. HEAD |
| 4 | | | | CYL. CAP |
| 5 | | | | CYL. TUBE |
| 6 | | | | ROD SEAL |
| 7 | | | | RETAINING PLATE |
| 8 | | | | ROD BUSHING |
| 9 | | | | TIE ROD NUTS |
| 10 | | | | BACK-UP RING |
| 11 | | | | TIE ROD |
| 12 | | | | ROD PRESSURE RING |
| 13 | | | | ROD SEAL CAGE |
| 14 | | | | CYL. END SEAL |
| 15 | | | | ROD WIPER |
| 16 | | | | ROD WAVE SPRING |
| 17 | | | | ANTI-ROLL RING |
| 18 | | | | PISTON RETAINING RING |
| 19 | | | | PISTON WEAR RING |
| 20 | | | | SPHERICAL BEARING |
| 21 | | | | RETAINING SCREWS |
| 22 | | | | RETAINING RING |
| 23 | | | | FILL PORT PLUG |
| 24 | | | | GY RINGS |
| 25 | | | | EXTERNAL BEARING |
| 26 | | | | RETAINER SCREWS |
| 27 | | | | EXTERNAL BEARING SEAL |
| 28 | | | | EXTENSION PIECE |
| 29 | | | | PIVOT LUG |
| 30 | | | | WIPER RETAINER PLATE |
| 31 | | | | ROD NUT |

| REV. | DESCRIPTION | DCN | BY | APP'D | Q.A. | DATE |
|------|-------------|-----|----|-------|------|-------------------|
| 32 | | | | | | 5/16" FLAT WASHER |
| 33 | | | | | | 1/2" FLAT WASHER |

| | | | | | |
|-------------------------------|--|---------------------------|--|---|--|
| SCALE: E.P.L. | | LIST OF PARTS | | ITT Grinnell Corporation PIPE HANGER DIVISION RESEARCH, DEVELOPMENT & ENGINEERING PROVIDENCE, R.I. | |
| MAT'L. SPEC. _____ | | SUPERSEDES | | B IMPROVED PIPE HANGER DIVISION STEEL PIPE ASSY. LIST OF PARTS HIL-50-2-SK-77 | |
| FAB. SPEC. _____ | | TOLERANCE EXCEPT AS NOTED | | | |
| WELD SPEC. _____ | | DATE 4-12-79 | | | |
| NDE PROCEDURE _____ | | DRAWN: JAM | | | |
| FINISH, EXCEPT AS NOTED _____ | | CHK'D: _____ | | | |
| Q.A. REVIEW _____ | | ANG _____ | | REV. _____ | |

W. H. SALISBURY & CO.

Linemen's Rubber Protective Devices



401 NORTH MORGAN STREET
CHICAGO, ILLINOIS 60622
AREA CODE 312 / 421-4850
Dec. 8, 1982

Mr. Dave Rosenberg
NuTech Engineering
7910 Woodmont Ave
Bethesda, Maryland

Dear Mr. Rosenberg:

The following is the information
you wanted concerning compound #80154

Original Properties

Tensile (psi) 2770
Elongation (%) 270
Shore A Hardness 85

After Heat Aged 70 hrs @ 212°F

Tensile (psi) 2775
Elongation (%) 185
Shore A Hardness 87

Since #80154 contains Norad 51DM,
I enclosed some interesting information about
Norad's protective properties. I copied from the Norad
bulletin.

Temperature Range

EPDM insulations maintain their elastomeric character over a broad temperature range. Typical compositions remain flexible at temperatures down to -70°F . and have brittleness temperatures as low as -100°F . At the other end of the scale, EPDM compositions provide excellent resistance to mechanical stresses and deformation at elevated temperatures. Tests run on a typical medium voltage insulation compound (Table IV) show that modulus is essentially unaffected at temperatures up to 300°F ., reflecting the resistance of EPDM compositions to thermal softening. Tensile strength and elongation are reduced as temperature is increased from 75 to 300°F ., but are superior to the values obtained with other types of insulation, particularly at 300°F .

TABLE IV

TENSILE PROPERTIES AT ELEVATED TEMPERATURES

| <u>Physical Properties</u> | <u>Test Temperature, $^{\circ}\text{F}$.</u> | | |
|----------------------------|---|---------------------------------|---------------------------------|
| | <u>75$^{\circ}$</u> | <u>158$^{\circ}$</u> | <u>300$^{\circ}$</u> |
| 100% Modulus, psi | 250 | 200 | 210 |
| Tensile Strength, psi | 1000 | 680 | 400 |
| Elongation at Break, % | 310 | 250 | 170 |

Flexibility and Handling

EPDM insulation is inherently very flexible. The extent to which this carries over to the finished cable is, of course, influenced by construction features. Where the insulation wall is heavy relative to conductor size, frequently the case in medium voltage cable, EPDM insulation contributes greatly to cable flexibility. This is of particular importance when splicing and terminating in restricted quarters, such as in manholes.

Ozone Resistance

EPDM compositions are, for all practical purposes, completely impervious to ozone. Ozone resistance is inherent in ethylene-propylene rubbers so that protective waxes, antiozonants, or special compounding are not required to achieve this property. Typical insulations based on EPDM show no sign of cracking when exposed to an ozone concentration of 0.03 percent by volume for 100 hours, using the procedure specified in ASTM D-470.

Radiation Resistance

The increasing number of nuclear generating facilities in recent years has focused attention on the need for elastomeric components with excellent radiation resistance. Ethylene propylene rubbers

are particularly resistant to the deteriorating effects of high energy radiation. Results of a series of tests conducted in our laboratories are summarized in Table V. Vulcanized slabs, 75 mils thick, were subjected to several dosage levels of beta radiation using a General Electric Resonant Transformer. Stress-strain properties measured in accordance with ASTM D-412 show that the EPDM insulation under test retained approximately 90% of its original tensile strength and over 40% of its original elongation after exposure to 5.5×10^7 rads of beta radiation. While elongation showed a further decrease as exposure time was lengthened, the EPDM insulation still remained quite flexible even after a total dosage of 10^8 rads.

TABLE V

INSULATION OF NORDEL®
RESISTANCE TO RADIATION

| <u>Exposure</u> | <u>Retention of Original Properties, %</u> | |
|--|--|-------------------|
| | <u>Tensile</u> | <u>Elongation</u> |
| 5.5×10^7 rads | 91 | 42 |
| 1.1×10^8 rads | 99 | 24 |
| 5.5×10^7 rads plus 7 days aging in 150°C. oven plus 7 days in 60 psi steam | 87 | 47 |

Original Tensile Strength, 1030 psi
Original Elongation, 550%

Radiation Conditions:

Vulcanized slabs were placed 30 cm. from radiation source;
beam current - 0.5 milliamps, acceleration potential - 2
megavolts, dosage rate - 8.5×10^4 rads/sec.

Blodgett and Fisher, in their paper on the effects of gamma radiation on cable coverings, point out that the total radiation dosage absorbed by a cable within the containment area of a thermal nuclear reactor might approach 5×10^7 rads, assuming a generator life of 40 years⁽¹⁾. The retention of tensile properties after exposure to gamma radiation reported by Blodgett and Fisher is reasonably close to that reported here using beta radiation.

Compositions based on EPDM would also be expected to survive abnormal bursts of energy from a thermal nuclear reactor conceivably involving exposure to a combination of radiation, steam and dry heat. In a laboratory test, an EPDM medium voltage insulation compound retained more than 80% of its original tensile strength more than 40% of its original elongation after exposure to a dose of 5.5×10^7 rads of beta radiation, 7 days oven aging at 150°C., and 7 days in 60 psi steam.

Electrically Stable Insulations For Low Voltage Applications

Where dielectric loss is not a prime consideration, such as is the case for low voltage insulation, lower cost EPDM insulations are feasible. This is accomplished primarily by greater extension with oil and filler, and the use of untreated clay in combination with a silane coupling agent. Such insulations possess electrical properties adequate for use in both wet and dry locations at voltages up to at least 5 KV.



The peroxide curing system offers several advantages. Among these are low dielectric loss, electrical stability in water, retention of physical properties after aging at temperatures as high as 300°F., and resistance to deformation during the jacketing operation.

EPDM insulations containing high levels of oil and filler can be peroxide cured without difficulty. In addition, such insulations not only possess excellent original properties, but also show little change on aging. These characteristics are attributable to the inherent properties of EPDM and to the permanence of the low-volatility paraffinic oils.

The physical and electrical properties of two typical, extended insulation compounds are shown in Tables VI and VII. Both possess good original physical and electrical properties, good resistance to heat degradation, and excellent stability in 75°C. water.

Of particular interest is the favorable comparison of physical and electrical properties for Compound B vs. Compound A, even though Compound B is much more highly extended with filler and oil. Compound B, with a pound-volume cost of \$.183 is 11% lower in cost than Compound A, and 30% lower than the compound shown in Table I.

THE EFFECTS OF RADIATION, HEAT, AND STEAM ON NORDEL[®] EPDM



KEY

A = ORIGINAL

B = AFTER 5.5×10^7 RADS

C = AFTER 5.5×10^7 RADS + 7 DAYS AGING @ 150°C.

D = AFTER 5.5×10^7 RADS + 7 DAYS AGING @ 150°C + 7 DAYS IN 60 PSI STEAM

silicones technical information

CDS-4175

Silicone Fluids in Radiation Environments

Silicone fluids have been used for a number of years in environments subject to radiation of various types. They have been used as an hydraulic fluid in nuclear power stations and on nuclear powered ships. They have operated in Van Allen Belt environments and in laboratory and diagnostic apparatus.

Four fluids have seen extensive service.

SF 96 series

Available in many viscosities these fluids are polydimethylsiloxanes.

They have the best viscosity/temperature properties of any known fluid and will operate from -65°F to $+400^{\circ}\text{F}$.

The radiation resistance will depend on the viscosity selected.

| Fluid | M_p to Gellation |
|-----------|--------------------|
| SF96-50 | 40 |
| SF96-100 | 20 |
| SF96-500 | 10 |
| SF96-1000 | 7 |

SF 1154

SF 1154 is the most common material used in these applications. SF 1154 fluid is a copolymer containing both methyl and phenyl units. It has excellent high temperature stability and can be used from -56 to $+540^{\circ}\text{F}$. It has excellent radiation resistance and is capable of absorbing up to 5×10^8 rads before gellation.

SF 1147

This moderately low viscosity ($=50$ cs/77F) silicone fluid is the best lubricant of the silicone family and very possibly the best lubricant known for bimetallic contact. It has high radiation stability gelling at 5×10^8 rads.

Versilube® F 50

This silicone fluid is a high temperature lubricant capable of operating at temperature extremes (-140°F to $+500^{\circ}\text{F}$) and has been used well in radiation environments encountered in space flight. Compared to the above fluids, it has a low radiation tolerance. It contains molecularly bound chlorine which starts to generate acid at 1×10^6 rads. This increases with increased dosage. Gellation occurs at 2 to 5×10^8 rads.

The effect of radiation on silicones is a cross linking mechanism which gradually increases the viscosity of the fluid eventually resulting in gellation.

Theoretical treatment of these effects will be found in:

A.A. Miller, J. Am. Chem. Soc. 82, 3519 (1950)

A.A. Miller, J. E.C. Product Research and Development 3, 3, 1964, pp. 252-255.



Physical Properties of Non Irradiated Fluids

| | SF 96-100 | SF 1154 | SF 1147 | F 50 |
|--|-----------------|----------------------|----------------------|-----------------|
| Viscosity @ -65°F | 600 | | | 2500 |
| " " -40°F | 300 | | | |
| " " 0°F | 100 | 2500 | 4500 | |
| " " 77°F | 75 | 175 | 350 | 70 |
| " " 100°F | 75 | 110 | 31 | 52 |
| " " 210°F | 30 | 23 | 7.5 | 16 |
| " " 350°F | | 7.5 | | |
| " " 400°F | 12 | 5.7 | | |
| " " 450°F | | | 1.8 | 4.5 |
| Pour Point | -67 | -40 | -65 | -140 |
| Flash Point COC | >575 | >550 | >500 | >550 |
| Fire Point | >675 | >650 | >600 | >640 |
| Fue Point | >675 | >650 | >600 | >640 |
| Specific Gravity | 0.966 | 1.05 | 0.89 | 1.045 |
| Refractive Index | 1.4030 | 1.4580 | | 1.4280 |
| Specific Heat | 0.36 | 0.39 | .64 | 0.34 |
| Thermal Expansion | 0.00025 | 7.5×10^{-4} | 7.2×10^{-4} | |
| Bulk Modulus | $>110,000$ | $>165,000$ | $>210,000$ | $>110,000$ |
| Weight Loss 24 hrs 150°C % | <0.5 | $<.5$ | $<.5$ | <0.4 |
| Max. radiation dosage with minimum change | 1×10^7 | 1×10^8 | 1×10^8 | 1×10^8 |

Effect of Radiation

Whereas the major effect of radiation on silicones is that of cross linking to increase viscosity, some of them, notably Versilube F 50 will also release small quantities of HCl.

The two accompanying curves show the effect of radiation on viscosity for all four fluids and the effect on acidity of Versilube F 50 and SF 1154.



As General Electric Company has no control over the use to which others may put the material, it does not claim or warrant that in your particular circumstances the results you will obtain from the use of the product will be the same as those described in this communication, or that you will find the information or recommendations complete, accurate, or useful. The Company accepts no liability in negligence or otherwise for any damage resulting from your reliance on the information or recommendations in this communication. You should test the material to determine if the material is suitable and/or our claims valid in your particular circumstances. None of the possible or suggested uses of the materials in this communication are a license under any General Electric patent covering such use or a recommendation for use of such materials in the infringement of any patent.

GENERAL ELECTRIC COMPANY
SILICONE PRODUCTS DIVISION
RUBBER AND FLUID PRODUCTS DEPARTMENT
WATERFORD, NEW YORK 12188
PHONE (518) 237-3330

GENERAL  ELECTRIC

FINAL REPORT
CONSUMERS POWER COMPANY
CONTRACT FOR CONSULTING SERVICES
FOR THE
REACTOR COOLANT PUMP SNUBBER SEAL STUDY
FOR THE
MIDLAND PLANT
CONSUMERS POWER P.O. CP10-1101
ITT GRINNELL PROJECT NO. SPS-8014

REPORT NO. SPS-ZPR-8014-5

PREPARED BY:

Glenda M. Mowhead DATE: Dec. 24/81

PREPARED BY:

Jaking P. Belaud DATE: 12-24-1981

APPROVED BY:

David P. Francis DATE: 12/24/81

APPROVED BY:

R.B. McLaughlin DATE: 12/24/81

TABLE OF CONTENTS

PAGE

| | |
|---|----|
| Abstract | 1 |
| Summary | ii |
| Conclusions | iv |
| Section I Establishing seal life state-of-the-art baseline. | 1 |
| 1.1 Screening and gathering of technical data. | 1 |
| 1.2 Evaluation of EPDM compounds. | 1 |
| 1.2.1 Overview. | |
| 1.2.2 Parker Compounds. | 3 |
| 1.2.3 Minnesota Rubber Compound. | 3 |
| 1.2.4 Federal Mogul Compound. | 3 |
| 1.2.5 Acushnet and W.H. Salisbury Compounds. | 4 |
| 1.2.6 ITT Grinnell Qualification Tests. | 4 |
| 1.3 Evaluation of "Other" Materials. | 4 |
| 1.3.1 Viton (Dupont Fluoroelastomer). | 4 |
| 1.3.2 Kalrez (Dupont Perfluoroelastomer). | 5 |
| 1.3.3 Hycar Nitrile Elastomer. | 7 |
| 1.3.4 Vespel. | 8 |
| 1.3.5 Envex 1115 | 9 |
| 1.3.6 Kel-F. | 9 |
| 1.3.7 Metallic Seals. | 10 |
| 1.4 Summary of Consulting Screening. | 11 |
| Section II Snubber Seal Failure Criteria. | 15 |
| 2.1 Outline of Purpose. | 15 |
| 2.2 Baseline Dimensional Review Design Analysis. | 15 |

| | | |
|-------------|--|----|
| 2.2.1 | Federal Mogul | 16 |
| 2.2.2 | Acushnet | 17 |
| 2.2.3 | Minnesota Rubber | 18 |
| 2.2.4 | W.H. Salisbury | 19 |
| 2.3 | F.T.A. | 19 |
| Section III | Seal Life Projections and Verification | 21 |
| 3.1 | Estimation of Life. | 21 |
| 3.2 | Testing | 22 |
| 3.2.1 | Purpose | 22 |
| 3.2.2 | Method of Testing | 23 |
| 3.2.3 | Evaluation Criteria | 23 |
| | | 25 |

Appendix 1

Appendix 2

Appendix 3

Appendix 4

Bibliography

ABSTRACT

This report covers all work accomplished by ITT Grinnell Corporation for Consumers Power Company under P.O. CP 10-1101, "Reactor Coolant Pump Snubber Seal Study for the Midland Plant". Results of evaluations based on seal material state-of-the-art, application considerations, failure modes and discussions with consultants knowledgeable in areas of concern are presented. Seal life modeling methodology is considered and an environmental test program to quantitatively define seal life based on overall results of this study is proposed.

SUMMARY

This study was conducted to evaluate the feasibility of extending the life of snubber seals exposed to a defined typical nuclear power plant environment. The primary goal of this study was to generate information in a quantity and level of refinement to provide a technically sound basis for defining, evaluating and finally choosing a means of extending seal life. It was proposed that the actual qualification of seal life extension would be accomplished by a Phase II follow up study and test program.

Initial effort consisted of gathering data and technical reports on seal material in the following categories:

- a. EP (ethylene propylene) compounds utilized in present Midland reactor coolant pump snubbers.
- b. "Other" elastomeric compounds.
- c. Plastic/resin compounds
- d. Metallics

An in-depth evaluation of extensive material gathered in each of these categories was conducted.

Further efforts were carried out in the following areas:

- a. Snubber seal design considerations and failure modes.
- b. Seal life modeling methodology.
- c. Testing considerations and requirements.

In carrying out these efforts, it was noted that very little has been done in industry as a whole with respect to dosage rate effects or combined effects of radiation, air, fluid and temperature. To confirm and possibly expand on our consideration of these effects and our overall effort, several prominent persons in the field of elastomeric studies were consulted. These included.

- a. Robert Barbarin, Technical Director R & D, Parker Seal Co.
- b. Daniel Hertz, President, Seals Eastern.
- c. Jerry Sieron, Technical Manager for Elastomers, WPAFB.
- d. Lloyd Bonzon, Project Engineer, Sandia Laboratory.

In general, all concurred with our findings and were in agreement with our considerations for testing and final evaluation. Many helpful suggestions were obtained. A summary of discussions with the above is included in Appendix 3 of this report.

CONCLUSION

Based on the overall considerations of environment, design, testing and cost, EPDM material exhibits the highest probability of success.

Due to the fact that many different EPDM compounds exist with a variety of combinations of fillers, extensive testing has to be performed in order to determine the best possible compound. The means by which this is to be accomplished includes, but is not limited to, stress relaxation tests and "bread-board" tests (tensile strength, elongation, durometer, etc.). Because of the nature of these tests and the compounds themselves, the actual testing has to be a minimum of six (6) months. These methods will yield significant results and will enable ITT Grinnell to quantitatively define seal life.

I. Establishing Seal Life State-of-the-Art Baseline

1.1 Screening and Gathering of Technical Data (Materials Survey)

Utilizing the resources of ITT Grinnell RD & E, the New England Research Application Center (NERAC) and a number of seal manufacturers, extensive data and publications have been acquired. Resulting from this, an updated file was compiled outlining new manufacturing practices, new materials and test results with respect to various extreme conditions (corrosive fluid, elevated temperature, radiation, and steam). From several in-house sources, a series of articles was obtained detailing failures of snubbers due to fluid leakage at various power plants along with the causes of these failures. It was noted that misinstallation is potentially the highest cause of seal failure in a snubber system. Seal degradation was not attributed as having an influence in any of the cases involving EPDM compounds. Data received was categorized and evaluated under the heading of EPDM, "other" elastomers, plastics/resinous compounds and metallic material.

1.2 Evaluation of EPDM Compounds

1.2.1 Overview

In general, EPDM exhibits superior qualities for our environmental parameters. Physical properties will depend on variations

in the compounding and the addition of reinforcing materials such as carbon black and silica amine or phenolic antioxidants, processing aids such as stearic acid or plasticizers, and curing agents like peroxide sulfur or sulfur donating accelerators.

EPDM General Characteristics

Durometer Range: 30A-90A

Tensile psi: 500-3500

Modulus (100%) psi: 100-3000

Elongation: 100-700%

Flex Cracking Resistance - very good

Tear Resistance: fair-good

Abrasion Resistance: good-excellent

Impact Resistance: very good

Service Temperatures (for continuous use)

-70 to 350°F

Environmental Resistance:

| | |
|-------|-------------|
| Ozone | outstanding |
|-------|-------------|

| | |
|-----------|-----------|
| Oxidation | excellent |
|-----------|-----------|

| | |
|-------|-----------|
| Water | excellent |
|-------|-----------|

| | |
|-----------|------|
| Radiation | good |
|-----------|------|

| | |
|---------------------|------|
| Silicate Hydrofluid | good |
|---------------------|------|

1.2.2 Parker Compounds

Parker has done extensive testings on its compounds. Both temperature and radiation (separate) testing were performed. Parker compound E740-75 is highly recommended due to its excellent resistance to radiation levels up to 10^8 rads under room temperature (see Table 4). When exposed to temperature, Parker E-740-75 shows a good back stress retention percent (Graphs 1-1A). Percent compression set is relatively low after temperature aging in both fluid and air (Graph 2).

Ranking of the Parker compounds on the approved vendor listing:

- a. E740-75 specially formulated for snubber applications.
- b. E692-75 high temperature resistant but not recommended for radiation.

1.2.3 Minnesota Rubber Compound

Minnesota Rubber Co. has performed radiation and temperature testing on its EP compound 559 EQ (Graphs 3-7). When temperature tested, this compound exhibited relatively low compression set at high temperature (Graph 8), but not as good as Parker compound E740-75 (Graph 9).

1.2.4 Federal Mogul Compound

Federal Mogul Compound E30 was not radiation tested

whereas compound E59 was and exhibited desirable compression set at 10^7 rads. Graphs 10 through 14 compare the physical properties of the compounds investigated. Note that the testing parameters differ which made it hard to draw any concrete conclusions as to what compound is a better one.

1.2.5 Acushnet and W.H. Salisbury Compounds

No data on environmental testing was available from Acushnet and W.H. Salisbury. We were provided with a technical sheet containing basic properties and breadboard test results.

1.2.6 ITT Grinnell Qualification Tests

ITT Grinnell had performed qualification tests on all of the EP compounds included on our approved vendor list. These were accelerated LOCA simulation tests and were judged on a basis of whether after radiation and temperature exposure, the seals leaked under dynamic testing. These tests did not give a true indication of seal life. Copies of these test results are available upon request.

1.3 Evaluation of "Other" Materials

1.3.1 Viton

Viton is a fluorocarbon elastomer which has exhibited very good heat and fluid resistance when compared to other elastomers.

Compounds of Viton have good tensile strength adequate for most applications. The durometer (Shore A) hardness ranges from 50 to 90 depending

material used for "O" rings and seals and accounts for about 80 percent of all applications of Kalrez. Table 2 outlines the general physical properties for Compound 1050.

Kalrez can be used continuously at temperatures of 600°F in many mechanical seal fluid environments. It is suitable for service at temperatures of 100°F to 180°F above that of any other commercial elastomer.

Kalrez does not exhibit outstanding compression set qualities with respect to elastomers but does outperform plastics in general. Table 3 represents traditional compression set data for Kalrez 1050 "O" ring (heat aged in air - Figure 3).

Kalrez can withstand 1 megarad (10^6 rads) of radiation with little effect on physical properties. Exposure to 10 megarads (10^7 rads) produces a moderate effect with 40 percent loss of tensile strength and 25 percent loss of elongation at break. At 100 megarads (10^8 rads) there are severe effects with 80 percent loss in tensile strength and 80 percent loss in elongation. Figure 4 shows the effects of radiation on Kalrez. Note that when compared with Viton, Kalrez expresses better sealing force retention at 400°F for long life (Figure 5).

1.3.3 Hycar Nitrile Elastomers

Hycar nitrile rubbers exhibit high tensile strength, good abrasion resistance and low compression set. Hycar rubbers in the medium and medium high acrylonitrile range offer a balance of physical properties between hardness and oil abrasion resistance on one hand and resilience and low temperature flexibility on the other. Medium - high acrylonitrile hycar (1002) has good water-resistance during prolonged service.

Hycar nitrile does not provide outstanding thermal resistance. The maximum service temperature for hycar nitrile is about 300°F. According to manufacturer catalogues and R. Harrington's report on Hycar nitrile rubber, amount and type of fillers are effective on hycar elastomer radiation stability. Data obtained from radiation exposure to gamma radiation (1×10^6 rads) in air of 25°C indicates that these compounds show decrease in elongation and increase in hardness with increasing exposure to radiation as the doses are increased. The tensile strength increases. This increase is a very strong indication that crosslinking is predominant. Although not as pronounced as the tensile strength, the hardness appears to be increased with increasing radiation exposure.

According to the evaluated data on nitrile elastomers, the use of these materials in a high dosage radiation environment is not recommended.

1.3.4 Vespel

Vespel parts are suitable for use in a wide range of temperatures with very good resistance to hydraulic fluid. It provides excellent abrasion resistance while maintaining extremely good mechanical properties with respect to temperature.

Radiation resistance of Vespel has not been fully documented. However, being part of the Polyamide family, which exhibits threshold damage at an absorbed dose of 8×10^5 rads and excessive degradation at 9×10^6 rads, Vespel should be carefully examined when and if used in an irradiated field.

Vespel has been compounded to withstand temperatures of up to 500°F (600°F when oxygen free). The major drawback in using Vespel (outside of questionable radiation resistance) is its inability to withstand a steam environment which could be present in a LOCA condition. Poor compression set and close tolerance requirements (for temperature cycling) are a major drawback.

1.3.5 Envex 1115

Envex 1115 is suitable for use in a wide range of temperatures (cryogenics to 550°F) with excellent chemical resistance to most hydraulic fluids. It provides a high compression strength (28000 psi) among other good physical properties.

Radiation resistance:

Being part of the Polyamides, Envex follows the same criteria as stated above (for Vespel).

The major drawbacks are very poor compression set and extremely close machining tolerances.

1.3.6 Kel-F

Kel-F plastic is a highly fluorinated resin which offers good mechanical properties. Kel-F plastic is unaffected and therefore compatible with a wide variety of chemicals. It operates over a temperature range of -400°F to +400°F without decomposition or mechanical failure. Furthermore, it exhibits zero moisture absorption and is unaffected by high humidity. Kel-F is a thermoplastic exhibiting high compressive strength and relatively good elastic memory (plastics as a whole usually lack in this respect).

Radiation resistance:

Kel-F is readily susceptible to radiation induced damage. Also under these conditions Kel-F releases gases which may have a corrosive effect on

adjacent components. It becomes quite soft and tacky at lower doses. In light of the above, the use of Kel-F thermoplastic is not recommended for our environment.

1.3.7 Metallic Seals

Two different types of metallic seals ("K-seal" and "helicoflex") have been evaluated.

The "K seal" is an all-metal seal designed for use in "static" application. A "K seal" consists of three basic elements, the body, the lips, and the surface coating (Figure 6).

Basic Helicoflex seals comprise one or two metal linings formed around the toroidal section of helically wound spring (Figure 7).

Metallic seals can perform in all "static" face sealing applications in a wide range of temperatures and in a radiation environment. Metallic seals are available in a wide choice of materials and shapes to meet property and fluid requirements. Because of the inability of a metal seal to readily conform to its cavity dimensions, extremely stringent tolerances must be adhered to. Surface finishes (both gland and seal) are very tightly controlled. Adherence to proper installation procedures would be extremely critical and if done incorrectly may result in an excessive failure percentage. The major drawback of these seals is the high cost of purchasing and remachining (redesign in some cases) of existing glands.

1.4 Summary of Consulting Screening

An agenda of questions was designed to discuss actual state-of-the-art technology of the elastomers. A breakdown of the general points is (see Appendix 3):

- a. EPDM is one of the best materials available for our operating environments.

From their actual experience with EPDM compounds and the physical state of the seals after being exposed for five (5) years in actual operating conditions, a substantial extension over five years is a realistic projection (detailed testing will be required).

- b. A mathematical model (life projection) has not been used extensively, if at all. This area needs extensive research work. The Air Force (WPAF) will start such a program in the future. Sandia Laboratory staff have done some work in this area, and based their projection (modeling) on accelerated aging testing. Sandia's consensus is the shorter the extrapolation, the better your life projection. It should be noted that this concept is not shared by the remainder of the industry. All three other consultants do not recommend induced harsh chemical degradation which is non-existent in actual working conditions. It is well known that in a strained elastomer two relaxations exist. These are known as physical and chemical stress relaxations. Physical relaxation involves two physical processes

(such as diffusion of polymer units or movement of entanglements) whereas chemical relaxation involves the breaking down of covalent bonds. Both of these processes are expected to have different temperature dependencies. It has been verified that in low temperature range (25°C - 111°C), no appreciable chemical relaxation occurs. This postulate has been verified by J. Sieron, R. Barbarin and D. Hertz (consultants).

D. Winkler, of the University of Akron, Applied Research Division of Polymers, (working in this area) also supports this postulate and strongly rejects the accelerated age testings.

- c. There is a synergistic effect on Radiation - Thermal degradation.
- d. Dosage rate is definitely a consideration that we have to pursue.
- e. Metallic seals show a good alternative. They are strongly recommended for static applications, although testing has to determine the degree of limitations for dynamic cases.
- f. Thermal cycling is a failure mode. For our temperature range (50°F - 120°F), there is little or no effect on the longevity of the seal.
- g. Due to the fact that some of our seals are immersed in a compatible silicone fluid

(GE SF-1154), effects of oxidation are minimized (irradiation of the polymers results in bond cleavage giving free radicals, which, in the presence of oxygen, react by a chain mechanism to form oxidation products that include thermally labile hydroperoxide). It is one parameter working to our advantage.

- h. Our testing program (relatively short time testing under actual operating conditions) has been judged adequate for seal life projection by all the consultants with the exception of Sandia Laboratory.
- i. Unreinforced plastics are not recommended for use in our snubbers. Consideration was given to procurement costs, dimensional criteria of the seal and gland, testing requirements and availability of the materials. Arrhenius projections and the WLF equations are mathematical interpretations of a chemical and physical (respectively) evaluation of temperature only. They will lose their high correlation when used in conjunction with multiple parameters (fluid, radiation, steam...).
- j. Degradation by temperature is highly minimized when $T_{\min} + 100^{\circ}\text{F} \leq T_{\text{operating}} \leq T_{\max} - 100^{\circ}\text{F}$. (T = Temperature)

II Snubber Seal Failure Criteria

2.1 Outline of Purpose

In order to provide a means of life prediction, an in-depth understanding had to be achieved of how a seal could be expected to fail. This was carried out in the manner described below. Dimensional analysis was conducted with respect to gland sizes and percentage squeeze realized by the seal. This information was then applied, in conjunction with the material properties outlined in Section I, to devise a pictorial model (FTA) which would depict areas with the greatest probability of failure. Once this had been determined, a potential seal material could be judged by its strength in these areas.

2.2 Baseline Dimensional Review Design Analysis

ITT Grinnell evaluated the minimum, nominal and maximum seal squeeze with respect to the temperatures existing in the seal environment (50°F - lowest reading based on a shutdown condition, 120°F - normal operating and 316°F - projected highest reading during a LOCA condition). These results (Tables 9.1 through 9.4) have been compared with the applicable vendor recommended squeeze range specified for each seal location (to secure design aspects and sealability of a seal, all calculated percent squeeze for each specific seal must fall between minimum and maximum range of

squeeze required by seal manufacturer).

Available design sealing surface finish requirements and existing extrusion gaps (maximum and minimum) have been defined and depicted in corresponding figures. Results from all evaluation and calculations are summarized in Figure 8 through 20 and corresponding Tables 4 and 9.1 through 9.4.

2.2.1 Federal Mogul

The valve retainer plate O ring (Figure 9) is exposed to system pressures of 5000 psi to 10,000 psi. Since the specified compound (E50) has a durometer of 70 ± 5 (Shore A), standard design practice indicates the use of back up rings or a zero clearance gap. However, since the valve seat disk-to-valve body does not constitute a seal, equal hydrostatic pressure will exist in the valve chamber (including the gap). Therefore, the .003 inch to .009 inch gap does not constitute an extrusion path.

Figures 9, 10, 11, 12, 13, and 14 are all static O rings (EPDM peroxide cured seals manufactured by Federal Mogul Reference Table 4). The Federal Mogul seal squeeze range requirement is .006 inches to 35 percent of cross section diameter. Recommended static seal surface finish requirements are 32 micro-inches. Figures 9, 10, 12, 13, and 14 comply with the above stated requirements. Figure 11 indicates that both nominal and maximum seal squeeze exceed

that standard requirement of 35 percent. However, since initial design squeeze or compression provided for low pressure sealing, and the reservoir sight glass is a low pressure seal only, the maximum squeeze of 41.51 percent will not be a detriment. Figure 15 is a static O ring (EPDM peroxide cured seal manufactured by Federal Mogul reference Table 1). The seal will not be compressed due to mismatched dimensions. Since this seal is not exposed to system high pressure and a leakage problem has not been experienced at this location, the use of this specific O ring does not constitute a major problem. However, change to an alternative "O" ring with a larger cross section is recommended.

2.2.2 Acushnet

Figures 16 and 17 are both static "O" rings (EPDM peroxide cured) manufactured by Acushnet (reference Table 1). The Acushnet seal squeeze range requirement is .010 inch to 35 percent of cross section diameter. Recommended static seal surface finish requirements are up to 64 micro-inches as indicated by Figures 4 and 5, the squeeze range requirement has been met.

Gap #1, depicted in Figure 17, indicates a .001 inch to .00275 inch intrusion path. Since the specified compound (E17018) has a durometer of 70 ± 5 (Shore A), and the "O" ring is exposed to system pressures of 6300 psi to 10,000 psi, standard design practice

indicates the use of a back up ring. However, cylinder vendor design experience indicates that the use of back up rings in this type of seal gland configuration is not effective and may actually detract from seal functionability. This fact, coupled with the fact that ITT Grinnell has not experienced any leakage problem with the external bearing seal, verifies seal design adequacy.

2.2.3 Minnesota Rubber

The rod seals (Figures 18.1 through 18.4 are dynamic seals (EPDM peroxide cured) manufactured by Minnesota Rubber (reference Table 4). Design configuration of this seal consists of one static and one dynamic portion. For an adequate seal to exist between this seal and the bushing, fit of the static portion of this seal in x direction is the main concern. For the static portion of this seal, the percent of compression in the x and y directions were determined at the temperatures of interest (reference Table 7.1 A through 7.4 A). Manufacturer recommended percent compression for this specific seal is undefined. However, calculated values in x direction do not appear to be inadequate. This is further supported by the fact that ITT Grinnell has not experienced any leakage problems with the rod seal.

Figures 19.1 through 19.2 show the rod wiper (EPDM peroxide cured) manufactured by Minnesota Rubber

(reference Table 4). In order to extend life of this wiper some design modification is recommended.

2.2.4 W.H. Salibury

The piston seal (Figure 20) is a dynamic seal (EPDM Sulfur cured) manufactured by W.H. Salisbury (reference Table 1). The percent of deflection at the seal lips has been defined and listed (reference Figure 20). The piston seal will not compress at any point. However, keeping in mind the allowable bypass, the current configuration of piston seal is adequate.

2.3 F.T.A.

The F.T.A. (Fault Tree Analysis) provides an adequate means to identify, document, and analyze potential failure of seals and their overall effects on system performance.

The F.T.A. generally starts by identifying an undesirable event at the system level and identifies the event at subsequent lower levels in the system that can cause the undesirable top event. The primary purpose of the F.T.A. is to ensure that the system (seal) will be reliable and safe for its intended use and foreseeable life time.

The standard logic symbols used in hardware technology were used to establish the fault tree. Appendix 1 outlines the different symbols and their respective meanings.

It was hoped that a quantitative probability would be assigned to lower levels of the F.T.A. and that the final probability of an event taking place would be evaluated using the subsequent logic gate mathematics (Appendix 1).

Due to the scarcity of meaningful data on seal failure in general (in a nuclear snubber environment) a quantitative probability of success could not be determined. The alternative method is to rank the relative probability of a part failure to the other possible failure modes in that system. This method utilized the ways that elastomeric or non-elastomeric seals degrade (data, articles, consultants) see Appendix 4.

III Seal Life Projection and Verification

3.1 Estimation of Life

Resulting from the in-depth study which has been performed, certain conclusions have been reached. EPDM has been determined to be the best candidate for an extended life. This choice was made taking several conditions into account. Foremost were the environmental considerations. EPDM has withstood this parameter in field use without exhibiting any discernable degree of degradation. In laboratory testing, EPDM consistently outperformed other elastomeric compounds (abrasion resistance, heat resistance, fluid compatibility, radiation resistance, etc). Secondly, consideration was given to geometric parameters, not only of the seal itself, but also, to the glands. Our snubber design was intended to be used with elastomers having allowed space for swell and thermal expansion (elastomers have a higher value than do plastics or metals) to name a few. If another material (plastic or metal) was to be used, then remachining or complete redesign of the glands would most likely have to take place. This process would entail a significant cost impact and in the case of certain seal locations (cylinder end seal) may

have proven to be very impractical. The third major consideration was the cost and availability of the materials. EPDM is relatively inexpensive, readily available from numerous vendors and has a short turn around time for delivery.

Based on the above stated information and the heavy endorsement that was given EPDM by our consultants who are experts in this field, we determined that EPDM had the highest probability for success. ITT Grinnell feels that the life of these seals could be extended significantly beyond the present seven (7) year period. In order to verify this, extensive testing will have to be performed (outlined in Section 3.2 below).

3.2 Testing

3.2.1 Purpose

This section will outline the test procedures necessary to verify life projections of EPDM seals as used in ITT Grinnell snubber systems under a nuclear power plant environment. Emphasis will be placed on simulated actual conditions and a degradation vs. time graph will be plotted. This will enable ITT Grinnell to state with a high degree of certainty the maximum life expectancy of the system seals.

3.2.2 Method of Testing

As previously stated, the ITT Grinnell test program utilizes simulated operational conditions. Close attention will be paid to radiation levels, temperature, fluid, steam and compression of the seal itself.

Qualification testings will be composed of the general breadboard testings plus the compression stress relaxation. Compression stress relaxation test is a direct representation of the several mechanisms of degradation (relaxation) the seal material will see under actual operation. Coupled with the breadboard tests, stress relaxation should develop adequate data to predict with a high confidence level the suitability and longevity of the polymeric material under the actual operating conditions.

3.2.3 Evaluation Criteria

Seal property data will be recorded in the form of percentage of properties retained or changed. This information will be used as input into a mathematical curve fitting (regression) computer program. Final extrapolations and analytical results (graphs) will then be compared to and checked against known benchmarks (data obtained from testing of five year and eight year exposed

seals) for accuracy. Efforts will be made (via sensitivity evaluation, separation of variables, etc) to discern the sphere of influence that each separate parameter contributes to the total degradation of the seal. Based on the above, and in conjunction with the knowledge of potential types of failure modes (brittleness, degree of swell, high set characteristics, etc.), a determination will be made as to how long EPDM seals can safely be used in a nuclear environment.


APPENDIX 1
CHARTS, GRAPHS
AND FIGURES

MIDLAND SNUBBER SEALS

| ITEM | SEAL TITLE | LOCATION | FUNCTION-TYPE | SIZE | MANUFACTURER | COMPOUND | CURE METHOD |
|------|-------------------------|------------------|------------------|-------------------|------------------|----------|---------------|
| 1 | O'RING - OUTLET ADAPTER | RESERVOIR | STATIC - O' RING | 1.737 ID x .103 W | FEDERAL - MOGUL | E 50 | EPDM-PEROXIDE |
| 2 | O'RING - DRAIN ADAPTER | RESERVOIR | STATIC - O' RING | .987 ID x .103 W | FEDERAL - MOGUL | E 50 | EPDM-PEROXIDE |
| 3 | O'RING - FILTER ADAPTER | RESERVOIR | STATIC - O' RING | .987 ID x .103 W | FEDERAL - MOGUL | E 50 | EPDM-PEROXIDE |
| 4 | O'RING - MTG. STUDS | SIGHT GLASS-RES. | STATIC - O' RING | .487 ID x .103 W | FEDERAL - MOGUL | E 50 | EPDM-PEROXIDE |
| 5 | O'RING - GLASS GAUGE | SIGHT GLASS-RES. | STATIC - O' RING | .299 ID x .103 W | FEDERAL - MOGUL | E 50 | EPDM-PEROXIDE |
| 6 | O'RING - CAP | SIGHT GLASS-RES. | STATIC - O' RING | .551 ID x .070 W | FEDERAL - MOGUL | E 50 | EPDM-PEROXIDE |
| 7 | O'RING - CR SEAL VALVE | TUBING RUN | STATIC - O' RING | .796 ID x .139 W | FEDERAL - MOGUL | E 50 | EPDM-PEROXIDE |
| 8 | O'RING - CR SEAL VALVE | TUBING RUN | STATIC - O' RING | .549 ID x .103 W | FEDERAL - MOGUL | E 50 | EPDM-PEROXIDE |
| 9 | EXTERNAL BEARING SEAL | MODEL 52 ONLY | STATIC - O' RING | VARICUS | ACUSHNET | E 17018 | EPDM-PEROXIDE |
| 10 | ROD SEAL | CYLINDER | DYNAMIC - LIP | VARIOUS | MINNESOTA RUBBER | 559-EQ | EPDM-PEROXIDE |
| 11 | O'RING - END SEAL | CYLINDER | STATIC - O' RING | VARIOUS | ACUSHNET | E 17018 | EPDM-PEROXIDE |
| 12 | ROD WIPER | CYLINDER | DYNAMIC - LIP | VARIOUS | MINNESOTA RUBBER | 559-EQ | EPDM-PEROXIDE |
| 13 | PISTON SEAL | CYLINDER | DYNAMIC - U-CUP | VARIOUS | W.H.SALISBURY | 80154 | EPDM-SULFUR |
| 14 | O'RING - VALVE | TUBE CONN. | STATIC - O' RING | 1.171 ID x .116 W | FEDERAL - MOGUL | E 50 | EPDM-PEROXIDE |
| 15 | O'RING - VALVE | RETAINER PL. | STATIC - O' RING | 1.299 ID x .103 W | FEDERAL - MOGUL | E 50 | EPDM-PEROXIDE |
| 16 | THREAD SEAL | VALVE | STATIC - THREAD | .644 ID x .087 W | FEDERAL - MOGUL | E 50 | EPDM-PEROXIDE |
| 18 | THREAD SEAL | VALVE | STATIC - THREAD | 1.299 ID x .103 W | FEDERAL - MOGUL | E 50 | EPDM-PEROXIDE |
| 17 | FILL PORT PLUG | CYLINDER | STATIC - O' RING | .644 ID x .087 W | FEDERAL - MOGUL | E 50 | EPDM-PEROXIDE |
| 19 | FILL PORT PLUG | CYLINDER | STATIC - O' RING | .755 ID x .097 W | FEDERAL - MOGUL | E 50 | EPDM-PEROXIDE |

| CYLINDER MODEL | QUANTITY OF SEALS |
|----------------|-------------------|
| 52 | 30 |
| 90 | 29 |

TABLE:4




BY Y.M. DATE 7-15-81
 CHKD. BY HB DATE 7-15-8

SUBJECT SEAL STUDY
 CUSTOMER CONSUMERS
 PROJECT MIDLAND

SYSTEM
 PROJECT NO. SPS-8014




BACKSTRESS
 RETENSION %



— COMPRESSION STRESS RELAXATION TEST —
PARKER E740-75

— GRAPH 1 —


BY YM DATE 7-15-81 SUBJECT SEAL STUDY SHEET NO. OF
CHKD. BY HB DATE 7-15-81 CUSTOMER CONSUMERS SYSTEM
PROJECT MIDLAND PROJECT NO. SPS-8014



BACKSTRESS RETENSION
OVERLAY COMPARISON
PARKER E740-75

— GRAPH 1A —

% COMPRESSION SET



PARKER-COMPOUND #740

Hardness varied from -2 to -1 from 75 orig. (insignificant)

Swell after 1008 Hrs. 1.1% - insignificant
 may be due to temp. also

NOTE: Results were similar after Test B immersion
 3 hrs. @ 340°F, 3 hrs. @ 320°F & 18 hrs. @ 250°F

| | Orig. | Test A (70 hrs) | Test A (504 hrs) | Test A (1008 hrs) | Test B |
|--------------|-------|--------------------|---------------------|----------------------|--------|
| Hardness | 75 | 73 | 74 | 73 | 72 |
| Tensile Str. | 2580 | 2620 | 2430 | 2750 | 2380 |
| Elong. % | 182 | 183 | 179 | 197 | 177 |
| Mod. @ 100% | 928 | 941 | 921 | 878 | 952 |
| Volume (%) | | +0.8 | +0.09 | +1.1 | 1.9 |

—GRAPH 2—

TESTING DONE




IN AIR AT ROOM TEMP FOR 2016 HOURS



IN AIR AT ROOM TEMP FOR 792 HOURS

PERCENT
COMPRESSION SET




GRAPH 2A - COMPRESSION SET
COMPOUND E740 75

NORDELL - EPDM
ENERGY

1:1 ACTIVATION

— AT 212°F (IN AIR)
- - - AT 248°F (IN AIR)




— TENSILE STRENGTH —
MINN. RUBBER-COMPOUND #559EQ
— GRAPH 3 —

*

BY YM DATE 7-15-81
 CHKD. BY HB DATE 7-15-81

SUBJECT SEAL STUDY
 CUSTOMER CONSUMERS
 PROJECT MIDLAND


SHEET NO. _____ OF _____
 SYSTEM _____
 PROJECT NO. SPS 8014



— % DEVIATION —
MINN. RUBBER - COMPOUND #559EQ
— GRAPH 4 —


*

THE Grinnell Corporation
 BY Y.M. DATE 7-15-81
 CHIEF, BY H.B. DATE 7-15-81
 SUBJECT SEAL STUDY
 CUSTOMER CONSUMERS
 PROJECT MIDLAND
 SYSTEM
 PROJECT NO. SPS 8014
 SHEET NO. OF




— HARDNESS —
 MINN. RUBBER-COMP #559EQ
 — GRAPH 5 —

+ HARDNESS
(SHORE A DUROMETER)



— HARDNESS —
 MINN. RUBBER-COMPOUND #559EQ
 — GRAPH 6 —

% COMPRESSION SET



N.G.


— COMPRESSION SET —
 MINN. RUBBER-COMPOUND #559EQ
 — GRAPH 7 —

BY Y.M. DATE 7-15-81. SUBJECT SEAL STUDY
CHKD. BY H.B. DATE 7-15-81. CUSTOMER CONSUMERS SYSTEM
PROJECT MIDLAND PROJECT NO. SPS-8014

% COMPRESSION SET

100%

50%




— METHOD B — COMPRESSION SET —
MINN. RUBBER — COMPOUND #559EQ

— GRAPH 8 —

BY YM DATE 7-15-81 SUBJECT SEAL STUDY SHEET NO. 1
CHKD. BY HB DATE 7-15-81 CUSTOMER CONSUMERS SYSTEM
PROJECT MIDLAND PROJECT NO. SPS-2014

% COMPRESSION SET




—COMPRESSION SET—


* 3 hrs. @ 340°F, 3 hrs. @ 320°F & 18 hrs. @ 250°F in
GE SF 96,200 Fluid (Dimethyl polysiloxane fluid)

** 3 hrs. @ 340°F, 3 hrs. @ 320°F & 18 hrs. @ 250°F in
GE SF 1154 Fluid (Methyl phenyl polysiloxane fluid)


—GRAPH 9—



—GRAPH 10—




—GRAPH 11—



—GRAPH 12— 37


L.I.E. Ginner Corporation
 BY YM DATE 7-15-81 SUBJECT SEAL STUDY SHEET NO. OF
 CHKD. BY HB DATE 7-15-81 CUSTOMER CONSUMERS SYSTEM
 PROJECT MIDLAND PROJECT NO. SPS-8014

HARDNESS (SHORE A DUROMETER)




— ORIGINAL PROPERTIES —

— GRAPH 13 —



— TENSILE STRENGTH —

— GRAPH 14 —



PERMANENT DEFORMATION RESISTANCE OF VITON

—FIG. 1—

Long-Term Compression Set of VITON

Compression set, %*

| Time, hr. | At R.T. | At 300°F. (149°C.) | At 392°F. (200°C.) |
|-----------|------------|-----------------------|-----------------------|
| 1,000 | — | 12 | 50 |
| 2,000 | — | 16 | 65 |
| 4,000 | 21 | 22 | 79 |
| 8,000 | 21 | 32 | 98 |

*ASTM D395, Method B.
(O-rings)

LONG TERM COMPRESSION SET OF VITON AT DIFFERENT
TEMPERATURES

—FIG. 1-A—


BY: **AK** DATE: **8/19/81** SUBJECT: **SEAL STUDY**
 CHKD. BY: DATE: CUSTOMER: **CONSUMER POWER SYSTEM**
 PROJECT: **MIDLAND** PROJECT NO.: **SPS-8014**

Oven Air Aging of VITON

| Physical Properties (dumbbell specimens unless otherwise noted) | Original | Temperature, Time | | | | |
|--|----------|------------------------------|------------------------------|------------------------------|-------------------------------|-------------------------------|
| | | 212°F. 100°C. 3 months | 250°F. 121°C. 3 months | 275°F. 135°C. 3 months | 300°F. 148°C. 11 months | 392°F. 200°C. 11 months |
| 100% modulus, psi | 800 | | | | 1050(131%) | 810(101%) |
| Ultimate tensile strength, psi (O-ring) | 1915 | 1835 | 1915(100%) | 2025(106%) | | |
| Ultimate tensile strength, psi | 2200 | | | | 1700(77%) | 1400(64%) |
| Ultimate elongation, % (O-ring) | 210 | 210 | 225(107%) | 235(112%) | | |
| Ultimate elongation, % | 220 | | | | 145(66%) | 150(68%) |
| Hardness, Durometer A points | 76 | | | | 76(100%) | 81(107%) |

THE EFFECT OF OVEN AIR AGING ON SPECIFIC MECHANICAL PROPERTIES OF VITON AT VARIOUS TEMPERATURES OVER PROLONGED PERIODS.

—FIG. 2—



SERVICE LIMITS OF VITON IN AIR AT
VARIOUS TEMPERATURES.

—FIG. 2-A—

BY AK DATE 8/19/81 SUBJECT SEAL STUDY SYSTEM
 CHKD BY DATE CUSTOMER CONSUMER POWER PROJECT NO 3PS-8014
 PROJECT MIDLAND

| PHYSICAL PROPERTIES | | | | |
|---------------------|--|-------------------------|---------------|----------|
| ENVIRONMENT | RADIATION DOSAGE ERGS g ⁻¹ (c) | TENSILE STRENGTH psi | ELONGATION % | HARDNESS |
| AIR | 0 | 1044 | 192 | 66.2 |
| AIR | 8.7 x 10 ⁷ | | DISINTEGRATED | |
| ARGON | 2 x 10 ⁸ | 2145 | 172 | 72 |
| ARGON | 5 x 10 ⁸ | 742 | 63 | 76 |
| MIL-L-7808 OIL | 8.7 x 10 ⁷ | 1112 | 208 | 64.8 |
| MIL-L-7808 OIL | 4.4 x 10 ⁸ | 1028 | 211 | 64.4 |
| MIL-L-7808 OIL | 1.7 x 10 ⁹ | 961 | 117 | 64.8 |

PROPERTY CHANGE IN "VITON" IRRADIATED IN AIR,
 ARGON AND JET TURBINE OIL AT 400°F BY COBALT - 60

—FIG. 2-B—

BY: AK DATE: 7/17/81 SUBJECT: SEAL STUDY
 CHECKED BY: _____ DATE: _____ CUSTOMER: CONSUMER POWER SYSTEM
 PROJECT: MIDLAND PROJECT NO.: SPS-8014

| | |
|--|-------|
| Hardness, Durometer A | 80 |
| 100% Modulus*, psi | 1,400 |
| MPa | 9.65 |
| Tensile Strength*, psi | 1,900 |
| MPa | 13.10 |
| Elongation at Break*, % | 130 |
| Compression Set, ASTM D395B Pellets 70 hr. | |
| at 400°F (204°C), % | 38 |
| at 550°F (288°C), % | 53 |
| Brittle Point, ASTM D746 | |
| °F | -35 |
| °C | -37 |
| *ASTM D412, 10 in./min. (4.2 x 10 ⁻³ m/s) | |

GENERAL PHYSICAL PROPERTIES OF KALREZ PERFLUOROELASTOMER

(COMPOUND 1050)


—TABLE-2—

BY: *AK* DATE: *8/19/81* SUBJECT: *SEAL STUDY*
 CHKD. BY: DATE: CUSTOMER: *CONSUMER POWER SYSTEM*
 PROJECT: *MIDLAND* PROJECT NO.: *SPS-8014*

| Test Conditions | | Compression Set % |
|--|-------|-------------------|
| Temperature | Time | KALREZ 1050 |
| 75°F (24°C) | 70hr. | 20 |
| 212°F (100°C) | 70hr. | 32 |
| 400°F (204°C) | 70hr. | 71 |
| 450°F (232°C) | 70hr. | 71 |
| 500°F (260°C) | 70hr. | 69 |
| 550°F (288°C) | 70hr. | 74 |
| *ASTM D-395B AS-568A = 214 O-Ring Specimens Heat Aged in Air | | |

COMPRESSION SET OF KALREZ AT DIFFERENT TEMPERATURES

— TABLE-3 —



— KALREZ —
(COMPOUND 1050)

— FIG. 3 —

KALREZ® TERFLUOROELASTOMER RADIATION RESULTS

Electron Radiation Source
G.E. Resonate Beam
Transformer 2 Million E.V.
1 Milliamp

Tensile at Break in PSI

Tensile At Break Vs. Radiation Dosage

2000

1500

1000

500

25

50

75

100

Radiation Dosage In Megarads

Elongation At Break Vs. Radiation Dosage

160

120

80

40

25

50

75

100


Radiation Dosage In Megarads

REF. 8831-126

% Elongation


-FIG.4-

BY: AK DATE: 2/19/81 SUBJECT: SEAL STUDY
CHKD. BY: DATE: CUSTOMER: CONSUMER POWER SYSTEM
PROJECT: MIDLAND PROJECT NO.: SPS-8014




— KALREZ —
— BACKSTRESS RETENTION —


— FIG. 5 —




CROSS SECTION of TYPICAL K-SEAL



CROSS SECTION of K-SEAL and SEAL CAVITY SHOWING INTERFERENCE




K-SEAL in INSTALLED POSITION




— FIG. 7 —

CROSSECTIONAL DIAGRAM
HELICOFLEX SEAL

APPENDIX 2
BASELINE STUDY
CHARTS, GRAPHS
AND FIGURES



BY DL DATE 5-27-91 SUBJECT SEAL STUDY SHEET NO. 2 OF 2
 CHKD. BY AK DATE 5-29-91 CUSTOMER CONSUMERS SYSTEM VALVE-RET. PLATE
 PROJECT MIDLAND PROJECT NO. SPS-8014



| O-RING SIZE |
|-------------------|
| 1.297 ID x .103 W |


| AT 70°F | | |
|-------------|-------|---------|
| COMPRESSION | | |
| MIN. | MAX. | NOMINAL |
| 17% | 23.6% | 20.33% |

NO ELONGATION

NO SCALE

REF: PHD-5222-27-REV.D

FIG. 10



| O-RING SIZE |
|--|
| .487 ^{±.005} I.D. x .103 ^{±.003} W |

NOTE: O-RING SIZE
 USED WAS NAT'L STD.
 PART NO. AS-112 (FOR
 ACTUAL DIM'S & TOL'S)

AT 70°F

| COMPRESSION | | |
|-------------|--------|---------|
| MIN. | MAX. | NOMINAL |
| 33% | 41.51% | 37.38% |


| ELONGATION | | |
|------------|-------|---------|
| MIN. | MAX. | NOMINAL |
| .813% | 3.73% | 2.25% |

FIG. 11

REF: OIL-RITE DRAWINGS

{ B-1556 - REV. J }
 # { B-1554-3 REV Q }

NO SCALE




— FIG. 12 —

| DIMENSIONS | | |
|-----------------------|----------------------|---------------------|
| A | B | C |
| $\frac{1.255}{1.250}$ | $1 \pm \frac{1}{64}$ | $\frac{.083}{.078}$ |

| O' RING SIZE |
|--------------------------------------|
| $.987 \pm .010 \times .103 \pm .003$ |

| COMPRESSION | | |
|-------------|--------|---------|
| MIN | MAX | NOMINAL |
| 17% | 26.42% | 21.85% |




- FIG. 13 -

| DIMENSIONS | | |
|-----------------------|----------------------|---------------------|
| A | B | C |
| $\frac{1.255}{1.250}$ | $1 \pm \frac{1}{16}$ | $\frac{.083}{.078}$ |

| 'D' RING SIZE |
|--------------------------------------|
| $.987 \pm .010 \times .103 \pm .003$ |

| COMPRESSION | | |
|-------------|--------|---------|
| MIN | MAX | NOMINAL |
| 17% | 26.42% | 21.85% |




-FIG.14-

| DIMENSIONS | | |
|-----------------------|---------------------------------|---------------------|
| A | B | C |
| $\frac{2.010}{2.000}$ | $1\frac{3}{4} \pm \frac{1}{64}$ | $\frac{.083}{.078}$ |

| 'D' RING SIZE |
|------------------------------------|
| $1.737 \pm .015$ & $.103 \pm .003$ |


| COMPRESSION | | |
|-------------|--------|---------|
| MIN | MAX | NOMINAL |
| 17% | 26.42% | 21.85% |



— FIG. 15 —

| O' RING SIZE |
|---|
| .551 ^{±.007} x .070 ^{±.003} W |

— SEAL SEES NO COMPRESSION —




| BORE SIZE | "O" RING SIZE | |
|-----------|-----------------|---------------|
| | $\pm .030$ I.D. | $\pm .003$ W. |
| 14" | 14.610 | X .070 |
| 16" | 16.610 | X .070 |
| 18" | 18.610 | X .070 |
| 20" | 20.610 | X .070 |

| AT 70° F | | |
|-------------|--------|--------|
| COMPRESSION | | |
| MIN. | MAX. | NOM. |
| 14.93% | 32.87% | 24.29% |

NO ELONGATION

FIG. 16



| "A" | | | "B" | | |
|------|------|------|--------|------|--------|
| MIN. | MAX. | NOM. | MIN. | MAX. | NOM. |
| .051 | .057 | .054 | .09475 | .096 | .09538 |

| GAP #1 | | | GAP #2 | | |
|--------|--------|--------|--------|------|-------|
| MIN. | MAX. | NOM. | MIN. | MAX. | NOM. |
| .001 | .00275 | .00188 | .001 | .006 | .0035 |

| "O"-RING SIZE | |
|---------------|--|
| BORE | SIZE |
| 14" | $7.900 \pm .030$ I.D. x $.070 \pm .003$ W |
| 16" | $8.900 \pm .030$ I.D. x $.070 \pm .003$ W |
| 18" | $9.900 \pm .030$ I.D. x $.070 \pm .003$ W |
| 20" | $10.900 \pm .030$ I.D. x $.070 \pm .003$ W |

| COMPRESSION (% DIAP.) | | |
|-----------------------|--------|--------|
| MIN. | MAX. | NOM. |
| 14.93% | 30.14% | 22.85% |

AT 70°F


NO COMPRESSION IN Y DIR.

NO ELONGATION

NO SCALE

FIG. 17


REF: MILLER'S FILE A1695B REV. 9
MILLER'S GEN. ASSY MODST #52 REV.
MILLER'S FILE A1031-REMEMORA



| % ELONGATION | | | | | |
|--------------------------------|--------|-----------|----------|-------------|------|
| POINT "A" | | POINT "B" | | SURFACE "D" | |
| MIN. | MAX. | MIN. | MAX. | MIN. | MAX. |
| 1.71% | 2.16% | 0% | 0% | .54% | .92% |
| % COMPRESSION (STATIC PORTION) | | | | | |
| "X" DIR. | | | "Y" DIR. | | |
| MIN. | MAX. | | MIN. | MAX. | |
| 18.22% | 22.15% | | 1.57% | 3.91% | |

FIG. 18.1 14" BORE ASSEMBLIES


NOTE: COMPRESSION/ELONGATION RESULTS BASED ON WORST POSSIBLE SITUATION W/ ROD ANGLED AT .085° AND W/ SEAL GLAND ECCENTRIC TO Φ .001. AT 70°F



| % ELONGATION | | | | | |
|--------------------------------|--------|-----------|----------|-------------|------|
| POINT "A" | | POINT "B" | | SURFACE "D" | |
| MIN. | MAX. | MIN. | MAX. | MIN. | MAX. |
| 1.71% | 2.10% | 0% | 0% | .54% | .92% |
| % COMPRESSION (STATIC PORTION) | | | | | |
| "X" DIR. | | | "Y" DIR. | | |
| MIN. | MAX. | | MIN. | MAX. | |
| 18.22% | 22.15% | | 1.59% | 3.91% | |

-FIG. 18.2 16" BORE ASSEMBLIES -


NOTE: COMPRESSION/ELONGATION RESULTS BASED ON WORST POSSIBLE SITUATION W/ ROD ANGLED AT .035° AND W/ SEAL GLAND ECCENTRIC TO Ø .001. AT 70°F



| % ELONGATION | | | | | |
|--------------------------------|--------|-----------|----------|-------------|------|
| POINT "A" | | POINT "B" | | SURFACE "D" | |
| MIN. | MAX. | MIN. | MAX. | MIN. | MAX. |
| 1.69% | 2.04% | 0% | 0% | .54% | .92% |
| % COMPRESSION (STATIC PORTION) | | | | | |
| "X" DIR. | | | "Y" DIR. | | |
| MIN. | MAX. | | MIN. | MAX. | |
| 18.22% | 22.15% | | 1.59% | 3.91% | |

FIG. 18.3 18' BORE ASSEMBLIES


NOTE: . COMPRESSION/ELONGATION RESULTS BASED ON WORST POSSIBLE SITUATION w/ ROD ANGLED AT .0850 AND w/ SEAL GLAND ECCENTRIC TO CL .001 AT 70°F



| % ELONGATION | | | | | |
|--------------------------------|--------|-----------|----------|-------------|-------|
| POINT "A" | | POINT "B" | | SURFACE "D" | |
| MIN. | MAX. | MIN. | MAX. | MIN. | MAX. |
| 1.68% | 2.05% | 0% | 0% | .54% | .92% |
| % COMPRESSION (STATIC PORTION) | | | | | |
| "X" DIR. | | | "Y" DIR. | | |
| MIN. | MAX. | | MIN. | | MAX. |
| 18.22% | 22.15% | | 1.59% | | 3.91% |


-FIG. 18.4 20" BORE ASSEMBLIES -

NOTE: COMPRESSION/ELONGATION RESULTS BASED ON WORST POSSIBLE SITUATION W/ ROD ANGLED AT .085° AND W/ SEAL GLAND ECCENTRIC TO CL .001. AT 70°F




—FIG. 19—

SNUBBERS D1, D3, D4, I1, I2
14" BORE SIZE




SNUBBERS E1A, E3A, E1B, E3B, F1, F2, G1, G2
1/2" BORE SIZE

FIG. 19.2




SNUBBERS B5/J2
15" BORE SIZE

— 19.3 —



—FIG. 19.4—

SNUGGERS B3, D4, E6
20" BORE SIZE



| PERCENT DEFLECTION * | | |
|----------------------|--------|--------|
| BORE | MIN. | MAX. |
| 14" | 25.39% | 28.36% |
| 16" | 28.12% | 30.94% |
| 18" | 30.94% | 32.16% |
| 20" | 31.88% | 34.48% |

*NOTE: RESULTS SHOWN ARE ENTIRE SEAL DEFLECTION, EACH LIFE WILL DEFLECT 1/2 OF RESULTS SHOWN.

FIG.20- PISTON SEAL

BY AK DATE 7/7/81 SUBJECT SEAL STUDY SHEET NO. OF
 CHECKED BY DATE CUSTOMER CONSUMERS SYSTEM
 PROJECT MIDLAND PROJECT NO.

| SEAL TITLE | LOCATION | TEMP. | MANUFACTURER | COMPOUND |
|------------|----------|-------|------------------|----------|
| ROD SEAL | CYLINDER | 70 °F | MINNESOTA RUBBER | 559 EQ |

| COMPRESSION - 14" CYL. | | | |
|------------------------|---------|---------------|--------|
| "X" DIRECTION | | "Y" DIRECTION | |
| NOMINAL | MAX. | NOMINAL | MAX. |
| 18.22 % | 22.15 % | 1.57 % | 3.91 % |

| COMPRESSION - 16" CYL. | | | |
|------------------------|---------|---------------|--------|
| "X" DIRECTION | | "Y" DIRECTION | |
| NOMINAL | MAX. | NOMINAL | MAX. |
| 18.22 % | 22.15 % | 1.59 % | 3.91 % |

| COMPRESSION - 18" CYL. | | | |
|------------------------|---------|---------------|--------|
| "X" DIRECTION | | "Y" DIRECTION | |
| NOMINAL | MAX. | NOMINAL | MAX. |
| 18.22 % | 22.15 % | 1.59 % | 3.91 % |

| COMPRESSION - 20" CYL. | | | |
|------------------------|---------|---------------|--------|
| "X" DIRECTION | | "Y" DIRECTION | |
| NOMINAL | MAX. | NOMINAL | MAX. |
| 18.22 % | 22.15 % | 1.59 % | 3.91 % |

— COMPRESSION AT 70 ° F

TABLE 9.1 ROD SEALS

BY AK DATE 7/7/81 SUBJECT SEAL STUDY SHEET NO. OF
 CHECK BY DATE CUSTOMER CONSUMERS SYSTEM
 PROJECT MIDLAND PROJECT NO.

| SEAL TITLE | LOCATION | TEMP | MANUFACTURER | COMPOUND |
|------------|----------|--------|------------------|----------|
| ROD SEAL | CYLINDER | 120 °F | MINNESOTA RUBBER | 559 EQ |

| COMPRESSION - 14" CYL. | | | |
|------------------------|--------|---------------|------|
| "X" DIRECTION | | "Y" DIRECTION | |
| NOMINAL | MAX. | NOMINAL | MAX. |
| 18.97% | 22.79% | 1.84% | 4.2% |

| COMPRESSION - 16" CYL. | | | |
|------------------------|--------|---------------|------|
| "X" DIRECTION | | "Y" DIRECTION | |
| NOMINAL | MAX. | NOMINAL | MAX. |
| 18.49% | 22.48% | 1.69% | 4.1% |

| COMPRESSION - 18" CYL. | | | |
|------------------------|--------|---------------|------|
| "X" DIRECTION | | "Y" DIRECTION | |
| NOMINAL | MAX. | NOMINAL | MAX. |
| 18.49% | 22.79% | 1.69% | 4.2% |

| COMPRESSION - 20" CYL. | | | |
|------------------------|--------|---------------|------|
| "X" DIRECTION | | "Y" DIRECTION | |
| NOMINAL | MAX. | NOMINAL | MAX. |
| 18.79% | 22.79% | 1.89% | 4.2% |

— COMPRESSION AT 120 °F

TABLE 9.2 ROD SEALS

| SEAL TITLE | LOCATION | TEMP | MANUFACTURER | COMPOUND |
|------------|----------|--------|------------------|----------|
| ROD SEAL | CYLINDER | 316 °F | MINNESOTA RUBBER | 559 EQ |

| COMPRESSION - 14" CYL. | | | |
|------------------------|---------|---------------|--------|
| "X" DIRECTION | | "Y" DIRECTION | |
| NOMINAL | MAX. | NOMINAL | MAX. |
| 21.27 % | 25.13 % | 2.87 % | 5.43 % |

| COMPRESSION - 16" CYL. | | | |
|------------------------|---------|---------------|--------|
| "X" DIRECTION | | "Y" DIRECTION | |
| NOMINAL | MAX. | NOMINAL | MAX. |
| 21.27 % | 25.13 % | 2.87 % | 4.60 % |

| COMPRESSION - 18" CYL. | | | |
|------------------------|---------|---------------|--------|
| "X" DIRECTION | | "Y" DIRECTION | |
| NOMINAL | MAX. | NOMINAL | MAX. |
| 21.27 % | 25.13 % | 2.87 % | 5.38 % |

| COMPRESSION - 20" CYL. | | | |
|------------------------|---------|---------------|--------|
| "X" DIRECTION | | "Y" DIRECTION | |
| NOMINAL | MAX. | NOMINAL | MAX. |
| 21.27 % | 24.17 % | 2.87 % | 5.38 % |

— COMPRESSION AT 316 °F —

TABLE 9.7 ROD SEALS

BY AK DATE 7/7/81 SUBJECT SEAL STUDY SHEET NO. OF
 CHKD. BY DATE CUSTOMER CONSUMERS SYSTEM
 PROJECT MIDLAND PROJECT NO.

| SEAL TITLE | LOCATION | TEMP | MANUFACTURER | COMPOUND |
|------------|----------|-------|------------------|----------|
| ROD SEAL | CYLINDER | 50 °F | MINNESOTA RUBBER | 559 EQ |

| COMPRESSION - 14" CYL. | | | |
|------------------------|--------|---------------|-------|
| "X" DIRECTION | | "Y" DIRECTION | |
| NOMINAL | MAX. | NOMINAL | MAX. |
| 17.89% | 22.04% | 1.46% | 3.85% |

| COMPRESSION - 16" CYL. | | | |
|------------------------|--------|---------------|-------|
| "X" DIRECTION | | "Y" DIRECTION | |
| NOMINAL | MAX. | NOMINAL | MAX. |
| 17.96% | 21.90% | 1.48% | 3.73% |

| COMPRESSION - 18" CYL. | | | |
|------------------------|--------|---------------|-------|
| "X" DIRECTION | | "Y" DIRECTION | |
| NOMINAL | MAX. | NOMINAL | MAX. |
| 17.96% | 21.86% | 1.48% | 3.75% |

| COMPRESSION - 20" CYL. | | | |
|------------------------|--------|---------------|-------|
| "X" DIRECTION | | "Y" DIRECTION | |
| NOMINAL | MAX. | NOMINAL | MAX. |
| 17.89% | 22.04% | 1.46% | 3.85% |

— COMPRESSION AT: 50 ° F

TABLE 9.4 ROD SEALS

| SEAL LOCATION | TYPE | % SQUEEZE | F(DESIGN) | F(REQ'D) | % MARGIN |
|-------------------|--------------|-----------------------|-----------|----------|----------|
| VALVE-RET. PLATE | "O" RING | 20.38% | 71.6499# | 7.06# | 90.15% |
| VALVE-RET. PLATE | "O" RING | 20.38% | 71.6499# | 7.06# | 90.15% |
| CYL.-END SEAL | "O" RING(14) | 24.29% | 691.54# | 51.72# | 92.52% |
| CYL.-END SEAL | "O" RING(16) | 24.29% | 785.76# | 58.77# | 92.52% |
| CYL.-END SEAL | "O" RING(18) | 24.29% | 879.97# | 65.82# | 92.52% |
| CYL.-END SEAL | "O" RING(20) | 24.29% | 974.19# | 72.86# | 92.52% |
| CYL.-EXT. BEARING | "O" RING(14) | 22.85% | 337.56# | 26.43# | 92.17% |
| CYL.-EXT. BEARING | "O" RING(16) | 22.85% | 379.91# | 29.74# | 92.17% |
| CYL.-EXT. BEARING | "O" RING(18) | 22.85% | 242.27# | 33.06# | 92.17% |
| CYL.-EXT. BEARING | "O" RING(20) | 22.85% | 464.62# | 36.38# | 92.17% |
| RES.MTC. STUDS | "O" RING | 37.38% | 83.79# | 4.71# | 94.43% |
| CYL.-ROD SEAL | SHEP. SEAL | SEE FIG. 7.1 THRU 7.4 | — | — | — |
| CYL. PISTON SEAL | U-CUP | SEE FIG. 8 | — | — | — |
| RES.-OUTLET | "O" RING | 21.85% | 66.09# | 6.88# | 89.58% |
| RES.-DRAIN | "O" RING | 21.85% | 48.40# | 5.04# | 89.58% |
| RES.-FILTER | "O" RING | 21.85% | 48.40# | 5.04# | 89.58% |
| RES.-EXT. CAP | "O" RING | 0% | — | — | — |

- TABLE 1 -

% SQUEEZE = % Compression of the seal associate with installation condition at room temperature.

F_{DES} = Force associate with backstress developed by installation seal squeeze at nominal room temperature condition.

F_{REQ'D} = Min. Backstress required to seal against steady state low pressure at design requirement of 35.PSI (for nominal room temperature condition).

% MARGIN = $\frac{F_D - F_R}{F_D} \times 100$

APPENDIX 3

SUMMARY OF THE
CONSULTANT'S MEETINGS

EPDM DISCUSSION, COMMENTS & SUGGESTIONS
D. L. HERTZ, JR. (ITT GRINNELL VISIT 8/7/81)

Submitted 8/20/81

EPDM - TWENTY YEAR SERVICE LIFE PREDICTABILITY

ABSTRACT

Ethylene-propylene terpolymers are base elastomers for seals designed to contain silicone type hydraulic fluids in seismic arresting devices. The preferred useful life expectancy is twenty-plus years in a moderate temperature environment that may also involve continuous low-level radiation. Ethylene and propylene, the two simplest of the alkene series, have been intensively studied. It is highly improbable that a failure mechanism previously unknown might appear in the service environment. The operating temperatures are well within the elastomer's accepted thermal resistance for long-term serviceability, leaving only the complications of stress relaxation and radiation damage to consider. Stress relaxation testing coupled with a modulus (shear or Young's) monitoring program should develop adequate data to predict with a high confidence level the suitability of EPDM seals for twenty year service life.

INTRODUCTION

Adequate references to stress relaxation corroborate the validity of this testing method as an accurate tool in prediction of long-term seal serviceability as a function of retained seal contact stress. The problem of sealing under conditions of long-term low-level radiation exposure encompasses both polymer physics (stress relaxation) and polymer chemistry (elastomer structural damage). Assuming radiation induced free radicals, the elastomer would be first subjected to: a. increasing crosslink density at unsaturated diene sites (which are limited by per cent diene monomer concentration) followed by: b. abstraction of methine hydrogen(1) resulting backbone scission (reversion). Compressive

stress relaxation rates would be greatly influenced by b and not noticeable by a.

Condition-a

Condition-a would be indicated by an increase in shear modulus(G), directly related to durometer(2). Conventional durometer measuring devices are operator sensitive. Therefore, the Wallace-Shawbury Microindenter (Testing Machines, Inc.-Mineola, NY) might be a more accurate instrument to consider. Lindley's approach(3) for load compression forces might also be considered to calculate Young's modulus increase. Elastomer sensitivity to radiation-induced crosslinking could be compared by using identically compounded model compounds with the elastomer differing only in per cent third monomer concentrations. (This ranges from 2 to 13%.) Initial crosslink density would be controlled by using Loan's(4) model approach to develop a known level of crosslinks.

Condition-b

Backbone scission would be physically indicated by surface stickiness. Stress relaxation rates would be greatly increased since the test is molecular weight sensitive, and it is assumed chain scission (backbone cleavage) would dominate. Quantitative results could be defined by using Kearsley's(5) approach.

POLYMER SCREENING

Since all elastomers have gaseous precursors, initial degradation by-products in ionizing radiation would be indicated by gas evolution. This test might be as simple as looking for gas bubbles from an elastomer immersed in water (radiation intensity, CO-60 source, would be only slightly diminished)(6).

CROSSLINK TYPES (PEROXIDE, SULFUR)

Peroxide Cure

Bulk of published EPDM data indicate peroxide cured elastomers to have superior compression set and lower stress relaxation rates (notably Meier, et al.)(7). Residual peroxide fragments have been identified as troublesome by numerous sources and techniques known to immobilize such fragments are well known. One reservation on peroxide cured EPDM (99.9% theoretical conversion of curative) was a solenoid valve seat failure in contact with potable water - 206-210°F surrounding the seal and 50-70°F potable water on the valve seating area. Extensive reversion on the cold water side occurred within six months in various parts of the country. Replacing the seal with a sulfur cured EPDM cured the problem. Residual sulfur or its by-product (zinc diethyldithiocarbamate) apparently acted as a free radical trap(8) with the probable mechanism-singlet oxygen, as defined by Kaplan et al.(9).

Sulfur Cure

Development of a monosulfidic crosslink using elemental sulfur, using the technique as developed by Baldwin(10) and verified by Meier, et al.(11) creates a very stable crosslink in the event the peroxide cured crosslink is susceptible to environmental and/or ionizing radiation damage.

THERMAL STABILITY

There is no problem regarding thermal stability of the EPDM. Upper service temperature limits are well below recommended maximum service temperatures and lower temperatures well above the elastomer transition range (point at which the elastomer can increase the shear modulus by one or two orders of magnitude with only a few degrees of temperature shift.)

ALTERNATIVE ELASTOMERS

Propylene-TFE copolymer (AFLAS) as produced by ASAHI Glass-Japan is probably the only other suitable elastomer for ionizing radiation service. It should be considered if oil resistance or a higher temperature environment becomes a design criteria.

SUPPLEMENTAL TESTING INSTRUMENTS

The Yertzley oscillograph (Yertzley Company-744 Broad St., Newark, NJ) should be reviewed. The instrument measures complex dynamic modulus which is strongly influenced by molecular weight and crosslink density.

MODEL COMPOUNDS

There is a strong case for use of model compounds (known compositions) as benchmarks in testing. EPDM's are inherently ozone resistant (therefore not requiring antiozonant protection), but a rubber compounder might incorporate antiozonant in sufficient amounts to act as a free radical trap in a radiation environment. This would mask or offset elastomer damage until the antiozonant is consumed, creating a "time-bomb" radiation effect (12, 14). A very interesting approach for an EPDM model compound is described by Baldwin, Borzel and Makowski(13). This same approach is also useful from a design standpoint as it points out effect of molecular weight on useful properties. Additional background on EPDM serviceability as influenced by compounding can be derived from Auda and Hazelton's paper(14).

CONCLUSIONS

Accurate stress relaxation and modulus-shift testing on EPDM elastomers should develop sufficiently linear data (Arrhenius) to predict long-term serviceability with a high confidence level. The area of least information is the effect of

low level radiation on crosslinking and subsequent chain scission of the elastomer. There are sufficient types of EPDM (varying ratios of ethylene-propylene-third monomers) so that crosslinking/scission reactions could be monitored readily over a short time period.

D. L. Hertz, Jr.

BIBLIOGRAPHY

- (1) F.P. Baldwin, G. VerStrate, Rubber Chem. Technol. 45, p. 769,819(1972).
- (2) A.N. Gent, Science and Technology of Rubber, (F.R. Eirich-Editor), p. 17, Academic Press, New York 1978.
- (3) P.B. Lindley, Engineering Design with Natural Rubber, MRPRA, p. 38, 4th Edition, 1974.
- (4) L.D. Loan, Rubber Chem. Technol., 40, 149(1967).
- (5) E.A. Kearsley, "A Basis for Predicting Long-Time Behavior from Short-Time Tests of Geothermal Sealants," National Bureau of Standards, Polymer Science and Standards Division(1979).
- (6) B.J. Lyons, V.L. Lanza, Polymer Stabilization (W.L. Hawkins-Editor) p. 252, Wiley-Interscience, New York-1972.
- (7) J.F. Meier, G. E. Rudd, D.F. Weir, Rubber Chem. Technol., 52, 50(1979).
- (8) Ref. 1, p. 821.
- (9) M.L. Kaplan, P.G. Kelleher, Rubber Chem. Technol., 45, 423 (1972).
- (10) F.B. Baldwin, Rubber Chem. Technol., 43, 1040(1970).
- (11) Ref. 7, p. 60.
- (12) Ref. 6, p. 258.
- (13) F.P. Baldwin, P. Borzel, H.S. Makowski, Rubber Chem. Technol., 42, 1167(1969).
- (14) R.S. Auda, D.R. Hazelton, "Ethylene Propylene Elastomer Technology for Improved High Temperature Serviceability" SAE Publication 750962.

CONSULTING VISIT TO ITT GRINNELL.

AUGUST 6, 1981

DISCUSSION, COMMENTS, AND SUGGESTIONS

J.K. SIERON

CONSULTING VISIT TO ITT GRINNELL - August 6, 1981

The following synopsis covers significant points I made during my visit to ITT:

A. Questions (Attachment 1)

1. EPDM is an excellent choice as the base elastomer for hydraulic system seals in the environment identified in Question 1 with the following qualifications: (a) the exact composition of the EPDM elastomer compounds on your qualified supplier list should be identified since an infinite number of possible compounds exists, (your legal department should explore confidential disclosure agreements on material compositions with your seal suppliers); (b) EPDM compounds co-vulcanized by peroxide curing systems with 1, 2 - polybutadiene liquid polymers have outstanding properties and could be superior to your presently used EPDM compounds (a suggested compound is AF-E-411, Parker Seal and others are familiar with this material); (c) clearance tolerances for elastomeric seals subjected to 10,000 psi would have to be very small to prevent seal extrusion and failure, (back-up rings are used in aircraft hydraulic systems at pressures above 1500 psi).

2. It is not likely that EPDM seals exposed to system temperatures ranging from 50°-120°F., silicone fluids and radiation exposure of 52 rad/hour would be severely damaged if the seals are properly formulated and processed. The above parameters should not seriously affect seal properties whether applied individually or collectively. The most reliable test to predict seal performance is compression set under anticipated conditions. It is suggested that compression set of candidate seals be measured on o-rings subjected to static operational conditions after 24 hours, 48 hours, 72 hours, 1 week, 2 weeks, 4 weeks and each month thereafter up to at least 6 months, (a flat curve normally is reached within 1 week for stable materials).

3. Again, in response to Question 3, I have to caution that "EPDM" covers a multitude of possible materials. EPDM base elastomers vary widely in molecular weight and molecular weight distribution. Further, the base EPDM elastomer (starting material) can be compounded with a variety of reinforcing materials such as carbon black and silica; amine or phenolic antioxidants, processing aids such as stearic acid or plasticizers, and curing agents like peroxides, sulfur or sulfur donating accelerators. To reiterate my answer to Question 1, peroxide cured co-vulcanizates of EPDM and 1, 2-polybutadiene liquid resins would probably be superior to conventional EPDM compounds. In addition, a new very stable elastomer called AFLAS which is a copolymer of propylene and tetrafluoroethylene could be superior to EPDM. AFLAS has exceptional oxidative stability and is stable to 500°F. Metal seals and seals based on radiation resistant high Tg polymers such as polyphenylene sulfide could also be superior to EPDM. The major problem with such seals would be machining and installation since they are not forgiving.

4. In response to Question 4, I don't think that PH_3 treatments of EPDM are required to achieve a "blocking" effect against oxidation for your environment. The PH_3 treatment probably was used to neutralize residual hydroperoxides in the EPDM compounds. A preferred and recommended procedure is to post-cure the EPDM seals under a nitrogen atmosphere at temperatures exceeding maximum use temperature, ie - 1 hour each at 250°F., 300°F., 350°F., and 400°F. and cool down to 200°F. or less before removal from the oven.

5. It is hard to beat real time testing! Since your EPDM seals have endured 5 years under working conditions without significant damage, a 10 year life is a conservative projection. My experience indicates that you can expect at least 20 to 30 years lifetime as long as exposure conditions do not change. For example, hydraulic system seals (nitrile rubber) were found to be in excellent

condition after recovery from World War II aircraft downed in desert and ice cap regions.

6. Question 6 is a little more difficult to answer. In general, properly compounded classes of elastomers will functionally seal to certain limits; for example, EPDM - 300°F., Viton/Fluorel - 400°F., Silicone - 400°F. In the absence of oxygen or an oxidizing environment, EPDM is stable and has sealed for more than 6 months at 500°F. in a geothermal well environment. Compression set is the usual cause of seal failure and set is always accentuated by high temperatures.

7. In general, I like your test outline because it relies on seal evaluations under operational conditions. Some suggestions to enhance your program are: (a) get the precise composition of the baseline seals exposed to 5 years under reactor conditions and subject similar, but new seals in compression set fixtures along with dumbbell specimens or freely suspended seals to your test conditions for at least 6 months; (b) measure compression set and physical properties - tensile strength, elongation, 100% modulus (very important) and hardness on seals or dumbbell specimens after 24 hour, 48 hour, 72 hour, 1 week, 2 weeks, 1 month and each month thereafter to at least 6 months (if possible, continue testing to about 2 years; my experience indicates that people believe real time testing) (c) in addition to the standard baseline seals, subject nitrogen post-cured baseline seals to the above tests and also EPDM/ 1, 2 -polybutadiene seals, preferably N₂ post-cured, to the above test conditions.

8. Based on the Sandia reports and other data, I feel that low dosage rates of 40-50 rad/hour will not significantly harm properly compounded EPDM seals. However, it is always better to rely on real time testing under simulated operational conditions to accurately assess seal life prediction.

9. We have as yet, not been able to correlate modeling studies with test data to predict seal lifetime. A program to predict seal lifetime as a function of material physical properties and dynamic test results will start in summer 1981.

QUESTIONS:

1. What elastomeric material would you consider would be superior in our environment to EPDM (fluid silicone base, temp. range $50^{\circ} - 120^{\circ}$, max. operating pressure 10,000 psi radiation exposure 52 rad/hour)?
2. Some of the physical properties' behavior observed from individual testing (T, Rad, fluid) follow a Maxwellian decay (exponential). This phenomenon is due to the initial bond relaxation. Are we in a position to say that they obey the same chemical degradation? Can the "synergism" of these parameters be an additive effect?
3. Based on # 1 above, is there another type of material (plastic, and/or metal) which would surpass EPDM? What would be the limitations (machining, non-standard sizing, etc.)?
4. Is the usage of PH_3 treatments of EPDM for a "blocking" effect of oxidation necessary (for our operating environment)?
5. Seals made of EPDM have lasted 5 years under working conditions and still remain in good shape. From your expertise, is a 10 year life a conservative projection?
6. Throughout your experience with elastomers have you at anytime been subjected to: if $T_{\min} + 100^{\circ}\text{F} < T_{\text{operating}} < T_{\max} - 100^{\circ}\text{F}$ temperature is of little or no effect on sealing capabilities (i.e., stress relaxation) of an elastomer?
(Address EPDM in particular).
7. After reviewing our testing outline, do you have any thoughts as to what, if anything, should be added to predict an extended life.
8. Is the total energy absorbed in a material which determines the property damages, the rate at which the energy is absorbed or some function of both (address total dosage (1.8×10^7 rad) vs dosage rate 52 rad/hour)?
9. How have you, in the past, attempted long term life modeling (math. model) from your test data?
Address: Separation of variables
Arrhenius Equation
WLF Method
Creep Function
Stress Relaxation

SUBJECT: PROPOSED TESTING EPDM QUALIFICATION
CUSTOMER: CONSUMERS POWL. CO.
PROJECT: EXTENDED SEAL STUDY (SPS-8014).

7/17/81

A. KHATAMGAZ
H. BELAIDI

Compression Stress Relaxation Test

Sample # - 10-20 O-rings of each EPDM compound (1/2" ID)
(all properties originally measured for reference point)

Test Equipment - Shawbury-Wallace compression stress relaxometer
(ASTM D.1390)

Test Conditions - Simultaneous rad. (52 rad/Hr.), varying temp.
(50°F - 120°F, LOCA @ end) & silicone fluid;
each parameter separately. (25% comp.)
and in comb. of 2 parameters (i.e. Temp. &
fluid, etc.)

Possible Variance - 10 O-rings treated with PH₃ (per Sandia Lab.
procedure), 10 O-rings untreated; average
results.

Duration - 6 months w/reading every 10 hrs. or continuously if
auto. graph readout available.

Data - Determine "best curve fit" for data obtained on % backstress
retained vs. time. Extrapolate to 5 yrs., compare with 5 yr.
known seals. If accurate, extrapolate for 10 yr., 15 yr. &
20 yr. Determine interaction of parameters as follows:

$$f(t) = at + bt^2 + ct^3$$

2. Compression set test (ASTM D395 Method B)

From above test: Measure compression set 30 min. after removal
from test jig. Compare with known values. Determine if it follows
curve.

3. Durometer Test (Shore A)

Check durometer after ABV tests and compare with known values.
Determine curve fit accuracy.

4. Tensile Test & Elongation (ASTM D412)

After above 3 tests: Check tensile % change. Compare with known
values. Determine curve fit accuracy.

5. Flex Test (ASTM D-430) Rod Seal & Piston Seal to be accomplished
after above test #2.

CONSULTING VISIT TO PARKER SEALS
AND SANDIA LABORATORIES
DISCUSSION, COMMENTS,
AND SUGGESTIONS

Minutes of meeting with R. H. Barbarin, 8/12/81, Culver City, Cal.

Introduction: Mr. R. H. Barbarin, technical director, Research and Development Division of Parker Hannifin Corporation, seal group. He has done extensive work on elastomeric products. He has performed stress relaxation testings for life evaluation of seals exposed to temperature. He has served at different symposiums related to elastomeric and non elastomeric products.

1. For the stated environment, EPDM, is one of the best materials. There might be strong competition from Viton. But for a combined environment, EPDM has shown very good stability (relative).
2. No, the chemical degradation by temperature and radiation does not follow the same mechanism. Their overall trend on the physical properties follows the same pattern (Maxwellian). The industry doesn't have enough information on the synergism effect. I would doubt any additive effects. Extensive testing might provide an answer.
3. Plastics in general are not recommended for the environment specified. After brief description of the dividing element between plastic and elastomer (formation of high level stress rings, etc.), he reiterated that plastics might be good and acceptable for our environment (not harsh). However, EPDM will still perform more effectively. Metal seals are even better than EPDM if careful design tolerances, remachining and actually redesigning of actual glands are being followed. However, in overall picture, EPDM is the "champ".
4. I don't know of such blocking effect. However, post-curing under nitrogen atmosphere has proven to be very effective. Peroxide and sulfur cured are other excellent methods.
5. 10 year life is very conservative projection for EPDM compounds. I would even state that a 20 year is not beyond "Horizons". Testing will show you the confirmation.
6. There is minimal degradation that the seal will see under your proposed "rule of thumb". On a relative basis, yes, there is little effect. But I would not say that the life of the seal is not compromised. Again in conjunction with radiation, there might be a pronounced effect. But for your environment (52 rad/hr, 120⁰ F) not to worry. EPDM has the stability to withstand this environments (saturated backbone).
7. No, except I would include % modulus. Compression stress relaxation should provide with enough information coupled with "Breadboard testings", you will be able to determine as to what is the extent of the seal life.

8. Both dosage rate and total integrated dose provide a combined effect on the seal degradation which is more destructive I cannot really confirm it. But I am inclined to say that total integrated dose will. However testing should be performed and analysed for it may prove the opposite.

9. Arrhenius projection is somewhat an adequate method when temperature is the only criteria. But using it in a combined environment, it will lose its high correlation. If the effect was additive, you might be lucky because this principle can be superposable. The same evaluation follows for the W.L.F. projection.

Minutes of meeting with L. Bonzon 8/13/81, Albuquerque,
New Mexico.

1. Mr. Bonzon stated that, for our operating condition, EPDM is probably the best elastomer to use with Viton ranking as a "maybe".
2. Mr. Bonzon was opposed to the use of the word "physical" (relaxation). He said that chemical degradation is the only way to predict life (and only in an accelerated method).
3. Metal seals were cited as the best solution but that machining, tolerances of installation are extremely vital to the success of these seals.
4. Mr. Bonzon said the PH_3 treatment would be useless in our application (this is 180° from the data presented in the report that Sandia sent us #SAND80-2149). Not effective for EPR though he never tried it.
5. EPDM seals probably good for 10 years, no guarantee. At this point he reiterated that accelerated age tests would be the only way to determine.
6. Agreed to $T_{\min} + 100^\circ\text{F} \leq T_{\text{oper}} \leq T_{\max} - 100^\circ\text{F}$
7. This question resulted in the longest discussion. Mr. Bonzon was opposed to our method of testing. Claims that accelerated induced chemical degradation tests are the only way to predict life (Commentary: Industry and academia have proven, per Dave Winkler-University of Akron, that induced chemical degradation is not an accurate way of predicting elastomer life. Sandia has recently been trying to re-instate this type of life study testing. Mr. Bonzon stated that the one thing that Sandia has been missing is a benchmark.) All of their accelerated tests have been done on temperature influence only. Mr. Bonzon said that Sandia is not sure if accelerated tests will be accurate for combined parameters.
8. Stated that degradation is a function of both dosage and dosage rate in conjunction with all the other parameters (heat, humidity, fluid,...). Claims the only way to determine this is by accelerated testing using 50 O rings per point of interest (at this point he was asked if this is due to the fact that it's a mandatory scientific procedure or just one that Sandia employs. He said that he recommends this).

- 9: No math modeling done. After some discussion, it became apparent that he really did not understand the concept behind math models so we dropped the subject (though he professed to know emphatically that math models don't work.)

Note: Tour of facility was provided. Facility is of the nature of wet radiation. No unusual instrumentation is present. Mr. Bonzon was very informative about his installation.

APPENDIX 4


FTA AND PROBABILITY ASSIGNMENTS
(RELATIVE)


A random probability number is assigned (.0001) to the very high (VH) relative degree of probability. This number will be equally subdivided and assigned to the relatively lower level of probability.


| | | | |
|----|----|---------|------------|
| VH | -- | .0001 | |
| H | -- | .000086 | |
| MH | -- | .000071 | |
| M | -- | .000057 | |
| ML | -- | .000043 | |
| L | -- | .000029 | |
| VL | -- | .000014 | (Very Low) |


On a relative basis, the F.T.A. will indicate what failure mode has the higher probability of occurrence. It will also serve as a verification of the logic designed for such failure.


FAULT TREE ANALYSIS LOGIC SYMBOLS


 The RECTANGLE identifies an event, usually a malfunction, that results from the combination of fault events through the logic gates.


 The AND GATE describes the type of situation whereby the occurrence of all input events is required to produce the desired event.


 The OR GATE defines the situation whereby the output event will occur if any or all of the input events are present.

 The CIRCLE describes a basic fault event that requires no further development. This category includes component failures whose frequency and/or mode of failure are known or unknown.

 The DIAMOND describes a fault event that is considered basic in a given fault tree; however, the causes of the event have not been developed, either because the mode of occurrence is unknown or the necessary information is unavailable.

 The INHIBIT GATE describes a causal relationship between any fault and an event. The input directly produces the output event if the inhibiting condition is satisfied.

 The HOUSE indicates an event that is manually expected to occur.

 The TRIANGLE indicates a transfer symbol. A line from the apex of the triangle down as a transfer in and a line from the apex directly a transfer out.


MATHEMATICS OF FAULT TREE ANALYSIS

In FTA, probabilities of events must be combined to produce the probability of top events. Most frequently the quantities must be combined in the AND gate or in the OR gate as shown here.



AND Gate
Output probability is the product of input probabilities.



$$P_A = P_1 \times P_2 \times P_3$$



OR Gate
Output probability is the sum of input probabilities.

$$P_A = P_1 + P_2 + P_3$$

$$P_A = P_1 + P_2 + P_3 - P_1 P_2 - P_1 P_3 - P_2 P_3 + P_1 P_2 P_3$$





Inhibit Gate
The INHIBIT Gate is composed of the same as an AND Gate. The output probability is the product of the input probabilities.


$$P_A = P_1 \times P_2$$


It is common in actual practice to simplify calculations by assuming statistical independence for the failure modes represented on the tree.

For this simplified example, only the failures are used to construct the fault tree. For a complete fault tree analysis, (unitary &1) and (unitary &2) would be the failures of basic fault events with probabilities of failure assigned to each.









BIBLIOGRAPHY

1. ARTICLES RELATING TO RADIATION EFFECTS

- 1.1 "Elastomers for Use in Radiation Fields", by Robert Harrington (Page 971-980) Rubber Age, Vol. 81, No. 6 September, 1957 (References included)
- 1.2 "Elastomers for Use in Radiation Fields Part II: Effects of Gamma Radiation on Heat-Resistant Elastomers" (Page 461-470) by Robert Harrington Rubber Age, Vol. 82, No. 3 December, 1957 References included.
- 1.3 "Elastomers for Use in Radiation Fields Part III: Effects of Gamma Radiation on Elastomers" (Page 1003-1015) by Robert Harrington Rubber Age Vol. 82, NO. 6 March, 1958 (References included)
- 1.4 "Part IV: Effects of Gamma Radiation on Miscellaneous Elastomers and Rubberlike Plastics Materials", (Page 472-481) by Robert Harrington, Rubber Age, June, 1958 (References included)
- 1.5 "How Hot Water Affects Elastomers", (Page 798-811), by Robert Harrington, Rubber Age, February, 1959 (References included)
- 1.6 "Elastomers for Use in Radiation Fields Part V: Effect of Gamma Radiation on Nitrile Elastomers (Page 963-973), by Robert Harrington, Rubber Age Vol. 85, No. 6, September 1959 (References included)
- 1.7 "Elastomers for Use in Radiation Fields Part IV: Radiation Resistance of the Neoprenes", (Page 819-825), by Robert Harrington, Rubber Age, February 1960 (References included)
- 1.8 "Elastomers for Use in Radiation Fields, Part VII" (Page 475-483), by Robert Harrington, Rubber Age December 1960, (References included)
- 1.9 "Elastomer for Use in Radiation Fields, Part VIII" (Page 265-270), by Robert Harrington, Rubber Age, November 1961, (References included)

- 1.10 "Elastomers for Use in Radiation Fields, Part IX",
Page 417-428), by Robert Harrington, Rubber Age,
June 1963, (References included)
- 1.11 "Elastomers for Use in Radiation Fields, Part X",
(Page 88-96), by Robert Harrington, Rubber Age,
September 1965, (References included)
- 1.12 "Effects of Radiation on Materials & Components"
edited by John F. Kircher & Richard E. Bowman,
Chapter 3, "Polymers", (Page 84-138), Reinhold
Publishing Corporation, New York.
- 1.13 ITT Grinnell Radiation Report No. 998B,
January 12, 1971.
- 1.14 Information for Experiments from Nuclear Lab,
Massachusetts Institute of Technology , October 1978.

2. MANUFACTURERS PUBLICATION

- 2.1 Simrir, Catalogue No. 763
- 2.2 Tefzel Fluoropolymer, Design Handbook by Dupont
- 2.3 Envex Polyimide by Rogers Corporation
- 2.4 Vespel Parts by Dupont
- 2.5 Rubber Material Selector for Engineered Molded Parts by Minnesota Rubber Company
- 2.6 Design with Elastomers by BF Goodrich
- 2.7 The General Chemical Resistance of Various Elastomers from the 1970 Yearbook of the Los Angeles Rubber Group, Inc.
- 2.8 Elastomers by Western Acadia Incorporated
- 2.9 National O-Ring Design Guide by Federal Mogul
- 2.10 Increase Reliability of Fluid Power Equipment with Seals of Dupont Viton Fluoroelastomer by Dupont.
- 2.11 Viton Fluoroelastomer by Dupont
- 2.12 Dupont Kalrez Perfluoroelastomer Parts by Dupont
- 2.13 Chemical Resistance Guide for Kalrez by Dupont
- 2.14 Select O-Rings Carefully by Malcolm G. Murray Jr. from Hydrocarbon Processing, April 1976
- 2.15 Fluid Power Designers Lighting Reference Handbook, The SP Manufacturing Corp.
- 2.16 Design Manual Section 3 by Advanced Products
- 2.17 Design Manual Introductory Section by Advanced Products
- 2.18 High Levels of Sealing with Helicoflex by Carbone USA, Corp.
- 2.19 Information About Specialty Lubricants
- 2.20 Information about Silicone Fluids by Dow Corning Corp.
- 2.21 Fluids by Paul-Munroe Hydraulics, Inc.
- 2.22 The Design Engineer's Cylinder Guide by Versatek Company
- 2.23 A Guideline for the FMEA/FTA Westinghouse Corporation
- 2.24 The Language of Rubber, Elastomer Chemicals Department i.e. Dupont De Nemours & Co. (Inc.)

- 2.25 Metal Static Seal (K Seal) Sierracin/Harrison, Burbank, CA
- 2.26 Elastomer Selection and Service Guide, Seals Eastern, Inc. Red Bank, New Jersey
- 2.27 The Shawbury-Wallace Compression Stress Relaxometer MK. II. H. W. Wallace & Co. Ltd., James Road, Croydon, England
- 2.28 A Compression of Lucas Compression, Relaxation and Compression Set for Evaluation of Seal Materials, by J. R. Dunn, Polysar Limited, Sarnia, Ontario
- 2.29 High Temperature Elastomers in Gas Turbine Engine Fuel Sealing, 8th International Conference on Fluid Sealing September 11-13, 1978, by K. P. Palmer & M. W. Aston
- 2.30 Developing Standards for Geothermal Seal, by Daniel L. Hertz, Jr., Standardization News, Vol. 7, No. 10
- 2.31 Sour Hydrocarbons-The Elastomer Challenge by D. L. Hertz, Jr., Seals Eastern Inc., presented at a meeting of the Rubber Division, American Chemicals' Society, Las Vegas, Nevada, May 1980.
- 2.32 Ethylene Propylene Elastomer Technology for Improved High Temperature Serviceability, Society of Automotive Engineers 750962, October 1975.

3. ARTICLES FROM MAGAZINES

- 3.1 Fine-Tuning the Engineering Thermoplastics, Machine Design, (Page 103-107), November 1979.
- 3.2 A Stepwise Approach to Designing Plastic, Machine Design, (Page 104-111), August 1980.
- 3.3 Projecting Short-Term Data to Long-Term Creep, Plastic Design Forum, (Page 38-45), November/December 1979, References included.
- 3.4 You Can Predict Creep in Plastic Parts, Machine Design, (Page 67-71), March 1976.
- 3.5 Plastics Engineering, Official Publication of the Society of Plastics Engineers, (Page 1-4), October 1977.
- 3.6 ME, December 1980, Section 4: Rubber & Elastomers, (Page 1240127).
- 3.7 Choosing Elastomers for 400F to 600F, Design Engineering, (Page 35-38), March 1980.
- 3.8 The Effects of Strain & Temperature on the Dynamic Properties of Elastomers, Journal of Mechanical Design, (Page 45-53), January 1980, Vol. 102.
- 3.9 The Dynamic Characteristics of O-Rings, Journal of Mechanical Design, (Page 132-138), January 1978, Vol. 100.
- 3.10 Leaking Seals: Causes and Cures, ASME Publication, 79-DE-E-7, (Page 1-4).
- 3.11 Product in Perspective, Design Engineering, (Page 56-59), October 1980.
- 3.12 Ideas & Applications, Fluid Power Magazine, (Page 22-23).
- 3.13 How to Detect & Prevent Hydraulic Fluid Cavitation by G. R. Jordan, Manager Marketing Engineering Mobil Oil Corp., New York, N.Y., (Page 190-192).
- 3.14 Reprinted from The Hidden Cause of Seal Failure, Machine Design, (Page 1-4), April 9, 1981.
- 3.15 O-Rings for Low-Pressure Service, Reprinted from Machine Design, (Page 1-6), April 12, 1979.
- 3.16 Selecting Gasket Materials, Machine Design, (Page 124-129), June 1979.
- 3.17 Keeping Hydraulic, Machine Design, (Page 156), December 1978.

- 3.18 Cylinders Healthy, Machine Design, (Page 157-159), December 1978.
- 3.19 Hydraulic Technology Stacks Up Gains in Power and Precision, Machine Design, (Page 84-89), January 1979.
- 3.20 Section 5: Fluid Seals and Packings, Machine Design, (Page 231-243), September 1979 (Fluid Power Reference Issue).
- 3.21 The Effects of Reactor Radiation on Three High-Temperature Solid-Film Lubricants, Journal of the American Society of Lubrication Engineers, (Page 463-473), November 1965.
- 3.22 Mechanical Behavior of O-Rings, from Rubber Chemistry & Technology, Vol. 46, No. 2, (Page 530-539), June 1972.
- 3.23 Section 4: Elastomers, Rubbers, Machine Design, (Page 215-222), April 1980.
- 3.24 Designing with Rubber, Part 1: The Design Surface, Machine Design, (Page 78-82), July 1977.
- 3.25 Mechanics of Elastomers at High Temperatures, Danil L. Hertz, Jr., (Page 1-13), Presented at the High Temperature Electronics & Instrumentation Seminar, Houston, TX, December 1979.
- 3.26 Seal For Profit-Making Design from Hydraulics & Pneumatics, (Page 1-32), March 1980.
- 3.27 Determining the Sealing Performance of Elastomers by Compression Stress Relaxation, M. W. Aston, A.P.I., L.R.I.C., Rubber Technologist, Chemistry Department Lucas Aerospace Ltd., Engine Management Group, and Chairman Lucas Group Standards Rubber Committee, (Page 90-98).
- 3.28 Fitting Curves to Data by George H. Neugebauer, Machine Design, (Page 91-95), September 6, 1979.
- 3.29 Unique Experimentation Strategy Lets You Test Less, Learn More, by John O. Geremia, Machine Design, (Page 110-115), September 7, 1977.

4. LAB REPORTS

- 4.1 Analysis of Abnormalities of Snubbers in Nuclear-Reactor Service (Report 1) by Oak Ridge National Lab
- 4.2 Radiation and Environmental Test of Seal and Fluid Materials for Snubbers, ITT Grinnell, Report No. PHD-5347-2R Rev. 1
- 4.3 Radiation and Environmental Test of Seal and Fluid Materials for Snubbers, ITT Grinnell, Report No. PHD-7569-1 Rev. 1
- 4.4 Parker-Seals Lab Report, Stress Relaxation, Report No. 10,4781 Long Term Aging E740 Nuclear
- 4.5 Test Procedure Qualification Testing of Elastometric Seal Materials for ITT Grinnell Snubbers; Test Procedure No. PHD-7559-1.
- 4.6 Test Report Sequential Radiation, Loca & Dynamic Testing of ITT Grinnell Suppressor Cylinder Seals, Test Report No. PHD-7559-2, Rev. 0.
- 4.7 Occurrence and Implication of Radiation Dose-Rate Effects for Material Aging Studies, Sandia National Lab, Nureg/DR-2157, Sand 80-1796.
- 4.8 Predicting Life Expectancy and simulating Age of Complex Equipment Using Accelerated Aging Techniques, Sandia National Lab, Nureg/DR-1466, Sand 79-1561, Unlimited distribution.
- 4.9 Radiation-Thermal Degradation of EP and PUC: Mechanism of Synergism and Dose Rate Effects, Sandia National Lab, Nureg/DR-2156, Sand 80-2149.
- 4.10 Qualification Testing Evaluation Program Light-Water Reactor Safety Research, Semiannual Report, April-Sept. 1980, Sandia National Lab, Nureg/CR-2089, Sand 81-0272.
- 4.11 Qualification Testing Evaluation Program Light-Water Reactor Safety Research, Quarterly Report, January-March 1978, Sandia National Lab, Nureg/CR-0278, Sand 78-0799, Unlimited Release.
- 4.12 Broad Temperature Range Hydraulic Systems Seal Materials, Technical Report AFML-TR-74-92, September 1974, Wright-Patterson Air Force Base, Ohio
- 4.13 A1AA-31-1716-1721, Nonflammable Aircraft Hydraulic Systems Development, Air Force Wright Aeronautical Lab.
- 4.14 Evaluation of Sealing Systems for Nonflammable Aircraft Hydraulic Fluids, William E. Berner, Air Force Wright Aeronautical Lab, Materials Lab, AFWAL/MLBT.

- 4.15 High Temperature Stabilization Systems for Hydrocarbon Elastomers by J.K. Sieron, March 1963, Technical Documentary Report No. ASD-TDR-62-1113, Wright-Patterson Air Force Base, Ohio.
- 4.16 An Investigation into Radiation Resistance of Selected Compounds, May 1973, Parker Seals Lab Report No. K10.063A.
- 4.17 Parker Seal Company, Lab Report No. K10,151-466.
- 4.18 Parker Seal Company, Lab Report No. K10,063B.
- 4.19 Acushnet Company, Lab Report No. 1010.

5. Books

- ✓ 5.1 Radiation Effects on Organic Materials (Chapter 5) Polymers, by Oscar Sisman, William W. Parkinson, and C. Daniel Bopp.
- 5.2 Physical Testing of Rubbers by J.R. Scott (Page 90-103).
- ✓ 5.3 Quality Control & Reliability Handbook (Interim) H 108, April 1960.
- 5.4 Science & Technology of Rubber by Frederick R. Eirich (American Press), N.Y. (1978).
- 5.5 Polymer Blends and Composites by J.A. Manson and L.H. Sperling Plenum Press, NY (1976).
- 5.6 Industrial Seal Technology by H. Hugobuchter, John Wiley & Sons, New York (1978).

Note: Extensive numbers of literature from different manufacturers have been obtained. Additional data would be available by request from ITT Grinnell Seal Study File.

Reference 5

ASME Boiler and Pressure Vessel Code, Section III,
Division 1, Subsection NF.

Reference 6

EPRI, "A Review of Equipment Aging Theory and Technology",
Report EPRI NP-1558, September 1980.

NATIONAL O-RINGS TECHNICAL REPORT

COMPOUND E50-70
 DATE APRIL 26, 1982
 PAGE 2 OF 2
 SPECIFICATIONS ASTM D2000
4CA715A25B44EA14F19G21 AND
3DA715A26B36EA14F19G21

| <u>ORIGINAL PHYSICAL PROPERTIES</u> | <u>LIMITS</u> <u>4CA715</u> | <u>LIMITS</u> <u>3DA715</u> | <u>E50-70</u> <u>RESULTS</u> |
|---|--------------------------------|--------------------------------|---------------------------------|
| Hardness, Shore A, points | 70±5 | 70±5 | 72 |
| Tensile Strength, psi, min. | 1500 | 1500 | 2300 |
| Elongation, %, min. | 200 | 200 | 240 |
| <u>AIR AGE, ASTM D865</u> | <u>A25</u> | | |
| | 70 HRS. @ 125°C(257°F) | | |
| Hardness Change, points, max. | +10 | | +2 |
| Tensile Change, %, max. | -20 | | -3.2 |
| Elongation Change, %, max. | -40 | | -9 |
| | <u>A26</u> | | |
| | 70 HRS. @ 150°C(302°F) | | |
| Hardness Change, points, max. | +10 | | +6 |
| Tensile Change, %, max. | -20 | | +1 |
| Elongation Change, %, max. | -20 | | -16 |
| <u>COMPRESSION SET, ASTM D395, METHOD B</u> | <u>B44</u> | | |
| | 70 HRS. @ 100°C(212°F) | | |
| % of Original Deflection, max. | 50 | | 14 |
| | <u>B36</u> | | |
| | 22 HRS. @ 150°C(302°F) | | |
| % of Original Deflection, max. | 25 | | 16 |
| <u>FLUID RESISTANCE, 70 HRS. @ 100°C(212°F)</u> <u>IN DISTILLED WATER, ASTM D471</u> | <u>EA14</u> | <u>EA14</u> | |
| Volume Change, % | ±5 | ±5 | +0.7 |
| <u>LOW TEMPERATURE BRITTLINESS, ASTM D2137,</u> <u>METHOD A</u> | <u>F19</u> | <u>F19</u> | |
| Must Be Non-Brittle @ | -55°C(-67°F) | -55°C(-67°F) | Passes |
| <u>TEAR RESISTANCE, ASTM D624</u> | <u>G21</u> | <u>G21</u> | |
| Die C, kN/m, min. | 26 | 17 | 28.9 |

NATIONAL O-RINGS TECHNICAL REPORT

COMPOUND E50-70
 DATE MARCH 31, 1982
 PAGE 2 OF 2
 SPECIFICATIONS TACO INC./UL 778
REQUIREMENTS

ORIGINAL PHYSICAL PROPERTIES

Hardness, Shore A, points
 Tensile Strength, psi. min.
 Elongation, %, min.

| <u>LIMITS</u> | <u>RESULTS</u> |
|---------------|----------------|
| 55 to 75 | 75 |
| 1500 | 2300 |
| 250 | 255 |

AIR AGE, 1440 HRS. @ 250°F

Tensile Strength Change, % of Original, min.
 Elongation Change, % of Original, min.

| | |
|----|--------|
| 75 | 102.61 |
| 65 | 74.51 |

COMPRESSION SET, 40% OF ORIGINAL THICKNESS, 24 HRS. @ 258°F

% Set, max.

| | |
|----|------|
| 15 | 11.8 |
|----|------|

ELONGATION SET, DUMBBELL STRETCHED FROM 1 INCH TO 2.5 INCHES, HELD FOR 2 MINUTES, AND MEASURED 2 MINUTES AFTER RELEASE

Acceptable Set, inches, max.

| | |
|-------|-------|
| .250" | .020" |
|-------|-------|

Laboratory Report No. 4034

RESULTS

| <u>Original Properties</u> | <u>Required</u> | <u>E-17018</u> |
|--|-----------------|----------------|
| Hardness, Shore "A" | 90 \pm 5 | 82 |
| Tensile Strength, psi | 1200 min. | 1957 |
| Elongation, % | 100 min. | 160 |
| <u>Wagner 21B, 70 Hrs. @ 257°F</u> | | |
| Hardness Change | -10 | -2 |
| Tensile Change, % | -10 max. | +35.4 |
| Elongation Change, % | -15 max. | 0 |
| Volume Change, % | 0 to +10 | +4.8 |
| <u>Dow Corning 50-4, 70 Hrs. @ 257°F</u> | | |
| Hardness Change | -10 | +1 |
| Tensile Change, % | -10 max. | +44.1 |
| Elongation Change, % | -15 max. | 0 |
| Volume Change, % | 0 to +10 | +0.7 |
| <u>Oven Aging, 70 Hrs. @ 257°F</u> | | |
| Hardness Change | 0 to +10 | +3 |
| Tensile Change, % | -10 max. | +11.1 |
| Elongation Change, % | -20 max. | -6.3 |
| <u>Compression Set, 22 Hrs. @ 257°F</u> | | |
| Plied Discs, % Set | 20 max. | 3.8 |
| % Recovery | 95 min. | 99 |
| <u>Low Temperature, 5 Hrs. @ -65°F</u> | | |
| Flexible | Pass | o.k. |

Acushnet Co.
P. M. Beattie

ITT GRINNELL CORPORATION
PRODUCT DEVELOPMENT
HANGER DIVISION

RADIATION AND ENVIRONMENTAL TEST OF SEAL AND FLUID MATERIALS
FOR SNUBBERS

Revision 1 Approval [Signature] Date 7.23-77
Dept. Mgr.

FOR REFERENCE ONLY

Report No. PHD-5347-2R Rev. 1

Prepared by F. Vozza Date 10/3/75
Prod. Engr.

Approved by [Signature] Date 10/3/75
Sec. Mgr.

Approved by E.R. Holmes Date 10/3/75
Dept. Mgr.

This report supersedes Report No. PHD-5347-1R, "Radiation Capacity of Snubber Seal Materials at Davis Besse Nuclear Power Station Unit 1" dated 7-29-75. This report contains data previously presented, with the addition of temperature and humidity data on seal material after irradiation and temperature, viscosity, and flash and flame point data on hydraulic fluid. Data previously presented is slightly modified as a result of review of collected data and calculations. These modifications are minor and do not reflect significant changes in results previously reported. There is also a change in method of identification of spacers used to determine precompression of seal material.

Appended to this report is report no. PHD-7569-1 Rev. 1 which tests four additional seal materials for radiation and environmental acceptability.

RESULTS AND CONCLUSIONS

Below is tabulated summary of results obtained on seal materials after exposure to a total integrated radiation dose of 3×10^7 Rads. Tabulation shows percent change in durometer, tensile strength, and compression set.

| <u>Compound</u> | <u>Durometer Average % Change</u> | <u>Tensile Strength Average % Change</u> | <u>Average Compression Set - % of Initial Compression</u> |
|---------------------------|---|--|---|
| National E-50 | +2.4 | -23.2 | 51.9 |
| Acushnet E-17018 | -1.8 | -41.5 | 46.4 |
| Parker E740-75 | +7.8 | -20.3 | 54.8 |
| Parker E692-75 | +5.9 | - 4.7 | 56.4 |
| Salisbury 80154 | +4.8 | - 3.2 | 53.3 |
| Minnesota 559EQ | +7.6 | - 4.8 | 71.6 |
| Manteline 70 Duro EPDM | Not Tested | -19.3 | 68.3 |
| Parker E515-80 | +4.7 | -11.3 | 70.0 |

Samples of the above materials after having been exposed to irradiation, were then subjected to 100% steam at 268°F for a period of 72 hours. Below is a tabulated summary of results obtained after this exposure. These results are based on original material properties.

| <u>Compound</u> | <u>Durometer Average % Change</u> | <u>Average Compression Set - % of Initial Compression</u> |
|-----------------|---|---|
| National E-50 | -9.6 | 52.5 |

| <u>Compound</u> | <u>Durometer Average % Change</u> | <u>Average Compression Set - % of Initial Compression</u> |
|------------------------|---|---|
| Acushnet E-17018 | -1.2 | 49.5 |
| Parker E740-75 | + .59 | 58.0 |
| Parker E692-75 | -1.8 | 58.5 |
| Salisbury 80154 | +6.0 | 70.8 |
| Minnesota 559EQ | 0.0 | 77.0 |
| Mantaline 70 Duro EPDM | Not Tested | 89.4 |
| Parker E515-80 | -4.1 | 75.1 |

Data from which the above were obtained, are included in Appendix I of this report.

Changes in durometer are not significant. Changes in tensile strength due to irradiation, can be classified on the average as moderate. Change in compression set can be classified as moderate to appreciable in some cases, however, sufficient resiliency is maintained in all cases to provide adequate sealing. It is noted that the Mantaline seals, which show the greatest degree of compression set, are static seals. In this application, compression set is not as significant a factor as would be in a dynamic seal.

Use of the above compounds are as follows:

- 1) At Snubber Valve Ports: National Seal Division
Federal Mogul Compound No. E-50, Acushnet E-17018,
Parker E740-75, Parker E692-75
- 2) Cylinder Piston Seals: W. H. Salisbury & Co.
Compound No. 80154

- 3) Rod Seal & Rod Wiper: Minnesota Rubber Co.
Compound No. 559EQ
- 4) Cylinder Tube to Head Seals: Mantaline Corporation
70 Durometer EPDM Cord Stock
- 5) Valve Adjustor Seals: Parker E515-80, Parker E740-75

Documentation on method and level of radiation exposure to seals is included in Appendix I of this report, page 36 and 37. (Code B)

After exposure to 3×10^7 Rads, samples of the hydraulic fluid exhibited a slight increase in viscosity. This increase was no more than would be produced by a 13° temperature drop. Fluid specimens, which did not contain hydraulic seal samples, experienced slightly more change in viscosity than fluid specimens in which seal samples had been immersed during radiation.

Maximum viscosity after exposure is roughly the same as the high limit of normal production viscosity.

Hydraulic fluid is considered suitable for continued use after exposure to 3×10^7 Rads and the presence of seal material does not adversely affect fluid properties.

Samples of fluid which had been exposed to maximum radiation (4.5×10^7) were subjected to flash point and fire point tests with the following results:

Flash Point = 615°F

Fire Point = or greater 720°F

PURPOSE

The purpose of these tests is to demonstrate the ability

PURPOSE (cont'd)

of seal and fluid material used in ITT Grinnell Corporation's Hydraulic Snubbers to meet the requirements of nuclear power plant applications.

PROCEDURE-SEAL IRRADIATION

Test specimens for all molded seals were O-Rings in ARP568-212 size. Test specimens for extruded seals were cut from pieces of the actual extruded stock. Specimens were tested for compression set, change in tensile strength, and change in durometer. The extruded stock was too small in cross-section to permit a meaningful durometer measurement and so only compression set and tensile strength were measured for these specimens.

Compression set indicates the extent to which squeeze initially applied by the gland to the seal is lost as the seal ages. It is measured by compressing a specimen by a given amount (to 75% of its initial thickness for this test); ageing the seal in this compressed state; and then measuring the free thickness of the seal after ageing. The difference between initial and final thickness is expressed as a percent of initial squeeze.

To test for compression set, a test fixture was made for each specimen. The fixture consisted of a series of steel plates ground flat separated by a spacer ground to a predetermined dimension to assure 25% compression. The complete assembly

PROCEDURE-SEAL IRRADIATION (cont'd)

was held together by a bolt running through the center (see Figure 1). The initial thickness of each compression set test specimen was measured at three locations around the O-Ring. The spacer for the test fixture was then ground to give exactly 25% squeeze for the specimen. Specimens were compressed and placed in the hydraulic fluid immediately prior to irradiation and were removed from the fluid and the compression relieved immediately following irradiation. Specimens were exposed to gamma radiation at a rate of .75 Megarads per hour for a period of 40 hours.

Durometer and tensile strength were measured with a separate set of specimens which were not compressed. First a durometer measurement was made, then the O-Ring was cut and mounted in a tensile tester.

Two specimens were used to determine initial tensile strength; another two specimens were used to measure durometer and tensile strength after irradiation; and a third pair of specimens were used to measure compression set.

Tensile strength measurements were made using a 0 - 250 lb. range Scott tensile tester. Durometer measurements were made with a Rex Model A Shore A durometer tester.

PROCEDURE-SEAL TEMPERATURE/STEAM EXPOSURE

After measurements were taken, the specimens used to measure compression set were remounted in the fixture of Figure 1.

PROCEDURE-SEAL TEMPERATURE/STEAM EXPOSURE (cont'd)

The complete assembly was installed in a test chamber as shown in Figure 2. Approximately three inches of water was put into the test chamber and then the complete chamber was placed in a power-o-matic mechanical convection oven. Temperature was determined and monitored for a period of 72 hours using a combination of Type J Thermocouple and Leeds-Northrup Potentiometer Model No. 8693-2. After completion of test, specimens were again measured for durometer and compression set as described in previous procedure.

PROCEDURE-FLUID IRRADIATION

A gallon of fluid was drawn from the production supply at the ITT Grinnell Hanger Division Plant in Warren, Ohio. This supply of fluid had been mixed with blue dye in accordance with normal production procedures. Identity and lot numbers of the fluid and of the dye are recorded in the Data Sheets.

This gallon sample was divided into several specimen containers. One, a small glass vial, contained only hydraulic fluid; a second, a polysulfone tube, contained hydraulic fluid, a steel test fixture, and 40 ethylene-propylene O-Rings. Both of these containers were irradiated to 3×10^7 Rads. After irradiation, fluid from these two containers and a fresh specimen from the gallon sample were

PROCEDURE-FLUID IRRADIATION (cont'd)

placed in polyethylene bottles and sent to the General Electric Silicone Products Department for testing. Test data was transmitted to the ITT Grinnell Corporation for this report.

BY N.E.W. DATE 7-29-75SUBJECT SEAL MATERIALSHEET NO. 1 OF 1CHKD. BY RAE DATE 7-29-75IRRADIATION TEST FIXTUREPROJECT NO. PHD-5347

Report No.

PHD-5347-2R




FIG. 1

BY R.D.D. DATE 10-1-75 SUBJECT STEAM TEST CHAMBER -

SHEET NO. 1 OF 1

CHKD: BY F.M. DATE 10-2-75

SEALS

PROJECT NO. PHD-534

PHD-5347-2R

1/4 BRASS MPT
PETCOCK

1x 1/4 RED
BUSH'G

2x1 RED
BUSH'G

3x2 RED
BUSH'G

1/8" THRU HOLE

3" C.I. PIPE
CPLG

3" SCH 40
BLK. STL PIPE


OUTLINE
O-RING
TEST FIXTURE

3" STL PIPE
CPLG

1/4 MPT BRASS
PETCOCK

4 1/2" SQ x
1/8" THK IP
BASE

FIG. #2
- 10 -



TEST DATA

TEST REPORT FORM - SEAL MATERIAL IRRADIATIONInitial Data

Specimen Type and Size: O-RING ARP 568-212
Molder: NATIONAL SEAL DIV., FEDERAL MOGUL Compound No. 250
Batch No. 47376 Cure Date 4-27-74
Certificate of Compliance BEARINGS INC., CLEVELAND, OHIO No. 102668

Durometer-Shore A: 83 83 81 82
Tensile Strgth-PSI 1746 1696
Irrad. Test Ident 3 5

Specimen Ident ...
Thickness: $T_{01} = .138$ $T_{02} = .139$ $T_{03} = .138$
 $\bar{T}_0 = .1383$ $.75 \bar{T}_0 = .104$
Fixture Dimension: $T = .1034$ Ident 103 Container Ident B

Specimen Ident
Thickness: $T_{01} = .139$ $T_{02} = .140$ $T_{03} = .140$
 $\bar{T}_0 = .1396$ $.75 \bar{T}_0 = .1047$
Fixture Dimension: $T = .1052$ Ident 105 Container Ident B

Specimen Ident _____
Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ $.75 \bar{T}_0 =$ _____
Fixture Dimension: $T =$ _____ Ident _____ Container Ident _____

Specimen Ident _____
Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ $.75 \bar{T}_0 =$ _____
Fixture Dimension: $T =$ _____ Ident _____ Container Ident _____

Specimen Ident _____
Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ $.75 \bar{T}_0 =$ _____
Fixture Dimension: $T =$ _____ Ident _____ Container Ident _____

Specimen Ident _____
Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ $.75 \bar{T}_0 =$ _____
Fixture Dimension: $T =$ _____ Ident _____ Container Ident _____

Signature of Test Supervisor Frank J. [Signature] Date 9/24/75

AFTER IRRADIATION

Radiation Type GAMA
 Radiation Dose 3×10^7
 Specimen Ident 3 5
 Durometer-Shore A: 85 85
 Tensile Strgth-PSI 1239 1404

Specimen Ident ... Radiation Dose 3×10^7
 Thickness: $T_{11} = .1203$ $T_{12} = .1192$ $T_{13} = .1185$
 $\bar{T}_1 = .1193$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} = 54.9\%$

Specimen Ident
 Thickness: $T_{11} = .1230$ $T_{12} = .1223$ $T_{13} = .1223$
 $\bar{T}_1 = .1225$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} = 48.9\%$

Specimen Ident _____ Radiation Dose _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____

Specimen Ident _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____

Specimen Ident _____ Radiation Dose _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____

Specimen Ident _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____

Signature of Test Supervisor

Date

9/24/75

AFTER IRRADIATION
AFTER STEAM

Radiation Type GAMARadiation Dose 3×10^7 Specimen Ident 3 5 _____Durometer-Shore A: 76 74 _____

Tensile Strgth-PSI _____

Specimen Ident ...Radiation Dose 3×10^7 Thickness: $T_{11} = .119$ $T_{12} = .1196$ $T_{13} = .1188$ $\bar{T}_1 = .1191$ Compression Set: $\bar{T}_0 - \bar{T}_1 = 55\%$ $\bar{T}_0 - T$ Specimen IdentThickness: $T_{11} = .1228$ $T_{12} = .1221$ $T_{13} = .1221$ $\bar{T}_1 = .1223$ Compression Set: $\bar{T}_0 - \bar{T}_1 = 50\%$ $\bar{T}_0 - T$

Specimen Ident _____

Radiation Dose _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____ $\bar{T}_1 =$ _____ Compression Set: $\bar{T}_0 - \bar{T}_1 =$ _____ $\bar{T}_0 - T$

Specimen Ident _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____ $\bar{T}_1 =$ _____ Compression Set: $\bar{T}_0 - \bar{T}_1 =$ _____ $\bar{T}_0 - T$

Specimen Ident _____

Radiation Dose _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____ $\bar{T}_1 =$ _____ Compression Set: $\bar{T}_0 - \bar{T}_1 =$ _____ $\bar{T}_0 - T$

Specimen Ident _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____ $\bar{T}_1 =$ _____ Compression Set: $\bar{T}_0 - \bar{T}_1 =$ _____ $\bar{T}_0 - T$ Signature of Test Supervisor Frank MeraDate 9/24/75

TEST REPORT FORM - SEAL MATERIAL IRRADIATIONInitial Data

Specimen Type and Size: O-RING ARP 568-212
Molder: ACUSHNET RUBBER Co. Compound No. E-17018
Batch No. 41 Cure Date 2/2/75
Certificate of Compliance J. ROYAL Co.

Durometer-Shore A: 84 83 81 84
Tensile Strgth-PSI 1704 1981
Irrad. Test Ident A B

Specimen Ident 1+11-1+
Thickness: $T_{01} = .140$ $T_{02} = .140$ $T_{03} = .140$
 $\bar{T}_0 = .140$.75 $\bar{T}_0 = .105$
Fixture Dimension: $T = .105$ Ident .105 Container Ident B

Specimen Ident 1+11-1+
Thickness: $T_{01} = .140$ $T_{02} = .140$ $T_{03} = .140$
 $\bar{T}_0 = .140$.75 $\bar{T}_0 = .105$
Fixture Dimension: $T = .105$ Ident 105 Container Ident B

Specimen Ident _____
Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ .75 $\bar{T}_0 =$ _____
Fixture Dimension: $T =$ _____ Ident _____ Container Ident _____

Specimen Ident _____
Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ .75 $\bar{T}_0 =$ _____
Fixture Dimension: $T =$ _____ Ident _____ Container Ident _____

Specimen Ident _____
Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ .75 $\bar{T}_0 =$ _____
Fixture Dimension: $T =$ _____ Ident _____ Container Ident _____

Specimen Ident _____
Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ .75 $\bar{T}_0 =$ _____
Fixture Dimension: $T =$ _____ Ident _____ Container Ident _____

Signature of Test Supervisor [Signature] Date 9/24/75

AFTER IRRADIATIONRadiation Type GAMARadiation Dose 3×10^7 Specimen Ident A BDurometer-Shore A: 81 87Tensile Strgth-PSI 1085 1070Specimen Ident 1+11-1+Radiation Dose 3×10^7 Thickness: $T_{11} = .124$ $T_{12} = .124$ $T_{13} = .124$ $\bar{T}_1 = .124$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} = 45.97\%$ $\bar{T}_0 - T$ Specimen Ident 1+1Thickness: $T_{11} = .1235$ $T_{12} = .124$ $T_{13} = .1238$ $\bar{T}_1 = .1237$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} = 46.83\%$ $\bar{T}_0 - T$

Specimen Ident _____

Radiation Dose _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____ $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____ $\bar{T}_0 - T$

Specimen Ident _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____ $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____ $\bar{T}_0 - T$

Specimen Ident _____

Radiation Dose _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____ $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____ $\bar{T}_0 - T$

Specimen Ident _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____ $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____ $\bar{T}_0 - T$ Signature of Test Supervisor Frank SpaceDate 9/24/75

AFTER IRRADIATIONAFTER STEAM

Radiation Type GAMA
 Radiation Dose 3×10^7
 Specimen Ident A B _____
 Durometer-Shore A: 81 82 _____
 Tensile Strgth-PSI _____

Specimen Ident 1+1-1+ Radiation Dose 3×10^7
 Thickness: $T_{11} = .1232$ $T_{12} = .1227$ $T_{13} = .1227$
 $\bar{T}_1 = .1228$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} = 49\%$

Specimen Ident 1+1
 Thickness: $T_{11} = .1226$ $T_{12} = .1226$ $T_{13} = .1226$
 $\bar{T}_1 = .1226$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} = 50\%$

Specimen Ident _____ Radiation Dose _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____

Specimen Ident _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____

Specimen Ident _____ Radiation Dose _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____

Specimen Ident _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____

Signature of Test Supervisor Frank Moore Date 9/24/75
 - 17 -

TEST REPORT FORM - SEAL MATERIAL IRRADIATIONInitial Data

Specimen Type and Size: O-RING ARP 568-212
 Molder: PARKER SEAL Co. Compound No. E740-75
 Batch No. 165326 Cure Date 10 75
 Certificate of Compliance _____

Durometer-Shore A: 63 84 _____ 85 84
 Tensile Strgth-PSI 1263 1289 _____
 Irrad. Test Ident _____ JJ VV

Specimen Ident 11+
 Thickness: $T_{01} = .140$ $T_{02} = .140$ $T_{03} = .141$
 $\bar{T}_0 = .1403$ $.75 \bar{T}_0 = .1052$
 Fixture Dimension: $T = .1053$ Ident 105 Container Ident B

Specimen Ident 101
 Thickness: $T_{01} = .142$ $T_{02} = .143$ $T_{03} = .143$
 $\bar{T}_0 = .1426$ $.75 \bar{T}_0 = .107$
 Fixture Dimension: $T = .1073$ Ident 107 Container Ident B

Speciment Ident _____
 Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ $.75 \bar{T}_0 =$ _____
 Fixture Dimension: $T =$ _____ Ident _____ Container Ident _____

Specimen Ident _____
 Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ $.75 \bar{T}_0 =$ _____
 Fixture Dimension: $T =$ _____ Ident _____ Container Ident _____

Specimen Ident _____
 Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ $.75 \bar{T}_0 =$ _____
 Fixture Dimension: $T =$ _____ Ident _____ Container Ident _____

Specimen Ident _____
 Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ $.75 \bar{T}_0 =$ _____
 Fixture Dimension: $T =$ _____ Ident _____ Container Ident _____

Signature of Test Supervisor Frank Meca Date 9/24/75

AFTER IRRADIATION

Radiation Type GAMA
 Radiation Dose 3×10^7
 Specimen Ident JJ VV _____
 Durometer-Shore A: 91 89 _____
 Tensile Strgth-PSI 947 1086 _____

Specimen Ident 11+ Radiation Dose 3×10^7
 Thickness: $T_{11} = .1210$ $T_{12} = .1205$ $T_{13} = .1210$
 $\bar{T}_1 = .1208$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} = 55.5\%$

Specimen Ident 101
 Thickness: $T_{11} = .1232$ $T_{12} = .1235$ $T_{13} = .1230$
 $\bar{T}_1 = .1232$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} = 54\%$

Specimen Ident _____ Radiation Dose _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____

Specimen Ident _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____

Specimen Ident _____ Radiation Dose _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____

Specimen Ident _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____

Signature of Test Supervisor Frank Moore Date 9/24/75
 - 19 -

AFTER IRRADIATION

AFTER STEAM

Radiation Type GAMA
 Radiation Dose 3×10^7
 Specimen Ident JJ VV _____
 Durometer-Shore A: 85 83 _____
 Tensile Strgth-PSI _____

Specimen Ident 11+ Radiation Dose 3×10^7
 Thickness: $T_{11} = .1203$ $T_{12} = .1200$ $T_{13} = .1204$
 $\bar{T}_1 = .1202$ Compression Set: $\bar{T}_0 - \bar{T}_1 = 57\%$
 $\bar{T}_0 - T$

Specimen Ident 101
 Thickness: $T_{11} = .1216$ $T_{12} = .1220$ $T_{13} = .1220$
 $\bar{T}_1 = .1218$ Compression Set: $\bar{T}_0 - \bar{T}_1 = 58.9\%$
 $\bar{T}_0 - T$

Specimen Ident _____ Radiation Dose _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\bar{T}_0 - \bar{T}_1 =$ _____
 $\bar{T}_0 - T$

Specimen Ident _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\bar{T}_0 - \bar{T}_1 =$ _____
 $\bar{T}_0 - T$

Specimen Ident _____ Radiation Dose _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\bar{T}_0 - \bar{T}_1 =$ _____
 $\bar{T}_0 - T$

Specimen Ident _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\bar{T}_0 - \bar{T}_1 =$ _____
 $\bar{T}_0 - T$

Signature of Test Supervisor Frank [Signature] Date 9/24/75
 20 -

TEST REPORT FORM - SEAL MATERIAL IRRADIATION

Initial Data

Specimen Type and Size: O-RING ARP 568-212
Molder: PARKER SEAL CO. Compound No. E 692-75
Batch No. 165326 Cure Date 2 Q 75
Certificate of Compliance _____

Durometer-Shore A: 84 84 _____ 85 85
Tensile Strgth-PSI 1098 1217
Irrad. Test Ident _____ DD NN

Specimen Ident +011
Thickness: $T_{01} = .142$ $T_{02} = .141$ $T_{03} = .142$
 $\bar{T}_0 = .1416$.75 $\bar{T}_0 = .1062$
Fixture Dimension: $T = .1062$ Ident 106 Container Ident B

Specimen Ident 1+0
Thickness: $T_{01} = .142$ $T_{02} = .142$ $T_{03} = .141$
 $\bar{T}_0 = .1416$.75 $\bar{T}_0 = .1062$
Fixture Dimension: $T = .1068$ Ident 1066 Container Ident B

Specimen Ident _____
Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ .75 $\bar{T}_0 =$ _____
Fixture Dimension: $T =$ _____ Ident _____ Container Ident _____

Specimen Ident _____
Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ .75 $\bar{T}_0 =$ _____
Fixture Dimension: $T =$ _____ Ident _____ Container Ident _____

Specimen Ident _____
Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ .75 $\bar{T}_0 =$ _____
Fixture Dimension: $T =$ _____ Ident _____ Container Ident _____

Specimen Ident _____
Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ .75 $\bar{T}_0 =$ _____
Fixture Dimension: $T =$ _____ Ident _____ Container Ident _____

Signature of Test Supervisor *Frank Moore* Date 9/24/75

AFTER IRRADIATION

Radiation Type GAMA
 Radiation Dose 3×10^7
 Specimen Ident DD NN
 Durometer-Shore A: 90 90
 Tensile Strgth-PSI 1086 1120

Specimen Ident +011 Radiation Dose 3×10^7
 Thickness: $T_{11} = .1226$ $T_{12} = .1215$ $T_{13} = .1215$
 $\bar{T}_1 = .1218$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} = 55.9\%$

Specimen Ident 1+0
 Thickness: $T_{11} = .1225$ $T_{12} = .1220$ $T_{13} = .1210$
 $\bar{T}_1 = .1218$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} = 56.8\%$

Specimen Ident _____ Radiation Dose _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____

Specimen Ident _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____

Specimen Ident _____ Radiation Dose _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____

Specimen Ident _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____

Signature of Test Supervisor Frank Massa Date 9/24/75

AFTER IRRADIATION
AFTER STEAM

Radiation Type GAMA
 Radiation Dose 3×10^7
 Specimen Ident DD NN
 Durometer-Shore A: 83 84
 Tensile Strgth-PSI -

Specimen Ident +011 Radiation Dose 3×10^7
 Thickness: $T_{11} = .1204$ $T_{12} = .1209$ $T_{13} = .1209$
 $\bar{T}_1 = .1207$ Compression Set: $\bar{T}_0 - \bar{T}_1 = 59\%$
 $\bar{T}_0 - T$

Specimen Ident 1+0
 Thickness: $T_{11} = .1212$ $T_{12} = .1213$ $T_{13} = .1212$
 $\bar{T}_1 = .1212$ Compression Set: $\bar{T}_0 - \bar{T}_1 = 58\%$
 $\bar{T}_0 - T$

Specimen Ident _____ Radiation Dose _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\bar{T}_0 - \bar{T}_1 =$ _____
 $\bar{T}_0 - T$

Specimen Ident _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\bar{T}_0 - \bar{T}_1 =$ _____
 $\bar{T}_0 - T$

Specimen Ident _____ Radiation Dose _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\bar{T}_0 - \bar{T}_1 =$ _____
 $\bar{T}_0 - T$

Specimen Ident _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\bar{T}_0 - \bar{T}_1 =$ _____
 $\bar{T}_0 - T$

Signature of Test Supervisor Frank Moore Date 9/24/75
 - 23 -

TEST REPORT FORM - SEAL MATERIAL IRRADIATION

Initial Data

Specimen Type and Size: O-RING ARP 568-212
 Molder: W.H. SALISBURY CO. Compound No. 80154
 Batch No. N/A Cure Date 10 75
 Certificate of Compliance ORDER No. 51897-0A

Durometer-Shore A: 83 84 83 84
 Tensile Strgth-PSI 1449 268
 Irrad. Test Ident II PP

Specimen Ident ++111
 Thickness: $T_{01} = .142$ $T_{02} = .142$ $T_{03} = .141$
 $\bar{T}_0 = .1416$.75 $\bar{T}_0 = .1062$
 Fixture Dimension: $T = .106$ Ident 106 Container Ident B

Specimen Ident ++
 Thickness: $T_{01} = .142$ $T_{02} = .142$ $T_{03} = .142$
 $\bar{T}_0 = .142$.75 $\bar{T}_0 = .1065$
 Fixture Dimension: $T = .106$ Ident 106 Container Ident B

Specimen Ident _____
 Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ .75 $\bar{T}_0 =$ _____
 Fixture Dimension: $T =$ _____ Ident _____ Container Ident _____

Specimen Ident _____
 Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ .75 $\bar{T}_0 =$ _____
 Fixture Dimension: $T =$ _____ Ident _____ Container Ident _____

Specimen Ident _____
 Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ .75 $\bar{T}_0 =$ _____
 Fixture Dimension: $T =$ _____ Ident _____ Container Ident _____

Specimen Ident _____
 Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ .75 $\bar{T}_0 =$ _____
 Fixture Dimension: $T =$ _____ Ident _____ Container Ident _____

Signature of Test Supervisor Frank Mera Date 9/24/75

AFTER IRRADIATION

Radiation Type GAMA
 Radiation Dose 3×10^7
 Specimen Ident II PP _____
 Durometer-Shore A: 88 87 _____
 Tensile Strgth-PSI 468 1252 _____

Specimen Ident ++111 Radiation Dose 3×10^7
 Thickness: $T_{11} = .1229$ $T_{12} = .1232$ $T_{13} = .1225$
 $\bar{T}_1 = .1228$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} = 52.8\%$

Specimen Ident ++
 Thickness: $T_{11} = .1232$ $T_{12} = .1222$ $T_{13} = .1225$
 $\bar{T}_1 = .1226$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} = 53.8\%$

Specimen Ident _____ Radiation Dose _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____

Specimen Ident _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____

Specimen Ident _____ Radiation Dose _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____

Specimen Ident _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____

Signature of Test Supervisor

Frank Spica

Date

9/20/75

AFTER IRRADIATIONAFTER STEAM

Radiation Type GAMA
 Radiation Dose 3×10^7
 Specimen Ident II PP
 Durometer-Shore A: 80 77
 Tensile Strgth-PSI _____

Specimen Ident ++111 Radiation Dose 3×10^7
 Thickness: $T_{11} = .1162$ $T_{12} = .1162$ $T_{13} = .1162$
 $\bar{T}_1 = .1162$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} = 71\%$

Specimen Ident ++
 Thickness: $T_{11} = .1166$ $T_{12} = .1166$ $T_{13} = .1166$
 $\bar{T}_1 = .1166$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} = 70.5\%$

Specimen Ident _____ Radiation Dose _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____

Specimen Ident _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____

Specimen Ident _____ Radiation Dose _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____

Specimen Ident _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____

Signature of Test Supervisor

Frank J. [Signature] Date 9/20/75
 - 26 -

TEST REPORT FORM - SEAL MATERIAL IRRADIATION

Initial Data

Specimen Type and Size: O-RING ARP 568-212
 Molder: MINNESOTA RUBBER CO. Compound No. 559EQ
 Batch No. F.O. No. G 2915 Cure Date 4th QUARTER 1974
 Certificate of Compliance MINNESOTA INVOICE No. 73580

Durometer-Shore A: 85 84 85 86
 Tensile Strgth-PSI 1416 1186
 Irrad. Test Ident X S

Specimen Ident 00111
 Thickness: $T_{01} = .139$ $T_{02} = .138$ $T_{03} = .140$
 $\bar{T}_0 = .139$ $.75 \bar{T}_0 = 1042$
 Fixture Dimension: $T = .104$ Ident 104 Container Ident B

Specimen Ident 00
 Thickness: $T_{01} = .139$ $T_{02} = .139$ $T_{03} = .138$
 $\bar{T}_0 = .1386$ $.75 \bar{T}_0 = .104$
 Fixture Dimension: $T = .1042$ Ident 104 Container Ident B

Specimen Ident _____
 Thickness: $T_{01} =$ $T_{02} =$ $T_{03} =$
 $\bar{T}_0 =$ $.75 \bar{T}_0 =$
 Fixture Dimension: $T =$ Ident _____ Container Ident _____

Specimen Ident _____
 Thickness: $T_{01} =$ $T_{02} =$ $T_{03} =$
 $\bar{T}_0 =$ $.75 \bar{T}_0 =$
 Fixture Dimension: $T =$ Ident _____ Container Ident _____

Specimen Ident _____
 Thickness: $T_{01} =$ $T_{02} =$ $T_{03} =$
 $\bar{T}_0 =$ $.75 \bar{T}_0 =$
 Fixture Dimension: $T =$ Ident _____ Container Ident _____

Specimen Ident _____
 Thickness: $T_{01} =$ $T_{02} =$ $T_{03} =$
 $\bar{T}_0 =$ $.75 \bar{T}_0 =$
 Fixture Dimension: $T =$ Ident _____ Container Ident _____

Signature of Test Supervisor Frank Moore Date 9/24/75

AFTER IRRADIATIONRadiation Type GAMARadiation Dose 3×10^7 Specimen Ident X SDurometer-Shore A: 93 91Tensile Strgth-PSI 1239 1239Specimen Ident 00111Radiation Dose 3×10^7 Thickness: $T_{11} = .1125$ $T_{12} = .113$ $T_{13} = .113$ $\bar{T}_1 = .1128$ Compression Set: $\bar{T}_0 - \bar{T}_1 = 72.24\%$ $\bar{T}_0 - T$ Specimen Ident 00Thickness: $T_{11} = .114$ $T_{12} = .114$ $T_{13} = .1145$ $\bar{T}_1 = .1141$ Compression Set: $\bar{T}_0 - \bar{T}_1 = 71\%$ $\bar{T}_0 - T$

Specimen Ident _____

Radiation Dose _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____ $\bar{T}_1 =$ _____ Compression Set: $\bar{T}_0 - \bar{T}_1 =$ _____ $\bar{T}_0 - T$

Specimen Ident _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____ $\bar{T}_1 =$ _____ Compression Set: $\bar{T}_0 - \bar{T}_1 =$ _____ $\bar{T}_0 - T$

Specimen Ident _____

Radiation Dose _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____ $\bar{T}_1 =$ _____ Compression Set: $\bar{T}_0 - \bar{T}_1 =$ _____ $\bar{T}_0 - T$

Specimen Ident _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____ $\bar{T}_1 =$ _____ Compression Set: $\bar{T}_0 - \bar{T}_1 =$ _____ $\bar{T}_0 - T$ Signature of Test Supervisor Frank M. SosaDate 9/24/75

AFTER IRRADIATION
AFTER STEAM

Radiation Type GAMA
 Radiation Dose 3×10^7
 Specimen Ident X S
 Durometer-Shore A: 85 86
 Tensile Strgth-PSI _____

Specimen Ident 00111 Radiation Dose 3×10^7
 Thickness: $T_{11} = .1105$ $T_{12} = .1105$ $T_{13} = .1102$
 $\bar{T}_1 = .1104$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} = 79.04\%$

Specimen Ident 00
 Thickness: $T_{11} = .1126$ $T_{12} = .1128$ $T_{13} = .1128$
 $\bar{T}_1 = .1127$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} = 75\%$

Specimen Ident _____ Radiation Dose _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____

Specimen Ident _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____

Specimen Ident _____ Radiation Dose _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____

Specimen Ident _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____

Signature of Test Supervisor

Frank M. Sosa Date 9/24/75

TEST REPORT FORM - SEAL MATERIAL IRRADIATION

Page 1

Initial Data

Specimen Type and Size: CORD STOCK
 Molder: MANTALINE
 Batch No. N.A. Cure Date _____ Compound No. 70 DURO EPDM
 Certificate of Compliance _____

Durometer-Shore A: _____
 Tensile Strgth-PSI 1432 1527
 Irrad. Test Ident NOT TAGGED

Specimen Ident NEXT TO LAST
 Thickness: $T_{01} = .072$ $T_{02} = .072$ $T_{03} = .072$
 $\bar{T}_0 = .072$ $.75 \bar{T}_0 = .054$
 Fixture Dimension: $T = .0578$ Ident 057 Container Ident B

Specimen Ident LAST
 Thickness: $T_{01} = .073$ $T_{02} = .073$ $T_{03} = .073$
 $\bar{T}_0 = .073$ $.75 \bar{T}_0 = .0548$
 Fixture Dimension: $T = .0578$ Ident 057 Container Ident B

Specimen Ident _____
 Thickness: $T_{01} =$ $T_{02} =$ $T_{03} =$
 $\bar{T}_0 =$ $.75 \bar{T}_0 =$
 Fixture Dimension: $T =$ Ident _____ Container Ident _____

Specimen Ident _____
 Thickness: $T_{01} =$ $T_{02} =$ $T_{03} =$
 $\bar{T}_0 =$ $.75 \bar{T}_0 =$
 Fixture Dimension: $T =$ Ident _____ Container Ident _____

Specimen Ident _____
 Thickness: $T_{01} =$ $T_{02} =$ $T_{03} =$
 $\bar{T}_0 =$ $.75 \bar{T}_0 =$
 Fixture Dimension: $T =$ Ident _____ Container Ident _____

Specimen Ident _____
 Thickness: $T_{01} =$ $T_{02} =$ $T_{03} =$
 $\bar{T}_0 =$ $.75 \bar{T}_0 =$
 Fixture Dimension: $T =$ Ident _____ Container Ident _____

Signature of Test Supervisor Frank Nocco Date 9/24/75

AFTER IRRADIATION

Radiation Type GAMA
 Radiation Dose 3×10^7
 Specimen Ident - - - - -
 Durometer-Shore A: - - - - -
 Tensile Strgth-PSI 1194 - - - - -

Specimen Ident NEXT To LAST Radiation Dose 3×10^7
 Thickness: $T_{11} = .0623$ $T_{12} = .0627$ $T_{13} = .0627$
 $\bar{T}_1 = .0625$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} = 66.9\%$

Specimen Ident LAST
 Thickness: $T_{11} = .0623$ $T_{12} = .0627$ $T_{13} = .0623$
 $\bar{T}_1 = .0624$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} = 69.7\%$

Specimen Ident Radiation Dose
 Thickness: $T_{11} =$ $T_{12} =$ $T_{13} =$
 $\bar{T}_1 =$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$

Specimen Ident
 Thickness: $T_{11} =$ $T_{12} =$ $T_{13} =$
 $\bar{T}_1 =$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$

Specimen Ident Radiation Dose
 Thickness: $T_{11} =$ $T_{12} =$ $T_{13} =$
 $\bar{T}_1 =$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$

Specimen Ident
 Thickness: $T_{11} =$ $T_{12} =$ $T_{13} =$
 $\bar{T}_1 =$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$

Signature of Test Supervisor

Frank Mera

Date

9/24/75

AFTER IRRADIATIONAFTER STEAMRadiation Type GAMARadiation Dose 3×10^7 Specimen Ident Durometer-Shore A: Tensile Strgth-PSI Specimen Ident NEXT To LASTRadiation Dose 3×10^7 Thickness: $T_{11} = .0593$ $T_{12} = .0593$ $T_{13} = .0596$ $\bar{T}_1 = .0594$ Compression Set: $\bar{T}_0 - \bar{T}_1 = 88.7\%$ $\bar{T}_0 - T$ Specimen Ident LASTThickness: $T_{11} = .0592$ $T_{12} = .0597$ $T_{13} = .0592$ $\bar{T}_1 = .0593$ Compression Set: $\bar{T}_0 - \bar{T}_1 = 90.1\%$ $\bar{T}_0 - T$ Specimen Ident Radiation Dose Thickness: $T_{11} =$ $T_{12} =$ $T_{13} =$ $\bar{T}_1 =$ Compression Set: $\bar{T}_0 - \bar{T}_1 =$ $\bar{T}_0 - T$ Specimen Ident Thickness: $T_{11} =$ $T_{12} =$ $T_{13} =$ $\bar{T}_1 =$ Compression Set: $\bar{T}_0 - \bar{T}_1 =$ $\bar{T}_0 - T$ Specimen Ident Radiation Dose Thickness: $T_{11} =$ $T_{12} =$ $T_{13} =$ $\bar{T}_1 =$ Compression Set: $\bar{T}_0 - \bar{T}_1 =$ $\bar{T}_0 - T$ Specimen Ident Thickness: $T_{11} =$ $T_{12} =$ $T_{13} =$ $\bar{T}_1 =$ Compression Set: $\bar{T}_0 - \bar{T}_1 =$ $\bar{T}_0 - T$ Signature of Test Supervisor Frank MercaDate 9/24/75

TEST REPORT FORM - SEAL MATERIAL IRRADIATION

Initial Data

Specimen Type and Size: O-RING ARP 568-212
 Molder: PARKER SEAL Co. Compound No. E515-80
 Batch No. 163993 Cure Date 4 Q 74
 Certificate of Compliance SUPPLIED BY C.E. CONOVER & Co., INC., ASHLAND, MASS.

Durometer-Shore A: 85 84 85 85
 Tensile Strgth-PSI 1302 1263
 Irrad. Test Ident N O

Specimen Ident 30111
 Thickness: $T_{01} = .141$ $T_{02} = .142$ $T_{03} = .141$
 $\bar{T}_0 = .1413$ $.75 \bar{T}_0 = .106$
 Fixture Dimension: $T = .1062$ Ident 106 Container Ident B

Specimen Ident +
 Thickness: $T_{01} = .141$ $T_{02} = .142$ $T_{03} = .143$
 $\bar{T}_0 = .142$ $.75 \bar{T}_0 = .1065$
 Fixture Dimension: $T = .106$ Ident 106 Container Ident B

Specimen Ident _____
 Thickness: $T_{01} =$ $T_{02} =$ $T_{03} =$
 $\bar{T}_0 =$ $.75 \bar{T}_0 =$
 Fixture Dimension: $T =$ Ident _____ Container Ident _____

Specimen Ident _____
 Thickness: $T_{01} =$ $T_{02} =$ $T_{03} =$
 $\bar{T}_0 =$ $.75 \bar{T}_0 =$
 Fixture Dimension: $T =$ Ident _____ Container Ident _____

Specimen Ident _____
 Thickness: $T_{01} =$ $T_{02} =$ $T_{03} =$
 $\bar{T}_0 =$ $.75 \bar{T}_0 =$
 Fixture Dimension: $T =$ Ident _____ Container Ident _____

Specimen Ident _____
 Thickness: $T_{01} =$ $T_{02} =$ $T_{03} =$
 $\bar{T}_0 =$ $.75 \bar{T}_0 =$
 Fixture Dimension: $T =$ Ident _____ Container Ident _____

Signature of Test Supervisor

Frank [Signature] Date 9/24/75

AFTER IRRADIATION

Radiation Type GAMA
 Radiation Dose 3×10^7
 Specimen Ident N O
 Durometer-Shore A: 88 90
 Tensile Strgth-PSI 1121 1153

Specimen Ident 302111 Radiation Dose 3×10^7
 Thickness: $T_{11} = .1170$ $T_{12} = .1172$ $T_{13} = .1168$
 $\bar{T}_1 = .117$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} = 69\%$

Specimen Ident +
 Thickness: $T_{11} = .1179$ $T_{12} = .1159$ $T_{13} = .1163$
 $\bar{T}_1 = .1164$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} = 71\%$

Specimen Ident _____ Radiation Dose _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____

Specimen Ident _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____

Specimen Ident _____ Radiation Dose _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____

Specimen Ident _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$ _____

Signature of Test Supervisor

Frank Moore

Date

9/24/75

AFTER IRRADIATION
AFTER STEAM

Radiation Type GAMA
 Radiation Dose 3×10^7
 Specimen Ident N O
 Durometer-Shore A: 81 82
 Tensile Strgth-PSI 1

Specimen Ident 302111 Radiation Dose 3×10^7
 Thickness: $T_{11} = .1150$ $T_{12} = .1152$ $T_{13} = .1150$
 $\bar{T}_1 = .115$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} = 74.9\%$

Specimen Ident +
 Thickness: $T_{11} = .1148$ $T_{12} = .1148$ $T_{13} = .1153$
 $\bar{T}_1 =$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} = 75.2\%$

Specimen Ident _____ Radiation Dose _____
 Thickness: $T_{11} =$ $T_{12} =$ $T_{13} =$
 $\bar{T}_1 =$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$

Specimen Ident _____
 Thickness: $T_{11} =$ $T_{12} =$ $T_{13} =$
 $\bar{T}_1 =$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$

Specimen Ident _____ Radiation Dose _____
 Thickness: $T_{11} =$ $T_{12} =$ $T_{13} =$
 $\bar{T}_1 =$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$

Specimen Ident _____
 Thickness: $T_{11} =$ $T_{12} =$ $T_{13} =$
 $\bar{T}_1 =$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$

Signature of Test Supervisor

- 35 -

Date

9/24/75



RECEIVED
PIPE HANGING DIVISION
AUG 22 1975
PRODUCT DEVELOPMENT

August 19, 1975

Mr. Dan Feingold
ITT-Grinnell Corporation
260 W. Exchange Street
Providence, Rhode Island 02091

Dear Mr. Feingold:

This will summarize parameters pertinent to the irradiation of cylinder and capsule samples recently completed.

Samples were placed in a Cobalt-60 gamma field per the attached "Test Report Form", to accumulate doses as shown.

The samples were rotated and turned during exposure to obtain the dose distribution described. Irradiation was conducted in air at ambient temperature and pressure. Radiant heat from the source heated the samples somewhat, but the temperature did not exceed 110°F, as indicated by previous measurements on an oil solution in the same relative position.

Dosimetry was performed using a Victoreen Model 555 Integrating Dose Rate Meter and Probe. The unit was calibrated on January 15, 1974 by the Victoreen Instrument Company, using cobalt-60 and cesium-137 sources whose calibrations are traceable to the U.S. National Bureau of Standards. A copy of the calibration certificate is available. Backup dosimetry using a Red Perspex system confirmed the Victoreen readings.

Irradiation was completed on July 25, 1975.

Very truly yours,

George R. Dietz
Manager, Radiation Services

GRD:km

Attachment

Isomedix Inc. . 25 Eastmans Road, Parsippany, New Jersey (201) 887-4700
Mailing Address: Post Office Box 177, Parsippany, New Jersey 07054

CHICAGO DIVISION • 7828 Nagle Ave., Morton Grove, Illinois 60053 (312) 966-1160

TEST REPORT FORMSEAL MATERIAL IRRADIATION

| <u>Fixture Ident. No.</u> | <u>Dosimeter Reading (per hour)</u> | <u>Calculated Dose</u> | <u>Comments</u> |
|--|---|----------------------------|-------------------|
| <u>CODE A</u> | | | |
| 1 cylinder marked 1x10 ⁷ | .725 | 10.0 Mrad | 14 hr. exposure |
| 1 capsule marked 1x10 ⁷ | .715 | | |
| | .712 | | |
| | .716 | | |
| Ave. | .715 | | |
| <u>CODE B</u> | | | |
| 1 cylinder marked 3x10 ⁷ | .720 | 30.0 Mrad | 42 hr. exposure |
| 1 capsule marked 3x10 ⁷ | .710 | | |
| | .714 | | |
| | .715 | | |
| Ave. | .715 | | |
| <u>CODE C</u> | | | |
| 1 cylinder marked 5x10 ⁷ | .718 | 45.4 Mrad | 63.5 hr. exposure |
| 1 capsule marked 5x10 ⁷ | .716 | | |
| 1 cylinder marked 1x10 ⁸ | .712 | | |
| 1 capsule marked 2x10 ⁸ | .714 | | |
| Ave. | .715 | | |

Please indicate here or by separate report the method by which calculated dose is determined.

Using Red Perspex Dosimetry, a total dose for a period of time is determined. Divided by time, this yields a dose rate. Total dose is a function of dose rate times time. Dosimeters are placed on or in test items, and readings averaged when two or more dosimeters are in the same relative positions.

HYDRAULIC FLUID IRRADIATION
PRE-IRRADIATION TEST DATA SHEET

HYDRAULIC FLUID Manufacturer G.E. Silicore Products Dep't.

Designation SF 11.54175 centistokes @ 77F Lot No. EC 282-1

DYE Manufacturer American Cyanamid Co.

Designation CALCO Oil Blue V Lot No. ML1462

FORMULA 4 fl. oz. (powder) dye
mixed with 5.5 gal (440 lb) fluid

SPECIMEN CONTAINERS

Ident ORIGINAL

Contents Fresh fluid from sample

Ident 1

Contents Fluid only - no seals (container made of glass)

Ident 2

Contents Fluid, seals, steel fixtures (container made of polysulfone)

Page 6

HYDRAULIC FLUID IRRADIATION
POST-IRRADIATION TEST DATA SHEET

Radiation Type gamma

Radiation Dose 0 3×10^7 R 3×10^7 R

Specimen Ident ORIGINAL 1 2

Temperature

Viscosity

-30°F

8102 122.36 108.31

77°F

164 191 181

300°F

12.9 14.5 13.9


APPENDIX A

PHD-7569-1


Radiation and Environmental Test
Of Seal Materials for Snubbers


ITT GRINNELL CORP.
HANGER DIVISION
RD & E, SNUBBER SECTION

Radiation and Environmental Test
of Seal Materials for Snubbers

Revision 1 Approval  Date 7-23-77
Dept. Mgr.

Report No. PHD-7569-1 Rev. 1

Prepared by  Date 3-31-77
Sr. Engr.

Approved by  Date 4/14/77
Sect. Mgr.

Approved by  Date 4-15-77
Dept. Mgr.

This report complements Report No. PHD-5347-2R, "Radiation and Environmental Test of Seal and Fluid Materials for Snubbers" dated 10/3/75. This report contains data on seal material subjected to an integrated radiation dose of 3×10^7 rads plus a 72 hour elevated temperature, 100% steam environmental test. The seal materials of this report were not qualified in the above referenced report.

Purpose

The purpose of these tests is to demonstrate the ability of the tested seal materials to meet the requirements for usage in ITT Grinnell snubbers used in nuclear power plant applications.

Results

Table 1 below summarizes the results obtained on seal materials exposed to a total integrated radiation dose of 3×10^7 rads. while immersed in GE SF 1154 hydraulic fluid. The table shows percent change in durometer, tensile strength and compression set. Compression set samples were compressed to 75% of their initial thickness. The average compression set is the percentage of initial compression that remains after relief of compressive force. Data sheets for the individual seals are at the end of this report.

| TABLE I | | | |
|-------------------|---|--|---|
| <u>Compound</u> | <u>Durometer Average % Change</u> | <u>Tensile Strength Average % Change</u> | <u>Average Compression Set - % of Initial Compression</u> |
| Minnesota 559GT | 0 | 0 | 58. |
| Minnesota 560ND | + 11.2 | - 7.7* | 33. |
| Polyseal HK-471 | + 9.9 | -26.3 | 31. |
| Polyseal E2050-90 | + 4.4 | -38.8 | 41.5 |

* Only one tensile value was used in this average; the second reading appeared to be in error

The compression samples were again compressed to 75% of initial pre-radiation thickness and they, along with uncompressed samples, were subjected to an additional environment of 250°F, all steam for 72 hours. Table II below shows the tabulated results as change of durometer, change of tensile strength and compression set. Changes are measured from initial quantities.

TABLE II

| <u>Compound</u> | <u>Durometer Average % Change</u> | <u>Tensile Strength Average % Change</u> | <u>Average Compression Set -% of Initial Compression</u> |
|-------------------|---|--|---|
| Minnesota 559GT | + 2.24 | 0 | 56.7 |
| Minnesota 560ND | + 14 | - 14.5 | 36.8 |
| Polyseal HK471 | + 3.5 | - 33.2 | 30.9 |
| Polyseal E2050-90 | + 15.8 | - 37.6 | 40.5 |

Data sheets showing individual seal properties can be found at the end of this report.

Conclusions

Durometer - The change in durometer for all compounds is negligible and should not be a factor in seal operability or life.

Tensile Strength - The change in tensile strength of the Polyseal compounds (HK471 and E2050-90) is significant; however, tensile strength change should not effect seal operability or life.

Compression Set - Compression set is a measure of the recoverability of compounds from compression and thence a measure of the continued contact between seal and container. Of the quantities measured, compression set should give the greatest indication of operability after conditioning. While the compression sets measured are significant, it should be noted that all but one of the compounds recovers 60% of the initial compression and that compound Minnesota 559GT recovers 40%.

Comparison of compression sets of this testing with those of PHD-5347-2R shows that the new seal materials are at the low end of compression set, and hence should be acceptable for usage in ITT Grinnell snubbers.

Procedure - Seal Irradiation

Test specimens for all seals were O-rings in ARP568-212 size. Specimens were tested for compression set, change in tensile strength, and change in durometer.

Compression set indicates the extent to which squeeze initially applied by the gland to the seal is lost as the seal ages. It is measured by compressing a specimen by a given

Procedure - Seal Irradiation (cont'd)

amount (to 75% of its initial thickness for this test); ageing the seal in this compressed state; and then measuring the free thickness of the seal after ageing. The difference between initial and final thickness is expressed as a percent of initial squeeze.

To test for compression set, a test fixture was made for each specimen. The fixture consisted of a series of steel plates ground flat separated by a spacer ground to a predetermined dimension to assure 25% compression. The complete assembly was held together by a bolt running through the center (see Figure 1). The initial thickness of each compression set test specimen was measured at three locations around the O-ring. The spacer for the test fixture was then ground to give exactly 25% squeeze for the specimen. Specimens were compressed and placed in GE SF-1154 hydraulic fluid immediately prior to irradiation and were removed from the fluid and the compression relieved approximately 75 hours after irradiation was completed. Specimens were exposed to gamma radiation at a rate of .75 Megarads per hour for a period of 40 hours.

Durometer and tensile strength were measured with a separate set of specimens which were not compressed. First the durometer and specimen diameter were measured, then the O-ring was cut and mounted in a tensile tester.

Two specimens were used to determine initial tensile strength; another two specimens were used to measure durometer and tensile strength after irradiation; a third pair of specimens were used to measure durometer and tensile strength after irradiation and steam; and a final pair were used to measure compression set.

Procedure - Seal Irradiation (cont'd)

Tensile strength measurements were made using a 0 - 250 lb. range Scott tensile tester. Durometer measurements were made with a Shore Instrument and Mfg. Co. Type A2 durometer.

Procedure - Seal Temperature/Steam Exposure

After measurements were taken, the specimens used to measure compression set were remounted in the fixture of Fig. 1, along with the two remaining uncompressed O-rings. The complete assembly was installed in a test chamber as shown in Figure 2. Approximately three inches of water was put into the test chamber and then the complete chamber was placed in a power-omatic mechanical convection oven. Temperature was determined and monitored using a Copper-Constantan Thermocouple and Leeds-Northrup Potentiometer Model No. 8693-2. Timing began when the temperature reached 250° F. The test was completed after 72 hours at this condition. After completion of test, specimens were again measured for durometer and compression set as described in previous procedure.




Figure 1





Figure 2



March 29 1977



Mr. Daniel W. Mills
Senior Engineer
ITT Grinell Corp.
260 West Exchange Street
Providence, RI 02901

Dear Mr. Mills:

This will summarize parameters pertinent to the irradiation of seal material per your letter of February 17, 1977.


The fixture, with seals, was placed in a Cobalt-60 gamma field such that the dose rate over the exposure period was 0.75 Mrad per hour. The sample was irradiated for 40 hours, yielding a dose of 30 Mrad.

Irradiation was conducted in air at ambient temperature and pressure. Radiant heat from the source heated the samples somewhat, but the temperature did not exceed 90°F, as indicated by previous measurements on an oil solution in the same relative position.

Dosimetry was performed using a Victoreen Model 555 Integrating Dose Rate Meter and Probe. The unit was calibrated on October 16, 1975, by the Victoreen Instrument Company, using Cobalt-60 and Cesium-137 sources whose calibrations are traceable to the U. S. National Bureau of Standards. A copy of the calibration certificate is available. Backup dosimetry using a Red Perspex system confirmed the Victoreen readings.

Irradiation was completed on March 7, 1977, at which time your representative picked up the sample.

Very truly yours,


George R. Dietz
Manager, Radiation Services

GRD:of

Isomedix Inc. • 25 Eastmans Road, Parsippany, New Jersey (201) 887-4700
Mailing Address: Post Office Box 177, Parsippany, New Jersey 07054

CHICAGO DIVISION • 7828 Nagle Ave., Morton Grove, Illinois 60053 (312) 966-1160

TEST REPORT FORM - SEAL MATERIAL IRRADIATION

Initial Data

Specimen Type and Size: O RING 8212
 Molder: MINNESOTA RUBBER CO. Compound No. 559 GT
 Batch No. 1077 Cure Date 1077
 Certificate of Compliance Minnesota Rubber Co FOM #3949

Durometer-Shore A: 90 90 93 89 91 90 89 90
 Tensile Strgth-PSI 1397 1331
 Irrad. Test Ident 1 2 3 4 5 6

Specimen Ident 2
 Thickness: $T_{01} = .138$ $T_{02} = .138$ $T_{03} = .138$

$\bar{T}_0 = .138$.75 $\bar{T}_0 = .1035$
 Fixture Dimension: $T = .1035$

Specimen Ident 4
 Thickness: $T_{01} = .137$ $T_{02} = .139$ $T_{03} = .139$

$\bar{T}_0 = .138$.75 $\bar{T}_0 = .1035$
 Fixture Dimension: $T = .1035$

Specimen Ident _____
 Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ .75 $\bar{T}_0 =$ _____
 Fixture Dimension: $T =$ _____

Specimen Ident _____
 Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ .75 $\bar{T}_0 =$ _____
 Fixture Dimension: $T =$ _____

Specimen Ident _____
 Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ .75 $\bar{T}_0 =$ _____
 Fixture Dimension: $T =$ _____

Specimen Ident _____
 Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ .75 $\bar{T}_0 =$ _____
 Fixture Dimension: $T =$ _____

Signature of Test Supervisor Daniel W. M. M. M. Date 3/9/77

3X10⁷ RAD

559GT

Radiation Type GAMA

Radiation Dose 3X10⁷ RAD

Specimen Ident 1 3

Durometer-Shore A: 93 91

Tensile Strgth-PSI 1324 1404

Specimen Ident 2

Radiation Dose 3X10⁷ RAD

Thickness: $T_{11} = .118$ $T_{12} = .118$ $T_{13} = .118$

$\bar{T}_1 = .118$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = .58

Specimen Ident 4

3X10⁷ RAD.

Thickness: $T_{11} = .118$ $T_{12} = .118$ $T_{13} = .118$

$\bar{T}_1 = .118$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = .58

Specimen Ident _____

Radiation Dose _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____

$\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = _____

Specimen Ident _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____

$\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = _____

Specimen Ident _____

Radiation Dose _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____

$\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = _____

Specimen Ident _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____

$\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = _____

Signature of Test Supervisor Daniel W. M. [Signature] Date 3/9/77

3X10⁷ RADS + 72 hrs Steam

559GT

Radiation Type GAMA

Radiation Dose 3X10⁷ Rad

Specimen Ident 5 6

Durometer-Shore A: 92 91

Tensile Strgth-PSI 1137 1137

Specimen Ident 2

Radiation Dose 3X10⁷ RAD

Thickness: $T_{11} = .119$ $T_{12} = .119$ $T_{13} = .118$

$\bar{T}_1 = .1187$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = .559

Specimen Ident 4

Thickness: $T_{11} = .119$ $T_{12} = .118$ $T_{13} = .118$

$\bar{T}_1 = .1183$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = .575

Specimen Ident _____

Radiation Dose _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____

$\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = _____

Specimen Ident _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____

$\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = _____

Specimen Ident _____

Radiation Dose _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____

$\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = _____

Specimen Ident _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____

$\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = _____

Signature of Test Supervisor

David W. Mulh

Date 3/14/77

TEST REPORT FORM - SEAL MATERIAL IRRADIATION

Initial Data

Specimen Type and Size: O Ring 8212
 Molder: MINNESOTA RUBBER CO. Compound No. 560 A/D
 Batch No. Cure Date 4 Q 76
 Certificate of Compliance MINNESOTA RUBBER CO., FOM #3949

Durometer-Shore A: 69 72 70 69 70 71 67-69
 Tensile Strgth-PSI 1276 1075
 Irrad. Test Ident 1 2 3 4 5 6

Specimen Ident 2
 Thickness: $T_{01} = .138$ $T_{02} = .138$ $T_{03} = .137$

$\bar{T}_0 = .1377$ $.75 \bar{T}_0 = .1032$
 Fixture Dimension: $T = .103$

Specimen Ident 4
 Thickness: $T_{01} = .138$ $T_{02} = .138$ $T_{03} = .138$

$\bar{T}_0 = .138$ $.75 \bar{T}_0 = .1035$
 Fixture Dimension: $T = .104$

Specimen Ident
 Thickness: $T_{01} = \underline{\hspace{1cm}}$ $T_{02} = \underline{\hspace{1cm}}$ $T_{03} = \underline{\hspace{1cm}}$
 $\bar{T}_0 = \underline{\hspace{1cm}}$ $.75 \bar{T}_0 = \underline{\hspace{1cm}}$
 Fixture Dimension: $T = \underline{\hspace{1cm}}$

Specimen Ident
 Thickness: $T_{01} = \underline{\hspace{1cm}}$ $T_{02} = \underline{\hspace{1cm}}$ $T_{03} = \underline{\hspace{1cm}}$
 $\bar{T}_0 = \underline{\hspace{1cm}}$ $.75 \bar{T}_0 = \underline{\hspace{1cm}}$
 Fixture Dimension: $T = \underline{\hspace{1cm}}$

Specimen Ident
 Thickness: $T_{01} = \underline{\hspace{1cm}}$ $T_{02} = \underline{\hspace{1cm}}$ $T_{03} = \underline{\hspace{1cm}}$
 $\bar{T}_0 = \underline{\hspace{1cm}}$ $.75 \bar{T}_0 = \underline{\hspace{1cm}}$
 Fixture Dimension: $T = \underline{\hspace{1cm}}$

Specimen Ident
 Thickness: $T_{01} = \underline{\hspace{1cm}}$ $T_{02} = \underline{\hspace{1cm}}$ $T_{03} = \underline{\hspace{1cm}}$
 $\bar{T}_0 = \underline{\hspace{1cm}}$ $.75 \bar{T}_0 = \underline{\hspace{1cm}}$
 Fixture Dimension: $T = \underline{\hspace{1cm}}$

Signature of Test Supervisor Daniel W. Mobb Date 3/9/77

3X10⁷ RAD

560 ND

Radiation Type GAMA

Radiation Dose 3X10⁷ RAD

Specimen Ident 1 3

Durometer-Shore A: 79 77

Tensile Strgth-PSI 1085 535

Specimen Ident 2

Radiation Dose 3X10⁷ RAD

Thickness: $T_{11} = .126$ $T_{12} = .126$ $T_{13} = .126$

$\bar{T}_1 = .126$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = .337

Specimen Ident 4

3X10⁷ RAD

Thickness: $T_{11} = .127$ $T_{12} = .127$ $T_{13} = .127$

$\bar{T}_1 = .127$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = .324

Specimen Ident _____

Radiation Dose _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____

$\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = _____

Specimen Ident _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____

$\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = _____

Specimen Ident _____

Radiation Dose _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____

$\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = _____

Specimen Ident _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____

$\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = _____

Signature of Test Supervisor Daniel W. M. M. M.

Date 3/9/77

3X10⁷ RAD + 72 hr STORM

560ND

Radiation Type GAMA

Radiation Dose

3X10⁷

Specimen Ident

5 6

Durometer-Shore A:

77 78

Tensile Strgth-PSI

1142 869

Specimen Ident

2

Radiation Dose 3X10⁷ RAD

Thickness: $T_{11} = .124$ $T_{12} = .125$ $T_{13} = .125$

$\bar{T}_1 = .1247$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = 374

Specimen Ident

4

Thickness: $T_{11} = .126$ $T_{12} = .125$ $T_{13} = .126$

$\bar{T}_1 = .1257$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = ~~362~~ 362

Specimen Ident

Radiation Dose

Thickness: $T_{11} =$ $T_{12} =$ $T_{13} =$

$\bar{T}_1 =$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ =

Specimen Ident

Thickness: $T_{11} =$ $T_{12} =$ $T_{13} =$

$\bar{T}_1 =$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ =

Specimen Ident

Radiation Dose

Thickness: $T_{11} =$ $T_{12} =$ $T_{13} =$

$\bar{T}_1 =$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ =

Specimen Ident

Thickness: $T_{11} =$ $T_{12} =$ $T_{13} =$

$\bar{T}_1 =$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ =

Signature of Test Supervisor Daniel W. Mills Date 3/14/77

TEST REPORT FORM - SEAL MATERIAL IRRADIATION

Initial Data

Specimen Type and Size: O Ring 212 Size
 Molder: Polysol (Buckeye Rubber) Compound No. HK471
 Batch No. 10277
 Certificate of Compliance Polysol / BUCKEYE RUBBER

Durometer-Shore A: 73 74 69 69 72 66 69 65
 Tensile Strgth-PSI 2017 2078
 Irrad. Test Ident 1 2 3 4 5 6

Specimen Ident 2
 Thickness: $T_{01} = .140$ $T_{02} = .141$ $T_{03} = .140$

$\bar{T}_0 = .1403$ $.75 \bar{T}_0 = .1052$
 Fixture Dimension: $T = .105$

Specimen Ident 4
 Thickness: $T_{01} = .140$ $T_{02} = .140$ $T_{03} = .139$

$\bar{T}_0 = .1397$ $.75 \bar{T}_0 = .1047$
 Fixture Dimension: $T = .105$

Specimen Ident _____
 Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ $.75 \bar{T}_0 =$ _____
 Fixture Dimension: $T =$ _____

Specimen Ident _____
 Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ $.75 \bar{T}_0 =$ _____
 Fixture Dimension: $T =$ _____

Specimen Ident _____
 Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ $.75 \bar{T}_0 =$ _____
 Fixture Dimension: $T =$ _____

Specimen Ident _____
 Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ $.75 \bar{T}_0 =$ _____
 Fixture Dimension: $T =$ _____

Signature of Test Supervisor David W. Milby Date 3/9/77

3X10⁷ RAD

Radiation Type GAMA

Radiation Dose 3X10⁷ RAD

Specimen Ident 1 3

Durometer-Shore A: 78 77

Tensile Strgth-PSI 1665 1351

Specimen Ident 2

Radiation Dose 3X10⁷ RAD

Thickness: $T_{11} = .130$ $T_{12} = .129$ $T_{13} = .129$

$\bar{T}_1 = .1293$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = .312

Specimen Ident 4

Thickness: $T_{11} = .129$ $T_{12} = .129$ $T_{13} = .128$

3X10⁷ RAD

$\bar{T}_1 = .1287$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = .312

Specimen Ident _____

Radiation Dose _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____

$\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = _____

Specimen Ident _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____

$\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = _____

Specimen Ident _____

Radiation Dose _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____

$\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = _____

Specimen Ident _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____

$\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = _____

Signature of Test Supervisor

David W. M. M. M.

Date 3/9/77

3X10⁷ RAD + 72hr Steam

Radiation Type GAMA

Radiation Dose

3X10⁷ RAD

Specimen Ident

5 6

Durometer-Shore A:

78 77

Tensile Strgth-PSI

1332 1402

Specimen Ident

2

Radiation Dose

3X10⁷ RAD

Thickness:

$T_{11} =$

.130

$T_{12} =$

.130

$T_{13} =$

.129

$\bar{T}_1 =$

.1297

Compression Set:

$\bar{T}_0 - \bar{T}_1 =$

.300

$\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$

Specimen Ident

4

Thickness:

$T_{11} =$

.128

$T_{12} =$

.129

$T_{13} =$

.129

$\bar{T}_1 =$

.1287

Compression Set:

$\bar{T}_0 - \bar{T}_1 =$

.317

$\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$

Specimen Ident

Radiation Dose

Thickness:

$T_{11} =$

$T_{12} =$

$T_{13} =$

$\bar{T}_1 =$

Compression Set:

$\bar{T}_0 - \bar{T}_1 =$

$\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$

Specimen Ident

Thickness:

$T_{11} =$

$T_{12} =$

$T_{13} =$

$\bar{T}_1 =$

Compression Set:

$\bar{T}_0 - \bar{T}_1 =$

$\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$

Specimen Ident

Radiation Dose

Thickness:

$T_{11} =$

$T_{12} =$

$T_{13} =$

$\bar{T}_1 =$

Compression Set:

$\bar{T}_0 - \bar{T}_1 =$

$\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$

Specimen Ident

Thickness:

$T_{11} =$

$T_{12} =$

$T_{13} =$

$\bar{T}_1 =$

Compression Set:

$\bar{T}_0 - \bar{T}_1 =$

$\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$

Signature of Test Supervisor

James W. Mally

Date 3/14/77

TEST REPORT FORM - SEAL MATERIAL IRRADIATION

Initial Data

Specimen Type and Size: O Ring 212 size
 Molder: Polyseal Buckeye Rubber Compound No. E2050-90
 Batch No. 1Q77
 Certificate of Compliance Polyseal / BUCKEYE RUBBER

Durometer-Shore A: 85 86 85 84 85 84 85 85
 Tensile Strgth-PSI 1737 1606
 Irrad. Test Ident 1 2 3 4 5 6

Specimen Ident 4
 Thickness: $T_{01} = .140$ $T_{02} = .140$ $T_{03} = .140$

$\bar{T}_0 = .140$ $.75 \bar{T}_0 = .105$
 Fixture Dimension: $T = .105$

Specimen Ident 6
 Thickness: $T_{01} = .140$ $T_{02} = .140$ $T_{03} = .140$

$\bar{T}_0 = .140$ $.75 \bar{T}_0 = .105$
 Fixture Dimension: $T = .105$

Specimen Ident _____
 Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ $.75 \bar{T}_0 =$ _____
 Fixture Dimension: $T =$ _____

Specimen Ident _____
 Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ $.75 \bar{T}_0 =$ _____
 Fixture Dimension: $T =$ _____

Specimen Ident _____
 Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ $.75 \bar{T}_0 =$ _____
 Fixture Dimension: $T =$ _____

Specimen Ident _____
 Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ $.75 \bar{T}_0 =$ _____
 Fixture Dimension: $T =$ _____

Signature of Test Supervisor Daniel W. Malsby Date 3/9/77

3 X 10⁷ RADRadiation Type GAMA

Radiation Dose

3X10⁷RAD

Specimen Ident

1 2

Durometer-Shore A:

88 88

Tensile Strgth-PSI

1120 927

Specimen Ident

4Radiation Dose 3X10⁷RADThickness: $T_{11} = .126$ $T_{12} = .126$ $T_{13} = .126$ $\bar{T}_1 = .126$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = 40

Specimen Ident

63 X 10⁷ RADThickness: $T_{11} = .125$ $T_{12} = .125$ $T_{13} = .126$ $\bar{T}_1 = .1253$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = 42

Specimen Ident

Radiation Dose

Thickness: $T_{11} =$ $T_{12} =$ $T_{13} =$ $\bar{T}_1 =$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ =

Specimen Ident

Thickness: $T_{11} =$ $T_{12} =$ $T_{13} =$ $\bar{T}_1 =$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ =

Specimen Ident

Radiation Dose

Thickness: $T_{11} =$ $T_{12} =$ $T_{13} =$ $\bar{T}_1 =$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ =

Specimen Ident

Thickness: $T_{11} =$ $T_{12} =$ $T_{13} =$ $\bar{T}_1 =$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ =

Signature of Test Supervisor

David W. M. M. M. Date 3/9/77

3X10⁷ RAD + 72 hr. SteamRadiation Type GAMARadiation Dose 3X10⁷ RADSpecimen Ident 3 5Durometer-Shore A: 88 88Tensile Strgth-PSI 1180 905Specimen Ident 4

Radiation Dose _____

Thickness: $T_{11} = .126$ $T_{12} = .126$ $T_{13} = .126$ $\bar{T}_1 = .126$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = .4Specimen Ident 6Thickness: $T_{11} = .125$ $T_{12} = .126$ $T_{13} = .126$ $\bar{T}_1 = .1257$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = .409

Specimen Ident _____

Radiation Dose _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____ $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = _____

Specimen Ident _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____ $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = _____

Specimen Ident _____

Radiation Dose _____


Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____ $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = _____

Specimen Ident _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____ $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = _____Signature of Test Supervisor Daniel W. Muth Date 3/14/77

ITT GRINNELL CORP.
HANGER DIVISION
RD & E, SNUBBER SECTION

Radiation and Environmental Test
of Seal Materials for Snubbers

Revision 1 Approval  Date 7-23-77
Dept. Mgr.

Report No. PHD-7569-1 Rev. 1

Prepared by  Date 3-31-77
Sr. Engr.

Approved by  Date 4/14/77
Sect. Mgr.

Approved by  Date 4-15-77
Dept. Mgr.

This report complements Report No. PHD-5347-2R, "Radiation and Environmental Test of Seal and Fluid Materials for Snubbers" dated 10/3/75. This report contains data on seal material subjected to an integrated radiation dose of 3×10^7 rads plus a 72 hour elevated temperature, 100% steam environmental test. The seal materials of this report were not qualified in the above referenced report.

Purpose

The purpose of these tests is to demonstrate the ability of the tested seal materials to meet the requirements for usage in ITT Grinnell snubbers used in nuclear power plant applications.

Results

Table 1 below summarizes the results obtained on seal materials exposed to a total integrated radiation dose of 3×10^7 rads while immersed in GE SF 1154 hydraulic fluid. The table shows percent change in durometer, tensile strength and compression set. Compression set samples were compressed to 75% of their initial thickness. The average compression set is the percentage of initial compression that remains after relief of compressive force. Data sheets for the individual seals are at the end of this report.

| <u>Compound</u> | <u>TABLE I</u> | | |
|-------------------|---|--|---|
| | <u>Durometer Average % Change</u> | <u>Tensile Strength Average % Change</u> | <u>Average Compression Set - % of Initial Compression</u> |
| Minnesota 559GT | 0 | 0 | 58. |
| Minnesota 560ND | + 11.2 | - 7.7* | 33. |
| Polyseal HK-471 | + 9.9 | -26.3 | 31. |
| Polyseal E2050-90 | + 4.4 | -38.8 | 41.5 |

* Only one tensile value was used in this average; the second reading appeared to be in error

The compression samples were again compressed to 75% of initial pre-radiation thickness and they, along with uncompressed samples, were subjected to an additional environment of 250°F, all steam for 72 hours. Table II below shows the tabulated results as change of durometer, change of tensile strength and compression set. Changes are measured from initial quantities.

TABLE II

| <u>Compound</u> | <u>Durometer Average % Change</u> | <u>Tensile Strength Average % Change</u> | <u>Average Compression Set - % of Initial Compression</u> |
|-------------------|---|--|---|
| Minnesota 559GT | + 2.24 | 0 | 56.7 |
| Minnesota 560ND | + 14 | - 14.5 | 36.8 |
| Polyseal HK471 | + 3.5 | - 33.2 | 30.9 |
| Polyseal E2050-90 | + 15.8 | - 37.6 | 40.5 |

Data sheets showing individual seal properties can be found at the end of this report.

Conclusions

Durometer - The change in durometer for all compounds is negligible and should not be a factor in seal operability or life.

Tensile Strength - The change in tensile strength of the Polyseal compounds (HK471 and E2050-90) is significant; however, tensile strength change should not effect seal operability or life.

Compression Set - Compression set is a measure of the recoverability of compounds from compression and thence a measure of the continued contact between seal and container. Of the quantities measured, compression set should give the greatest indication of operability after conditioning. While the compression sets measured are significant, it should be noted that all but one of the compounds recovers 60% of the initial compression and that compound Minnesota 559GT recovers 40%.

Comparison of compression sets of this testing with those of PHD-5347-2R shows that the new seal materials are at the low end of compression set, and hence should be acceptable for usage in ITT Grinnell snubbers.

Procedure - Seal Irradiation

Test specimens for all seals were O-rings in ARP568-212 size. Specimens were tested for compression set, change in tensile strength, and change in durometer.

Compression set indicates the extent to which squeeze initially applied by the gland to the seal is lost as the seal ages. It is measured by compressing a specimen by a given

Procedure - Seal Irradiation (cont'd)

amount (to 75% of its initial thickness for this test); ageing the seal in this compressed state; and then measuring the free thickness of the seal after ageing. The difference between initial and final thickness is expressed as a percent of initial squeeze.

To test for compression set, a test fixture was made for each specimen. The fixture consisted of a series of steel plates ground flat separated by a spacer ground to a predetermined dimension to assure 25% compression. The complete assembly was held together by a bolt running through the center (see Figure 1). The initial thickness of each compression set test specimen was measured at three locations around the O-ring. The spacer for the test fixture was then ground to give exactly 25% squeeze for the specimen. Specimens were compressed and placed in GE SF-1154 hydraulic fluid immediately prior to irradiation and were removed from the fluid and the compression relieved approximately 75 hours after irradiation was completed. Specimens were exposed to gamma radiation at a rate of .75 Megarads per hour for a period of 40 hours.

Durometer and tensile strength were measured with a separate set of specimens which were not compressed. First the durometer and specimen diameter were measured, then the O-ring was cut and mounted in a tensile tester.

Two specimens were used to determine initial tensile strength; another two specimens were used to measure durometer and tensile strength after irradiation; a third pair of specimens were used to measure durometer and tensile strength after irradiation and steam; and a final pair were used to measure compression set.

Procedure - Seal Irradiation (cont'd)

Tensile strength measurements were made using a 0 - 250 lb. range Scott tensile tester. Durometer measurements were made with a Shore Instrument and Mfg. Co. Type A2 durometer.

Procedure - Seal Temperature/Steam Exposure

After measurements were taken, the specimens used to measure compression set were remounted in the fixture of Fig. 1, along with the two remaining uncompressed O-rings. The complete assembly was installed in a test chamber as shown in Figure 2. Approximately three inches of water was put into the test chamber and then the complete chamber was placed in a power-o-matic mechanical convection oven. Temperature was determined and monitored using a Copper-Constantan Thermocouple and Leeds-Northrup Potentiometer Model No. 8693-2. Timing began when the temperature reached 250° F. The test was completed after 72 hours at this condition. After completion of test, specimens were again measured for durometer and compression set as described in previous procedure.




Figure 1






Figure 7



March 29 1977



Mr. Daniel W. Mills
Senior Engineer
ITT Grinell Corp.
260 West Exchange Street
Providence, RI 02901

Dear Mr. Mills:

This will summarize parameters pertinent to the irradiation of seal material per your letter of February 17, 1977.


The fixture, with seals, was placed in a Cobalt-60 gamma field such that the dose rate over the exposure period was 0.75 Mrad per hour. The sample was irradiated for 40 hours, yielding a dose of 30 Mrad.

Irradiation was conducted in air at ambient temperature and pressure. Radiant heat from the source heated the samples somewhat, but the temperature did not exceed 90°F, as indicated by previous measurements on an oil solution in the same relative position.

Dosimetry was performed using a Victoreen Model 555 Integrating Dose Rate Meter and Probe. The unit was calibrated on October 16, 1975, by the Victoreen Instrument Company, using Cobalt-60 and Cesium-137 sources whose calibrations are traceable to the U. S. National Bureau of Standards. A copy of the calibration certificate is available. Backup dosimetry using a Red Perspex system confirmed the Victoreen readings.

Irradiation was completed on March 7, 1977, at which time your representative picked up the sample.

Very truly yours,


George R. Dietz
Manager, Radiation Services

GRD:of

Isomedix Inc. • 25 Eastmans Road, Parsippany, New Jersey (201) 887-4700

Mailing Address: P.O. Box 177, Parsippany, New Jersey, 07654

CHICAGO DIVISION • 100 North La Salle Street, Chicago, Illinois 60601

TEST REPORT FORM - SEAL MATERIAL IRRADIATION

Initial Data

Specimen Type and Size: O Ring .8212
 Molder: MINNESOTA RUBBER CO. Compound No. 559 GT
 Batch No. Cure Date 10/77
 Certificate of Compliance MINNESOTA RUBBER CO FOM 3949

Durometer-Shore A: 90 90 93 89 91 90 89 90
 Tensile Strgth-PSI 1397 1331 :
 Irrad. Test Ident 1 2 3 4 5 6

Specimen Ident 2
 Thickness: $T_{01} = .138$ $T_{02} = .138$ $T_{03} = .138$

$\bar{T}_0 = .138$ $.75 \bar{T}_0 = .1035$
 Fixture Dimension: $T = .1035$

Specimen Ident 4
 Thickness: $T_{01} = .137$ $T_{02} = .139$ $T_{03} = .139$

$\bar{T}_0 = .138$ $.75 \bar{T}_0 = .1035$
 Fixture Dimension: $T = .1035$

Specimen Ident
 Thickness: $T_{01} = \underline{\hspace{1cm}}$ $T_{02} = \underline{\hspace{1cm}}$ $T_{03} = \underline{\hspace{1cm}}$
 $\bar{T}_0 = \underline{\hspace{1cm}}$ $.75 \bar{T}_0 = \underline{\hspace{1cm}}$
 Fixture Dimension: $T = \underline{\hspace{1cm}}$

Specimen Ident
 Thickness: $T_{01} = \underline{\hspace{1cm}}$ $T_{02} = \underline{\hspace{1cm}}$ $T_{03} = \underline{\hspace{1cm}}$
 $\bar{T}_0 = \underline{\hspace{1cm}}$ $.75 \bar{T}_0 = \underline{\hspace{1cm}}$
 Fixture Dimension: $T = \underline{\hspace{1cm}}$

Specimen Ident
 Thickness: $T_{01} = \underline{\hspace{1cm}}$ $T_{02} = \underline{\hspace{1cm}}$ $T_{03} = \underline{\hspace{1cm}}$
 $\bar{T}_0 = \underline{\hspace{1cm}}$ $.75 \bar{T}_0 = \underline{\hspace{1cm}}$
 Fixture Dimension: $T = \underline{\hspace{1cm}}$

Specimen Ident
 Thickness: $T_{01} = \underline{\hspace{1cm}}$ $T_{02} = \underline{\hspace{1cm}}$ $T_{03} = \underline{\hspace{1cm}}$
 $\bar{T}_0 = \underline{\hspace{1cm}}$ $.75 \bar{T}_0 = \underline{\hspace{1cm}}$
 Fixture Dimension: $T = \underline{\hspace{1cm}}$

Signature of Test Supervisor Date 2/7/77

Radiation Type GAMARadiation Dose 3×10^7 RADSpecimen Ident 1 3Durometer-Shore A: 93 91Tensile Strgth-PSI 1324 1404Specimen Ident 2Radiation Dose 3×10^7 RADThickness: $T_{11} = \underline{.118}$ $T_{12} = \underline{.118}$ $T_{13} = \underline{.118}$ $\bar{T}_1 = \underline{.118}$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} = \underline{.58}$ Specimen Ident 4 3×10^7 RAD.Thickness: $T_{11} = \underline{.118}$ $T_{12} = \underline{.118}$ $T_{13} = \underline{.118}$ $\bar{T}_1 = \underline{.118}$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} = \underline{.58}$

Specimen Ident _____

Radiation Dose _____

Thickness: $T_{11} = \underline{\hspace{1cm}}$ $T_{12} = \underline{\hspace{1cm}}$ $T_{13} = \underline{\hspace{1cm}}$ $\bar{T}_1 = \underline{\hspace{1cm}}$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} = \underline{\hspace{1cm}}$

Specimen Ident _____

Thickness: $T_{11} = \underline{\hspace{1cm}}$ $T_{12} = \underline{\hspace{1cm}}$ $T_{13} = \underline{\hspace{1cm}}$ $\bar{T}_1 = \underline{\hspace{1cm}}$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} = \underline{\hspace{1cm}}$

Specimen Ident _____

Radiation Dose _____

Thickness: $T_{11} = \underline{\hspace{1cm}}$ $T_{12} = \underline{\hspace{1cm}}$ $T_{13} = \underline{\hspace{1cm}}$ $\bar{T}_1 = \underline{\hspace{1cm}}$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} = \underline{\hspace{1cm}}$

Specimen Ident _____

Thickness: $T_{11} = \underline{\hspace{1cm}}$ $T_{12} = \underline{\hspace{1cm}}$ $T_{13} = \underline{\hspace{1cm}}$ $\bar{T}_1 = \underline{\hspace{1cm}}$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} = \underline{\hspace{1cm}}$ Signature of Test Supervisor _____Date 3/6/77

3X10⁷ RADs + 72 hrs Steam

559GT

Radiation Type Gamma

Radiation Dose

3X10⁷ Rad

Specimen Ident

5 6

Durometer-Shore A:

92 91

Tensile Strgth-PSI

1137 1137

Specimen Ident

2Radiation Dose 3X10⁷ RAD

Thickness:

 $T_{11} = \underline{.119}$ $T_{12} = \underline{.119}$ $T_{13} = \underline{.118}$ $\bar{T}_1 =$.1187

Compression Set:

$$\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} = \underline{.559}$$

Specimen Ident

4

Thickness:

 $T_{11} = \underline{.119}$ $T_{12} = \underline{.118}$ $T_{13} = \underline{.118}$ $\bar{T}_1 =$.1183

Compression Set:

$$\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} = \underline{.575}$$

Specimen Ident

Radiation Dose

Thickness:

 $T_{11} =$ $T_{12} =$ $T_{13} =$ $\bar{T}_1 =$

Compression Set:

$$\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$$

Specimen Ident

Thickness:

 $T_{11} =$ $T_{12} =$ $T_{13} =$ $\bar{T}_1 =$

Compression Set:

$$\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$$

Specimen Ident

Radiation Dose

Thickness:

 $T_{11} =$ $T_{12} =$ $T_{13} =$ $\bar{T}_1 =$

Compression Set:

$$\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$$

Specimen Ident

Thickness:

 $T_{11} =$ $T_{12} =$ $T_{13} =$ $\bar{T}_1 =$

Compression Set:

$$\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T} =$$

Signature of Test Supervisor

[Signature]

Date

3/4/77

Initial Data

Radiation Type GAMA
 Radiation Dose 3X10⁷ RAD
 Specimen Ident 1 3
 Durometer-Shore A: 79 77
 Tensile Strgth-PSI 1085 535

Specimen Ident 2 Radiation Dose 3X10⁷ RAD
 Thickness: $T_{11} = .126$ $T_{12} = .126$ $T_{13} = .126$
 $\bar{T}_1 = .126$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = .337

Specimen Ident 4 Radiation Dose 3X10⁷ RAD
 Thickness: $T_{11} = .127$ $T_{12} = .127$ $T_{13} = .127$
 $\bar{T}_1 = .127$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = .324

Specimen Ident _____ Radiation Dose _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = _____

Specimen Ident _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = _____

Specimen Ident _____ Radiation Dose _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = _____

Specimen Ident _____
 Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = _____

Signature of Test Supervisor [Signature] Date 3/9/77

Radiation Type GMP

Radiation Dose

3×10^7

Specimen Ident

5 6

Durometer-Shore A:

77 78

Tensile Strgth-PSI

1142 869

Specimen Ident

2

Radiation Dose 3×10^7 RAD

Thickness: $T_{11} = .124$ $T_{12} = .125$ $T_{13} = .125$

$\bar{T}_1 = .1247$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = .374

Specimen Ident

4

Thickness: $T_{11} = .126$ $T_{12} = .125$ $T_{13} = .126$

$\bar{T}_1 = .1257$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = .362

Specimen Ident

Radiation Dose

Thickness: $T_{11} =$ $T_{12} =$ $T_{13} =$

$\bar{T}_1 =$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ =

Specimen Ident

Thickness: $T_{11} =$ $T_{12} =$ $T_{13} =$

$\bar{T}_1 =$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ =

Specimen Ident

Radiation Dose

Thickness: $T_{11} =$ $T_{12} =$ $T_{13} =$

$\bar{T}_1 =$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ =

Specimen Ident

Thickness: $T_{11} =$ $T_{12} =$ $T_{13} =$

$\bar{T}_1 =$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ =

Signature of Test Supervisor

Date 3/1/77

TEST REPORT FORM - SEAL MATERIAL IRRADIATION

Initial Data

Specimen Type and Size: O Ring 212 Size
 Molder: Polysol (Buckeye Rubber) Compound No. HK471
 Batch No. _____ Cure Date 10/77
 Certificate of Compliance Polysol / BUCKEYE RUBBER

Durometer-Shore A: 73 74 69 69 72 66 69 65
 Tensile Strgth-PSI 2017 2078
 Irrad. Test Ident 1 2 3 4 5 6

Specimen Ident 2
 Thickness: $T_{01} = .140$ $T_{02} = .141$ $T_{03} = .140$
 $\bar{T}_0 = .1423$ $.75 \bar{T}_0 = .1052$
 Fixture Dimension: $T = .105$

Specimen Ident 4
 Thickness: $T_{01} = .140$ $T_{02} = .140$ $T_{03} = .139$
 $\bar{T}_0 = .1397$ $.75 \bar{T}_0 = .1047$
 Fixture Dimension: $T = .105$

Specimen Ident _____
 Thickness: $T_{01} = \underline{\hspace{1cm}}$ $T_{02} = \underline{\hspace{1cm}}$ $T_{03} = \underline{\hspace{1cm}}$
 $\bar{T}_0 = \underline{\hspace{1cm}}$ $.75 \bar{T}_0 = \underline{\hspace{1cm}}$
 Fixture Dimension: $T = \underline{\hspace{1cm}}$

Specimen Ident _____
 Thickness: $T_{01} = \underline{\hspace{1cm}}$ $T_{02} = \underline{\hspace{1cm}}$ $T_{03} = \underline{\hspace{1cm}}$
 $\bar{T}_0 = \underline{\hspace{1cm}}$ $.75 \bar{T}_0 = \underline{\hspace{1cm}}$
 Fixture Dimension: $T = \underline{\hspace{1cm}}$

Specimen Ident _____
 Thickness: $T_{01} = \underline{\hspace{1cm}}$ $T_{02} = \underline{\hspace{1cm}}$ $T_{03} = \underline{\hspace{1cm}}$
 $\bar{T}_0 = \underline{\hspace{1cm}}$ $.75 \bar{T}_0 = \underline{\hspace{1cm}}$
 Fixture Dimension: $T = \underline{\hspace{1cm}}$

Specimen Ident _____
 Thickness: $T_{01} = \underline{\hspace{1cm}}$ $T_{02} = \underline{\hspace{1cm}}$ $T_{03} = \underline{\hspace{1cm}}$
 $\bar{T}_0 = \underline{\hspace{1cm}}$ $.75 \bar{T}_0 = \underline{\hspace{1cm}}$
 Fixture Dimension: $T = \underline{\hspace{1cm}}$

Signature of Test Supervisor Ch. J. [Signature] Date 3/7/77

Radiation Type GAMA

Radiation Dose 3×10^7 RAD

Specimen Ident 1 3

Durometer-Shore A: 78 77

Tensile Strgth-PSI 1665 1351

Specimen Ident 2 Radiation Dose 3×10^7 RAD

Thickness: $T_{11} = \underline{.130}$ $T_{12} = \underline{.129}$ $T_{13} = \underline{.129}$

$\bar{T}_1 = \underline{.1293}$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$.312

Specimen Ident 4 Radiation Dose 3×10^7 RAD

Thickness: $T_{11} = \underline{.129}$ $T_{12} = \underline{.129}$ $T_{13} = \underline{.128}$

$\bar{T}_1 = \underline{.1287}$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$.317

Specimen Ident _____ Radiation Dose _____

Thickness: $T_{11} = \underline{\hspace{1cm}}$ $T_{12} = \underline{\hspace{1cm}}$ $T_{13} = \underline{\hspace{1cm}}$

$\bar{T}_1 = \underline{\hspace{1cm}}$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ _____

Specimen Ident _____
Thickness: $T_{11} = \underline{\hspace{1cm}}$ $T_{12} = \underline{\hspace{1cm}}$ $T_{13} = \underline{\hspace{1cm}}$

$\bar{T}_1 = \underline{\hspace{1cm}}$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ _____

Specimen Ident _____ Radiation Dose _____

Thickness: $T_{11} = \underline{\hspace{1cm}}$ $T_{12} = \underline{\hspace{1cm}}$ $T_{13} = \underline{\hspace{1cm}}$

$\bar{T}_1 = \underline{\hspace{1cm}}$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ _____

Specimen Ident _____
Thickness: $T_{11} = \underline{\hspace{1cm}}$ $T_{12} = \underline{\hspace{1cm}}$ $T_{13} = \underline{\hspace{1cm}}$

$\bar{T}_1 = \underline{\hspace{1cm}}$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ _____

Signature of Test Supervisor Chad A. Miller Date 3/9/77

3X10⁷ RAD + 72hr Steam

Radiation Type. GAMA

Radiation Dose 3X10⁷ RAD

Specimen Ident 5 6

Durometer-Shore A: 78 77

Tensile Strgth-PSI 1332 1402

Specimen Ident 2 Radiation Dose 3X10⁷ RAD

Thickness: $T_{11} = .130$ $T_{12} = .130$ $T_{13} = .129$

$\bar{T}_1 = .1297$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = .300

Specimen Ident 4
Thickness: $T_{11} = .128$ $T_{12} = .129$ $T_{13} = .129$

$\bar{T}_1 = .1287$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = .317

Specimen Ident _____ Radiation Dose _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____

$\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = _____

Specimen Ident _____
Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____

$\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = _____

Specimen Ident _____ Radiation Dose _____

Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____

$\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = _____

Specimen Ident _____
Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____

$\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = _____

Signature of Test Supervisor

Date 3/1/77

TEST REPORT FORM - SEAL MATERIAL IRRADIATION

Initial Data

Specimen Type and Size: O Ring 217 512
 Molder: D polysol Buckeye Rubber Compound No. E2050-90
 Batch No. 1077
 Certificate of Compliance D polysol / BUCKEYE RUBBER

Durometer-Shore A: 85 86 85 84 85 84 85 85
 Tensile Strgth-PSI 1737 1606
 Irrad. Test Ident 1 2 3 4 5 6

Specimen Ident 4
 Thickness: $T_{01} = .140$ $T_{02} = .140$ $T_{03} = .140$

$\bar{T}_0 = .140$ $.75 \bar{T}_0 = .105$
 Fixture Dimension: $T = .105$

Specimen Ident 6
 Thickness: $T_{01} = .140$ $T_{02} = .140$ $T_{03} = .140$

$\bar{T}_0 = .140$ $.75 \bar{T}_0 = .105$
 Fixture Dimension: $T = .105$

Specimen Ident _____
 Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ $.75 \bar{T}_0 =$ _____
 Fixture Dimension: $T =$ _____

Specimen Ident _____
 Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ $.75 \bar{T}_0 =$ _____
 Fixture Dimension: $T =$ _____

Specimen Ident _____
 Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ $.75 \bar{T}_0 =$ _____
 Fixture Dimension: $T =$ _____

Specimen Ident _____
 Thickness: $T_{01} =$ _____ $T_{02} =$ _____ $T_{03} =$ _____
 $\bar{T}_0 =$ _____ $.75 \bar{T}_0 =$ _____
 Fixture Dimension: $T =$ _____

Signature of Test Supervisor [Signature] Date 3/9/77

3 X 10⁷ RAD

Radiation Type GAMA
Radiation Dose 3X10⁷RAD
Specimen Ident 1 2
Durometer-Shore A: 88 88
Tensile Strgth-PSI 1120 927

Specimen Ident 4 Radiation Dose 3X10⁷RAD
Thickness: $T_{11} = .126$ $T_{12} = .126$ $T_{13} = .126$
 $\bar{T}_1 = .126$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = 40

Specimen Ident 6 Radiation Dose 3 X 10⁷ RAD
Thickness: $T_{11} = .125$ $T_{12} = .125$ $T_{13} = .126$
 $\bar{T}_1 = .1253$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = .42

Specimen Ident _____ Radiation Dose _____
Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = _____

Specimen Ident _____
Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = _____

Specimen Ident _____ Radiation Dose _____
Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = _____

Specimen Ident _____
Thickness: $T_{11} =$ _____ $T_{12} =$ _____ $T_{13} =$ _____
 $\bar{T}_1 =$ _____ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = _____

Signature of Test Supervisor [Signature] Date 3/9/77

3X10⁷ RAD + 72 hr. Steam

Radiation Type GAMA

Radiation Dose 3X10⁷ RAD

Specimen Ident

3 5

Durometer-Shore A:

88 88

Tensile Strgth-PSI

1180 905

Specimen Ident

4

Radiation Dose

Thickness: $T_{11} = .126$ $T_{12} = .126$ $T_{13} = .126$

$\bar{T}_1 = .126$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = .4

Specimen Ident

6

Thickness: $T_{11} = .125$ $T_{12} = .126$ $T_{13} = .126$

$\bar{T}_1 = .1257$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ = .409

Specimen Ident

Radiation Dose

Thickness: $T_{11} =$ $T_{12} =$ $T_{13} =$

$\bar{T}_1 =$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ =

Specimen Ident

Thickness: $T_{11} =$ $T_{12} =$ $T_{13} =$

$\bar{T}_1 =$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ =

Specimen Ident

Radiation Dose

Thickness: $T_{11} =$ $T_{12} =$ $T_{13} =$

$\bar{T}_1 =$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ =

Specimen Ident

Thickness: $T_{11} =$ $T_{12} =$ $T_{13} =$

$\bar{T}_1 =$ Compression Set: $\frac{\bar{T}_0 - \bar{T}_1}{\bar{T}_0 - T}$ =

Signature of Test Supervisor

[Signature]

Date

3/11/77

ENGINE

Size 18 Dia. Bore

Page 1 of 6

| Type | Support | Large Bore Snubber |
|------|---------|--------------------|
| 1 | 1 | 1 |
| 2 | 2 | 2 |
| 3 | 3 | 3 |
| 4 | 4 | 4 |
| 5 | 5 | 5 |
| 6 | 6 | 6 |
| 7 | 7 | 7 |
| 8 | 8 | 8 |
| 9 | 9 | 9 |
| 10 | 10 | 10 |
| 11 | 11 | 11 |
| 12 | 12 | 12 |
| 13 | 13 | 13 |
| 14 | 14 | 14 |
| 15 | 15 | 15 |
| 16 | 16 | 16 |
| 17 | 17 | 17 |
| 18 | 18 | 18 |
| 19 | 19 | 19 |
| 20 | 20 | 20 |
| 21 | 21 | 21 |
| 22 | 22 | 22 |
| 23 | 23 | 23 |
| 24 | 24 | 24 |
| 25 | 25 | 25 |
| 26 | 26 | 26 |
| 27 | 27 | 27 |
| 28 | 28 | 28 |
| 29 | 29 | 29 |
| 30 | 30 | 30 |
| 31 | 31 | 31 |
| 32 | 32 | 32 |
| 33 | 33 | 33 |
| 34 | 34 | 34 |
| 35 | 35 | 35 |
| 36 | 36 | 36 |
| 37 | 37 | 37 |
| 38 | 38 | 38 |
| 39 | 39 | 39 |
| 40 | 40 | 40 |
| 41 | 41 | 41 |
| 42 | 42 | 42 |
| 43 | 43 | 43 |
| 44 | 44 | 44 |
| 45 | 45 | 45 |
| 46 | 46 | 46 |
| 47 | 47 | 47 |
| 48 | 48 | 48 |
| 49 | 49 | 49 |
| 50 | 50 | 50 |
| 51 | 51 | 51 |
| 52 | 52 | 52 |
| 53 | 53 | 53 |
| 54 | 54 | 54 |
| 55 | 55 | 55 |
| 56 | 56 | 56 |
| 57 | 57 | 57 |
| 58 | 58 | 58 |
| 59 | 59 | 59 |
| 60 | 60 | 60 |
| 61 | 61 | 61 |
| 62 | 62 | 62 |
| 63 | 63 | 63 |
| 64 | 64 | 64 |
| 65 | 65 | 65 |
| 66 | 66 | 66 |
| 67 | 67 | 67 |
| 68 | 68 | 68 |
| 69 | 69 | 69 |
| 70 | 70 | 70 |
| 71 | 71 | 71 |
| 72 | 72 | 72 |
| 73 | 73 | 73 |
| 74 | 74 | 74 |
| 75 | 75 | 75 |
| 76 | 76 | 76 |
| 77 | 77 | 77 |
| 78 | 78 | 78 |
| 79 | 79 | 79 |
| 80 | 80 | 80 |
| 81 | 81 | 81 |
| 82 | 82 | 82 |
| 83 | 83 | 83 |
| 84 | 84 | 84 |
| 85 | 85 | 85 |
| 86 | 86 | 86 |
| 87 | 87 | 87 |
| 88 | 88 | 88 |
| 89 | 89 | 89 |
| 90 | 90 | 90 |
| 91 | 91 | 91 |
| 92 | 92 | 92 |
| 93 | 93 | 93 |
| 94 | 94 | 94 |
| 95 | 95 | 95 |
| 96 | 96 | 96 |
| 97 | 97 | 97 |
| 98 | 98 | 98 |
| 99 | 99 | 99 |
| 100 | 100 | 100 |

Ass'y No. F-PHD-5222-5-A1

[illegible]

| ENGINEERING PARTS LIST | | | EPL No. MB-5222-31 | Page 2 of 6 | Rev. ⁴ | Date 10/12/88 |
|------------------------|--------------------------------|---------------------------|---|-------------|-------------------|---------------|
| Qty Per | Drawing No. | Description | Material | Rev. | Rev. Date | |
| 1 | PHD-5222-5 | Large Bore Snubber Ass'y | | G | 11/10/81 | |
| 2 | CPHD-5222-184 | Rear Bracket Ass'y | ASTM 487-74d GR. 10Q * | H | 6/23/80 | |
| 3 | BPHD-5222-100 | Rear Bracket Casting | ASTM 487-74d GR. 10Q * | G | 6/23/80 | |
| 4 | APHD-5222-12 | Lifting Lug | ASTM 487-74d GR. 10Q * | D | 6/23/80 | |
| 5 | CPHD-5222-166 | Pivot Lug Ass'y | ASTM 487-74d GR. 10Q * | D | 6/23/80 | |
| 6 | BPHD-5222-157 | Pivot Lug Casting | ASTM 487-74d GR. 10Q * | E | 1/2/80 | |
| 7 | 2 [#] SKF GEZ-600 ESB | Spherical Bearing | Steel ** | | | |
| 8 | D5689H-13 | Cylinder Hyd MFP Model 52 | | 14 | 5/21/80 | |
| 9 | D5689H-13 -1 | Piston-Piston Rod | ASTM A668-72 GR.M Forging * | | | |
| 10 | D5689H-13 -2 | Piston Seal | Ethylene Propylene See Appr Comp. List, Pg. 6 ** | ✓ | | |
| 11 | D5689H-13 -3 | Head | ASTM A516-73 GR. 70 Plate * | | | |
| 12 | D5689H-13 -4 | External Bearing | ASTM A516-73 GR. 70 Plate * | | | |
| 13 | D5689H-13 -5 | Tubing | ASTM A148-73 GR. 150-125 Casting * | | | |
| 14 | D5689H-13 -6 | Rod Seal | Ethylene Propylene See Appr Comp. List Pg. 6 ** | ✓ | | |
| 15 | D5689H-13 -7 | Retainer | ASTM A516-73 GR. 70 Plate * | | | |
| 16 | D5689H-13 -8 | Rod Bushing | ASTM A546 GR. 80-55-06 or 80-60-03 Bronze Plate CDA 524** | | | |
| 17 | D5689H-13 -9 | Tie Rod Nuts | ASTM-A194-71 GR. 7 or 7B * | | | |
| 18 | D5689H-13 -10 | Threaded Cap | ASTM-A516-73 GR. 70 Plate * | | | |
| 19 | D5689H-13 -11 | Tie Rods | ASTM-A-193-73 GR. B7 * | | | |
| 20 | D5689H-13 -12 | Rod Pressure Ring | SAE 660 Bronze ** | | | |
| | D5689H-13 -13 | Rod Seal Cage | AISI 1018 or 1020 ** | | | |

| ENGINEERING PARTS LIST | | | | EPL No. MB-5222-31 | Page 3 of 6 | Rev. 4 Date 10/12/82 |
|------------------------|----------------|-----------------------------------|--|--------------------|-------------|----------------------|
| Qty Per | Drawing No. | Description | Material | Rev. | Rev. Date | |
| 1 2 | D5689H-13 -14 | Cylinder End Seal | Ethylene Propylene See Appr. Comp. List, Pg. 6 ** | / | | |
| 2 1 | D5689H-13 -15 | Rod Wiper | Ethylene Propylene See Appr. Comp. List, Pg. 6 ** | / | | |
| 3 1 | D5689H-13 -16 | Rod Wave Spring | AISI 1070-1090 Spr. Stl. Rc 44-54 ** | | | |
| 4 2 | D5689H-13 -17 | Piston-Anti Roll Ring | AISI 1010-1018 RB 40 Max. ** | | | |
| 5 2 | D5689H-13 -18 | Piston Retaining Ring | AISI 1070-1090 Spr. Stl. Rc 44-54 ** | | | |
| 6 1 | D5689H-13 -19 | Piston Wear Ring | Bronze Leaded ASTM B584-73 Alloy 937 ** | | | |
| 7 2 | D5689H-13 -20 | Piston Seal Backup Ring | Bronze Leaded ASTM B584-73 Alloy 937 ** | | | |
| 8 16 | D5689H-13 -21 | Retainer Scr. 5/16-24 x 1 1/2 Lg. | ASTM A354-66 GR. BB, BC or BD* | | | |
| 9 1 | D5689H-13 -22 | Retaining Ring | AISI 1075-1095 Spr. Stl. Rc 47-51 ** | | | |
| 10 1 | D5689H-13 -23 | External Brg. Seal | Ethylene Propylene See Appr. Comp. List Pg. 6 ** | / | | |
| 11 12 | D5689H-13 -24 | Retainer Screws 1/2 - 20 x 5" Lg. | ASTM A354-66 GR. BB, BC or BD * | | | |
| 12 16 | D5689H-13 -25 | 5/16 Flat Washer | Steel ** | | | |
| 13 1 | CPHD-5222-198 | Clevis Ass'y | ASTM 487-74d GR. 10Q * | C | 6/23/80 | |
| 14 1 | BPHD-5222- 176 | Clevis End Casting | ASTM 487-74d GR. 10Q * | E | 6/23/80 | |
| 15 1 | BPHD-5222-56-1 | Pivot Pin R.B. | A 564-74 GR. XM-13 * | D | 6/23/80 | |
| 16 4 | 5100-600 | Retaining Ring | AISI 1075-1095 Spr. Stl. Rc 47-51 ** | | | |
| 17 1 | BPHD-5222- 56 | Pivot Pin Clevis | A564-74 GR. XM-13 * | D | 6/23/80 | |
| 18 2 | BPHD-5222-20 | Snubber Valve Ass'y | | D | 1/28/80 | |
| 19 2 | BPHD-5222-21 | Valve Body | AISI 1018 ASTM A108 GR.1013 CW 60 ksi Min UTS. 40 ksi Y.S. 215 BU! Max.* | S. H | 6/19/81 | |
| 20 2 | APHD-5222-22 | Valve Poppet | AISI 1018 ASTM A108 GR.1013 CW 60 ksi Min UTS. 40 ksi Y.S. 215 BU! Max.* | S. D | 1/14/81 | |
| 21 2 | APHD-5222-23 | Valve Seat Disc | ASTM A515-72 GR.65 or GR.70 | E | 8/25/80 | |

| ENGINEERING PARTS LIST | | | EPL No. MB-5222- 31 | Page 4 of 6 | Rev. 4 Date 10/12/82 |
|------------------------|----------------|--|--|-------------|----------------------|
| Qty Per | Drawing No. | Description | Material | Rev. | Rev. Date |
| 1 | LC-049H-5 | Tension Spr.-Lee Spr. Co. | Mil-QQ-W-423, FS-302 | | |
| 1 | LC-055H-5 | Comp. Spr.-Lee Spr. Co. | AMS-5688 ** | | |
| 2 | APHD-5222-24 | Spring Plunger | AISI 10118, ASTM A-108 GR. 1018 CW 60 KSI Min. UTS 40 KSI ** Y.S. 215 BLN Max. * | C | 1/22/80 |
| 2 | APHD-5222-25 | Adjustment Screw | Holo-Krome Alloy Stl. ** | B | 1/22/80 |
| 4 | 649027-1/4 | Thread Seal | Seal EP Retainer Comm. Stl. Cad. Pltd. Appr. Comp. List Pg. 6 ** | | |
| 4 | C4-4.1 | 1/4 Plain Washer | L.C. Steel ** | | |
| 4 | C2-3.2 | 1/4-28 NF Hex Jam Nut | ASTM A307-74 GR.A or SA307 GR.B | | |
| 2 | APHD-5222-26 | Orifice Valve Stem | SA-36 or ASTM A-108-73 GR. 1018 CW | C | 12/11/80 |
| 2 | APHD-5222-27 | Retainer Plate | SA-36 or ASTM A-108-73 GR. 1018 CW ** | D | 5/6/81 |
| 4 | C2-2.6 | Retainer Plate Screw #10-32 x 1/2 Lg. Soc. Hd. Cap Scr. | Holo-Krome Alloy Stl. ** | | |
| 4 | -125 | O-Ring | Ethylene Propylene See Appr. Comp. List Pg. 6 ** | ✓ | |
| 2 | -916 | O-Ring | Ethylene Propylene See Appr. Comp. List Pg. 6 ** | ✓ | |
| 8 | | Mntg. Bolt 3/8-16 UNC x 4.375 Lg. | SA-320 GR. L7 or SA-193 GR. B7 | | |
| 65 Ft | | Tubing 1" OD x .065 Wall | A179 Soft Annealed Qual. to SA-106 GR. A ** | | |
| 1 | AH-1441 | Nameplate | .015 Thk. St. St. ** | B | 9/19/75 |
| 4 | | #4 Parker Kalon Dr. Sc. | Hardened Stl. ** | | |
| 1 | CPHD-5222- 54 | Extension Piece Ass'y | SA-181 CL-2 & SA-36 | G | 6/20/80 |
| 1 | BPHD-5222-51-1 | Extension Piece | SA-181 CL-2 | D | 3/5/82 |
| 2 | BPHD-5222- 52 | Extension Base Plate | SA-36 or SA 515 GR. 70 | C | 6/20/80 |
| 8 | APHD-5222- 58 | Lifting Lug | SA-515 GR. 65 | E | 6/20/80 |
| 28 | | Soc. Hd. Cap Scr. 1 1/4-12 UNF-2A x 7.5 Lg. | A-354 GR.BC or A-193 GR. B7 | | |
| 56 | | Washer 1 1/4 I.D. x 1.903/ 1.938 O.D. .136/.192 Thk. | SAE Hardened Steel ** | | |

| ENGINEERING PARTS LIST | | | EPL No. MB-5222- 31 | Page 5 | of 6 | Rev. 4 | Date 10/12/82 |
|------------------------|--|--|--|--------|-----------|--------|---------------|
| Qty Per | Drawing No. | Description | Material | Rev. | Rev. Date | | |
| 1 2 | 721-FSO-1/2 | Fill Port Plug, Hi Seal | Stl. w/908 EP O-Ring ** | | | | |
| 2 2 | APHD-5222-28 | Tamper-Proof Valve Cover | Steel ** | A | 1/22/80 | | |
| 3 4 | C2-2.6 | Soc. Hld. Cap Scr. 10-32 UNC-3A x .38 Lq. | Steel ** | | | | |
| 4 1 | | Safety Wire | St.St. w/Lead Press Seal ** | | | | |
| 5 1 | H-1610-P or S-1610-P or SS-1610-P Equiv. | Plug - Swagelok 1" | Brass ** Steel ** Stainless Steel ** | | | | |
| 6 1 | S810-R-16 or SS-810-R-16 Equiv. | Reducer - Swagelok 1"x1/2" | Steel ** Stainless Steel ** | | | | |
| 7 2 | S-1610-3 or SS-1610-3 Equiv. | Union Tee - Swagelok 1" | Steel ** Stainless Steel ** | | | | |
| 8 2 | S-1610-1-16 ST or SS-1610-1-16 ST Equiv. | Male Connector - Swagelok 1" | Steel ** Stainless Steel ** | | | | |
| 9 2 | | Tubing 1" O.D.x.065 WL | A179 Soft Annealed Qual. to SA106 GR. A ** | | | | |
| 10 1 | YB-2342 | Reservoir & Mntg. Brkt. | Oil-Rite (3 Gal) St. St. ** | | | | |
| 11 2 | D5689H-13 -26 | Wiper Retainer Plate | ASTM A620 ** | | | | |
| 12 20 | D5689H-13 -27 | Flat Washer 1/2 | Steel ** | | | | |
| 13 8 | D5689H-13 -28 | Push Nut - Truarc | SAE 1075 Spring Steel ** | | | | |
| 14 1 | 9200B Series - 4PP | Circle Seal Plug Valve | Bronze ** | | | | |
| 15 1 | -113 | O'Ring | Ethylene Propylene, See Appr. Comp. List Pg. 6 ** | ✓ | | | |
| 16 2 | -211 | O'Ring | Ethylene Propylene, See Appr. Comp. List Pg. 6 ** | ✓ | | | |
| 17 1 | SS-810-1-8, S-81Q-1-8 | Male Connector-Swagelok | Stainless Steel, Steel ** | | | | |
| 18 1 | SS-8-TA-1-8, S-8-TA-1-8 | Tube Adapter- Cajon | Stainless Steel, Steel ** | | | | |
| 19 1 | SS-810-P, S-810-P | Plug-Swagelok | Stainless Steel, Steel ** | | | | |
| 20 1 | BPHD-5222-278 | Filter Screen | AYSI Type 302 or 304 S.S.** | A | 1/13/81 | | |
| 21 1 | 5005-50 | Retaining Ring Truarc | Steel** | | | | |

| ENGINEERING PARTS LIST | | | EPL No. MB-5222-31 | Page 6 of 6 | Rev. 4 | Date 10/12/82 |
|------------------------|-------------|--|------------------------------------|-------------|-----------|---------------|
| Qty Per | Drawing No. | Description | Material | Rev. | Rev. Date | |
| 1 10.38 | Gallons | Hydraulic Fluid | GE SF1154 Silicone Fluid ** | | | |
| 2 | | | | | | |
| 3 | | | | | | |
| 4 | | | | | | |
| 5 | | | | | | |
| 6 | | | | | | |
| 7 | | | | | | |
| 8 | | | | | | |
| 9 | | | | | | |
| 10 | | | | | | |
| 11 | | * Code Case 1644 | **Code Exempt Per NF 2121 | | | |
| 12 | | | | | | |
| 13 | | Approved Ethylene Propylene Compounds per PHD-7559-1 | | | | |
| 14 | | Acusmet #E-17018 | Minnesota Rubber #560 ND | | | |
| 15 | | Parker #E-740-75 | National Seal, Federal Mogul #E-50 | | | |
| 16 | | Parker #E-692-75 | Mantaline, 70 Dur EPDM | | | |
| 17 | | Parker #E-515-80 | W.H. Salisbury, #80154 | | | |
| 18 | | Minnesota Rubber #559 EQ | Polyseal HK 471 | | | |
| 19 | | Minnesota Rubber #559 GT | Polyseal E2050-90 | | | |
| 20 | | | | | | |

#Denotes: (1) bearing, with mftg. identification mark, is supplied loose for snubber RCP attachment lug.

#Denotes: (1) bearing, with mftg. identification mark, is supplied loose for snubber RCP attachment lug.

| | | | |
|--------------|--------------------|-------------------|--------------------|
| Type Support | Large Bore Snubber | Size 14 Dia. Bore | EPL No. MB-5222-45 |
| Ass'y No. | D-PHD-5222-6-D1 | Cap. 1000 kips | Page 1 of 6 |

[illegible]

| ENGINEERING PARTS LIST | | | EPL No. MB-5222- 45 | Page 2 of 6 | Rev. 4 Date 10/12/82 |
|------------------------|----------------|----------------------------|--|-------------|----------------------|
| Qty Per | Drawing No. | Description | Material | Rev. | Rev. Date |
| 1 | EPHD-5222- 6 | Large Bore Snubber Ass'y | | J | 12/6/82 |
| *** 1 | CPHD-5222- 187 | Rear Brkt Ass'y | ASTM 487-74d GR. 10Q * | D | 6/23/80 |
| 1 | BPHD-5222- 106 | Rear Brkt Casting | ASTM 487-74d GR. 10Q * | D | 6/23/80 |
| 2 | APHD-5222- 12 | Lifting Lug | ASTM 487-74d GR. 10Q * | D | 6/23/80 |
| 1 | D5689H- 2 | Cylinder, Hyd MFP Model 90 | | 17 | 5/21/80 |
| 1 | D5689H- 2 -1 | Piston, Piston Rod | ASTM A668-72 CL M Forging * | | |
| 2 | D5689H- 2 -2 | Piston Seal | Ethylene Propylene See Appr. Comp. List Pg. 6 ** | | |
| 1 | D5689H- 2 -3 | Head | ASTM A516-73 GR. 70 Plate * | | |
| 1 | D5689H- 2 -4 | Pivot Lug/Cap Ass'y | ASTM 487-74d GR. 10Q * | | |
| 1 | CPHD-5222- 168 | Pivot Lug Ass'y | ASTM 487-74d GR. 10Q * | F | 6/23/80 |
| 1 | BPHD-5222-160 | Pivot Lug Casting | ASTM 487-74d GR. 10Q * | E | 6/23/80 |
| 1 | D5689H-2 -5 | Tubing | ASTM A148-73 GR. 150-125 Casting * | | |
| 1 | D5689H-2 -6 | Rod Seal | Ethylene Propylene See Appr. Comp. List Pg. 6 ** | | |
| 1 | D5689H-2 -7 | Retainer | ASTM A516-73 GR. 70 Plate * | | |
| 1 | D5689H-2 -8 | Rod Bushing | ASTM A546 GR. 80-55-06 or 80-60-03 Bronze Plate CDA 524 ** | | |
| 28 | D5689H-2 -9 | Tie Rod Nuts | ASTM-A194-71 GR. 7 or 7B * | | |
| 2 | D5689H-2 -10 | Piston Seal Backup Ring | Bronze-Leaded ASTM B584-73 Alloy 937 ** | | |
| 28 | D5689H-2 -11 | Tie Rod | ASTM A193-73 GR. B7 * | | |
| 1 | D5689H-2 -12 | Rod Pressure Ring | SAE 660 Bronze ** | | |
| 1 | D5689H-2 -13 | Rod Seal Cage | AISI 1018 or 1020 ** | | |

| ENGINEERING PARTS LIST | | | | EPL No. MB-5222- 45 | Page 3 | of 6 | Rev. 4 | Date 10/12/82 |
|------------------------|-------------|------------------|--|---|--------|------|-----------|---------------|
| Qty Per | Drawing No. | | Description | Material | | Rev. | Rev. Date | |
| 1 | 2 | D5689H- 2 -14 | Cylinder End Seal | Ethylene Propylene See Appr. Comp. List Pg. 6 | | ✓ | | |
| 2 | 1 | D5689H- 2 -15 | Rod Wiper | Ethylene Propylene ** See Appr. Comp. List Pg. 6 | | ✓ | | |
| 3 | 1 | D5689H- 2 -16 | Rod Wave Spring | AISI 1070-1090 Spr. Stl. R _C 44-54 ** | | | | |
| 4 | 2 | D5689H- 2 -17 | Piston Anti Roll Ring | AISI 1010 or 1018 R _B 40 Max. ** | | | | |
| 5 | 2 | D5689H- 2 -18 | Piston Retaining Ring | AISI 1070 or 1090 Apr. Stl. R _C 44-54 ** | | | | |
| 6 | 1 | D5689H- 2 -19 | Piston Wear Ring | Bronze-Leaded ** ASTM B584-73 Alloy 937 | | | | |
| 7 | 2 | D5689H- 2 -20 | SKF GEZ 408 ESB Spherical Bearing | Steel ** | | | | |
| 8 | | D5689H- 2 -21 | Retainer Scr. 5/16 - 24 x 1 1/2 Lg. | ASTM A354-66 GR. BB, BC, BD * | | | | |
| 9 | | D5689H- 2 -22 | Retaining Ring | AISI 1075-1095 Spr. Stl. R _C 47-51 ** | | | | |
| 10 | 1 | CPHD-5222- 180-3 | Clevis Ass'y | ASTM 487-74d GR. 10Q * | | E | 6/23/80 | |
| 11 | 1 | BPHD-5222- 178 | Clevis End Casting | ASTM 487-74d GR. 10Q * | | F | 6/23/80 | |
| 12 | 1 | BPHD-5222- 131-1 | Pivot Pin - R.B. | A564-74 GR. XM-13 * | | D | 6/20/80 | |
| 13 | 4 | 5100- 450 | Retaining Ring (TRUARC) | AISI 1075-1095 Spr. Stl. R _C 47-51 ** | | | | |
| 14 | 1 | BPHD-5222- 131-2 | Pivot Pin, Clevis | A564-74d GR. 10Q * | | D | 6/20/80 | |
| 15 | 2 | BPHD-5222-20 | Snubber Valve Ass'y | | | D | 1/26/80 | |
| 16 | 2 | BPHD-5222-21 | Valve Body | AISI 10L18 ASTM A108 GR. 1018 CW 60 ksi Min. UTS. 40 ksi Y.S. 215 BHN Max. * | | H | 6/19/81 | |
| 17 | 2 | APHD-5222-22 | Valve Poppet | AISI 10L18 Min. UTS. 40 ksi Y.S. 215 BHN Max. * | | D | 1/14/81 | |
| 18 | 2 | APHD-5222-23 | Valve Seat Disc | ASTM A515-72 GR. 65 or 70 | | F | 3/25/80 | |
| 19 | 1 | LC-045H-5 | Tension Spr. - Lee Spr. Co. | Mil-QQ-W-423, FS-302 AMS-5688 ** | | | | |
| 19 | 1 | LC-049H-5 | Comp. Spr. - Lee Spr. Co. | AISI 10L18 ASTM A108 GR. 1018 CW 60 ksi Min. UTS. 40 ksi Y.S. 215 BHN Max. ** | | C | 1/22/80 | |
| 20 | 2 | APHD-5222-24 | Spring Plunger | | | | | |
| | | APHD-5222-25 | Adjustment Screw | Holo Krome Alloy Steel ** | | B | 1/22/80 | |

| ENGINEERING PARTS LIST | | | EPL No. MB-5222-45 | Page 4 of 6 | Rev. 4 Date 10/12/82 |
|------------------------|-------------|--|---|---|----------------------|
| Qty Per | Drawing No. | Description | Material | Rev. | Rev. Dat |
| 1 | 4 | 649027-1/4 | Thread Seal | Seal-E.P. Retainer Comm. Stl. Cap. Pltd. Appr. Comp. List Pg. 6 | ✓ |
| 2 | 4 | C4-4.1 | 1/4 Plain Washer | L.C. Steel ** | |
| 3 | 4 | C2-3.2 | 1/4-28 NF Hex Jam Nut | ASTM A307-74 GR.A OR SA307 GR.B | |
| 4 | 2 | APHD-5222-26 | Orifice Valve Stem | SA 36 or ASTM A108-73 GR. 1018 CW | C 12/11/80 |
| 5 | 2 | APHD-5222-27 | Retainer Plate | SA 36 or ASTM A108-73 GR. 1018 CW ** | D 5/8/81 |
| 6 | 4 | C2-2.6 | Retainer Plate Screw 10-32 UNF x 1/2 Lq. Soc. Hd. Cap Scr | Holo Krome Alloy Steel ** | |
| 7 | 4 | -125 | O-Ring | Ethylene Propylene See Appr. Comp. List Pg. 6 ** | ✓ |
| 8 | 2 | -916 | O-Ring | Ethylene Propylene See Appr. Comp. List Pg. 6 ** | ✓ |
| 9 | 65 Feet | | Tubing 1" OD x .065 wall | A179 Soft Annealed Qual. to SA106 GR. A ** | |
| 10 | 1 | AH-1441 | Nameplate | .015 Thk. St. St. ** | B 9/19/75 |
| 11 | 4 | | #4 Parker Kalon Drive Scr. | Hardened Steel ** | |
| 12 | 2 | 721-FSO-1/2 | Fill Port Plug, Hi Seal | Stl. w/908 EP O-ring ** | ✓ |
| 13 | 2 | APHD-5222-28 | Tamper-Proof Valve Cover | Steel ** | A 1/22/80 |
| 14 | 4 | C2-2.6 | Soc. Hd. Cap Screw #10-32 UNC -3A x .38 Lq. | Steel ** | |
| 15 | 1 | | Safety Wire | St. St. w/Lead Press Seal ** | |
| 16 | 1 | S-1610-P or SS-1610-P Equiv. | Plug - Swagelok 1" | Brass ** Steel ** Stainless Steel ** | |
| 17 | 1 | S-810-R-16 or SS-810-R-16 Equiv. | Reducer - Swagelok 1"x1/2" | Steel ** Stainless Steel ** | |
| 18 | 2 | S-1610-3 or SS-1610-3 Equiv. | Union Tee - Swagelok 1" | Steel ** Stainless Steel ** | |
| 19 | 2 | S-1610-1-16ST or SS-1610-1-16ST Equiv. | Male Connector - Swagelok 1" | Steel ** Stainless Steel ** | |
| 20 | 2 | | Tubing 1" O.D.x.065 Wall | A179 Soft Annealed Qual. to SA106 GR. A ** | |

| ENGINEERING PARTS LIST | | | EPL NO. MB-5222-45 | Page 5 of 6 | Rev. 4 | Date 10/12/82 |
|------------------------|-------------------------|--------------------------|--|-------------|-----------|---------------|
| Qty Per | Drawing No. | Description | Material | Rev. | Rev. Date | |
| 1 | YB-2342 | Reservoir & Mntg. Brkt. | Oil-Rite (3 Gal) St. St. ** | | | |
| 2 | D5689H-2 -24 | Wiper Retainer Plate | ASTM A620 ** | | | |
| 3 | D5689H-2 -25 | Flat Washer 1/2 | Steel ** | | | |
| 4 | D5689H-2 -26 | Push Nut- Truarc | SAE 1075 Spring Steel ** | | | |
| 5 | 9200B Series - 4PP | Circle Seal Plug Valve | Bronze ** | | | |
| 6 | -113 | O'ring | Ethylene Propylene, See Appr. Comp. List, Pg. 6 ** | | | |
| 7 | -211 | O'ring | Ethylene Propylene, See Appr. Comp. List, Pg. 6 ** | | | |
| 8 | SS-810-1-8, S-810-1-8 | Male Connector- Swagelok | Stainless Steel, Steel ** | | | |
| 9 | SS-8-TA-1-8, S-8-TA-1-8 | Tube Adapter- Swagelok | Stainless Steel, Steel ** | | | |
| 10 | SS-810-P, S-810-P | Plug- Swagelok | Stainless Steel, Steel ** | | | |
| 11 | D5689H-2 -23 | 5/16 Flat Washer | Steel ** | | | |
| 12 | BPHD-5222-278 | Filter Screen | AISI Type 302 or 304 S.S. ** A | | 1/13/81 | |
| 13 | 5005-50 | Retaining Ring Truarc | Steel ** | | | |
| 14 | 7.21 Gallons | Hydraulic Fluid | GE SF1154 Silicone Fluid ** | | | |
| 15 | | | | | | |
| 16 | | | | | | |
| 17 | | | | | | |
| 18 | | | | | | |
| 19 | | | | | | |
| 20 | | | | | | |

| ENGINEERING PARTS LIST | | | EPL No. MB-5222-45 | Page 6 of 6 | Rev. 4 | Date 10/12/82 |
|------------------------|-------------|-------------|--------------------|-------------|-----------|---------------|
| Qty Per | Drawing No. | Description | Material | Rev. | Rev. Date | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |

Denotes: (1) bearing, with mftg. identification mark, is supplied loose for snubber RCP attachment lug.

*Code Case 1644


A Quantity of One (1) of These Items Will Accomodate Two (2) D-1 Snubber Assemblies

Approved Ethylene - Propylene Compounds per PHD-7559-1

| | |
|--------------------------|------------------------------------|
| Acushnet #E-17018 | Minnesota Rubber #560 ND |
| Parker #D-740-75 | National Seal, Federal Mogul #E-50 |
| Parker #E-690-75 | Mantol line, 70 Dur EPDM |
| Parker #E-515-80 | W. H. Salisbury, #80154 |
| Minnesota Rubber #559 EQ | Polyseal HK 471 |
| Minnesota Rubber #559 GT | Polyseal E2050-90 |

Reference 14


EPRI, "Radiation Effects on Organic Materials in Nuclear Plants", Report EPRI NP-2129, November 1981.




| TORQUE VALUES | |
|------------------|-----------------|
| TYPE | VALUE FT LBS |
| EXT. FC STUDS | 47.5 |
| ME. RODS | 100 |
| BLEV. END | 600 |
| VALVE MTG. BOLTS | 75 |
| FILL PORT PLUG | 7 |

| SNUBBER INSTALLATION DRAWING | SNUBBER ASSEMBLY NO. | CYL SIZE | QTY | LOAD/ SNBR KIPS | SPRING RATE KIP-INCH | | PISTON POSITION | | PISTON SE "A-A" |
|------------------------------------|----------------------------|-------------|-----|-----------------------|-------------------------|---------|-----------------|--------|--------------------|
| | | | | | COMP. | TENSION | HOT | COLD | |
| B PHD 5222-83 | PHD-5222-8-H2 | 20 | 2 | 1500 | 11,002 | 11,240 | 128.64 | 129.54 | 8.39 |

| SNUBBER INSTALLATION DRAWING | SNUBBER IDENTIFICATION | CYL SIZE | QTY | LOAD/ SNBR KIPS | SPRING RATE KIP-INCH | | PISTON POSITION | | PISTON "A-A" |
|------------------------------------|---------------------------|-------------|-----|-----------------------|-------------------------|---------|-----------------|---------|-----------------|
| | | | | | COMP. | TENSION | HOT | COLD | |
| B PHD 5222-83 | 1-H2-1 | 20 | 1 | 1500 | 9,412 | 10,858 | 128.450 | 129.340 | Ø 8.33 |
| | 1-H2-2 | | | | | | 128.542 | 129.432 | |
| | 2-H2-1 | 20 | 1 | 1500 | 9,484 | 11,310 | 128.516 | 129.406 | |
| | 2-H2-2 | | | | | | | | |




NOTE: VALVE ASSY LOCATED ON CAP
IS ABOVE G ON THIS SIDE AND
BELOW G ON OPPOSITE SIDE



ING

TING



10 GAL. CYLINDRICAL RESERVOIR

TOTAL ASSY WT 12.00 LBS

FOR REFERENCE ONLY

MOLAND PLANT UNIT 124
CONTAINER POWER

| | | | | |
|---------------------------|----------------|----------------------------|---|------------------------|
| SCALE NONE | EPL NE 5 22 02 | LIST OF PARTS PHD-522-8 | ITT Grinnell Corporation PIPE HANGER DIVISION RESEARCH DEVELOPMENT & ENGINEERING PROVIDENCE R.I. | |
| MAT'L SPEC | FAB SPEC | WELD SPEC | WDE PROCEDURE | FINISH EXCEPT AS NOTED |
| Q.A. REVIEW | | | | |
| TOLERANCE EXCEPT AS NOTED | | DATE 1-2-70 | D PHD-522-8 | |
| FRAC | DRAWN | CHK'D | APPD | REV |
| DEC | CHK'D | APPD | | |
| ANG | | | | |
| LARGE BORE SNUBBER ASSY | | | REV | |
| ECC-12, EC-1220, D-AC | | | F | |

| | | | | |
|----|-----------------------|-----|-----|-----|
| 1 | TEMPERATURE SENSITIVE | 1.1 | 1.1 | 1.1 |
| 2 | TEMPERATURE SENSITIVE | 1.1 | 1.1 | 1.1 |
| 3 | TEMPERATURE SENSITIVE | 1.1 | 1.1 | 1.1 |
| 4 | TEMPERATURE SENSITIVE | 1.1 | 1.1 | 1.1 |
| 5 | TEMPERATURE SENSITIVE | 1.1 | 1.1 | 1.1 |
| 6 | TEMPERATURE SENSITIVE | 1.1 | 1.1 | 1.1 |
| 7 | TEMPERATURE SENSITIVE | 1.1 | 1.1 | 1.1 |
| 8 | TEMPERATURE SENSITIVE | 1.1 | 1.1 | 1.1 |
| 9 | TEMPERATURE SENSITIVE | 1.1 | 1.1 | 1.1 |
| 10 | TEMPERATURE SENSITIVE | 1.1 | 1.1 | 1.1 |
| 11 | TEMPERATURE SENSITIVE | 1.1 | 1.1 | 1.1 |
| 12 | TEMPERATURE SENSITIVE | 1.1 | 1.1 | 1.1 |
| 13 | TEMPERATURE SENSITIVE | 1.1 | 1.1 | 1.1 |
| 14 | TEMPERATURE SENSITIVE | 1.1 | 1.1 | 1.1 |
| 15 | TEMPERATURE SENSITIVE | 1.1 | 1.1 | 1.1 |

REPLACEMENT INTERVAL CALCULATION FOR THE ITT

Title of Calculation: GRINNELL HYDRAULIC SNUBBER SEALS AND HYDRAULIC FLUID

Project: MIDLAND PLANT UNITS 1 & 2

Client: CONSUMERS POWER COMPANY File Number: EPC-09-E.041

Check as Applicable ☒ Manual Calculation ☐ Computer Calculation

Method: THE REPLACEMENT INTERVALS FOR ORGANIC MATERIALS HAS BEEN QUANTIFIED UTILIZING THE ARRHENIUS METHODOLOGY AS RECOMMENDED IN NUREG-0588.

Assumptions: (SEE PAGE 3 OF 6)

References: (SEE PAGE 4 OF 6)

Computer Run Information: (future revision changes shall be shown in the body of the calculation)

Computer Run Document Number: _____ Date: _____
 Computer Program: _____ Version: _____
 QA Category (QEP 3-5): _____ Verified: ☐ /YES ☐ /No
 Operating System: _____ Version: _____
 Tape Number: _____ Date: _____

| Calculation Revision | Description of Change | Approval Signature | Date |
|----------------------|-----------------------|-----------------------------|--------------------|
| 0 | N/A | with R Kelly R. A. Kelly | 1/20/83 1/20/83 |
| | | | |
| | | | |
| | | | |

REPLACEMENT INTERVAL CALCULATION FOR THE ITT GRINNELL

TITLE: HYDRAULIC SNUBBER SEALS AND HYDRAULIC FLUIDPROJECT: MIDLAND PLANT, UNITS 1 & 2CLIENT: CONSUMERS POWER COMPANY FILE NUMBER: CPC-09-E.041Method of Verification (Check as applicable)☒ Criteria Check* ☐ Alternate Calculation (attached)☐ Design Review ☐ Qualification Testing☐ Other: MARKED UP CALCULATION IN ACCORDANCE WITH 3-2IF APPLICABLENote: An accuracy check must be performed of all work.

*The signature below signifies that this calculation has received design verification by a criteria check. No other signature will be shown on the individual sheets to document this verification.

| <u>Revision</u> | <u>Signature</u> | <u>Revision</u> | <u>Signature</u> |
|-----------------|---------------------|-----------------|------------------|
| <u>0</u> | <u>W. R. KELLEY</u> | _____ | _____ |
| _____ | _____ | _____ | _____ |
| _____ | _____ | _____ | _____ |
| _____ | _____ | _____ | _____ |

Personnel Identification

All personnel participating in preparing, checking and approving this calculation must enter the below information.

| <u>Name (Printed)</u> | <u>Signature</u> | <u>Initials</u> | <u>Employee No.</u> |
|--------------------------|--------------------------|-----------------|---------------------|
| <u>M. ROSA LEE</u> | <u>M. Rosa Lee</u> | <u>MLR</u> | <u>0838</u> |
| <u>W. R. KELLEY</u> | <u>W. R. KELLEY</u> | <u>WRK</u> | <u>0803</u> |
| <u>P. A. DiBENEDETTO</u> | <u>P. A. DiBenedetto</u> | <u>PAB</u> | <u>0593</u> |
| _____ | _____ | _____ | _____ |
| _____ | _____ | _____ | _____ |
| _____ | _____ | _____ | _____ |

PROJECT Midland Units 1 & 2 FILE NO. CPC-09-E.041
OWNER Consumers power Co.
CLIENT Consumers power Co.

Purpose

This calculation justifies the replacement interval of non-metallic parts in the ITT Grinnell Hydraulic Snubber due to thermal degradation.

Results

Fluid & Seal replacement due to thermal degradation should be accomplished on a 5 year interval. Calculations are shown on page 4.

Assumptions

1. The Hydraulic Snubber is subjected to a constant 120°F temperature.
2. The activation energy for Ethylene Propylene is 0.95 eV.
for Hydraulic Fluid (silicon base) is 1.1 eV (Reference 2)
3. The material degradation is a function of temperature only - i.e. Arrhenius methodology is applicable to determine the thermal degradation.

| | | | | | | |
|--------------------|-------------|--|--|--|--|---------------|
| REVISION | 0 | | | | | PAGE <u>3</u> |
| PREPARED BY / DATE | MRT 1/6/83 | | | | | OF <u>6</u> |
| CHECKED BY / DATE | CRC 1/20/83 | | | | | |

PROJECT Midland Units 1 & 2 FILE NO. CPC-09-E.041
 OWNER Consumers Power Co.
 CLIENT Consumers Power Co.

Reference

1. ITT Grinnell Corp. "Radiation and Environmental Test of Seal and Fluid materials for snubbers", Report No. PHD-5439-2R
 Rev. 1, July 23, 1977
2. EPRI, "A Review of Equipment Aging Theory and Technology"
 EPRI Report EPRI NP-1538, September 1980

Calculations

The qualified life of the seals made of EPDM (listed on page 5) based on thermal degradation can be established by using the Arrhenius relationship and test data from Reference 1. During testing the seals were subjected to a temperature of 268°F for a period of 72 hours (Ref 1).

The Arrhenius relationship can be written as:

$$\ln\left(\frac{t_1}{t_2}\right) = \frac{\phi}{K} \left(\frac{1}{T_1} - \frac{1}{T_2} \right)$$

where: t_1 = qualified service life

t_2 = time at test temperature = 72 hours

| | | | | | | |
|--------------------|-------------|--|--|--|--|---------------|
| REVISION | 0 | | | | | PAGE <u>7</u> |
| PREPARED BY / DATE | MIR 1/6/83 | | | | | OF <u>6</u> |
| CHECKED BY / DATE | LAK 1/24/83 | | | | | |

nutech

Bethesda, Maryland

PROJECT Midland Units 1 & 2 FILE NO. CPC-09-E.041
OWNER Consumers power Co.
CLIENT Consumers power Co.

ϕ = activation energy for Ethylene propylene
= 0.95 eV.

K = Boltzmann's Constant = 0.8617×10^{-4} eV/K

T_1 = service temperature = $120^\circ\text{F} = 321.9^\circ\text{K}$

T_2 = test temperature = $268^\circ\text{F} = 404.1^\circ\text{K}$

$$\ln\left(\frac{t_1}{72}\right) = \frac{0.95}{0.8617 \times 10^{-4}} \left(\frac{1}{321.9} - \frac{1}{404.1} \right)$$
$$= 6.96792$$

$$t_1 = 72 \times e^{6.96792}$$
$$= 7.6465 \times 10^4 \text{ hr}$$
$$= \underline{8.73 \text{ yrs}}$$

The activation energy of hydraulic fluid is higher than that of seals. Therefore the service life of hydraulic fluid is longer than 8.73 yrs. For conservatism, a 5-year replacement interval is recommended for both seals and hydraulic fluid.

| | | | | | | |
|--------------------|--------------------|--|--|--|--|---------------|
| REVISION | <u>C</u> | | | | | PAGE <u>5</u> |
| PREPARED BY / DATE | <u>MKL 11/1/82</u> | | | | | OF <u>6</u> |
| CHECKED BY / DATE | <u>LAK 1/20/83</u> | | | | | |

MIDLAND SNUBBER SEALS

| ITEM | SEAL TITLE | LOCATION | FUNCTION-TYPE | SIZE | MANUFACTURER | COMPOUND | CURE METHOD |
|------|-------------------------|------------------|-----------------|-------------------|------------------|----------|---------------|
| 1 | O-RING - OUTLET ADAPTER | RESERVOIR | STATIC - O-RING | 1.737 ID x .103 W | FEDERAL - MOGUL | E 50 | EPDM-PEROXIDE |
| 2 | O-RING - DRAIN ADAPTER | RESERVOIR | STATIC - O-RING | .987 ID x .103 W | FEDERAL - MOGUL | E 50 | EPDM-PEROXIDE |
| 3 | O-RING - FILTER ADAPTER | RESERVOIR | STATIC - O-RING | .987 ID x .103 W | FEDERAL - MOGUL | E 50 | EPDM-PEROXIDE |
| 4 | O-RING - MTG. STUDS | SIGHT GLASS-RES. | STATIC - O-RING | .487 ID x .103 W | FEDERAL - MOGUL | E 50 | EPDM-PEROXIDE |
| 5 | O-RING - GLASS GAUGE | SIGHT GLASS-RES. | STATIC - O-RING | .299 ID x .103 W | FEDERAL - MOGUL | E 50 | EPDM-PEROXIDE |
| 6 | O-RING - CAP | SIGHT GLASS-RES. | STATIC - O-RING | .551 ID x .070 W | FEDERAL - MOGUL | E 50 | EPDM-PEROXIDE |
| 7 | O-RING - CR. SEAL VALVE | TUBING RUN | STATIC - O-RING | .796 ID x .139 W | FEDERAL - MOGUL | E 50 | EPDM-PEROXIDE |
| 8 | O-RING - CR. SEAL VALVE | TUBING RUN | STATIC - O-RING | .549 ID x .103 W | FEDERAL - MOGUL | E 50 | EPDM-PEROXIDE |
| 9 | EXTERNAL BEARING SEAL | MODEL 52 ONLY | STATIC - O-RING | VARIOUS | ACUSHNET | E 17018 | EPDM-PEROXIDE |
| 10 | ROD SEAL | CYLINDER | DYNAMIC - LIP | VARIOUS | MINNESOTA RUBBER | 555-EQ | EPDM-PEROXIDE |
| 11 | O-RING - END SEAL | CYLINDER | STATIC - O-RING | VARIOUS | ACUSHNET | E 17018 | EPDM-PEROXIDE |
| 12 | ROD WIPER | CYLINDER | DYNAMIC - LIP | VARIOUS | MINNESOTA RUBBER | 559-EQ | EPDM-PEROXIDE |
| 13 | PISTON SEAL | CYLINDER | DYNAMIC - U-CUP | VARIOUS | W.H.SALISBURY | 80154 | EPDM-SULFUR |
| 14 | O-RING - VALVE | TUBE CONN. | STATIC - O-RING | 1.171 ID x .116 W | FEDERAL - MOGUL | E 50 | EPDM-PEROXIDE |
| 15 | O-RING - VALVE | RETAINER PL. | STATIC - O-RING | 1.299 ID x .103 W | FEDERAL - MOGUL | E 50 | EPDM-PEROXIDE |
| 16 | THREAD SEAL | VALVE | STATIC - THREAD | .644 ID x .087 W | FEDERAL - MCSUL | E 50 | EPDM-PEROXIDE |
| 17 | THREAD SEAL | VALVE | STATIC - THREAD | 1.299 ID x .103 W | FEDERAL - MOGUL | E 50 | EPDM-PEROXIDE |
| 18 | FILL PORT PLUG | CYLINDER | STATIC - O-RING | .644 ID x .087 W | FEDERAL - MOGUL | E 50 | EPDM-PEROXIDE |
| 19 | FILL PORT PLUG | CYLINDER | STATIC - O-RING | .755 ID x .097 W | FEDERAL - MOGUL | E 50 | EPDM-PEROXIDE |

| CYLINDER MODEL | QUANTITY OF SEALS |
|----------------|-------------------|
| 52 | 30 |
| 50 | 29 |

TABLE 4

CPC-09-E.041
page 6 of 6
1/6/13
1/20/13

Client: CONSUMERS POWER COMPANY File Number: CPC-09-E.040

Method: THIS CALCULATION UTILIZES CONVECTIVE AND CONDENSING HEAT TRANSFER EVALUATIONS FOR SURFACE TEMPERATURE ANALYSES OF THE SUBJECT EQUIPMENT UNDER POSTULATED MSLB CONDITIONS FOR THE MIDLAND PLANT.

Assumptions: SEE PAGE 4 OF 20

References: SEE PAGE 5 OF 20

Computer Run Document Number: _____ Date: _____
Computer Program: _____ Version: _____
QA Category (QEP 3-5): _____ Verified: / YES / NO
Operating System: _____ Version: _____
Tape Number: _____ Date: _____

| Calculation Revision | Description of Change | Approval Signature | Date |
|-------------------------|-----------------------|------------------------------------|--------------------|
| 0 | N/A | with 2 Kelly <i>[Signature]</i> | 1/20/83 1/24/83 |
| | | | |
| | | | |
| | | | |

SURFACE TEMPERATURE ANALYSIS FOR THE ITT

TITLE: GRINNELL HYDRAULIC SNUBBERS

PROJECT: MIDLAND PLANT, UNITS 1 & 2

CLIENT: CONSUMERS POWER COMPANY FILE NUMBER: CPC-09-E040

Method of Verification (Check as applicable)

☒ Criteria Check* ☐ Alternate Calculation (attached)
☐ Design Review ☐ Qualification Testing
☐ Other: MARKED UP CALCULATION IN ACCORDANCE WITH 3-2
IF APPLICABLE

Note: An accuracy check must be performed of all work.

*The signature below signifies that this calculation has received design verification by a criteria check. No other signature will be shown on the individual sheets to document this verification.

| <u>Revision</u> | <u>Signature</u> | <u>Revision</u> | <u>Signature</u> |
|-----------------|---------------------|-----------------|------------------|
| <u>0</u> | <u>W. R. KELLEY</u> | _____ | _____ |
| _____ | _____ | _____ | _____ |
| _____ | _____ | _____ | _____ |
| _____ | _____ | _____ | _____ |

Personnel Identification

All personnel participating in preparing, checking and approving this calculation must enter the below information.

| <u>Name (Printed)</u> | <u>Signature</u> | <u>Initials</u> | <u>Employee No.</u> |
|--------------------------|--------------------------|-----------------|---------------------|
| <u>M. ROSA LEE</u> | <u>M. Rosa Lee</u> | <u>MLR</u> | <u>0838</u> |
| <u>W. R. KELLEY</u> | <u>W. R. KELLEY</u> | <u>WRK</u> | <u>0803</u> |
| <u>P. A. DiBENEDETTO</u> | <u>P. A. DiBenedetto</u> | <u>PAD</u> | <u>0593</u> |
| _____ | _____ | _____ | _____ |
| _____ | _____ | _____ | _____ |
| _____ | _____ | _____ | _____ |

nutech

Bethesda, Maryland

PROJECT Midland Units 1 & 2 FILE NO. CPC-09-E, 040
OWNER Consumers Power Co.
CLIENT Consumers Power Co.

Purpose

The purpose of this calculation is to determine the surface temperature of the hydraulic snubber seals during an MSLB environment (which envelops LOCA temperature profile). The NRC CSB-IEM method is used to determine the maximum surface temperature.

Results

The results are shown on pages 10 & 11.

| | | | | | | | |
|--------------------|-------------|--|--|--|--|------|----|
| REVISION | c | | | | | PAGE | 3 |
| PREPARED BY / DATE | HLK 1/7/83 | | | | | OF | 20 |
| CHECKED BY / DATE | HLK 1/24/83 | | | | | | |

PROJECT Midland Units 1 & 2

FILE NO. CPC-09-E.040

OWNER Consumers Power Co.

CLIENT Consumers Power Co.

Assumptions:

1. The initial temperature of the seals T_0 is 120°F (was given as the maximum normal surface temperature)
2. The convective heat transfer coefficient $h_c = 750 \text{ Btu}/(\text{hr} \cdot \text{ft}^2 \cdot \text{F})$ has been assumed constant whenever the condensing heat flux is less than the convective heat flux. The condensing heat flux will be calculated based on the four times of the Targem condensing heat transfer coefficient taken from figure 3 which is from figure A-1 of Reference 2.
3. The transient bulk temperature profile is shown on figure 1 which is from midland figure F2 of Reference 2.
4. The equivalent thermal conductivity k_e is determined based on the composite wall model.
5. The equivalent $(\rho C_p)_e$ (the product of material specific heat and density) is determined based on the composite wall model.
6. The temperature rise of the object after being exposed 1 second of a sudden change of outside environmental temperature is slow enough to be overridden by the temperature rise resulted from the next sudden change of outside temperature.
7. The equivalent k_e and $(\rho C_p)_e$ are used to determine the surface temperature of the Neutron detector, e.g. the heat transferred through a composite wall with different k 's and (ρC_p) 's is equivalent to the heat transferred through a single wall with k_e and $(\rho C_p)_e$.
8. The environmental steam partial pressure is equal to the containment pressure.

| | | | | | | |
|--------------------|-------------|--|--|--|--|---------------|
| REVISION | 0 | | | | | PAGE <u>4</u> |
| PREPARED BY / DATE | N/K 4/1/83 | | | | | OF <u>20</u> |
| CHECKED BY / DATE | WOK 4/20/83 | | | | | |

nutech

Bethesda, Maryland

PROJECT Midland Units 1 & 2 FILE NO. CPC-09-E, 040
OWNER Consumers Power Co.
CLIENT Consumers Power Co.

References

1. Kreith, Frank : "Principles of Heat Transfer" International Textbook Company, Scranton, PA 1965.
2. Midland 1 & 2 - FSAR Equipment Qualification, Report on Equipment Qualification for Main Steam Line Break Conditions.
3. Holman, J. P. "Heat Transfer" McGraw Hill, Inc, 1968
4. Crane "Flow of Fluids Through Valves, Fittings, and Pipe" Technical paper No 410.
5. NUREG 0588, "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment", Rev. 1, Jul 1981.
6. Keenan, Keyes, Hill, and Moore, "Steam Tables" John Wiley & Sons, Inc. 1969.

| | | | | | | | |
|--------------------|--------------|--|--|--|--|------|----|
| REVISION | 0 | | | | | PAGE | 5 |
| PREPARED BY / DATE | NIKE 1/7/83 | | | | | OF | 20 |
| CHECKED BY / DATE | CAIC 1/20/83 | | | | | | |

PROJECT Midland Units 1 & 2


FILE NO. CPC-09-E.040

OWNER Consumers Power Co.

CLIENT Consumers Power Co.

Introduction

Non-metallic components of the IIT Grinnell Hydraulic Snubber consist of hydraulic fluid and seals at various locations. The seals are listed on page 18 and their locations are shown on page 19. The seals are made of EPDM (a Ethylene propylene based material). Item 7 of the list on page 18 is the one that is direct exposed to the accident environment and has the least heat conductive material next to it. For conservatism, the surface temperature determined for No 7 seal will be compared to the temperature of 350 °F which is recognized as maximum service temperature* of EPDM by the industry. The dimension of the circle seal valve (to which No 7 seal is attached) is sketched as follows:



* for continuous use

| | | | | | | |
|--------------------|-------------|--|--|--|--|---------------|
| REVISION | 0 | | | | | PAGE <u>6</u> |
| PREPARED BY / DATE | MDZ 1/18/20 | | | | | OF <u>20</u> |
| CHECKED BY / DATE | WAX 1/20/20 | | | | | |

PROJECT Midland Units 1 & 2
OWNER Consumers Power Co.
CLIENT Consumers Power Co.

FILE NO. CPC-09-E, 040

material properties

(1) Ethylene-propylene

$$K = 0.19 \text{ Btu/in} \cdot \text{ft} \cdot ^\circ\text{F}$$

Reference 2, page 16

$$C_p = 0.65 \text{ Btu/lb} \cdot ^\circ\text{F}$$

Reference 2, page 16

$$\rho = 81.1 \text{ lbm/ft}^3$$

Reference 2, page 16

$$(\rho C_p)_{\text{wall}} = 52.7 \text{ Btu/ft}^3 \cdot ^\circ\text{F}$$

Reference 2, page 16

(2) Stainless Steel


$$K = 10.0 \text{ Btu/in} \cdot \text{ft} \cdot ^\circ\text{F}$$

$$(\rho C_p)_{\text{value body}} = 54.0 \text{ Btu/ft}^3 \cdot ^\circ\text{F}$$

Reference 2, page 18

Calculation

This problem is treated as a joint cylinder
subject to an NISLB temperature exposure.



$$2a = 0.796 + 0.139 \times 2 = 1.074$$

$$a = 0.537$$

$$r_0 = \frac{0.796 + 0.139}{2}$$

$$= 0.537"$$

| | | | | | | |
|--------------------|-------------|--|--|--|--|--------|
| REVISION | 0 | | | | | PAGE 7 |
| PREPARED BY / DATE | IIIK 1/1/82 | | | | | OF 20 |
| CHECKED BY / DATE | WAK 1/20/82 | | | | | |

PROJECT Midland units 1 & 2 FILE NO. CPC-09-E.040
 OWNER Consumers Power Co.
 CLIENT Consumers Power Co.

$$K_e = \frac{\frac{0.796 + 2 \times 0.139}{0.796} + \frac{2 \times 0.139}{0.19}}{10} = 0.6962$$

$$(PCp)_e = \frac{\frac{1.074}{0.796} + \frac{0.22}{52.7}}{54.0} = 53.657$$

For X-direction

Fourier modulus FF_0 for $T = 1 \text{ sec}$

$$FF_0 = \frac{K_e \cdot T}{(PCp)_e \cdot h^2} = \frac{0.6962 \cdot \frac{1}{3600}}{53.657 \cdot \left(\frac{10.537}{12}\right)^2} = 1.8 \times 10^{-3}$$

Biot Modulus Bi for $R = 250 \text{ BTU/hr-ft}^2\text{-}^\circ\text{F}$ (convective heat transfer coefficient)

$$Bi = \frac{R \cdot h}{K_e} = \frac{250 \cdot \frac{0.537}{12}}{0.6962} = 16.069$$

$$Bi^{-1} = 6.22 \times 10^{-2} = 0.0622$$

For y-direction

Fourier Modulus FF_0 for $T = 1 \text{ sec}$

$$FF_0 = \frac{K_e \cdot T}{(PCp)_e \cdot a^2} = 1.8 \times 10^{-3}$$

Biot Modulus Bi for $R = 250 \text{ BTU/hr-ft}^2\text{-}^\circ\text{F}$

$$Bi = \frac{R \cdot a}{K_e} = 16.069$$

$$Bi^{-1} = 0.0622$$

| | | | | | | |
|--------------------|-------------|--|--|--|--|--------|
| REVISION | 0 | | | | | PAGE 8 |
| PREPARED BY / DATE | WIK 1/18/23 | | | | | OF 20 |
| CHECKED BY / DATE | WAK 1/18/23 | | | | | |

PROJECT Midland Units 1 & 2 FILE NO. CPL-09-E.040
 OWNER Consumers Power Co.
 CLIENT Consumers Power Co.

To calculate the Temperature at pt. A (the surface of the seals) the relationship $T_s = \theta(T_o - T_{\infty}) + T_{\infty}$ and figures 1, 2, 3 and 4 are used. Here:

$$\theta_{\text{cyl 20 long}} = \theta_{\text{infinite cyl}} \cdot \theta_{\text{2a plate}}$$

$$\theta = \theta_x \cdot \theta_y$$

From figure 2, page 15

$$\theta_x = 0.985 \quad \text{from } x/L = 1.0 \text{ chart}$$

From figure 3, page 16

$$\theta_y = 0.99 \quad \text{from } x/L = 1.0 \text{ chart}$$

$$\therefore \theta = 0.985 \times 0.99 = 0.975$$

$$\text{at } t=0 \quad \text{seal surface} = 120^\circ\text{F} \quad T_{\infty} = 120^\circ\text{F}$$

$$t=1 \quad \text{seal surface} = 120^\circ\text{F} \quad T_{\infty} = 230^\circ\text{F}$$

$$t=2 \quad \tau=1 \quad \theta=0.975 \quad T_{\infty}=230 \text{ @ } t=1 \quad \text{from figure 1}$$

$$T_s = 0.975(120 - 230) + 230 = 122.8^\circ\text{F}$$

$$t=3 \quad \tau=1 \quad \theta=0.975 \quad T_{\infty}=290 \text{ @ } t=2 \quad \text{from figure 1}$$

$$T_s = 0.975(122.8 - 290) + 290 = 126.9^\circ\text{F @ } t=3$$

| | | | | | | |
|--------------------|------------|--|--|--|--|--------|
| REVISION | 0 | | | | | PAGE 9 |
| PREPARED BY / DATE | HK 1/1/83 | | | | | OF 20 |
| CHECKED BY / DATE | HK 1/20/83 | | | | | |

PROJECT Midland Units 1 & 2FILE NO. CPC-09-E,040OWNER Consumers Power Co.CLIENT Consumers Power Co.

The surface temperature of the seal was determined by the above procedure and the total conductive heat flux is compared to the condensing heat flux which is calculated by the relationship of $Q/A = h_{cond}(T_{sat} - T_s)$ where h_{cond} = condensing heat transfer coefficient is equal to the larger of 4 times of Tzumi correlation or 4 times Uchida correlation from figure 4, page 17,

T_{sat} = saturation temperature corresponding to the containment pressure from figure 1, page 14. In any case of that the condensing heat flux is greater than the convective heat flux calculated by $h_{conv} = 250 \text{ Btu/hr-ft}^2\text{-}^\circ\text{F}$, the surface temperature will be recalculated by using the more conservative heat transfer coefficient. The table on next page summarizes the results.

| | | | | | | | |
|--------------------|------------|--|--|--|--|------|----|
| REVISION | 0 | | | | | PAGE | 10 |
| PREPARED BY / DATE | MRS 1/1/83 | | | | | OF | 20 |
| CHECKED BY / DATE | MRS 1/1/83 | | | | | | |

nutech

Bethesda, Maryland

PROJECT Midland Units 1 & 2
 OWNER Consumers Power Co
 CLIENT Consumers Power Co

FILE NO. CPC-09-E.040

Table 1

| (11) | (12) | (13) | (14) | (15) | (16) | (17) | (18) | (19) | (20) |
|------------|--------------|----------------------------|------------------------|--|--|--------------------------|--|--|--|
| t (sec) | t-1 (sec) | T _{DB} -1 (°F) | T _S (°F) | (ΔP/Δt) _{cond} (10 ⁴ Btu/hr-ft ²) | Reinforcement (lb/ft ²) | T _{sat} (°F) | t _{cond} (10 ⁴ Btu/hr-ft ²) | 4 x R _{cond} (10 ⁴ Btu/hr-ft ²) | (ΔP/Δt) _{cond} (10 ⁴ Btu/hr-ft ²) |
| 0 | | | 120 | 2.75 | 7.0 | 232.3 | 24 | 96 | 1.07 |
| 1 | 0 | 120 | 120 | 4.18 | 14.2 | 247.8 | 38 | 152 | 1.90 |
| 2 | 1 | 130 | 122.8 | 5.20 | 18.5 | 256.2 | 52 | 208 | 2.69 |
| 3 | 2 | 290 | 126.9 | 5.82 | 22.5 | 270.5 | 73 | 292 | 4.44 |
| 4 | 3 | 335 | 132.1 | 6.30 | 33.0 | 278.1 | 88 | 352 | 4.93 |
| 5 | 4 | 365 | 138.0 | 6.64 | 38.5 | 285.0 | 105 | 420 | 5.91 |
| 6 | 5 | 390 | 144.3 | 6.98 | 42.0 | 289.1 | 121 | 484 | 6.69 |
| 7 | 6 | 410 | 150.9 | 7.05 | 45.5 | 292.0 | 137 | 548 | 7.40 |
| 8 | 7 | 430 | 157.9 | 8.42 | 45.5 | 293.0 | 137 | 508 | 7.33 |
| 9 | 8 | 440 | 162.7 | 8.46 | 48.5 | 296.1 | 151 | 604 | 7.76 |
| 10 | 9 | 450 | 176.2 | 8.21 | 51.0 | 298.7 | 167 | 668 | 8.18 |
| 11 | 10 | 450 | 184.4 | 7.97 | 52.0 | 299.7 | 187 | 748 | 8.62 |
| 11 | 10 | 450 | 185.5 | 9.26 | 52.0 | 299.7 | 187 | 748 | 8.54 |
| 12 | 11 | 450 | 194.5 | 8.94 | 53.0 | 300.7 | 201 | 804 | 8.54 |
| 13 | 12 | 450 | 203.2 | 8.64 | 54.0 | 301.7 | 215 | 860 | 8.47 |
| 14 | 13 | 450 | 211.6 | 8.34 | 54.5 | 302.2 | 230 | 920 | 8.33 |
| 15 | 14 | 450 | 219.7 | 8.06 | 55.5 | 303.2 | 250 | 1000 | 8.33 |
| 15 | 14 | 450 | 219.9 | 8.62 | 55.5 | 303.2 | 250 | 1000 | 8.33 |
| 25 | 24 | 450 | 230.2 | 5.50 | 56.0 | 303.7 | 140 | 640 | 4.90 |
| 35 | 34 | 450 | 240.0 | 5.35 | 58.0 | 305.5 | 100 | 400 | 2.62 |
| 45 | 44 | 450 | 249.4 | 5.02 | 57.0 | 304.6 | 100 | 400 | 2.21 |
| 55 | 54 | 450 | 257.2 | 4.20 | 56.0 | 303.7 | 100 | 400 | 1.86 |
| 65 | 64 | 415 | 264.2 | 3.77 | 52.0 | 299.7 | 100 | 400 | 1.42 |
| 75 | 74 | 410 | 270.7 | 3.48 | 50.0 | 297.7 | 100 | 400 | 1.08 |
| 85 | 84 | 405 | 276.7 | 3.21 | 51.08 | | 100 | 400 | |

nutech

Bethesda, Maryland

PROJECT Midland Units 1 & 2 FILE NO. CPC-09-E.040
 OWNER Consumers Power Co.
 CLIENT Consumers Power Co.

Table 1 continues

| t | t-1 | T _{ad} | T _s | (R/A) _{env} | P | T _{act} | R _{cond.} | W × R _{cond} | (R/A) _{cond} |
|-----|-----|-----------------|----------------|----------------------|---|------------------|--------------------|-----------------------|-----------------------|
| 95 | 94 | 400 | 282.2 | 2.95 | | | | | |
| 105 | 104 | 395 | 287.2 | 2.70 | | | | | |
| 115 | 114 | 390 | 291.8 | 2.46 | | | | | |
| 125 | 124 | 385 | 295.9 | 2.23 | | | | | |
| 135 | 134 | 380 | 299.7 | 2.01 | | | | | |
| 145 | 144 | 375 | 303.0 | 1.80 | | | | | |
| 155 | 154 | 370 | 306.0 | 1.60 | | | | | |
| 165 | 164 | 365 | 308.9 | 1.40 | | | | | |
| 175 | 174 | 360 | 310.9 | | | | | | |
| 185 | 184 | 355 | 312.9 | | | | | | |
| 195 | 194 | 350 | 314.6 | | | | | | |
| 205 | 204 | 345 | 315.9 | | | | | | |
| 215 | 214 | 342.5 | 317.1 | | | | | | |
| 225 | 224 | 340 | 318.1 | | | | | | |
| 235 | 234 | 337.5 | 319.0 | | | | | | |
| 245 | 244 | 335 | 319.7 | | | | | | |
| 255 | 254 | 332.5 | 320.2 | | | | | | |
| 265 | 264 | 330 | 320.7 | | | | | | |
| 275 | 274 | 327.5 | 321.0 | | | | | | |
| 285 | 284 | 325 | 321.2 | | | | | | |
| 295 | 294 | 322.5 | 321.2 | | | | | | |
| 305 | 304 | 320 | 321.2 | | | | | | |
| 315 | 314 | 317.5 | 321.0 | | | | | | |
| 325 | 324 | 315.0 | 320.7 | | | | | | |

> (R/A)_{cond} and T_s > T_{act} ∴ no condensing will occur.

maximum surface temperature

| | | | | | | | |
|--------------------|-------------|--|--|--|--|--|---------|
| REVISION | 0 | | | | | | PAGE 12 |
| PREPARED BY / DATE | NRK 1/7/83 | | | | | | OF 20 |
| CHECKED BY / DATE | WAC 1/20/83 | | | | | | |

PROJECT Midland Units 1 & 2

FILE NO. cpc-09-E.040

OWNER Consumers Power Co.

CLIENT Consumers Power Co.

Explanatory note for Table 1

col

(1) time t

(2) time $t-1$

(3) Environmental temperature T_{∞} from figure 1, page

(4) $T_b@t = \theta \cdot (T_s@t-1 - T_{\infty}@t-1) + T_{\infty}@t-1$

(5) $(Q/A)_{conv.} = h \cdot (T_{\infty} - T_s)@t$ initially $h = 250$

(6) Permittance from figure 1

(7) $T_{sat} = f(\text{Permittance})$ from steam Table

(8) condensing heat transfer coefficient from figure 4, page

(9) $4 \times \text{col}(8)$

(10) $(Q/A)_{cond} = \text{col}(9) \times (\text{col}(7) - \text{col}(4))$

* $t = 8$ $h = 300$ $B_i = 19.283$ $B_i^{-1} = 0.051$
 $\theta_x = 0.98$ $\Rightarrow \theta = 0.970$
 $\theta_y = 0.99$

** $t = 11$ $h = 350$ $B_i = 22.29$ $B_i^{-1} = 0.044$
 $\theta_x = 0.978$ $\Rightarrow \theta = 0.966$
 $\theta_y = 0.988$

*** $t = 15$ $h = 375$ $B_i = 24.10$ $B_i^{-1} = 0.042$
 $\theta_x = 0.977$ $\Rightarrow \theta = 0.965$
 $\theta_y = 0.985$

| | | | | | | |
|--------------------|-------------|--|--|--|--|---------|
| REVISION | 0 | | | | | PAGE 13 |
| PREPARED BY / DATE | MLK 1/7/83 | | | | | OF 20 |
| CHECKED BY / DATE | WAK 1/24/83 | | | | | |

nutech

Bethesda, Maryland

PROJECT Midland Units 1 & 2 FILE NO. CPC-09-E.040
 OWNER Consumers Power Co.
 CLIENT Consumers Power Co.

**** $T = 10 \text{ sec}$ $R = 250$

$$F_0 = \frac{K_e \cdot T}{(P_{CP} \cdot \eta)^2} = 1.8 \times 10^{-2}$$

$$B_{\lambda} = 16.069$$

from page

$$B_{\lambda}^{-1} = 0.0622$$

$$\theta_x = 0.970$$

$$\theta_y = 0.985$$

$$\theta = 0.97 \cdot 0.985 = 0.9555$$

| | | | | | | |
|--------------------|-------------|--|--|--|--|---------|
| REVISION | 0 | | | | | PAGE 14 |
| PREPARED BY / DATE | MRS 1/7/83 | | | | | OF 20 |
| CHECKED BY / DATE | WRC 1/20/83 | | | | | |




Figure 1.

CPC-09-E.040

page 15 of 20

Rev. 0
7/1/83
WRK - 1/20/83

CONSUMERS POWER COMPANY MIDLAND UNITS 1 AND 2

Reactor Building Pressure and
Temperature vs Time After MSLB

F2

60-G 2536-41

Program Revision 0
10/82




FIG. 4-10. Dimensionless temperature distribution in a long circular cylinder subjected to a sudden change in environmental temperature. (By permission from L. M. K. Hoelter, V. H. Cherry, and H. A. Johnson, *Heat Transf.*, 3d ed., 1942)

Figure 2

CPC-09-E.070
page 16 of 20

MRL 1/7/83
WRK 1/24/83





FIG. 4-8. Dimensionless temperature distribution in a wall subjected to a sudden change in environmental temperature.

Figure 3

CPC-19-E.040
page 17 of 20
REV 0
MRE 1/7/83
LAC 1/2/83

Condensing Heat Transfer Coefficient (BTU/hr-ft²-°F)



COMPARISON OF MODIFIED TAGAMI HEAT TRANSFER COEFFICIENT
WITH UCHIDA HEAT TRANSFER COEFFICIENT
Figure A.1

CPC-05-G.O.V.
page 18 of 20
REV'D
MFE 1/7/83
WAC 1/20/83

Figure 4

MIDLAND SNUBBER SEALS

| ITEM | SEAL TITLE | LOCATION | FUNCTION-TYPE | SIZE | MANUFACTURER | COMPOUND | CURE METHOD |
|------|-------------------------|------------------|-----------------|-------------------|------------------|----------|-----------------|
| 1 | O-RING - OUTLET ADAPTER | RESERVOIR | STATIC - O-RING | 1.737 ID x .103 W | FEDERAL - MOGUL | E 50 | EPDM - PEROXIDE |
| 2 | O-RING - DRAIN ADAPTER | RESERVOIR | STATIC - O-RING | .987 ID x .103 W | FEDERAL - MOGUL | E 50 | EPDM - PEROXIDE |
| 3 | O-RING - FILTER ADAPTER | RESERVOIR | STATIC - O-RING | .987 ID x .103 W | FEDERAL - MOGUL | E 50 | EPDM - PEROXIDE |
| 4 | O-RING - MTG. STUDS | SIGHT GLASS-RES. | STATIC - O-RING | .487 ID x .103 W | FEDERAL - MOGUL | E 50 | EPDM - PEROXIDE |
| 5 | O-RING - GLASS GAUGE | SIGHT GLASS-RES. | STATIC - O-RING | .299 ID x .103 W | FEDERAL - MOGUL | E 50 | EPDM - PEROXIDE |
| 6 | O-RING - CAP | SIGHT GLASS-RES. | STATIC - O-RING | .551 ID x .070 W | FEDERAL - MOGUL | E 50 | EPDM - PEROXIDE |
| 7 | O-RING - CR. SEAL VALVE | TUBING RUN | STATIC - O-RING | .796 ID x .139 W | FEDERAL - MOGUL | E 50 | EPDM - PEROXIDE |
| 8 | O-RING - CR. SEAL VALVE | TUBING RUN | STATIC - O-RING | .549 ID x .103 W | FEDERAL - MOGUL | E 50 | EPDM - PEROXIDE |
| 9 | EXTERNAL BEARING SEAL | MODEL 52 ONLY | STATIC - O-RING | VARIOUS | ACUSHNET | E 17018 | EPDM - PEROXIDE |
| 10 | ROD SEAL | CYLINDER | DYNAMIC - LIP | VARIOUS | MINNESOTA RUBBER | 555-EQ | EPDM - PEROXIDE |
| 11 | O-RING - END SEAL | CYLINDER | STATIC - O-RING | VARIOUS | ACUSHNET | E 17018 | EPDM - PEROXIDE |
| 12 | ROD WIPER | CYLINDER | DYNAMIC - LIP | VARIOUS | MINNESOTA RUBBER | 555-EQ | EPDM - PEROXIDE |
| 13 | PISTON SEAL | CYLINDER | DYNAMIC - U-CUP | VARIOUS | W.H.SALISBURY | 80154 | EPDM - SULFUR |
| 14 | O-RING - VALVE | TREE CONN. | STATIC - O-RING | 1.171 ID x .116 W | FEDERAL - MOGUL | E 50 | EPDM - PEROXIDE |
| 15 | O-RING - VALVE | RETAINER PL. | STATIC - O-RING | 1.299 ID x .103 W | FEDERAL - MOGUL | E 50 | EPDM - PEROXIDE |
| 16 | THREAD SEAL | VALVE | STATIC - THREAD | .644 ID x .087 W | FEDERAL - MOGUL | E 50 | EPDM - PEROXIDE |
| 17 | THREAD SEAL | VALVE | STATIC - THREAD | 1.299 ID x .103 W | FEDERAL - MOGUL | E 50 | EPDM - PEROXIDE |
| 18 | FILL PORT PLUG | CYLINDER | STATIC - O-RING | .644 ID x .087 W | FEDERAL - MOGUL | E 50 | EPDM - PEROXIDE |
| 19 | FILL PORT PLUG | CYLINDER | STATIC - O-RING | .755 ID x .097 W | FEDERAL - MOGUL | E 50 | EPDM - PEROXIDE |


| CYLINDER MODEL | QUANTITY OF SEALS |
|----------------|-------------------|
| 52 | 30 |
| 50 | 29 |

TABLE 4

Rev. 0
 MKR 1/7/83
 MKR 11/2/83
 page 19 of 20
 CPC-09-E.040

REV 0
MKT 1/1/83
WMC 12/2/83

PAGE 20 OF 20
CPC-09-61040



Reference 18

Midland Plant, Units 1 & 2 Environmental Qualification Report,
Vol. I, Revision 1, December 1982.