GENERAL 🍪 ELECTRIC

GENERAL ELECTRIC COMPANY, 175 CURTNER AVE., SAN JOSE, CALIFORNIA 95125 MC 682, (408) 925-5040

NUCLEAR POWER

SYSTEMS DIVISION

MFN-019-83 JNF-007-83

March 9, 1983

. 1

U. S. Nuclear Regulatory Commission Office of Nuclear Reactor Regulation Washington, D. C. 20555

Attention: Mr. D. G. Eisenhut, Director Division of Licensing

SUBJECT: IN THE MATTER OF 238 NUCLEAR ISLAND GENERAL ELECTRIC STANDARD SAFETY ANALYSIS REPORT (GESSAR II) DOCKET NO. 50-447

> CHAPTER 15 RADIOLOGICAL DOSE CALCULATIONS WITH POOL SCRUBBING CREDIT

Reference: Glenn G. Sherwood to D. G. Eisenhut, "Revision of Chapter 15 Radiological Dose Calculations," January 25, 1983.

The purpose of this letter is to document agreements made with the Staff regarding credit for suppression pool scrubbing in Chapter 15 radiological dose calculations.

On January 13, 1983, GE personnel met with Mr. L. G. Hulman and other members of the Staff to discuss credit for pool scrubbing for GESSAR II Chapter 15 accident evaluations. In that meeting, the Staff indicated that if GE provided the analysis of reduced radiological doses resulting from pool scrubbing, the Staff would recognize the potential decontamination capability attributed to the pool. This would be reflected in the GESSAR II SER in March, 1983. In addition the Staff would provide a detailed review of the submittal and would prepare a supplement to the SER which would include pool scrubbing credit. It was indicated such a supplement could be issued by September 1983. In accordance with this approach, GE submitted the required information on the GESSAR II docket (reference letter).

As discussed in this meeting the January 25 submittal culminates several technical meetings with the Staff on the subject of suppression pool decontamination factors.

FOOB

GENERAL 🏶 ELECTRIC

U. S. Nuclear Regulatory Commission Page 2

If there are any questions on the information provided herein, or in the referenced letter, please contact J. N. Fox of my staff at (408) 925-5039.

Very truly yours,

illa for

Glenn G. Sherwood, Manager Nuclear Safety & Licensing Operation

GGS:pes/112R

Attachment

- cc: F. J. Miraglia, NRC
 - D. C. Scaletti, NRC
 - L. G. Hulman, NRC
 - C. O. Thomas, NRC
 - R. M. Ketcheil, GE (Washington Liaison Office)
 - L. S. Gifford, GE (Bethesda Liaison Office)

GENERAL S ELECTRIC

NUCLEAR POWER

SYSTEMS DIVISION

GENERAL ELECTRIC COMPANY, 175 CURTNER AVE., SAN JOSE, CALIFORNIA 95125 MC 682, (408) 925-5040

January 25, 1933

MFN-011-83

U. S. Nuclear Regulatory Commission Office of Nuclear Reactor Regulation Washington, D. C. 20555

Attention: Mr. D. G. Eisenhut, Director Division of Licensing

Gentlemen:

SUBJECT:

IN THE MATTER OF 238 NUCLEAR ISLAND GENERAL ELECTRIC STANDARD SAFETY ANALYSIS REPORT DOCKET NO. 50-447

REVISION OF CHAPTER 15 RADIOLOGICAL DOSE CALCULATIONS

Attached please find a revision of the Chapter 15 radiological dose calculations for the Inside Containment Loss of Coolant Accident. Also included are the affected pages of Chapter 6.

These calulations have been revised to account for the capability of the suppression pool to retain particulate fission products. As demonstrated by General Electric's suppression pool scrubbing test program, and documented in Section 15D. 2, the suppression pool provides an extremely effective fission product retention mechanism. General Electric personnel have been working with your staff during 1982 to facilitate the review of these test results and their application to GESSAR's Chapter 15 analysis.

This revision demonstrates the capability of the suppression pool to significantly reduce offsite radiological doses for Design Basis Accident conditions. Following your preliminary review we will schedule the submittal of an amendment to implement this revision.

Very truly yours,

Glenn G. Sherwood, Manager

Nuclear Safety and Licensing Operation

Attachments

cc: F.J. Miraglia, w/o att. D.C. Scaletti L.G. Hulman C.O. Thomas, w/c/ att. L.S. Gifford, w/c att.



6.4.2.4 Interaction With Other Zones and Pressure-Containing Equipment (Continued)

outdoor air are mixed and drawn through filters, a cooling coil and zone electric reheating coils.

There are two intakes, a normal intake located on the roof of the Control Building, and an alternate intake on the opposite side of the Nuclear Island at the end of the Auxiliary Building. Radiation monitoring sensors located in each duct warn the operating personnel (by means of readouts and alarms in the main control room) of the presence of airborne contamination. Also, the signal automatically closes down the normal air intake dampers and starts up the reduced flow (2000 cfm) air intake. This alternate service air, which is classified as makeup air, is routed through the HEPA and charcoal filtering system for cleanup before being used for pressurization.

The control room must remain habitable during emergency conditions. In order to make this possible, potential sources of danger such as steam lines, pressure vessels, CO₂ fire fighting containers, etc. are located outside of the control room and removed from the compartments containing Control Building life support systems.

A tabulation of moving components in the Control Building HVAC System, along with the respective failure mode and effects, is shown in Table 6.4-1.

All dampers except the mixing dampers in the air conditioning units are of the two position (open or closed) type.

6.4-11

)

6.4.2.5 Shielding Design

6.4.2.5.1 Design Basis

The Control Building shielding design is based upon adequately protecting against the radiation resulting from an incident or postouated incidents leading to a LOCA. The dose rates received under normal operating conditions of the reactor are not determining factors in any of the walls sized in this specification. Under normal operating conditions, a dose rate of less than 1 mRem/hr is anticipated in the area surrounding the Control Building. Assuming an average gamma energy of 1.25 MeV and 2-ft shielding walls, this will yield a dose rate of less than 0.01 mRem/hr within the Control Building, which is well within the acceptable limit.

Radioactivity released by an inadequate response to LOCA can result in four different activity distributions, or sources, that can affect Control Building personnel whole body doses.

- The fission products held in the containment "shine" on the Control Building. (Those remaining in the reactor vessel, however, contribute negligibly to this effect.)
- (2) The fission products which are released from the SGTS stack form a cloud in which the Control Building is enveloped (Figure 6.4-5).
- (3) Some of the fission products released from the containment will be taken into the Control Building via the building ventilation system air intakes. The majority of the iodine taken in will be absorbed on a charcoal bed, which will then become a concentrated source within the building. Also, solid daughters of noble gases

6.4-12

22A7007 Rev. 0

6.4.2.5.1 Design Basis (Continued)

6 -

collect on the filters. Personnel on the control room level, as well as the equipment room and HVAC room levels, will be shielded from this source.

(4) Fission products that pass through and evolve from the filters become a source of radiation exposure to control building personnel. This source determines a portion of the whole body dose, as well as the entirety of the thyroid and beta skin doses. See Subsection 15.6.5 for these dose analyses.

The DBA analysis is structured on the conservative NRC assumptions. The GUANFITY OF The Percentages of 105% rated power fission products equilibrium inventories released from the REACTOR VESSEL TO THE CONTAINMENT release from the containment are given below: IS PRESENTED IN SUBSECTION 15.6.5

Fission Product	Released from Reactor Vessel	Release from Containment
Noble Gases	100%	1008
Halogens	-50%	-25%
Colids	-10-	Negligible

The containment leak rate assumed for the design analyses is 1.0% of the containment volume per day. Radioactive decay during transport through the containment is taken into account. The leaked radioactivity goes into the strend building annulus, and then to the SGTS, from which it is vented to the atmosphere. Mixing is assumed to occur in half of the shield building annulus free volume. The SGTS charcoal filter is assumed to be 99% of CANIC AND PARTICULATE FORMS OF efficient for filtering, redie iodines, and none of the vented gas is assumed to bypass the filter.

22A7007 Rev. 0

6.4.2.5.2 Source Terms

WETWELL Containment, sources "shining" on the Control Building, are listed FOR RELEASE in Table 15.6.5-2. Source terms for the cloud and filter are consistent with the activity releases of Table 15.6.5-3. Concentration of each isotope is calculated as the product of the release rate (Ci/sec) times the appropriate relative concentration, or χ/Q (sec/square meter). These values, derived from "Nuclear Power Plant Control Room Ventilation System Design for Meeting General Design Criterion 19", by Kampe and Murphy, are presented below:

Time Period	(X/Q (see/m ³) LOCA in Same Unit
0-0-hro	0.0015
8 24 hrs	
1 4 days	0.0006
4-103 days	0.0005

For the cloud source term, no credit was taken for decay between the release point and the cloud location. Buildup and decay of radiohalogens and solids on the filter was appropriately accounted for.

6.4.2.5.3 Results

Calculated whole body doses to centrol room personnel are given below for an assumed six-month pest-LOCA period. One hundredpercent occupancy factor is assumed.

WHOLE BODY GAMMA DOSES CALCULATED BY CONSERVATIVELY ASSUMING 100% OCCUPANCY FOR A SIX-MONTH POST-LOCA PERIOD ARE GIVEN BELOW FOR THE CONTAINMENT, CLOUD AND FILTER SHINE CONTRIBUTIONS.

6.4.2.5.3 Results (Continued)

Dose Component	Location (1 Control Room	Dose in Rem) Equipment Room
Containment Shine	0.0054	0.0063
Cloud	0.19	0.20
Charcoal Filter	0.0012 ·	0.078

WHOLE BODY, THYROLD, AND SKIN DOSES RESULTING FROM THE AIRBORNE A CTIVITY WITHIN THE CONTRO ROOM ARE EVALUATED IN SECTION 15.6.5 AND ARE SHOW TO BE WELL WITHIN THE LIMITS OF 10 CFR 50. THE COMBINED WHOLE BUDY POSE RESULTING FROM INCLUSION OF THE SMALL That the above doses are much less than the locTRS0 guidelines, implies the acceptability of full Accupancy of these areas for the BURATIO. OF THE post-LOCA period, SAURED and Will, however, have to be restricted somewhat in the chiller rooms at El (+)28'-6" during the first day post-LOCA, due to somewhat high dose rates (up to 0.5 Rem/hr attributable to radioactive gases in the intake duct. However, safety-related equipment redundancy obviates the need for full occupancy. After the first day, full occupancy in these areas would result in less than 5 Rem.

> Concrete shielding thickness effecting the above doses are seen in plan and elevation in Figures 6.4-1 through 6.4-4. Penetrations and resultant streaming through the adjacent walls of the Auxiliary and Control Buildings are not considered to be significant for the following reasons. The penetrations are all relatively small (cable trays less than 24 in pipes less than 6 in.) and not radially aligned with the containment. Also, the overall contribution of the containment source component is guite small; thus, an increase due to streaming would not be a significant overall increase. Figure 6.4-6 shows a cross section of the Division 1 and 2 HVAC air intake. This is the only significant penetration of the Control Building external shielding. Examination of this figure shows no credible streaming for the external cloud source. Finally, arrangement of the filter cubicle precludes

> > 6.4-15

22A7007 Rev. 0

.)

6.4.2.5.3 Results (Continued)

door streaming. There are no floor penetrations of any consequence, and wall penetrations are kept well away from the source region.

6.4.3 System Operational Procedures

During normal operation, the control room group operates with mixed recirculated and fresh air, which pressurizes the subject spaces. Emergency conditions such as LOCA or high radiation cause automatic change over to reduced outside air and charcoal filtering of all outside air to effectively isolate operating personnel from the environment and from airborne contamination. Protection from direct radiation is discussed in Subsection 6.4.2.5; isolation can be complete, even to food and water (Subsection 6.4.4).

Detection of radioactivity is instrumented, and changeover to reduced circulation and charcoal filtering is automatic. Redundancy of instrumentation and air handling systems ensures against system failure due to single component failure.

The above operational description is brief. For a more detailed description of normal and emergency operation of the control room habitability systems, see Subsections 9.4.1, 9.5.1, 9.5.3, 12.3.4, 6.5.1, 7.3.1.1.17, and Chapter 8.

6.4.4 Design Evaluations

6.4.4.1 Radiological Protection

Assumptions used in the generation of post-LOCA radiation source terms are described fully in Subsections 5:2:4.5 and 15.6.5.

15.6.5.3.3 Results

Results of this event are given in detail in Section 6.3. The temperature and pressure transients resulting as a consequence of this accident are insufficient to cause perforation of the fuel cladding. Therefore, no fuel damage results from this accident. Post-accident tracking instrumentation and control is assured. Continued long-term core cooling is demonstrated. Radiological input is minimized and within limits. Continued operator control and surveillance is examined and guaranteed.

15.6.5.4 Barrier Performance

(.

The design basis for the containment is to maintain its integrity NOT EXCEED LEVEL C ACCEPTANCE CRITERIA and Competience normal stresses after the instantaneous rupture of the largest single primary system piping within the structure, while also accommodating the dynamic effects of the pipe break at the same time an SSE is also occurring. Therefore, any postulated LOCA does not result in exceeding the containment design limit (see Sections 3.8.2.3, 3.6, and 6.2 for details and results of the analyses).

15.6.5.5 Radiological Consequences

Two separate radiological analyses are provided for this accident:

 The first is based on conservative assumptions considered to be acceptable to the NRC for the purpose of determining adequacy of the plant design to meet

15.1

6

15.6.5.5 Radiological Consequences (Continued)

10CFR100 guidelines. This analysis is referred to as the "design basis analysis".

(2) The second is based on assumptions considered to provide MORE a realistic estimate of radiological consequences. This analysis is referred to as the "realistic analysis", ALTHOUGH MANY CONSERVATIVE ASSUMPTIONS STILL REMAIN.

A schematic of the transport pathway is shown in Figure 15.6-2.

Additional parameters and information for specific design basis accidents are provided in Subsection 19.3.15.1.

15.6.5.5.1 Design Basis Analysis

The methods, assumptions and conditions used to evaluate this accident are in accordance with those guidelines oct forth in Regulatory Guidee 1.3 and 1.7. The specific models, assumptions and computer code used to evaluate this event based on the above spiteria are presented in Reference 2. Specific values of parameters used in this evaluation are presented in Table 15.6-7.

15.6.5.5.1.1 Fission Product Release from Fuel

B

NSERT

It is assumed that 100% of the noble gases and 50% of the iodine are released from an equilibrium core operating at a power level of 3651 MWt for 1000 days prior to the accident. While not specifically stated in Regulatory Guide 1.3, the assumed release of 100% of the core noble gas activity and 50% of the iodine activity implies fuel damage approaching melt conditions. Even though this condition is inconsistent with operation of the ECCS system (Section 6.3), it is assumed applicable for the evaluation of this accident. Of this release, 100% of the noble gases and 50% of the iodine become airborne. The remaining 50% of the iodine is removed by plate-out and condensation; therefore, it is not available for airborne release to the environment. The activity airborne in the containment is presented in Table 15.6-8/

22A7007 Rev. C.

15.6.5.5.1.2 Fission Product Transport to the Environment

The transport pathway consists of leakage from the containment to the secondary containment-like structures by several different mechanisms and discharge to the environment through the Standby Gas Treatment System (SGTS):

- (1) <u>Containment leakage</u> The design basis leak rate of the primary containment and its penetrations (excluding the main steamlines) is 1.0%/day for the duration of the accident. All of this leakage is to the secondary containment and from there to the environment via a 99% SGTS. Credit is taken for mixing and holdup within the secondary containment. The Shield Building exhaust rate, leakage rate, and mixing ratio are given on Tables 15.6-9 and 15.6-10.
- (2) Leakage from engineered safety feature (ESF) components outside primary containment.
- (1) <u>Hydrogen purge</u> In the event of failure of the Hydrogen Recombiner System, purging of the containment may be necessary to control hydrogen concentration inside the primary containment. The earliest this purge may be utilized is one hour after the accident ATA minimum. The purge would be processed by SGTS prior to release to the environment. SINCE THE HYDROGEN CONTROL EQUIPMENT IS EST EQUIPMENT, IT IS NOT ASSUMED TO FAIL IN EVALUATING THE POTENTIAL RADIOLOGICAL EXPOSURES ASSOCIATED WITH THIS ACCIDENT. Fission product release to the environment based on the above assumptions is given in Table 15.6-11.

15.6.5.5.1.3 Results

The calculated exposures for the design basis analysis are presonted in Table 15.6-12 are well within the guidelines of 10CFR100.

INSERT A (page 15.6-15)

· ...

The methods, assumptions and conditions used to evaluate the potential radiological exposure to onsite and offsite personnel are consistent with the guidelines set forth in Regulatory Guide 1.3 except as noted below.

The guidance of Regulatory Guide 1.3 has been supplemented using information from: 1) NUREG-0772 to account for the expected chemical forms of the fission products; and 2) Section 15 D.2 to account for the retention of particulate fission products in the suppression pool. The specific models, assumptions and computer code used to evaluate this event based on the above criteria are presented in Reference 2. Specific values of parameters used in this evaluation are presented in Table 15.6-7.

INSERT B (p 15.6-15)

It is assumed that 100% of the noble gases and 50% of the iodine are released to the drywell from an equilibrium core operations at a power level of 3651 MWt for 1000 days prior to the accident. These assumed releases imply that severely degraded ECCS performance has resulted in fuel damage approaching melt conditions. Even though this condition is inconsistent with operation of the ECCS system (Section 6.3), it is assumed applicable for this evaluation of containment system effectiveness.

Any iodine which is released from the reactor vessel would exist predominantly in a particulate chemical form. This analysis assumes that chemical forms of iodine released to the drywell are distributed in accordance with NUREG-0772, with '99.97% being in the particulate form and 0.03% being organic iodine. Of the particulate iodine released, 50% is assumed to be removed by plateout and condensation and therefore is not available for potential release to the environment.

15.6.5.5.1.2 FISSION PRODUCT TRANSPORT TO THE ENVIRONMENT

The Mark III containment is designed with the drywell and suppression pool totally enclosed within the containment wetwell. In this configuration, any fission products released to the drywell, or discharged through the safety/relief valves, must bass through the suppression pool before they can reach the containment wetwell airspace. Once in the primary containment airspace, the transport pathway consists of limited leakage from the primary containment to the secondary containment by several different mechanisms and discharge to the environment through the Standby Gas Treatment System (SGTS). Consistent with the SGTS design capability and in accordance with R.G. 1.52 and the BWR/6 Standard Technical Specifications, it is assumed that the SGTS has an iodine removal efficiency of 99%.

These Transport pathways and any associated retention mechanisms are identified below:

INSERT & CONTINUED

- 1) <u>Suppression Pool</u> All fission products discharged from the drywell or safety/relief values enter the suppression pool 7 to the feet under the pool surface. As described in Section 15 D.2, General Electric has performed tests which demonstrate that the suppression pool will act as an extremely effective retention device for particulate fission products discharged into the pool under these conditions. Based upon the testing and modeling documented in Section 15 D.2, a suppression pool scrubbing decontamination factor (DF) equal to 10,000 was applied to reduce the activity of particulate iodine reaching the primary containment airspace. All noble gases and organic forms of iodine were assumed to pass through the pool without retention (i.e., DF = 1). The resulting activity airborne in the containment wetwell airspace due to noble gases and iodine is presented in Table 15.6-8.
- 2) Primary Containment Leakage The design basis leak rate of the primary containment and its penetrations is 1.0%/day for the duration of the accident. All of this leakage is to the secondary containment and from there to the environment via the SGTS. Parameters applicable TRANSPORT FROM to the primary and secondary containments are given on Tables 15.6-9 and 15.6-10, and the activity airborne in the primary containment is presented in Table 15.6-8.
- 3) Engineered Safety Feature Leakage Engineered safety feature (ESF) components located outside the primary containment contribute insignificant leakage to the secondary containment.

INSERT C (PIS.6-16)

The results of the design basis analysis are presented in Table 15.6-12. The calculated exposures at the Exclusion Area and Low Population Zone are well within the guidelines of 10CFR100.

12

These calculated results are believed to be significantly greater than the maximum potential dose due to the conservative assumptionSused in the design basis analysis. For example, the calculated exposures would be significantly reduced if a more realistic time dependent release of fission products from the fuel were assumed. Further, other fission product retention mechanisms are present, in addition to the suppression pool, which would act to limit the release of fission products to the environment. These additional retention mechanisms include agglomeration and settling of particulate forms plus surface deposition and absorption in the water vapor which would exist in the containment air space following a LOCA. An additional retention mechanism exists as a result of the containment sprays.

A sensitivity study has been performed to determine to what extent these results would change if the fuel release source term model recommended by NUREG-0772 were used instead of the Regulatory Guide 1.3 source term. If the NUREG-0772 model for a fully melted core were applied, the fuel release would change from 100% noble gas and 50% iodine to that specified in Table F.3-1 of Section 15D.3. Since the noble gas release remains at a maximum value of 100% and the suppression pool and SGTS would reduce any increase in the particulate release by a factor of 10⁶, the effect on the offsite BODY the negligible. Only the thyroid dose would be calculated to change, with an increase from 0.05 rem to 0.1 rem in the Exclusion Area and 0.1 rem to 0.2 rem in the low population zone. Thus, the results would still remain well within the guidelines of 10CFR100.

22A7007 Rev. 0

15.6.5.5.2 Realistic Analysis

The realistic analysis is based on a realistic but still conservative assessment of this accident. The specific models, assurtions and the program-used for computer evaluation are described in Reference 3. Specific values of parameters used in the evaluation are presented in Table 15.6-7.

15.6.5.5.2.1 Fission Product Release from Fuel

Since this accident does not result in any fuel damage, the only activity released to the drywell is that activity contained in the reactor coolant plus any additional activity which may be released as a consequence of reactor scram and vessel depressurization.

While there are valous activation and corrosion products contained in the reactor coolant, the products of primary importance are the iodine isotopes I-131 to I-135. The ccolant concentration for these isotopes is:

I-131 2:03 E-2,02+Ci/gm 0.02 K Ci/gm I-132 2:59 E 1.26+Ci/gm 0.26 K Ci/gm I-133 1.49 E 1.15+Ci/gm 0.15 K Ci/gm I-134 4:75 E-1.48+Ci/gm 0.48 K Ci/gm I-135 2:39 E 1.24+Ci/gm 0.24K Ci/gm

Considering that approximately 40% of the released liquid flashes to steam, it is conservatively assumed that 40% of the released iodine activity is airborne initially. However, as a result of plate out and condensation effects, only 50% of the activity initially airborne remains available for release to the environment.

15.6.5.5.2.1 Fission Product Release from Fuel (Continued)

As a consequence of reactor scram and depressurization, additional iodine activity is released from those rods which experienced cladding perforation during normal operation. Measurements performed (Reference, e) at operating BWRs during reactor shutdown have been used to develop an analytical model for the prediction of iodine and noble gas spiking as a consequence of reactor scram and vessel depressurization. Based on the 95th percentile (i.e., only 5% of the time will the release be greater) probability, the I-131 release is calculated to be 2.14 Ci/bundle and Xe-133 to be 11.55 Ci/bundle. Other iodine and noble gas isotopes are determined in accordance with their cumulative fission yields and are tabulated in Table 15.6-13.

SINCE

While no measurements have been obtained during a pressure transient as rapid as the LOCA, it is difficult to predict the actual release rate from the fuel as a consequence of iodine ...) spiking. Therefore, it is arbitrarily assumed that 100% of the HAS GEEN TO THE DRYWELL BEFORE THE BLOWDOWN TRANSFENT IS spiking source term is released during the time period that 40% OVER. of the discharge coolant is flashing to steam. THE LEDINE FRACTIONS INVOLVED IN THIS RELEASE ARE CONSISTENT WITH THOSE SPECIFIED IN NUREG 0772 (ie., 99.97% in PARTICULATE FORM AND 0.03% AS CRGANIC IODINE). It is also assumed that plate-out and condensation removed 50% Of the airborne iodine activity. The total activity airborne in

the containment is presented in Table 15.6-14.

NSERT-> F The look rate from the primery contained to the Environment

The leak rate from the primary containment to the secondary containment is 1.0%/day, where 100% mixing is assumed to occur. Release from the secondary containment to the environment via a 99.9% iodine efficient SGTS is presented in Table 15.6~15. The integrated isotopic activity released to the environment is presented in Table 15.6-15.

INSERT D (P. 15.6-17)

The chemical forms of iodine used in this realistic analysis are consistent with those specified in NUREG-0772. As in the case of the design basis analysis, appropriate credit is given for suppression pool scrubbing. Specific values of the parameters used in the evaluation are presented in Table 15.6-7. The specific models, assumptions and the program used for computer evaluation are described in Reference 2.

INSERT E (P 15.6-18)

The activity released in this analysis is directed to the drywell and from there into the suppression pool. Any fission products not retained in the suppression pool due to scrubbing are assumed to be distributed in the wetwell airspace. This transport process is discussed in detail in Section 15.6.5.5.1. As in the case of the design basis analysis, credit was taken for a decontamination factor of 10,000 for particulate iodine due to the suppression pool. The activity airborne in the containment wetwell airspace is presented in Table 15.6-14.

Parameters applicable to the primary and secondary containmentSare given in Table 15.6-10. The integrated isotopic activity release to the environment via the SGTS is presented in Table 15.6-15. The SGTS has a OCCANIC 99% lodine removal efficiency AND A 99.9% PARTICULATE ICDINE REMOVAL EFFICIENCY.

Rev. 0

15.6.5.5.2.3 Results

AS SHOWN IN TABLE 15.6-16, The calculated radiological exposures for this event are presented in Table 15.6 16 and as shown are a small fraction of 10CFR100.

15.6.5.5.3 Control Room

INSERT -

A dose analysis has been performed to demonstrate that the ventilation system satisfies the NRC radiation guidelines. The results of the analysis show that the ventilation system design does satisfy their guideline. A schematic of the control room intake vents is shown in Figure 15.6-3.

The doses received during a 30-day period after a loss-of-coolant accident are:

	(Rem)	U.S. NRC Limit (Rem)
Whole Body	2.56	5
Thyroid	29.4	30
Beta	53.8	75

A factor of 1/4 was taken into account for a dual inlet with manual override capabilities. The methods used to calculate these doses are presented in Reference 5. A complete list of assumptions and input data follows:

1) Source Terms

The source terms used in this analysis are consistent with R.G. 1.3 (i.e., 25% halogens and 100% noble gases airborne in the containment) and were presented in Table 15.6-8.

22A7007 Rev. 0

15.6.5.3 Control Room (Continued) ADDITIONAL ASSUMPTIONS ON VENTILATION PARAMETERS AND METEOROLOGICAL DATA ARE GIVEN BELOW Ventilation Parameter (SEE FIGURE 15.6-3 FOR VENTILATION INTAKE SCHEMATIC)

THTEE GIT LIOMA	
filtered	0.944 m ³ /sec
unfiltered	0.0014 m ³ /sec
INLEF Filter efficiency	998
Control Room Volume	1.102 E+4 m ³

Occupancy factors

0-2 hrs	1.0
2-8 hrs	1.0
8-24 hrs	1.0
1-4 days	0.6
4-30 days	0.4

Meteorology Data

X/Q	Values		sec/m ³
	0-2 hrs		8.0 E-3
	2-8 hrs	3.2	1+6 E-3
	8-24 hrs	2.8	1-+ E-3
	24 hr 4 days	2.2	1-1 E-3
	4-30 days	2.2	1-1 E-3

15.6.6 Feedwater Line Break - Outside Containment

In order to evaluate large liquid process line pipe breaks outside containment, the failure of a feedwater line is assumed to evaluate the response of the plant design to this postulated event. The postulated break of the feedwater line, representing the largest liquid line outside the containment, provides the envelope INSERT F (p: 15.6-19)

The control room and its associated ventilation system has been designed with the objective of continuous occupancy following a LOCA. An analysis has therefore been performed to demonstrate that the ventilation system satisfies the NRC's control room habitability guidelines relative to radiation exposure. The potential doses to control room personnel during a 30-day period after a LOCA are shown below. These are based on: 1) the source terms, iodine fractions and scrubbing discussed in Section 15.6.5.5.1 ; 2) a factor of 0.25 to take credit for a dual inlet with manual override capabilities; and 3) the calculation methods presented in Reference 4.

. .

	Dose	U.S. NRC Limit
	(Rem)	(Rem)
Whole Body	2.9*	5
Thyroid	0.02	30
Beta	36	75

* A SMALL INCREMENT TO THE WHOLE BODY DOSE RESULTS FROM GAMMA SOURCES EXTERNAL TO THE CONTROL ROOM. THIS EFFECT IS EVALUATED IN SECTION 6.4.2.5.

٦

15.6.7 References

- F. J. Moody, "Maximum Two-Phase Vessel Blowdown from Pipes", ASME Paper Number 65-WA/HT-1, March 15, 1965.
- P. P. Stancavage and E. J. Morgan, "Conservative Radiological Accident Evaluation - The CONACOL Gode", March 1976 (NEDO-21142).
- D. Nguyen, "Realistic Accident Analysis The RELAC Code",
 October 1977 (NEDO-21142).
- X.3 F. J. Frutschy, G. R. Hills, N. R. Horton, A. J. Levine, "Behavior of Iodine in Reactor Water During Plant Shutdown and Startup", August 1972 (NEDO-10585).
- 5. D. G. Weiss and V. O. Nguyen, "Control Room Accident Exposure Evaluation - CRDE Program", January 1979 (NEDO 22000)
 - #2 D. NGUYEN, et al, "RADIOLOGICAL ACCIDENT EVALUATION THE CONAC O3 CODE", DECEMBER 1981 (NEDO -21143-1),
 - #4 D. NGUYEN, et al, "CONTROL ROOM ACCIDENT EXPOSURE EVALUATION -CROOS PROGRAM, FEBRUARY 1981 (NEDO-23909A)

15.6-27/15.6-28

• •

]

Table 15.6-6

STEAMLINE BREAK ACCIDENT (REALISTIC ANALYSIS) RADIOLOGICAL EFFECTS

	Whole Body Dose (rem)	Inhalation Dose (rem)
Exclusion Area	1.1E-2	5.2E-1

Low Population Zone 5.4E-3

6

(

2.6E-1

1.4 1.1 + ES. 0.1 5

22A7007 Rev. 0

Table 15.6-7

LOSS-OF-COOLANT ACCIDENT - PARAMETERS TABULATED FOR POSTULATED ACCIDENT ANALYSES

		Design Basis Assumptions	Realistic Basis Assumptions
I.	Data and assumptions used to		
	estimate radioactive source		
	from postulated accidents		
	A. Power level	3651 MW+	3651 MW+
	B. Burnup	NA	NA NA
	C. Fuel damage	1009	0
	D. Release of activity by nuclide	100% NOBLE GAS	100% NOBLE GAS
	E. Iodine fractions	Selo Leoine	DO TO LODINE
	(1) Organic	gr 0,0003	RO 0003
	(2) Elemental	20	XO
	(3) Particulate	\$0.9997	80.9997
	F. Reactor coolant activity before the accident	NA	15.6.5.5.2.1
II.	Data and assumptions used to		
	estimate activity released		
	A. Primary containment leak	TARIE IS 6-10	TARIE 15.6-10
	rate (%/dav)	1-A	1.0
	B. Secondary containment leak	A 2 hrs 210 2	122
	rate (%/dav)	TARIE IS LAID	TAREIELO
	C.	10 10.010	122 IS.6-10
15	2. Valve movement times	NA NA	NA
1 6	B. Adsorption and filtration		MA
6	efficiencies (1)		
	(1) Organic iddine	NA 99	NA 09
	(2) Elemental iodine	00 10	MR 11
	(3) Particulate indine	NA OO	JJJJ NH
	(4) Particulate fission	- 44 	NA 99.7
	products	NA OO	P00 414
F	R. Recirculation system		
1.1	narameters		
	(1) Flow rate ((FM)	E000	5000
	(2) Mixing officience	5000	5000
	(2) Filter off giongy	50	100
G	F Containment any navatators	NA	NA
	(flow rate drop size ate)		
	(110w rate, drop size, etc.)	NA	NA
H	W All other nortical date	NA	NA
L	A. All other pertinent data	Mana	And the second se
1	and assumptions	NOR	None
1			
/	C. SUPPRESSION FOOL	State date.	
	Act Act	A A	

SCRUBBING DECONTAMINATION FACT

(1) ORGANIC LODINE 15.6-36 10,000

1 10,000

22A7007 Rev. 0

Table 15.6-7 (Continued)

		Design Basis Assumptions	Realistic Basis Assumptions
III.	Dispersion Rate		
	A. Boundary and LPZ distance (m) B. χ/Q 's for time intervals of		
	(1) $0-2$ hr - SB/LPS	2.0E-3/1.0E-3	2.0E-3/1.0E-3
	(2) 2-8 hr - LPZ (3) 8-24 hr - LPZ (4) 1-4 days - LPZ (5) 4-30 days - LPZ	1.0E-3 3.8E-4 1.0E-4 3.4E-5 7.5E-6	1.0E-3 3.8E-4 1.0E-4 3.4E-5 7.5E-6
IV.	Dose Data		
	 A. Method of dose calculation B. Dose conversion assumptions C. Peak activity concentrations in containment WFTWELL AIRSPACE 	Reference 2 Reference 2 Table	Reference 32 Reference 32 Table
	D. Doses	Table 15.6-12	15.6-14 Table 15.6-16

*Applicant to Supply

4

(

(

Table 15.6-8

LOSS-OF-COOLANT ACCIDENT (DESIGN BASIS ANALYSIS) ACTIVITY AIRBORNE IN PRIMARY CONTAINMENT (Ci)

Isotope	1 min	<u>30 min</u>	<u>l hr</u>	2 hr	4 hr	8 hr	12 hr	1 day	4 day	3C day
1131	2.1E 07	2.1E 07	2.1E 07	2.1E 07	2.1E 07	2.1E 07	2.0E 07	1.9E 07	1.5E 07	1.2E 06
1132	3.5E 07	3.0E 07	2.6E 07	1.9E 07	1.0E 07	3.1E 06	9.2E 05	2.4E 04	7.3E-06	0.
1133	3.3E 07	3.2E 07	3.1E 07	3.0E 07	2.8E 07	2.5E 07	2.2E 07	1.4E 07	1.3E 06	9.3E-04
1134	5.5E 07	3.7E 07	2.5E 07	1.1E 07	2.3E 06	9.8E 04	4.1E 03	3.0E-01	0.	0.
1135	4.6E 07	4.3E 07	4.1E 07	3.7E 07	3.0E 07	2.0E 07	1.3E 07	3.6E 06	1.8E 03	0.
Total I	1.90 08	1.6E 08	1.4E 08	1.2E 08	9.2E 07	6.8E 07	5.6E 07	3.7E 07	1.6E 07	1.2E 06
Kr83m	9.5E 06	8.0E 06	6.6E 06	4.5E 06	2.1E 06	4.8E 05	1.1E 05	1.2E 03	2.2E-09	0.
Kr85m	2.3E 07	2.1E 07	2.0E 07	1.7E 07	1.2E 07	6.6E 06	3.6E 06	5.5E 05	7.6E 00	0.
Kr85	5.9E 05	5.9E 05	5.9E 05	5.9E 05	5.9E 05	5.9E 05	5.8E 05	5.8E 05	5.6E 05	4.3E 05
Kr87	4.7E 07	3.6E 07	2.7E 07	1.6E 07	5.3E 06	5.9E 05	6.6E 04	9.2E 01	6.5E-16	0.
Kr88	6.7E 07	5.9E 07	5.2E 07	4.1E 07	2.5E 07	9.2E 06	3.4E 06	1.7E 05	2.9E-03	0.
Kr89	6.7E 07	1.2E 05	1.6E 02	3.0E-04	1.1E-15	0.	0.	0.	0.	0.
Xel31m	5.7E 05	5.7E 05	5.7E 05	5.7E 05	5.7E 05	5.6E 05	5.5E 05	5.4E 05	4.4E 05	7.5E 04
Kel33m	2.3E 07	2.3E 07	2.3E 07	2.2E 07	2.2E 07	2.1E 07	2.0E 07	1.7E 07	6.4E 06	1.5E 03
Kel33	1.3E 08	1.3E 08	1.3E 08	1.3E 08	1.3E 08	1.3E 08	1.2E 08	1.2E 08	7.6E 07	1.9E 06
Ke135m	3.6E 07	9.8E 06	2.5E 06	1.7E 05	7.2E 02	1.4E-02	2.6E-07	0.	0.	0.
Ke135	2.4E 07	2.3E 07	2.3E 07	2.1E 07	1.8E 07	1.3E 07	9.8E 06	3.9E 06	1.6E 04	0.
Ke137	1.5E 08	7.8E 05	3.4E 03	6.8E-02	2.6E-11	0.	0.	0.	0.	0.
Xe138	1.6E 08	3.9E 07	9.0E 06	4.8E 05	1.4E 03	1.1E-02	8.9E-08	0.	0.	0.
Total MG	7.4E 08	3.5E 08	3.0E 08	2.5E 08	2.2E 08	1.8E 08	1.6E 08	1.4E 08	8.3E 07	2.4E 06
										/

15.6-38

GESSAR II 238 NUCLEAR ISLAND

NEPLACE

TARLE 15.6-8

22A7007 Rev. 0

œ
1
ŵ
-
5
-
6)
_
-
P
_

LOSS-OF-COOLANT ACCIDENT (DESIGN BASIS ANALYSIS) ACTIVITY AIRBORNE IN PRIMARY CONTAINMENT $_{\Lambda}$ (Ci)

METWITL

	ANO-		02	0	2	2	0			•			0	0	0	-	-	-	-	-			1.1.1
	O		ž	- HO	-	E-	- 3C	E O		F - 2	E-2	E O	E-2	E-2	E-2	EO	E O	EO	E-20	E-20	12-3	E-20	90
	ē		8.3	1.00	8 4	1.00	1.00	8.32		1.00	1.00	4.33	1.00	1.00	1.00	7.40	1.27	1.87	1.00	1.00	1.00	1.001	2.38
	AY		0	60-	20	-20	00	6		60-	00	80	-16	-03	-20	20	90	01	50	50	20	50	01
	4		1.02E	6.44E	8.93E	1.00E	1.31E	1.10E		1.50E	7.78E	5.64E	8. 53E	4.28E	1 . 00E	4 . 36E	6.22E	7. 56E	- DOE	1.53E	1.00E-	1.00E-	8.28E
	AY	Ű,	04	0	04	04	03	04		03	03	05	10	20		00	10	80	50	000	50	50	80
	0-1		1 . 36E	1.76E	1.01E	2.20E	2. 56E	2.63E		1.07E	5. 53E	5.82E	9.73E	1. 89E		305.0	1999.	101	- 300 · 1	3.85E	- 300 . I	- 300 . I	1. 38E
۰,	¥	2		20	04	00	60	04		03	90	0	8			2				90	0	8	8
:	-21	307 1		10.0	1.52E	2.92E	3. 05E	3.91E		1.01E	3.56E	5. 85E	- //E	1000			ANC I			3/0.8	1 . UUE -	8.45E-0	1.62E C
-	NOO	20	50	3	04	5	04	04		50	90	5		00		20		000		200	2.0	NO	80
	0	1.455	2 DOE		1.140	0.91E	1. 305	4.79E		4.62E	10.0	100 0 B	0 45F	1.00F-	5.60F	2.06F	1.275	- 31C - C	110			- 300 . I	1.79E
8	5	04	03	200	50	50	5	04		90		200	20	-	20	07	80	20	22	-		2	8
H-P		1.47E	7. 35E	1 QOF	SAC .	1 1 OF	1	5.46E		11E	BEF	325	315	-36E -	. 67E	. 18E	30E .	.17E	79F	- 11E-	3VE	1000	. 16E 0
NO.		5	14	10	5	2 4		7		9		-	2	4	5	7 2	8 1	6 8	1 2	0	-		8
2-H0		1.485	1.34E	2.13E	7.955	2.59E		8.34E (1.68F 0	5.87E 0	1.58E 0	4.105 0	3.38E-0	5. 70E 0	2.24E 0	1.32E 0	1.87E 0	2.08E 0	0-36E-0	1.74F 0		. 55E 0
NR.		04	04	04	04	04		02	2	20	03	22		25	20	12	8	90	7	03	9		0
0H-1		1.49E	1.82E	2.20E	1.75E	2.88E		1.01E	. 875	1.96E	5.87E	2.73E (5.23E (1.69E	5.72E	2.27E 0	1.33E 0	2.66E 0	2.25E 0	3.37E 0	3.92E 0		. 96E 0
z		5	04	04	04	04	1	80	4	02	33	22	22	90	0	-	8	~	2	2	8		80
10-6		1.49E	2.34E	2.26E	3.39E	3.15E		1.26E	100	2.23E	5.87E	4.30E	6.41E	9.43E	30.73E	262.2	1.33E	2.44E	2.40E 0	2.87E 0	1.03E 0		1. 85E 0
z		50	50	04	04	04		60	90	07	02	01	20				0			8	8		8
IW-1		1.495	144	ZOZ . ZOE	3.82E	3.20E		1.326	9. 53E	2.28E	5.87E	1075	100.00	301.0	100	346	1000	100	101	ABE .	. 60E C		3/6
ISOTOPE		1-131	- 1 33		1-134	1-135	TATAL I	1 10101	KR-83M	KR-85M	KR-85	10-24	00-14	XF131M	XF133M	XF-133	XF13KM 2	XF-13K	XE-100	101-10	AE-138 1	TAL NO T	DAL THE

GESSAR II 238 NUCLEAR ISLAND

22A7000 Rev. 0

22A7007 Rev. 0

Table 15.6-9

SHIELD BUILDING EXHAUST RATE

Ti (h	r)	Average Exhaust Flow Rate t (SCFM)	o SGTS
0 -	2	480	
2 -	10	90	
>10		66	

:()

(...

1

Table 15.6-10

LEAKAGE RATES AND MIXING RATIO

		Numerical	Value
	Parameter	Design Basis	Realistic
Α.	Primary to Secondary Containment (%/day)		
	0 - 2 hr 2 - 10 hr >10 hr	0.832 0.903 0.908	1.00.832 1.00.903 1.00.908
в.	Primary Containment Leakage to SGTS (%/day)		
	0 - 2 hr 2 - 10 hr >10 hr	0.168 0.097 0.092	NA 0.168 NA 0.097 NA 0.092
c.	Secondary Containment Leakage to SGTS (%/day)		
	0 - 2 hr 2 - 10 hr >10 hr	319.3 59.9 43.6	123 159.6 123 29.9 123 22.0
D	Mixing Efficiency (%)		
	Primary Containment Shield Building Annulus	100 50	100

/		LOSS-	-OF-COOL ACTIVI	ANT ACC	Table 15 IDENT (D ASE TO E	.6-11 ESIGN BA	ASIS ANA ENT (Ci)	LYSIS)		15.6-11	REPLACE W
Isotope	1 min	30 min	l hr	2 hr	4 hr	8 hr	12 hr	l day	4 day	30 day	SE
1131	2.58-01	8.7E 00	2.08.01	A 9P 01	7 58 01	1 60.00	2 40 00				
1132	4.1E-01	1. 3E 01	2.8E 01	5.78 01	7.58 01	1.5E 02	2.4E 02	5.7E 02	3.9E 03	1.88 04	
1133	3.8E-01	1.3E 01	2.9E 01	7.08.01	1 18 02	3.05 01	1.02 02	1.18 02	1.1E 02	1.1E 02	
1134	6.4E-01	1.8E 01	3.4E 01	5.7E 01	6 42 61	6. 6P 01	5.0E 02	6.0E 02	1.6E 03	1.7E 03	
1135	5.48-01	1.8E 01	4.08 01	9.18 01	1.38.02	2 38 02	2 08 02	0.0E UI	6.6E 01	6.6E 01	
				J UI	1.35 02	2.25 02	2.95 02	4.18 02	4.88 02	4.8E 02	
TOTAL I	2.2E 00	7.1E 01	1.5E 02	3.2E 02	4.6E 02	7.4E 02	1.0E 03	1.8E 03	6.2E 03	2.0E 04	
Kr83m	1.1E 01	3.5E 02	7.3E 02	1.4E 03	1.9E 03	2.2E 03	2.3E 03	2.4E 03	2.4E 03	2.4E 03	
Kr85m	2.78 O1	8.9E 02	1.9E 03	4.3E 03	6.2E 03	9.4E 03	1.2E 04	1.4E 04	1.5E 04	1.5E 04	
Kr85	6.9E-01	2.4E 01	5.4E 01	1.3E 02	2.1E 02	4.2E 02	6.7E 02	1.7E 03	1.3E 04	1.4E 05	
Kr87	5.58 01	1.7E 03	3.3E 03	6.0E 03	7.2E 03	7.9E 03	8.0E 03	8.1E 03	8.1E 03	8.1E 03	
Kr88	7.8E 01	2.5E 03	5.4E 03	1.1E 04	1.6E 04	2.1E 04	2.4E 04	2.5E 04	2.5E 04	2.5E 04	
Kr89	8.8E 01	4.7E 02	4.7E 02	4.7E 02	4.7B 02	4.7E 02	4.7E 02	4.7E 02	4.7E 02	4.7E 02	
Xel31m	6.7E-01	2.3E 01	5.3B 01	1.3E 02	2.0E 02	4.0E 02	6.5E 02	1.6E 03	1.1E 04	6.4E 04	
Xel 33m	2.7E 01	9.3E 02	2.1E 03	5.1E 03	7.9E 03	1.6E 04	2.4E 04	5.5E 04	2.6E 05	4.5E 05	
Xel33	1.6E 02	5.4E 03	1.2E 04	3.0E 04	4.7E 04	9.3E 04	1.5E 05	3.5E 05	2.2E 06	7.3E 06	1
Xel35m	4.4E 01	8.2E 02	1.1E 03	1.2E 03	1.2E 03	1.2E 03	1.2E 03	1.2E 03	1.2E 03	1.2E 03	1
Xe135	2.8E 01	9.7E 02	2.1E 03	5.0E 03	7.5E 03	1.3E 04	1.8E 04	2.8E 04	4.0E 04	4.02 04	
Xe137	1.9E 02	1.2E 03	1.2B 03	1.2E 03	1.2E 03	1.2E 03	1.2E 03	1.2E 03	1.2E 03	1.2E 03	
Xe138	1.9E 02	3.5E 03	4.5E 03	4.8E 03	4.9E 03	4.9E 03	4.9E 03	4.9E 03	4.9E 03	4.98 03	
Total NG	9.0E 02	1.9E 04	3.5E 04	7.1E 04	1.0E 05	1.7E 05	2.4E 05	4.9E 05	2.6E 05	8.1E 06	

15.6-40

22A7007 Rev. 0

GESSAR II 238 NUCLEAR ISLAND

Table 15.6-11

2

LOSS-OF-COOLANT ACCIDENT (DESIGN BASIS ANALYSIS) ACTIVITY RELEASE TO ENVIRONMENT (C1)

								. 0											
AN	5	20-	8	20-	ō	5	03	8	80	03	8	02	5	80	80	03	8	03	03
-	36	365	BO	BE	17E.	BO	SE	BE	36	36C	SBE	OE	DE	38	36	3E	IE	SOE	SE
	-	-	-	4.6		-	~	-	-		~	-		4	-	-		-	-
2	8	02	8	05	10	8	6	8	3	03	5	02	8	80	90	03	3	03	60
PA-		- 36	B	- JE	-32	2	35	BE	36	36	BE	OE	36	8E	2E	BE	E	S	SE
4	2.7	7.3		4.6	9.3	4.3		-			8.0		-	2	3		3.9	-	4.8
*	5	02	10	02	10	8	03	8	03	03	5	02	03	8	02	03	8	03	03
VQ-	-1	- 38	- 31	- JE	- 31	36	30	E	BE	36	9 E	OE	EE	3E	OE	BE	25	B	E
-	4.0	7.5	4.2	4.6	2.8	1.2	8.3	1.4	1.6	8.0	2.5	4.7		8.4	3.5	1.2	2.8	1.2	4.8
~		22	10	25	5	5	6	8	20	03	8	02	20	5	20	03	3	03	03
I.	-1		E-C	- 3E	- H	-	ž	E	32	36	H	E	3E	SE	36	3E	36	BE	M
=	8	1.3	2.1		0	ö	3	-	8.7	9.0	5. 3	1.7	8.4	8.4	4.4		1.7	1.2	
æ	_	N	-	0	-	-			~		4	~	~	4	4			•	
no-		0-3	0-3	0-3	0-3	-	0	C H	0	0	0	0	0	0	0 3	E O	0	E O	8
	02	75	42	621	55	8	21	42	181	. 97	121.	. 70	.04	52.	30	. 23	30	. 20	. 85
	-	9	-	4	-	10	~	0	4	~	~	4	4	-		-	-	-	4
DO	-02	-02	-02	-02	-02	-01	03	03	0	03	04	02	02	03	04	03	03	03	03
	AE	28E	SBE	46E	41E	205	84E	18E	08E	24E	57E	70E	OZE	93E	67E	23E	49E	20E	85E
			-	4		ė	-		~	-	-	4	~	-	4	-	-	-	Ť
N	05	02	05	05	05	5	03	03	02	03	04	02	02	03	04	03	03	03	03
Ŧ	AE.	- BE	3E	19E	. BOI	- BB	14E	34E	32E	3E	SE	POE	28E	36C	BE	322	JIE	SOE	34E
			4		9	~	-	4	-	8.0	-	4		-	2	-		-	4
N S	03	03	10	20	05	5	02	03	10	03	03	02	10	03	104	03	03	03	03
P.	75-	35-	-19	- HO	- 36	-36	4E	AE	E	TE	E	DE	7E	B	SE	-	14	DE	BE
-	6.1			10	2		2.0		9	0		4.7	8.2	0	-	-		-	4
z	5	50	20	200	33	05	50	20	00	20	10	20	8	02	503	00	00	20	100
W-	-	-1	1 14	-	- H		H	-	3E	-	L	SE	E	E	-		14	L	BE
=		0	1		6.0	ŝ.	1	2.7	0	10	0.0		0 4	8		2 2	0		1.6
					-		-				_	_	_	_					2
-	0	0			0-	0	0	0	0-1	0		0	0-3	0					E E
-	78.	87	10		70	261	12	68	BB		82	85	22	20		36		BB	. 92
	-				10	-	-		1 4		10			0			10		-
340				200	10	2	HE	MSH	-	20		08	WIE	WEE	221	WW C		221	138
SOT	-			-	-	OTA	-87	- 22 ×		- 2 -	- 04	- 83	1 AX				AF.	- 13%	XE-
-						\$m		1		1						1			

896-01 506 01 826 01 726-01 726-01 706 01 3576 01 856 01 856 01 856 01 956 02 0000 Ň KR-87 KR-87 KR-89 KR-89 KR-89 XE133 XE-133 XE-135 XE-133 XE-138 XE-138

15.6-2840

GESSAR II 238 NUCLEAR ISLAND

Rev. 0 033180

*

8

3EO .

80

2.60E

80

3C6

4

80

2.45E

8

1.71E

08

1.01E

8

7.12E

5

52E .

03

BAE ~

02

8.97E

OTAL NG

238 NUCLEAR ISLAND

Rev. 4

Table 15.6-12

LOSS-OF-COOLANT ACCIDENT (DESIGN BASE ANALYSIS) RADIOLOGICAL EFFECTS

	Whole Body Dose (rem)	Inhalation Dose (rem)
Exclusion Area	19.71	\$6.7 0.05
Low Population Zone	14.1	≥4.9 0.11

Table 15.6-13

ISOTOPIC SPIKING ACTIVITY

Isotope Name	The 95th Cumulative Probability Spiking Activity (Ci/bundle)
1131	2.14
1132	3.21
1133	5.03
1134	5.44
1135	4.79
Kr83m	9.04-1*
Kr85m	2.23+0
Kr85	4.90-1
Kr87	4.33+0
K188	6.12+0
K239	7.96+0
Xel31m	6.60-2
Xel33m	3.26-1
Xe133	1.16+1
Xel35m	1.80+0
Xe135	1.10+1
Xe137	1.05+1
Xe138	1.06+1

-*9.04-1 = 9.04 x 10-1

1.8.1

(

(

Table 15.6-14

LOSS-OF-COOLANT ACCIDENT (REALISTIC ANALYSIS) ACTIVITY AIRBORNE IN THE CONTAINMENT (Ci)

Isotope	1 min	1 hr	2 hr	8 hr	1 day	3 day	26 day
1131	8.59E 01	8.55E 01	8.52E 01	8.33E 01	7.84E 01	5 968 01	
1132	1.41E 02	1.05E 02	7.73E 01	1.25E 01	9 695-02	3.902 01	5.64L UU
1133	2.08E 02	2.01E 02	1.94E 02	1.598 02	0 38E 01	2.99E-11	0.
1134	2.39E 02	1.10E 02	4.97E 01	4. 298-01	3.26E UI	8.26E 00	6.912-09
1135	2.03E 02	1.83E 02	1.65E 02	0.75E 01	1.62E 01	8.16E-03	0. 0.
Total	· 8.77E 02	6.84E 02	5.71E 02	3.43E 02	1.08E 02	6.79E 01	5.64E 00
Kr83m	6.72E 02	4.65E 02	3.20E 02	3.37E 01	8.385-02	1.538-13	
Kr85m	1.67E 03	1.43E 03	1.23E 03	4.83E 02	4.03E 01	5.55P-04	0.
Kr85	3.67E 02	3.66E 02	3.66E 02	3.65E 02	1.635 07	3.528.02	0.
Kr87	3.21E 03	1.87E 03	1.08E 03	4.05E 01	6.35E-03	3.326 02	· 2.73E 02
Kr88	4.56E 03	3.57E 03	2.79E 03	6.29E 02	1 197 01	2.025.03	0.
Kr89	4.78E 03	1.13E-02	2.14E-08	0.		2.02E-07	0.
Xel31m	4.94E 01	4.92E 01	4.318 01	4 938 01	4.610.01	0.	0.
3e133m	2.445 02	2.41E 02	2.378 02	3.10E 01	4.61E 01	3.778 01	6.53E 00
Xe133	8.64E 03	8.59E 03	8 54P 03	2.156 02	1.77E 02	6.75E 01	1.63E-02
Xel35m	1.288 03	8 975 01	8.34E U3	8.24E 03	7.50E 03	4.91E 03	1.26E 02
Xel35	8 198 03	3.60P 01	5.85E 00	4.83E-07	0.	0.	0.
Xe137	6. 648 03	2.60E 03	7.042 03	4.46E 03	1.32E 03	5.51E 00	0.
A0137	0.54E 03	1.54E-01	3.03E-06	0.	0.	0.	0.
X0138	7.58E 03	4.25E 02	2.27E 01	5.23E-07	0.	0.	0.
Total	4.78E 04	2.47E 04	2.17E 04	1.45E 04	9.46E 03	5.37E 03	4.06E 02

GESSAR II 238 NUCLEAR ISLAND

NEW TABLE 15.6-14

REPLACE WITH

22A7007 Rev. 0

2

Table 15.6-14

LOSS-OF-COOLANT ACCIDENT (REALISTIC ANALYSIS) ACTIVITY AIRBORNE IN THE CONTAINMENT, (Ci) WETWELL

ISOTOPE 1-MIN 10-MIN 1-HOUR 2-HOUR 4-HOUR 8-HOUR 12-HR 1-DAY 4-DAY 30-DAT I-131 5.63E-01 5.63E-01 5.61E-01 5.59E-01 . 5.55E-01 5.46E-01 5.37E-01 5.12F-01 3.83E-01 3.14E-02 I-132 8.60E-01 8.22E-01 6.39E-01 4.73E-01 2.59E-01 7.735-02 2.31E-02 6.19E-04 2.27E-13 1.00E-20 I-133 1.33E 00 1.32E 00 1.29E 00 1.24E 00 1.16E 00 1.02E 00 8.87E-01 5.92E-01 5.21E-02 3.74E-11 1-134 1.45E 00 1.29E 00 6.65E-01 3.01E-01 6.20E-02 2.625-03 1.115-04 8.35E-09 1.00E-20 1.00F-20 I-135 1.28E 00 1.26E 00 1.15F 00 1.03F 00 8.38E-01 5.50E-01 3.615-01 1.07E-01 5.21E-05 1.00E-20 TOTAL I 5.48E 00 5.25E 00 4.30E 00 3.61E 00 2.38E 00 2.19E 00 1.81E 00 1.21E 00 4.36E-01 3.14E-02 KR-83M 6.72E 02 6.35E 02 4.63E 02 3.17E 02 1.48E 02 3.26E 01 7.15E 00 7.55E-02 1.05E-13 1.00E-20 KR-85M 1.67E 03 1.63E 03 1.43E 03 1.22E 03 8.98E 02 4.83E 02 2.60E 02 4.03E 01 5.688-04 1.00E-20 KR-85 3.67E 02 3.67E 02 3.67E 02 3.67E 02 3.66E 02 3.66E 02 3.65E 02 3.63E 02 3.52E 02 2.70E 02 KR-87 3.21F 03 2.96E 03 1.88E C3 1.09E 03 3.64E 02 4.13E 01 4.65E 00 6.69E-03 1.00E-20 1.00E-20 KR-88 4.56E 03 4.40E 03 3.59E 03 2.81E 03 1.728 03 6.48E 02 2.44F 02 1.30E 01 2.93E-07 1.00E-20 KR-89 4.78E 03 6.68E 02 1.19E-02 2.40E-08 1.00E-20 1.00E-20 1.00E-20 1.005-20 1.00E-20 1.00E-20 XE131M 4.94E 01 4.94E 01 4.93F 01 4.91E 01 4.88E 01 4.83E 01 4.77E 01 4.61E 01 3.76E 01 6.38E 00 XE133M 2.44E 02 2.43E 02 2.41E 02 2.37E 02 2.31E 02 2.19F 02 2.078 02 1.76E 02 6.60E 01 1.35E-02 XE-133 8.64E 03 8.63E 03 8.59E 03 8.54E 03 8.44E 03 8.24E 03 8.05F 03 7.405 03 4.89E 03 1.21E 02 XE135M 1.285 03 8. AOF 02 9.39F 01 6.58E 00 3.23E-02 7.81E-07 1.98E-11 1.00E-20 1.00E-20 1.00E-20 XE-135 8.19E 03 8.10E 03 7.59E 03 7.03E 03 6.03E 03 4.44E 03 3.27F. 03 1.30E 03 5.18E 00 1.00E-20 XE-137 6.54E 03 1.28E 03 1.51E-01 2.91E-06 1.08F-15 1.00E-20 1.00F-20 1.00E-20 1.00E-20 1.00E-20 XE-138 7.58E 03 4.88E 03 4.23E 02 2.245 01 6.33E-02 5.03E-07 4.00E-12 1.00E-20 1.00E-20 1.00E-20 TOTAL NG 4.78E 04 3.47E 04 2.47E 04 2.17E 04 1.83E 04 1.45E 04 1.24F 04 9.43E 03 5.35E 03 3.98E 02

22A7000

GESSAR MUCLEAR ISLAND

238

. .

			Table	15.6-15			
		LOSS-OF-CO ACTIVITY	OLANT ACCID RELEASED T	ENT (REALIS O THE ENVIR	TIC ANALYSI CONMENT (Ci)	S))
sotope	<u>1 min</u>	<u>1 hr</u>	2 hrs	8 hrs	1 day	4 days	30 days
131	2.54E-10	8.98E-07	3.52E-06	5.04E-05	3.44E-04	2.24E-03	8.208-01
132	4.19E-10	1.22E-06	3.95E-06	2.07E-05	2.80E-05	2.81E-05	2.818-05
133	6.14E-10	2.13E-06	8.19E-06	1.04E-04	5.39E-04	1.46E-03	1.56E-03
134	7.12E-10	1.53E-06	3.76E-06	7.66E-06	7.74E-06	7.74E-06	7.748-06
.35	6.01E-10	1.99E-06	7.30E-06	7.15E-05	2.2E-04	2.63E-04	2.63E-04
tal	2.60E-09	7.76E-06	2.67E-05	2.55E-04	1.13E-03	4.00E-03	1.01E-02
83m	1.99E-06	5.54E-03	1.72E-02	7.48E-02	9.03E-02	9.04E-02	9 048-02
85m	4.94E-06	1.58E-02	5.62E-02	4.64E-01	1.03E 00	1.11E 00	1.118 00
85	1.08E-07	3.84E-03	1.51E-02	2.19E-01	1.55E 00	1.15E 01	9.298 01
87	9.53E-06	2.38E-02	6.68E-02	1.99E-01	2.11E-01	2.11E-01	2.118-01
88	1.35E-05	4.07E-02	1.37E-01	8.40E-01	1.30E 00	1.32E 00	1. 328 00
89	1.52E-05	7.28E-04	7.28E-04	7.28E-04	7.28E-04	7.28E-04	7.288-04
131m	1.46E-07	5.16E-04	2.03E-03	2.91E-02	2.01E-01	1.36E 00	6.01E 00
133m	7.22E-07	2.53E-03	9.88E-03	1.36E-01	8.48E-01	3.95E 00	6.07R 00
133	2.56E-05	9.02E-02	3.53E-01	5.01E 00	3.36E 01	2.03E 02	5.448 02
135m	3.86E-06	2.89E-03	3.70E-03	3.81E-03	3.81E-03	3.81E-03	3.818-03
.35	2.42E-05	8.17E-02	3.06E-01	3.33E 00	1.21E 01	1.81E 01	1.81E 01
137	2.06E-05	1.42E-03	1.42E-03	1.42E-03	1.42E-03	1.428-03	1.428-03
138	2.28E-05	1.54E-02	1.90E-02	1.94E-02	1.94E-02	1.94E-02	1.94E-02
al	1.44E-04	2.85E-01	9.88E-01	1.03E 01	5.10E 01	2.40E 02	6.70E 02

0

1

22A7007 Rev. 0

GESSAR II 238 NUCLEAR ISLAND

*

22A7007 Rev. 0

Table 15.6-16

LOSS-OF-COOLANT ACCIDENT (REALISTIC ANALYSIS) RADIOLOGICAL EFFECTS

	Whole Body Dose (rem)	Inhalation Dose (rem)
Exclusion Area	1.2E-3 2.28 4	1.4E-6 5.58 6
Low Population Zone	8.7E-4	2.9E-6

Table 15.6-17

SEQUENCE OF EVENTS FOR FEEDWATER LINE BREAK OUTSIDE CONTAINMENT

Time			
C. Martine Contraction			

Event

- 0 sec One feedwater line breaks.
- 0+ sec Feedwater line check valves isolate the reactor from the break.
- <30 sec At low-low water reactor level RCIC would initiate, HPCS would initiate, MSLIV closure would initiate, reactor scram would initiate and recirculation pumps would trip.
- ~2 min The safety/relief valves would open and close and maintain the reactor vessel pressure at approximately 1100 psig.
- 1-2 hr Normal reactor cooldown procedure established.

*Applicant to Supply

1

)



Figure 15.6-2. Post-LOCA, BEARAGE Pathways

22A7007 Rev. 0



(...

(

Steam Flow Schematic for Steam Break Outside Containment Figure 15.6-1.

Table 15.6-15

(.

1

.

4,

1.

LOSS-OF-COOLANT ACCIDENT (REALISTIC ANALYSIS) ACTIVITY RELEASED TO THE ENVIRONMENT (C1)

30-DAY	3. 50E-04	1.86E-06	4.26E-03	1.296-06		on- 300 . 4	4.05E-04	1.345-01	8.17E-01	A 315 01		4. 51E-01	1.39E 00	3.25E-02			3.48E 00	3.925 02	3.94E-02	9.42E 00		20. 212.0	2.10E-01		4.96E 02	
A-DAY	6.27E-05	1.86E-06	3.86E-05	1 29F 06		0. 20E-00	1.13E-04	1.34E-01	8.17E-01		2	4.61E-01	1.39E 00	3.25E-02	0 325-01	10-30. · 0	1.89E 00	a 93E 01	5.94E-02	0 41E 00		2.21E-02	2.10E-01		1. 20E 02	
1-DAY	9. 30E-06	1.86E-06	1.53F-05	1 DOF-DR		7.41E-06	3.52E-03	1.345-01	7. RAF -01		1.205-01	4.61E-01	1.38E 00	3 255-02		9.49E-02	4.09E-01	1.60E 01	3.94E-02	R 075 00		5.21E-02	2.10E-01		2.73E 01	
12-HR	4.13E-06	1 AOF-06	A DIF-DR	1 205-06	1.636-00	5.46E-06	2.09E-05	1.335-01	6 58F-01		3. 15E-01	A. 60E-01	1 30F 00	- 346 - US		4.18E-02	1.94E-01	7.18F 00	3 94F. 02		- 02L 00	5.21E-02	2 10F-01		1.52E 01	
8-HOUR	2.69F-06	I RAF-DR	* COL-DO	- 100 ·	1.232-00	4.26E-06	1.56E-05	1 24F-01	# 40F-01	0. 406.0	2.04E-01	4.55E-01	1 175 00		3. 202-06	2.72E-02	1.29E-01	4 70F 00	- 10 - 100		2.435 00	5.21E-02	2 10F-01	6.1VC V	1.11E 01	
4-HOUR	1 425-06	SAF-DE		3.1/6-00	1.256-06	2.69E-06	9.87E-06	1 085-01		3. / ZE-UI	1.06E-01	4.17E-01		0.020.0	3. 236-02	1.43E-02	6 91F-02	S ARE DO		3. 345-06	2.08E 00	5.21E-32	10-101 0	C. 105-01	6.87E 00	
2-HOUR	0 005-07		00- 320 · I	Z. 06E-08	1.11E-06	1.83E-06	6.92E-06	CU-314 0		2.01E-01	6.76E-02	AAF-01		0.34E-01	3.25E-02	9.07E-03	A 475-02		1. 30C 00	3. 935-02	1.39E 00	5 21F-02		Z. 10E-01	4.78E 00	
1-HOUR		3. 30C -01	2. 236-U/	9.26E-07	7.056-07	8.57E-07	3.41E-06		4. 33E-UC	1.25E-01	2 9AF-02	10-300 c		3. 28E-01	3 25E-02	A 015-03	. 075-00	- 3/E-00	1. UUE - UI	3.60E-02	6.40E-01	R 215-02		1.96E-01	2.41E 00	
NIM-01		2. 666-08	8. 60E-08	1.39E-07	1.435-07	1.32E-07	5.61E-07		7.85E-03	1,98E-02	A ADE-DI		3. /15-02	5. 38E-02	2.87E-02	# 02F-04		2.92E-03	1.04E-01	1.30E-02	9 77E-02		4. 31C-00	7. 53E-02	4 68E-01	
N1M-1		5.74E-09	8.79E-09	1.36E-08	1 AGE-DR	1.30E-08	5. 60E-08		7.88E-04	1.95E-03	A DOF - DA		3.77E-03	5. 35E -03	6.25E-03	- 101 - 08	0. 10E-00	2.855-04	1.01E-02	1.53E-03	CU-JON O		8. 39E-03	9.09E-03	- 76F-02	
ISOTOPE		1-131	1-132	1-133	1-174	-135	TOTAL I		WC8-WX	KR-85M		CO-11	KR-87	KR-88	KR-AG		ALIJIA	XE133M	XE-133	XE135M	NC		XE-137	XE-138	TOTAL NO	10141

15.6-M 43

222.7000 Rev. C 033180