



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

March 1, 1983
83 MAR 8 10:19

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Update Report - Fire Doors
1A308 and 1A316 Blocked
Open
LER 82-141/99 X-1
AECM-83/0135

This letter submits an update to a previous report submitted on December 16, 1982. The event for which the report was submitted occurred on November 12, 1982, when fire door 1A308 and 1A316 were blocked open to route hoses in support of sandblasting operations in the suppression pool. A Limiting Condition for Operation was entered in accordance with Technical Specification 3.7.7. The event was reported as a Special Report pursuant to Technical Specification 3.7.7.

All corrective action is complete. Attached is LER 82-141/99 X-1, which is a final report.

Yours truly,

J.P. McGaughy, Jr.
FOR J.P. McGaughy, JR.

JPM:sap
Attachment

- cc: Mr. N. L. Stampley (w/a)
- Mr. R. B. McGehee (w/o)
- Mr. T. B. Conner (w/o)
- Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

OFFICIAL COPY

8303150242 830301
PDR ADOCK 05000416
S PDR

ember Middle South Utilities System

IE 22