

APPROVED BY OMB
3150-0011
EXPIRES 4-30-82

CONTROL BLOCK: [] [] [] [] [] [] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 SCVCS1 00-000000-00 41000 02 03 04 05

LICENSE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT 38

CON'T 01 REPORT SOURCE L 05000395 020683 030483 09

DOCKET NUMBER 60 61 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 On February 6, 1983, while in Mode 1, the Plant started a reduction in power.

03 From 0330 to 0440, the Plant went from 50% to 30% Rx power. From 0730 to 0835,

04 the Plant went from 30% to 5% Rx power. Technical Specifications require an

05 Isotopic Iodine Analysis be performed for power changes greater than 15% rated

06 thermal power. Only one analysis was performed at the conclusion of the power

07 reduction. No adverse consequences resulted as the analysis yielded satisfactory

08 results.

09

SYSTEM CODE 9 10 CAUSE CODE 11 CAUSE SUBCODE 12 COMPONENT CODE 13 COMP. SUBCODE 14 VALVE SUBCODE 15

17 LER/RO REPORT NUMBER 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

ACTION TAKEN 33 FUTURE ACTION 34 EFFECT ON PLANT 35 SHUTDOWN METHOD 36 HOURS 37 ATTACHMENT SUBMITTED 40 NPRO-4 FORM SUB. 42 PRIME COMP. SUPPLIER 43 COMPONENT MANUFACTURER 44

10 CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Personnel involved interpreted both power changes during the power reduction

11 process to be one event. An Isotopic Iodine Analysis was performed with

12 satisfactory results on the same day. A Chemistry Lab Policy has been issued

13 regarding when the analysis is to be taken.

14

15 FACILITY STATUS 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

16 PERSONNEL EXPOSURES NUMBER 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

17 PERSONNEL INJURIES NUMBER 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

18 LOSS OF OR DAMAGE TO FACILITY TYPE 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

19 PUBLICITY ISSUED DESCRIPTION 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

20

NAME OF PREPARER H. C. Fields

PHONE: (803) 345-5209