



Friday, July 1, 1994

Daniel J. Westall
Non-Power Reactors and Decommissioning Project Directorate
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Ref: Docket 50-27

Dear Mr. Westall:

Thank you for catching the change required for Section 6.10 in our Technical Specifications. According to your FAX dated June 30, 1994 we had not included the change from Region V to the appropriate USNRC Regional Office in the June 6, 1994 list of revisions.

Amendment No. 15 should therefore include the following items:

Proposed Changes:

Page	Change
12	"Scram if power level exceeds 1100 kW" to "Scram if power level exceeds 125% of full licensed power"
35	In section 6.10, <u>Reporting Requirements</u> , (1): change "A report within 24 hours by telephone and FAX to the Regional Administrator, USNRC, Regional V Office, and to the NRC Operations Center, of" "A report within 24 hours by telephone and FAX to the Regional Administrator of the appropriate USNRC Regional Office, and to the NRC Operations Center, of"

080015
9407110294 940701
PDR ADDCK 05000027
P PDR

A020 1/0

35

In section 6.10, Reporting Requirements, (2): change

"A report within 10 days in writing to the Director, Office of Nuclear Reactor Regulation USNRC, Washington, D.C. 20555, with a copy to the Regional Administrator, USNRC, Regional V Office, of" to

"A report within 10 days in writing to the Director, Office of Nuclear Reactor Regulation USNRC, Washington, D.C. 20555, with a copy to the Regional Administrator of the appropriate USNRC Regional Office, of"

35


In section 6.10, Reporting Requirements, (3): change

"A report within 30 days in writing to the Director, Office of Nuclear Reactor Regulation, USNRC, Washington, D.C. 20555, with a copy to the Regional Administrator, USNRC, Regional V Office, of" to

"A report within 30 days in writing to the Director, Office of Nuclear Reactor Regulation, USNRC, Washington, D.C. 20555, with a copy to the Regional Administrator of the appropriate USNRC Regional Office, of"

If you have any questions, please contact Dr. Gerald Tripard, Facility Director (509) 335-0172

Sincerely,



Gerald E. Tripard
Director