

MAY 11 1983

Docket No. 50-271

Vermont Yankee Nuclear Power Corporation
ATTN: Mr. W. P. Murphy
Vice President and Manager of
Operations
RD 5, Box 169
Ferry Road
Brattleboro, Vermont 05301

Gentlemen:

Subject: Meeting Report 50-271/83-10

This refers to the meeting held by NRC Region I management with yourself and members of your staff on April 19, 1983, to discuss Intergranular Stress Corrosion Cracking (IGSCC) of the Recirculation System. These cracks were discovered as a result of testing required by IE Bulletin 83-02.

The scope and content of the meeting is described in the enclosed NRC Region I Meeting Report. As discussed in the enclosed report, the lead responsibility for approval of corrective actions has been transferred to NRR. Region I will retain responsibility for inspection of site activities involved in the repair of the pipe cracks. Additionally, the enclosed report identifies concerns that must be addressed prior to approval of your repair program and other items that must be addressed to fulfill the intent of IE Bulletin 83-02.

In accordance with 10 CFR 2.790(a), a copy of this letter and the enclosure will be placed in the NRC Public Document Room unless you notify this office, by telephone, within ten days of the date of this letter and submit written application to withhold information contained therein within thirty days of the date of this letter. Such application must be consistent with the requirements of 2.790(b)(1). The telephone notification of your intent to request withholding, or any request for an extension of the 10 day period which you believe necessary, should be made to the Supervisor, Files, Mail, and Records, USNRC Region I, at (215) 337-5223.

Your cooperation with us is appreciated.

Sincerely,

Original Signed By:

Richard W. Starostecki, Director
Division of Project and Resident
Programs

8305250447 830511
PDR ADOCK 05000271
Q PDR

IEO1

OFFICE									
SURNAME									
DATE									

Vermont Yankee Nuclear Power
Corporation

2

MAY 11 1983

Enclosure: NRC Region I Meeting Report
50-271/83-10

cc w/encl:

J. B. Sinclair, Licensing Engineer
W. F. Conway, President and Chief Executive Officer
J. P. Pelletier, Plant Manager
L. H. Heider, Vice President
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
State of New Hampshire
State of Vermont
W. Hazelton, NRR, MTEB
V. Rooney, NRR, Project Manager

bcc w/encl:

Region I Docket Room (with concurrences)
Senior Operations Officer (w/o encl)
DPRP Section Chief

OFFICE	RI: DPRP	RI: DPRP	RI: DPRP	RI: DETP	RI: DETP	RI: DPRP
SURNAME	Holden/meo	Ga	Greenman	Ebnetter	Martin	Starostecki
DATE	5/5/83	5/5	5/5	5/9	5/10/83	5/10/83